

# ACCELERATED DOCUMENT DISTRIBUTION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9305110295      DOC. DATE: 93/04/28      NOTARIZED: NO      DOCKET #  
FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co.      05000269  
50-270 Oconee Nuclear Station, Unit 2, Duke Power Co.      05000270  
50-287 Oconee Nuclear Station, Unit 3, Duke Power Co.      05000287

AUTH. NAME      AUTHOR AFFILIATION      R  
HAMPTON, J.W.      Duke Power Co.      I  
RECIP. NAME      RECIPIENT AFFILIATION  
Document Control Branch (Document Control Desk)      I

SUBJECT: Forwards suppl to 910115 response to GL 88-14, "Instrument Air Supply Sys Problems Affecting Safety-Related Equipment."      D  
Three non-load shed compressors, aftercoolers, desiccant      S  
dryers added to support valve & instrument operation.      S

DISTRIBUTION CODE: A048D      COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 3      /  
TITLE: OR/Licensing Submittal: Equipment Qualification      A

NOTES:

	RECIPIENT		COPIES		RECIPIENT		COPIES		
	ID	CODE/NAME	LTR	ENCL	ID	CODE/NAME	LTR	ENCL	
	PD2-3	PD	1	0	WIENS, L		1	1	D
INTERNAL:	ACRS		6	6	NRR/DE/EMEB		1	1	S
	OC/LEMB		1	0	OGC/HDS2		1	1	
	<u>REG FILE</u>	01	1	1	RES/DSIR/EIB		1	1	
EXTERNAL:	NRC	PDR	1	1	NSIC		1	1	

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 15 ENCL ~~13~~ 0      *may*

Duke Power Company  
Oconee Nuclear Site  
P.O. Box 1439  
Seneca, SC 29679

J. W. HAMPTON  
Vice President  
(803)885-3499 Office  
(803)885-3564 Fax



**DUKE POWER**

April 28, 1993

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D. C. 20555

Subject: Oconee Nuclear Site  
Docket Nos. 50-269, -270, -287  
Generic Letter No. 88-14 Response  
Instrument Air Supply System Problems  
Affecting Safety-Related Equipment


Gentlemen:

By letter dated January 15, 1991, Duke Power committed to adding three small, non-load shed compressors, aftercoolers, desiccant dryers, and filters to support the operation of certain critical valves and instruments at Oconee. The schedule for implementation of this commitment was provided in our letter of August 12, 1991. This system is now operational for all Oconee units. This was the final action required by the Oconee Site to meet the requirements of Generic Letter 88-14.

Issues concerning air quality, maintenance and operational practices with regard to the instrument air system as identified in GL 88-14 have been addressed in previous correspondence (reference letter of November 26, 1991). Therefore, this notification will be considered our final response on GL 88-14.

Should you have further questions, please feel free to contact M.E. Patrick at (803) 885-3292.

Very truly yours,

  
J. W. Hampton  
Vice President

TDP/tdp

10000000  
9305110295 930428  
PDR ADDCK 05000269  
P PDR

Printed on recycled paper

AD48 1/0

J. W. Hampton, being duly sworn, states that he is Site Vice President of Duke Power Company, that he is authorized on the part of said Company to sign and file with the Nuclear Regulatory Commission this revision to the Oconee Nuclear Station License Nos. DPR-38, DPR-47, and DPR-55; and that all statements and matters set forth therein are true and correct to the best of his knowledge.

  
\_\_\_\_\_  
J. W. Hampton, Vice President

Subscribed and sworn to before me this 28 day of April, 1993.

  
\_\_\_\_\_  
Notary Public

My Commission Expires:

2-12-2003

Document Control Desk  
April 28, 1993  
Page 2

xc: S. D. Ebnetter, Regional Administrator  
U. S. Nuclear Regulatory Commission, Region II

L. A. Wiens, Project Manager, Oconee  
Office of Nuclear Reactor Regulation - USNRC

P. Harmon, Sr. Resident Inspector, Oconee  
Nuclear Regulatory Commission