

July 6, 1989

Docket Nos. 50-269, 50-270, 50-287,
50-369, 50-370,
50-413, 50-414

MEMORANDUM FOR: Dave B. Matthews, Director
Project Directorate II-3
Division of Reactor Projects - I/II

FROM: Darl S. Hood, Project Manager, Project
Directorate II-3
Division of Reactor Projects - I/II
Kahtan N. Jabbour, Project Manager, Project
Directorate II-3
Division of Reactor Projects - I/II
Leonard A. Wiens, Project Manager, Project
Directorate II-3
Division of Reactor Projects - I/II

SUBJECT: CLOSURE OF BULLETIN 89-01 ON ALL DUKE STATIONS
(TACS 73179, 73180, 73183, 73184, 73185, 73157, 73158)

By letter of June 20, 1989, Duke replied to NRC Bulletin 89-01 "Failure of Westinghouse Steam Generator Tube Mechanical Plugs" for each of its seven nuclear stations. The reply indicates that no Duke plant has mechanical plugs from the suspect heat numbers. While Duke has no plans to remove any Westinghouse mechanical plugs from service, should future evaluation indicate susceptibility to failure, plug repair would likely be by "plug-in-a-plug" technique, and any future Duke data would be provided to the Westinghouse data base.

We find that this response satisfies the actions required by Bulletin 89-01, and that the subject TACS can be closed.

Leonard A. Wiens,
Project Manager
Project Directorate II-3
Division of Reactor
Projects - I/II

Kahtan N. Jabbour,
Project Manager
Project Directorate II-3
Division of Reactor
Projects - I/II

Darl S. Hood,
Project Manager
Project Directorate II-3
Division of Reactor
Projects - I/II

DISTRIBUTION

Docket File

NRC PDR

Local PDR

PDII-3 Reading

S. Varga 14-E-4

G. Lainas 14-H-3

D. Matthews 14-H-25

M. Rood 14-H-25

D. Hood 14-H-25

L. Engle 14-H-22

L. Reyes RII

OGC (For inform. Only) 15-B-18

E. Jordan MNBB-3302

B. Grimes 9-A-2

ACRS (10) P-315

*See previous concurrence

PD II-3

PD II-3

PD II-3

PD II-3

DHood*

KJabbour*

LWiens*

DMatthews*

07/06/89

07/06/89

07/06/89

07/06/89

DF01
1/0

cc
Memo 4

8907140073 890706
PDR ADOCK 05000269
FDIC

Docket Nos. 50-269, 50-270, 50-287,
50-369, 50-370,
50-413, 50-414

MEMORANDUM FOR: Dave B. Matthews, Director
Project Directorate II-3
Division of Reactor Projects - I/II

FROM: Darl S. Hood, Project Manager, Project
Directorate II-3
Division of Reactor Projects - I/II
Kahtan N. Jabbour, Project Manager, Project
Directorate II-3
Division of Reactor Projects - I/II
Leonard A. Wiens, Project Manager, Project
Directorate II-3
Division of Reactor Projects - I/II

SUBJECT: CLOSURE OF BULLETIN 89-01 ON ALL DUKE STATIONS
(TACS 73179, 73180, 73183, 73184, 73185, 73157, 73158)

By letter of June 20, 1989, Duke replied to NRC Bulletin 89-01 "Failure of Westinghouse Steam Generator Tube Mechanical Plugs" for each of its seven nuclear stations. The reply indicates that no Duke plant has mechanical plugs from the suspect heat numbers. While Duke has no plans to remove any Westinghouse mechanical plugs from service, should future evaluation indicate susceptibility to failure, plug repair would likely be by "plug-in-a-plug" technique, and any future Duke data would be provided to the Westinghouse data base.

We find that this response satisfies the actions required by Bulletin 89-01, and that the subject TACS can be closed.

Leonard A. Wiens,
Project Manager
Project Directorate II-3
Division of Reactor
Projects - I/II

Kahtan N. Jabbour,
Project Manager
Project Directorate II-3
Division of Reactor
Projects - I/II

Darl S. Hood,
Project Manager
Project Directorate II-3
Division of Reactor
Projects - I/II

[DUKE PLANTS CLOSE BULTN 89-01]

^{DSIF}
PD II-3
DHood
7/6/89

^{KJ}
PD II-3
KJabbour
7/6/89

^{LW DSIF}
PD II-3
LWiens
7/6/89

~~PD II-2
LEngle
7/6/89~~

^{ml}
PD II-3
DMatthews
7/6/89