



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

September 9, 2015

LICENSEE: Pacific Gas and Electric Company

FACILITY: Diablo Canyon Power Plant, Unit Nos. 1 and 2

SUBJECT: SUMMARY OF AUGUST 4, 2015, MEETING WITH PACIFIC GAS AND ELECTRIC COMPANY ON RISK-INFORMED COMPLETION TIMES TECHNICAL SPECIFICATION TASK FORCE (TSTF)-505, REVISION 1, "PROVIDE RISK-INFORMED EXTENDED COMPLETION TIMES – RITSTF INITIATIVE 4B," FOR DIABLO CANYON POWER PLANT, UNIT NOS. 1 AND 2 (TAC NOS. MF3240 AND MF3241)

On August 4, 2015, a Category 1 public meeting was held between the U.S. Nuclear Regulatory Commission (NRC) and representatives of Pacific Gas and Electric Company (PG&E, the licensee) at NRC Headquarters, One White Flint North, 11555 Rockville Pike, Rockville, Maryland. The purpose of the meeting was to discuss the license amendment request (LAR) submitted by PG&E on November 25, 2013, to adopt risk-informed completion times per TSTF-505, Revision 1 at Diablo Canyon Power Plant, Unit Nos. 1 and 2 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML13330A557). The meeting notice and agenda dated July 21, 2015, are available at ADAMS Accession No. ML15202A075. A list of attendees is provided in Enclosure 1. The licensee's presentation slides may be accessed from ADAMS at Accession No. ML15232A010.

The publicly noticed meeting was held to discuss issues associated with the NRC staff's TSTF-505 LAR review. Specifically, requests for additional information (RAIs) transmitted from NRC to PG&E on June 29, 2015 (ADAMS Accession No. ML15180A388), and NRC Instruments and Controls (I&C) Branch concerns were discussed during this meeting. I&C Branch presentation slides may be accessed from ADAMS at Accession No. ML15216A411.


Highlights from this meeting include the following:

- Out of 10 commitments made in the original TSTF-505 LAR by the licensee, the licensee completed eight commitments and proposed to change the others to license conditions.
- The licensee will describe all compensatory measures that will be placed in response to the NRC RAIs dated June 29, 2015.
- The licensee will also provide justification for taking equal credit for compensatory measures versus actual modifications that will be made.
- Modifications for fire protection to adopt to the National Fire Protection Association (NFPA) 805 standard will not be completed, probably until 2018.

- Licensee representatives and the NRC staff extensively discussed the definition of loss of function regarding instrumentation and controls. The NRC staff expects to have additional meetings with industry on this topic.

Two members of the public were in attendance for the teleconference meeting and had no comments. Further, no public meeting feedback forms were submitted. No regulatory decisions were made at the meeting.

Please direct any inquiries to me at 301-415-1564 or at Siva.Lingam@nrc.gov.



Siva P. Lingam, Project Manager
Plant Licensing Branch IV-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-275 and 50-323

Enclosure:
List of Attendees

cc w/encl: Distribution via Listserv

LIST OF ATTENDEES
AUGUST 4, 2015, MEETING WITH
PACIFIC GAS AND ELECTRIC COMPANY
TSTF-505, REVISION 1 LICENSE AMENDMENT REQUEST FOR
DIABLO CANYON POWER PLANT, UNIT NOS. 1 AND 2
DOCKET NOS. 50-275 AND 50-323

<u>NAME</u>	<u>ORGANIZATION</u>
R. Baradaran	Pacific Gas and Electric (PG&E)
P. Bemis	PG&E
B. Harris	PG&E
K. Schrader	PG&E
M. Shepard	PG&E
A. Howe	JBC Nuclear Consultant for PG&E
R. Linthicum	PWROG/Exelon
V. Anderson	Nuclear Energy Institute
R. Rollard	Nuclear Energy Institute
H. Barrett	Nuclear Regulatory Commission (NRC)
N. Carte	NRC
M. Chernoff	NRC
D. Gennardo	NRC
T. Hilsmeier	NRC
A. Klein	NRC
S. Lingam	NRC
B. Miller	NRC
S. Rosenberg	NRC
D. Gilmore	Public Member (by phone)
M. Lewis	Public Member (by phone)

Enclosure

- Licensee representatives and the NRC staff extensively discussed the definition of loss of function regarding instrumentation and controls. The NRC staff expects to have additional meetings with industry on this topic.

Two members of the public were in attendance for the teleconference meeting and had no comments. Further, no public meeting feedback forms were submitted. No regulatory decisions were made at the meeting.

Please direct any inquiries to me at 301-415-1564 or at Siva.Lingam@nrc.gov.

/RA/

Siva P. Lingam, Project Manager
Plant Licensing Branch IV-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-275 and 50-323

Enclosure:
List of Attendees

cc w/encl: Distribution via Listserv

DISTRIBUTION:

PUBLIC	RidsNrrDraApla Resource	CRosales-Cooper, EDO RIV
LPL4-1, Reading	RidsNrrLAJBurkhardt Resource	MChernoff, NRR/DSS/STSB
RidsAcraAcnw_MailCTR Resource	RidsNrrPMDiabloCanyon Resource	NCarte, NRR/DE/EICB
RidsNrrDeEicb Resource	RidsRgn4MailCenter Resource	SMakor, RIV/DRS/EB2
RidsNrrDorl Resource	BMiller, NRR/DRA/AFP	THilsmeier, NRR/DRA/APLA
RidsNrrDorlLp4-1 Resource	DGennardo, NRR/DRA/APLA	WMaier, RIV
RidsNrrDraAfpb Resource	HBarrett, NRR/DRA/AFP	TWertz, NRR

ADAMS Accession Nos. Meeting Notice ML15202A075; Meeting Summary ML15233A005

OFFICE	NRR/DORL/LPL4-1/PM	NRR/DORL/LPL4-1/LA	NRR/DE/EICB (A)
NAME	SLingam	JBurkhardt	DRahn
DATE	8/24/15	8/21/15	8/27/15
OFFICE	NRR/DRA/APLA/BC	NRR/DORL/LPL4-1/BC	NRR/DORL/LPL4-1/PM
NAME	SRosenberg	MMarkley	SLingam
DATE	9/2/15	9/9/15	9/9/15

OFFICIAL RECORD COPY