

Enclosure 1

MFN 15-050, Revision 1

**Revised GEH Response to Item #4,
Maximum Groundwater Level**

IMPORTANT NOTICE REGARDING CONTENTS OF THIS DOCUMENT Please Read Carefully

The information contained in this document is furnished solely for the purpose(s) stated in the transmittal letter. The only undertakings of GEH with respect to information in this document are contained in the contracts between GEH and its customers or participating utilities, and nothing contained in this document shall be construed as changing that contract. The use of this information by anyone for any purpose other than that for which it is intended is not authorized; and with respect to any unauthorized use, GEH makes no representation or warranty, and assumes no liability as to the completeness, accuracy, or usefulness of the information contained in this document.

NRC- Suggested Design Changes Item #4 – Ground Water Elevation

Address the significance of design basis maximum groundwater level in the hydrology section and its allowable margin if any, identify where this parameter is used, and if possible, set the design basis maximum groundwater level at site grade.

Revised GEH Response:

Ground water level is used in determining the shear wave and compression wave velocity of soil at soil sites, which are used in the performance of the soil structure interaction analysis. It is also used in determining the at-rest soil pressure and hydrostatic pressure on buildings below grade exterior walls. Changing the DCD ground water level would impact the analyses presented in ABWR DCD Appendices 3A and 3H.

As discussed in the face to face meeting on May 7, 2015; GEH will add the basis for the current ground water level of 0.6m below grade to the DCD.

The ABWR DCD rev 5 Section 2.0 will be modified as follows:

Added subsection 2.0.2;

2.0.2 References

2.0.2-1 Electric Power Research Institute, "Advanced Light Water Reactor Utility Requirements Document," [Revision 8, March 1999](#).

Revised Table 2.0-1 to add the same footnote mark for Maximum Ground Water Level and Maximum Flood (or Tsunami) Level.

Revised the third footnote of Table 2.0-1 to read: "As defined in Table 1.2-6 of Volume II of Reference 2.0.2-1"

Impact on DCD:

DCD, Tier 2, Section 2.0 is revised as shown. The ABWR DCD Rev 5 marked up pages are attached in Enclosure 2.