

PRIORITY 1

(ACCELERATED RIDS PROCESSING)

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9507110086	DOC. DATE: 95/06/29	NOTARIZED: NO	DOCKET #	
FACIL: 50-269	Oconee Nuclear Station, Unit 1, Duke Power Co.		05000269	P
	50-270 Oconee Nuclear Station, Unit 2, Duke Power Co.		05000270	
	50-287 Oconee Nuclear Station, Unit 3, Duke Power Co.		05000287	R

AUTH. NAME	AUTHOR AFFILIATION	
HAMPTON, J.W.	Duke Power Co.	
RECIP. NAME	RECIPIENT AFFILIATION	
	Document Control Branch (Document Control Desk)	I

SUBJECT: Advises NRC that review of Oconee Nuclear Station mods indicates that LPSW flow instrumentation mods have been completed. O R

DISTRIBUTION CODE: A003D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2
 TITLE: OR/Licensing Submittal: Suppl 1 to NUREG-0737 (Generic Ltr 82-33) I

NOTES:

	RECIPIENT		COPIES		
	ID CODE/NAME	LTR	ENCL		
	PD2-2 LA	1	1		
	WIENS, L	1	1		
INTERNAL:	<u>FILE CENTER</u> 01	1	1	NRR/DRCH/HHFB	1 1
	<u>RES/DSTR/EIB</u>	1	1		
EXTERNAL:	NOAC	1	1	NRC PDR	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM OWFN 5D8 (415-2083) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 8 ENCL 8

msf

Duke Power Company
Oconee Nuclear Site
P.O. Box 1439
Seneca, SC 29679

J. W. HAMPTON
Vice President
(803)885-3499 Office
(803)885-3564 Fax



DUKE POWER

June 29, 1995

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Subject: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287
Regulatory Guide 1.97

By letter dated April 29, 1993, Duke Power Company revised the response to Regulatory Guide (RG) 1.97 as addressed in Supplement 1 in NUREG-0737. The revision indicated that the instrumentation monitoring the Low Pressure Service Water (LPSW) flow to the Low Pressure Injection (LPI) coolers would be replaced with instrumentation meeting the Type A, Category 1 requirements of RG 1.97. The following schedule was provided for modifying the instrumentation during refueling outages in April 1994 for Unit 1, in April 1993 for Unit 2, and in December 1993 for Unit 3.

The completion schedule for the modifications was revised in a Duke Power letter dated February 28, 1994. A review of the Oconee Nuclear Station modifications indicates that the LPSW flow instrumentation modifications have been completed.

Very truly yours,

J. W. Hampton, Site Vice President
Oconee Nuclear Station

9507110086 950629
PDR ADOCK 05000269
P PDR

A2003
11

cc: Mr. S. D. Ebnetter, Regional Administrator
U. S. Nuclear Regulatory Commission, Region II

Mr. L. A. Wiens, Project Manager
Office of Nuclear Reactor Regulation

Mr. P. E. Harmon
Senior Resident Inspector
Ocone Nuclear Site