

PRIORITY 1

(ACCELERATED RIDS PROCESSING)

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9508010147 DOC.DATE: 95/07/17 NOTARIZED: NO DOCKET #
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269 P
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287 R

AUTH.NAME AUTHOR AFFILIATION
 HAMPTON, J.W. Duke Power Co.
 RECIP.NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk) I

SUBJECT: Provides list of changes made to Unit 3 Data Point Library. O

DISTRIBUTION CODE: A026D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 5
 TITLE: Emergency Response Data System (ERDS) R

NOTES:

	RECIPIENT		COPIES		RECIPIENT		COPIES		
	ID	CODE/NAME	LTR	ENCL	ID	CODE/NAME	LTR	ENCL	
	AEOD/IRB	01	2	2	NRR/PD3-2		1	1	T
	WIENS, L		1	1					Y
INTERNAL:	ACRS		1	1	AEOD		1	1	
	AEOD/DOA/IRB		1	1	<u>FILE CENTER</u>		1	1	
	RGN2 ERC		1	1	RGN2 FILE		1	1	1
EXTERNAL:	NRC PDR		1	1					

NOTE TO ALL "RIDS" RECIPIENTS:
 PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL
 DESK, ROOM OWFN 5D8 (415-2083) TO ELIMINATE YOUR NAME FROM
 DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 11 ENCL 11

MAY

Duke Power Company
Oconee Nuclear Generation Department
P.O. Box 1439
Seneca, SC 29679

J.W. HAMPTON
Vice President
(803)885-3499 Office
(704)373-5222 FAX



DUKE POWER

July 17, 1995

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D. C. 20555

Subject: Oconee Nuclear Station
Docket Number 50-269, 50-270, 50-287
Emergency Response Data System


10CFR50, Appendix E, Section VI 3.a. requires that any software change that affects the transmitted data points identified in the ERDS Data Point Library must be submitted to the NCR within 30 days after the changes are completed.

Listed below are the changes that were made to Unit 3 Data Point Library.

<u>DATA POINT</u>	<u>UNIT 3</u>
A1537	06/22/95
A1541	06/22/95
A1031	06/30/95
A1026	06/30/95

If there are questions regarding the Emergency Response Data System, please contact Coleman Jennings at (803) 855-3294.

Very truly yours,


J. W. Hampton
VP, Oconee Nuclear Site

cc: Mr. S. D. Ebnetter, Regional Administrator
U.S. Nuclear Regulatory Commission, Region II

Mr. L. A. Wiens, Project Manager
Oconee Project Manager

Mr. Paul Harmon
Oconee Resident Inspector

Mr. John Jolicoeur
Office of Analysis & Evaluation

9508010147 950717
PDR ADOCK 05000269
P PDR

A026
11

=====
Oconee Emergency Resp
=====

=====
onse Data System
=====

DATE:	7/22/93
REACTOR UNIT:	oc3
DATA FEEDER:	N/A
NRC ERDS PARAMETER:	NI SOURC RNG
POINT ID:	a1537
PLANT SPEC POINT DESC:	
GENERIC/COND DESC:	
ANALOG/DIGITAL:	A
ENGR UNITS/DIG STATES:	CPS
ENGR UNITS CONV:	N/A
MINIMUM INSTR RANGE:	.1
MAXIMUM INSTR RANGE:	1E5
ZERO POINT REFERENCE:	N/A
REFERENCE POINT NOTES:	N/A
PROC OR SENS:	S
NUMBER OF SENSORS:	1
HOW PROCESSED:	N/A
SENSOR LOCATIONS:	OUTSIDE OF RX VESSEL
ALARM/TRIP SET POINTS:	NONE
NI CUTOFF PWR LEVEL:	N/A
NI CUTON PWR LEVEL:	N/A
INST FAILURE MODE:	LOW
TEMP COMPENSATION:	N
LEVEL REF LEG:	N/A
UNIQUE SYSTEM DESC:	

=====

Oconee Emergency Resp

=====

=====

onse Data System

=====

DATE:	1/19/93
REACTOR UNIT:	oc3
DATA FEEDER:	N/A
NRC ERDS PARAMETER:	NI INTER RNG
POINT ID:	a1541
PLANT SPEC POINT DESC:	
GENERIC/COND DESC:	
ANALOG/DIGITAL:	A
ENGR UNITS/DIG STATES:	PCT
ENGR UNITS CONV:	N/A
MINIMUM INSTR RANGE:	1E-8
MAXIMUM INSTR RANGE:	2E2
ZERO POINT REFERENCE:	N/A
REFERENCE POINT NOTES:	N/A
PROC OR SENS:	S
NUMBER OF SENSORS:	1
HOW PROCESSED:	N/A
SENSOR LOCATIONS:	OUTSIDE OF RX VESSEL
ALARM/TRIP SET POINTS:	NONE
NI CUTOFF PWR LEVEL:	N/A
NI CUTON PWR LEVEL:	N/A
INST FAILURE MODE:	LOW
TEMP COMPENSATION:	N
LEVEL REF LEG:	N/A
UNIQUE SYSTEM DESC:	

=====

Oconee Emergency Resp

=====

=====

onse Data System

=====

DATE:	1/19/93
REACTOR UNIT:	oc3
DATA FEEDER:	N/A
NRC ERDS PARAMETER:	SG LEVEL 2/B
POINT ID:	a1031
PLANT SPEC POINT DESC:	
GENERIC/COND DESC:	
ANALOG/DIGITAL:	A
ENGR UNITS/DIG STATES:	INCH
ENGR UNITS CONV:	N/A
MINIMUM INSTR RANGE:	0
MAXIMUM INSTR RANGE:	650
ZERO POINT REFERENCE:	COMPLE
REFERENCE POINT NOTES:	SEE PO/0/A/1108/01, Encl. 3.19
PROC OR SENS:	S
NUMBER OF SENSORS:	1
HOW PROCESSED:	N/A
SENSOR LOCATIONS:	?
ALARM/TRIP SET POINTS:	NONE
NI CUTOFF PWR LEVEL:	N/A
NI CUTON PWR LEVEL:	N/A
INST FAILURE MODE:	LOW
TEMP COMPENSATION:	N
LEVEL REF LEG:	N/A
UNIQUE SYSTEM DESC:	From FDWLT0009P

=====

Oconee Emergency Resp

=====

=====

onse Data System

=====

DATE:	1/19/93
REACTOR UNIT:	oc3
DATA FEEDER:	N/A
NRC ERDS PARAMETER:	SG LEVEL 1/A
POINT ID:	a1026
PLANT SPEC POINT DESC:	
GENERIC/COND DESC:	
ANALOG/DIGITAL:	A
ENGR UNITS/DIG STATES:	INCH
ENGR UNITS CONV:	N/A
MINIMUM INSTR RANGE:	0
MAXIMUM INSTR RANGE:	650
ZERO POINT REFERENCE:	COMPLE
REFERENCE POINT NOTES:	SEE PO/0/A/1108/01, Encl. 3.19
PROC OR SENS:	S
NUMBER OF SENSORS:	1
HOW PROCESSED:	N/A
SENSOR LOCATIONS:	?
ALARM/TRIP SET POINTS:	NONE
NI CUTOFF PWR LEVEL:	N/A
NI CUTOFF PWR LEVEL:	N/A
INST FAILURE MODE:	LOW
TEMP COMPENSATION:	N
LEVEL REF LEG:	N/A
UNIQUE SYSTEM DESC:	From FDWLT0007P