

January 30, 1996

Duke Power Company
ATTN: Mr. J. W. Hampton
Vice President
Oconee Site
P. O. Box 1439
Seneca, SC 29679

SUBJECT: OCONEE NUCLEAR SITE EMERGENCY PLAN REVIEW, REVISION 95-03

Dear Mr. Hampton:

We have completed our review of Revision 95-03 to your Oconee Nuclear Site Emergency Plan. The change to ENCLOSURE 4.3, Abnormal Rad Levels/Radiological Effluent, Alert, deleted reference to RIA 33. In a conversation with members of our staff, Oconee committed to reinstate the reference to RIA 33 but, will use a different, "acknowledgement", setpoint for RIA 33. Your staff committed to correct the change in revision 96-01.

Our review concluded that the remainder of the changes were satisfactory and met the planning standards of 10 CFR 50.47(b) and the requirements of Appendix E to 10 CFR Part 50.

Please be reminded that 10 CFR 50.54(q) requires that proposed changes which decrease the effectiveness of your Emergency Plan may not be implemented without application to and approval by the Commission. However, changes may be made without Commission approval if such changes do not decrease the effectiveness of the Plan, and the Plan, as changed, continues to meet the standards of 10 CFR 50.47(b) and the requirements of Appendix E to 10 CFR Part 50. If a change is made without approval, you should furnish copies in accordance with 10 CFR 50.54(q). Also, any changes to the Emergency Plan Implementing Procedures should be made in accordance with the requirements of Appendix E to 10 CFR Part 50.

Should you have any questions, or if your understanding of the correction and commitment are different, please contact Mr. Glen Salyers of our staff on 404-331-5604.

Sincerely,

(Original signed by K. P. Barr)

Kenneth P. Barr, Chief
Plant Support Branch
Division of Reactor Safety

Docket Nos. 50-269, 50-270, 50-287
License Nos. DPR-38, DPR-47, DPR-55

cc: {See page 2}

120044
9602120033 960130
PDR ADDCK 05000269
F PDR

MAY
10
1996

cc: Mr. J. E. Burchfield
Compliance
Duke Power Company
P. O. Box 1439
Seneca, SC 29679

Mr. Paul R. Newton
Duke Power Company
422 South Church Street
Charlotte, NC 28242-0001

Mr. Robert P. Gruber
Executive Director
Public Staff - NCUC
P. O. Box 29520
Raleigh, NC 27626-0520

Mr. Robert B. Borsum
Babcock and Wilcox Company
Nuclear Power Generation
Division
1700 Rockville Pike, Suite 525
Rockville, MD 20852

Mr. J. Michael McGarry, III,
Esq.
Winston and Strawn
1400 L Street, NW
Washington, D. C. 20005

Office of Intergovernmental
Relations
116 West Jones Street
Raleigh, NC 27603

Mr. Max Batavia, Chief
Bureau of Radiological Health
South Carolina Department of Health
and Environmental Control
2600 Bull Street
Columbia, SC 29201

County Supervisor of
Oconee County
Walhalla, SC 29621

Manager, LIS
NUS Corporation
2650 McCormick Drive
Clearwater, FL 34619-1035

Mr. G. A. Copp
Licensing - EC050
Duke Power Company
P. O. Box 1007
Charlotte, NC 28201-1007

Ms. Karen E. Long
Assistant Attorney General
N. C. Department of Justice
P. O. Box 629
Raleigh, NC 27602

Distribution:
L. A. Wiens, NRR
R. Carroll, RII
G. A. Hallstrom, RII
PUBLIC

NRC Resident Inspector
U.S. Nuclear Regulatory Commission
78128 Rochester Highway
Seneca, SC 29672

SEND TO PUBLIC DOCUMENT ROOM?						
			YES	NO		
OFFICE	RII:DRS	RII:DRS	RII:DRP			
SIGNATURE	<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>			
NAME	GSalyers	K.Bair	RCrlenjak			
DATE	01/30/96	01/30/96	01/30/96	01 / / 96	01 / / 96	01 / / 96
COPY?	YES NO	YES NO	YES NO	YES NO	YES NO	YES NO

OFFICIAL RECORD COPY

DOCUMENT NAME: G:\DOCUMENT\OLTR953r.GWS