

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8303240465 DOC. DATE: 82/03/17 NOTARIZED: NO DOCKET #  
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269  
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270  
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287

AUTH. NAME AUTHOR AFFILIATION  
 TUCKER, H.B. Duke Power Co.  
 RECIPIENT NAME RECIPIENT AFFILIATION  
 DENTON, H.R. Office of Nuclear Reactor Regulation, Director  
 EISENHUT, D.G. Division of Licensing

SUBJECT: Responds to Generic Ltr 83-10 re resolution of TMI Action Plan Item II.K.3.5, "Automatic Trip of Reactor Coolant Pumps." Plans & schedule for resolution of issue will be provided by 830701.

DISTRIBUTION CODE: A001S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1  
 TITLE: OR Submittal: General Distribution

NOTES: AEOD/Ornstein:1cy, 05000269  
 AEOD/Ornstein:1cy, 05000270  
 AEOD/Ornstein:1cy, 05000287

RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
NRR ORB4 BC 01	7 7		

INTERNAL: ELD/HDS4	1 0	NRR/DE/MTEB	1 1
NRR/DL DIR	1 1	NRR/DL/ORAB	1 0
<del>NRR/DSI/METB</del>	1 1	NRR/DSI/RAB	1 1
<u>REG FILE</u> 04	1 1	RGN2	1 1

EXTERNAL: ACRS 09	6 6	LPDR 03	1 1
NRC PDR 02	1 1	NSIC 05	1 1
NTIS	1 1		

NOTES: 1 1

DUKE POWER COMPANY

P.O. BOX 33189  
CHARLOTTE, N.C. 28242

HAL B. TUCKER  
VICE PRESIDENT  
NUCLEAR PRODUCTION

TELEPHONE  
(704) 373-4531

March 17, 1983

Mr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555


Attention: Mr. D. G. Eisenhut, Director  
Division of Licensing

Subject: Oconee Nuclear Station  
Docket Nos. 50-269, -270, -287

Dear Sir:

By letter dated February 8, 1983, the NRC issued Generic Letter 83-10 concerning resolution of TMI Action Plan Item II.K.3.5, Automatic Trip of Reactor Coolant Pumps. In response to your letter, Duke, as a member of the Babcock and Wilcox Owners Group, will support generic resolution of this issue. To allow time to evaluate existing analyses that have been previously performed and to compare a new RC pump trip criteria to the recommendations contained in Generic Letter 83-10, plans and schedule for resolution of this issue will not be provided until July 1, 1983. In the interim, Oconee will utilize the existing RC pump trip instructions based on automatic actuation of engineered safeguards on low reactor coolant pressure.

Very truly yours,



Hal B. Tucker

RLG/php

cc: Mr. James P. O'Reilly, Regional Administrator  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30303

Mr. E. L. Conner, Jr.  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Mr. J. C. Bryant  
NRC Resident Inspector  
Oconee Nuclear Station

*A001*

8303240465 830317  
PDR ADOCK 05000269  
P PDR