

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8002200455 DOC. DATE: 80/02/15 NOTARIZED: NO DOCKET #
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287

AUTH. NAME: PARKER, W. O. AUTHOR AFFILIATION: Duke Power Co.
 RECIP. NAME: DENTON, H. R. RECIPIENT AFFILIATION: Office of Nuclear Reactor Regulation
 REID, R. W. Operating Reactors Branch 4

SUBJECT: Forwards analysis of small break LOCA which repressurizes to power operated relief valve setpoint, in response to NRC 790921 request. Repressurization will not occur in primary sys unless feedwater is lost to steam generators.

DISTRIBUTION CODE: A041S COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 14
 TITLE: Resp to Lesson Learn Task Force - B&W and 50-409

NOTES: M. CUNNINGHAM - ALL AMENDS TO FSAR & CHANGES TO TECH SPECS.

ACTION:	RECIPIENT	COPIES		RECIPIENT	COPIES	
	ID CODE/NAME	LTR	ENCL		ID CODE/NAME	LTR
	8 BC <u>ORB #4</u>	7	7			
INTERNAL:	1 <u>REG FILE</u>	1	1	15 I & E	2	2
	18 CORE PERF BR	1	1	19 ENG BR	1	1
	2 NRC PDR	1	1	20 REAC SFTY BR	1	1
	21 PLANT SYS BR	1	1	22 EEB	1	1
	23 EFLT TRT SYS	1	1	3 LPDR	1	1
	4 NSIC	1	1	5 C LONG	1	1
	6 G LANIK	1	1	7 J. DONOHEW	1	1
	J.T. TELFORD	2	2	0 CHOPRA	1	1
	OELD	1	0			
EXTERNAL:	24 ACRS	16	16			

FEB 25 1980

T

MA 4

TOTAL NUMBER OF COPIES REQUIRED: LTR 42 ENCL 0 AT

DUKE POWER COMPANY

POWER BUILDING

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242

WILLIAM O. PARKER, JR.
VICE PRESIDENT
STEAM PRODUCTION

February 15, 1980

TELEPHONE: AREA 704
373-4083

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555


Attention: Mr. R. W. Reid, Chief
Operating Reactors Branch No. 4

Re: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287

Dear Sir:

In response to the Staff's letter of August 21, 1979 and pursuant to my letter of September 21, 1979, please find attached an analysis of a small break LOCA which repressurizes to the PORV setpoint.

Very truly yours,


William O. Parker, Jr.

RLG:scs

Attachment

A041
S/D

8002200 455

P

SMALL BREAK WITH FAILED PORV

1. INTRODUCTION

It has been established in reference 1, that very small cold leg breaks (<0.01) will repressurize to the PORV setpoint of 2465 psia if the auxiliary feedwater is delayed significantly. Since there is a probability of the PORV sticking open after being actuated, concerns have been raised regarding the impact of this consequential failure. This report presents the results of an analysis of a 0.01 ft^2 cold leg break with the subsequent failure of the PORV to close.

2. SUMMARY & CONCLUSIONS

As has been demonstrated by the analyses presented in Section 6 of reference 1, small breaks in the primary system will not cause a repressurization to the PORV setpoint unless all feedwater is lost to the steam generators. Under this situation, there exists a class of very small breaks, (less than 0.01 ft^2) wherein the system will repressurize to the PORV setpoint. An analysis is presented herein for a 0.01 ft^2 break, without feedwater to the steam generator, which results in a repressurization to approximately the PORV setpoint. At 20 minutes, the PORV was actuated and was assumed to stick open.

As is demonstrated in Section 4, for the 177-FA lowered-loop plants, operator action by 20 minutes to manually actuate the two high pressure injection trains will keep the core covered. A qualitative analysis is also presented which demonstrates that reestablishment of auxiliary feedwater by 20 minutes, for both the 177-FA raised and lowered loop plants, will prevent core uncover. Therefore, a 0.01 ft^2 break with no auxiliary feedwater can be mitigated safely with B&W's present operator guidelines. These operator guidelines require establishing feedwater to the steam generator as soon as possible, if the AFW is not available initially, and manual initiation of the HPI upon loss of the steam generator heat sink or saturated conditions in the primary system.

3. METHOD OF ANALYSIS

Evaluations of very small breaks which result in repressurization phenomena are presented in reference 1. These analyses demonstrate that if auxiliary feedwater is delivered to the steam generators, the primary system would not repressurize to the PORV setpoint. However, the analyses in reference 1 also

demonstrate that if feedwater is not delivered to the steam generator within 20 minutes, there is a class of very small breaks, less than 0.01 ft², which will result in system repressurization to the PORV setpoint. Since the PORV might stick open after being actuated, concerns have been raised regarding the impact of this consequential failure.

An analysis of a 0.01 ft² break in the cold leg pump discharge piping, without auxiliary feedwater to the SG, was performed wherein the PORV was actuated and assumed to stick open. As has been demonstrated in reference 1, larger breaks will result in automatic actuation of the HPI system and will not repressurize. While smaller breaks will repressurize to the PORV setpoint earlier, less inventory would be lost out the break. Therefore, the 0.01 ft² small break with the subsequent failure of the PORV is expected to be the worst case for transients of this type.

The analysis was performed using the B&W ECCS evaluation model for the 177-FA lowered-loop plants.² The analysis was performed using the same model and assumptions listed in Section 6.2.1.3.5 of reference 1 with the only changes being those made to reflect the PORV sticking open. Key assumptions of the analysis are listed below.

1. The initial core power level is 102% of 2772 MWt.
2. The core decay heat is based on 1.2 times the ANS standard.
3. Operator action was taken at 20 minutes to manually actuate both HPI pumps.
4. The PORV was modeled as a leak path on the top of the pressurizer. The orifice area of .0073 ft² was used, however, a C_D of 0.72 was utilized in order to reflect the proper relief characteristics of the PORV with the Moody critical flow model.
5. The PORV was opened at 20 minutes. This is consistent with the operator guidelines for a LOCA with no feedwater to the steam generators. However, if the operator had not acted within this time frame, approximately a 2 minute delay in operator action would have resulted in the PORV being actuated automatically.

4. RESULTS

Figures 1 through 7 show the system response during the transient and Table 1 presents a sequence of events for this accident. The resultant system pressure response of a 0.01 ft² cold leg break with no AFW is shown in Figure 1. This particular response is due to (1) the loss of the SG heat sink; (2) no automatic HPI actuation prior to the loss of the steam generator heat sink; and (3) the opening of the PORV and actuation of the HPI at 20 minutes. As seen in Figure 1, the pressure initially decreases following the break opening. During this depressurization period, the reactor trips, the pumps trip, the pressurizer empties, and the steam generator secondary inventory boils off. With the loss of the SG heat sink, the primary system starts to repressurize before the ESFAS signal is reached. Therefore, the HPI is not automatically actuated. The system repressurizes to 2350 psia by 20 minutes at which time the PORV was assumed to open. This is only 115 psi below the PORV setpoint which would have been reached approximately 2 minutes later. However, the operator is instructed to manually open the PORV if the system repressurizes and the SG heat sink is lost. Thus, the opening at 20 minutes is not totally arbitrary. During the system repressurization the pressurizer level increases (Figure 2) and when the PORV is opened the pressurizer rapidly fills with two phase mixture. At the time of the PORV opening, the two HPI pumps are manually actuated, and due to the addition of the cold makeup water and the additional leak path area, the RCS depressurizes.

The inner vessel mixture height is shown on Figure 3. As can be seen, operator action by 20 minutes to manually actuate the HPI prevents core uncover and a minimum two-phase mixture level of 4.5 feet above the top of the core is maintained. Long term cooling is established at 25 minutes as the injected HPI fluid exceeds the core boil-off. Thus, the acceptance criteria of 10 CFR 50.46 are satisfied.

While the analysis performed herein addressed the effect of operator action to manually actuate the HPI by 20 minutes, the effect of operator action to manually restore the auxiliary feedwater within 20 minutes can be qualitatively assessed. As has been shown in Section 6.2.1.3.5 of reference 1, actuation of the auxiliary feedwater system at 20 minutes for a 0.01 ft² break results in a rapid system depressurization and the subsequent actuation of the HPI. For the case analyzed herein, the depressurization effect of the auxiliary feedwater would be faster than that shown in reference 1 due to the effect of the loss of inventory through the PORV. Thus, the HPI would be actuated earlier and long term cooling

would be established faster than that shown in reference 1. Therefore, no core uncover is expected if the operator only actuates the auxiliary feedwater system within 20 minutes and, contrary to the guidelines, does not manually actuate the HPI.

Table 1. Sequence of Events

<u>Event</u>	<u>Time, s</u>
1. 0.01 ft ² cold leg break occurs	0.0
2. Reactor trip, loss of feedwater, and RC pump trip	54.5
3. Main feedwater coastdown ends	60.0
4. SG secondary boils dry	270.0
5. PORV opened	1200.0
6. HPI is manually initiated	1200.0
7. Long term cooling established	1510.0

REFERENCES

- ¹ Letter J.H. Taylor (B&W) to S.A. Varga (NRC), "Evaluation of Transient Behavior and Small Reactor Coolant System Breaks in the 177-Fuel Assembly Plant," May 7, 1979.
- ² B.M. Dunn, et. al., "B&W's ECCS Evaluation Model," BAW-10104, Rev. 3, Babcock & Wilcox, May 1975.

Figure 1

.01 FT² COLD LEG BREAK W/NO AFW 2 HPI'S & STUCK PORV
AT 20 MIN. - NODE 14 PRESSURE VS TIME




Figure 2

.01 FT² COLD LEG BREAK W/NO AFW 2 HPI'S & STUCK
PORV AT 20 MIN. - PRESSURIZER LIQUID LEVEL




Figure 3
.01 FT² COLD LEG BREAK W/NO AFW 2 HPI'S & STUCK PORV
AT 20 MIN. - UPPER PLENUM LIQUID LEVEL




Figure 4

.01 FT² COLD LEG BREAK W/NO AFW 2 HPI'S & STUCK PORV
AT 20 MIN. - PORV LEAK FLOW




Figure 5

.01 FT² COLD LEG BREAK W/NO AFW 2 HPI'S & STUCK PORV
AT 20 MIN. - PORV LEAK FLOW QUALITY




Figure 6

.01 FT² COLD LEG BREAK W/NO AFW 2 HPI'S & STUCK PORV
AT 20 MIN. - COLD LEG BREAK FLOW




Figure 7

.01 FT² COLD LEG BREAK W/NO AFW 2 HPI'S & STUCK PORV
AT 20 MIN. - COLD LEG BREAK LEAK FLOW QUALITY

