

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

MA/4

ACCESSION NBR: 8004080614 DOC. DATE: 80/04/02 NOTARIZED: NO
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co.
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co.
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co.

DOCKET #
 05000269
 05000270
 05000287

AUTH. NAME: PARKER, W.O. AUTHOR AFFILIATION: Duke Power Co.
 RECIP. NAME: DENTON, H.R. RECIPIENT AFFILIATION: Office of Nuclear Reactor Regulation

SUBJECT: Supplements 800102 ltr & confirms discussions w/NRC re reactor vessel head vent required by NUREG-0578. Remotely operable reactor vessel head vent will be installed. Design will be similar to that of hot leg vents per 800102 ltr.

DISTRIBUTION CODE: A041S COPIES RECEIVED: LTR L ENCL L SIZE: L
 TITLE: Resp to Lesson Learn Task Force - B&W and 50-409

NOTES: M. CUNNINGHAM - ALL AMENDS TO FSAR & CHANGES TO TECH R. CAPRA - ICY SPECS.

ACTION:	RECIPIENT	COPIES		RECIPIENT:	COPIES	
	ID CODE/NAME	LTR	ENCL		ID CODE/NAME	LTR
	08 BC <u>ORB #4</u>	7	7			
INTERNAL:	<u>01 REG FILE</u>	1	1	02 NRC PDR	1	1
	05 LONG, C.	1	1	06 LANIK, G.	1	1
	07 DONOHEW, J.	1	1	15 I & E	2	2
	18 CORE PERF BR	1	1	19 ENG BR	1	1
	20 REAC SFTY BR	1	1	21 PLANT SYS BR	1	1
	22 EEB	1	1	23 EFLT TRT SYS	1	1
	CHOPRA, O.	1	1	OELD	1	0
	TELFORD, J. T.	2	2			
EXTERNAL:	03 LPDR	1	1	04 NSIC	1	1
	24 ACRS	16	16			

APR 10 1980

TOTAL NUMBER OF COPIES REQUIRED: LTR 43 ENCL 42
42 41

DUKE POWER COMPANY

POWER BUILDING

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242

WILLIAM O. PARKER, JR.
VICE PRESIDENT
STEAM PRODUCTION

April 2, 1980

TELEPHONE: AREA 704
373-4083

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Mr. Robert W. Reid, Chief
Operating Reactors Branch No. 4


Subject: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287

Dear Sir:

This letter supplements my letter of January 2, 1980 and confirms discussions held recently with the Staff concerning the Reactor Vessel head vent required by NUREG-0578.

In addition to the hot leg vents previously committed to, Duke will install a remotely operable Reactor Vessel head vent on each Oconee unit. The design will be similar to that which was described for the hot leg vents in my letter of January 2, 1980.

Very truly yours,



William O. Parker, Jr.

RLG:scs

am

*A041
S 1/1
8004080614*