

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8101190385 DOC. DATE: 81/01/13 NOTARIZED: NO DOCKET #
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287

AUTH. NAME AUTHOR AFFILIATION
 PARKER, W.O. Duke Power Co.
 RECIPIENT NAME RECIPIENT AFFILIATION
 DENTON, H.R. Office of Nuclear Reactor Regulation, Director
 REID, R.W. Operating Reactors Branch 4

SUBJECT: Forwards request for relief from ASME Code Section XI requirements re main feedwater sys check valves. Approval requested by 810114.

DISTRIBUTION CODE: A001S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 5
 TITLE: General Distribution for after Issuance of Operating License

NOTES: M Cunningham: all amends to FSAR & changes to Tech Specs. 05000269
 AEOD, Ornstein: 1cc.
 M Cunningham: all amends to FSAR & changes to Tech Specs. 05000270
 AEOD, Ornstein: 1cc.
 M Cunningham: all amends to FSAR & changes to Tech Specs. 05000287
 AEOD, Ornstein: 1cc

W/CHECK: \$4800.00

ACTION:	RECIPIENT ID CODE/NAME		COPIES		RECIPIENT ID CODE/NAME	COPIES	
			LTR	ENCL		LTR	ENCL
	REID, R.	04	13	13			
INTERNAL:	D/DIR, HUM FAC08		1	1	DIR, DIV OF LIC	1	1
	I&E	06	2	2	NRC PDR 02	1	1
	OELD	11	1	0	OR ASSESS BR 10	1	0
	<u>REG FILE</u>	01	1	1			
EXTERNAL:	ACRS	09	16	16	LPDR	03	1
	NSIC	05	1	1			

JAN 21 1981

TOTAL NUMBER OF COPIES REQUIRED: LTR 40 ENCL 38

SF

DUKE POWER COMPANY

POWER BUILDING

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242

WILLIAM O. PARKER, JR.
VICE PRESIDENT
STEAM PRODUCTION

January 13, 1981

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Mr. R. W. Reid, Chief
Operating Reactors Branch No. 4


Re: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287

Dear Sir:

Pursuant to 10CFR 50, §50.55a, please find attached a request for relief from the current Inservice Inspection requirements following valve replacement. The attached request concerns the main feedwater system check valves which are scheduled to be replaced during the current Oconee 3 refueling outage and the next refueling outage for each of the other Oconee units. It is urgently requested that this request be approved by January 14, 1981 in order that the Oconee 3 check valves may be replaced during the current refueling outage, without delaying the restart of the unit. Replacement time is expected to take about three weeks.

Pursuant to 10CFR 170, §170.27 please find attached a check in the amount of \$4,800. This amount represents one Class III license fee for Oconee 3 and two Class I license fees for Oconee 1, 2. Your prompt review and approval of this request will enable this modification to be accomplished during the current Oconee 3 outage.

Very truly yours,


William O. Parker, Jr.

RLG:scs
Attachment

RECEIVED DISTRIBUTION
U.S. NUCLEAR REGULATORY COMMISSION
1981 JAN 15 PM 3 51
TELEPHONE AREA 704
373-4080
FEDERAL SERVICES

A001
S
1/1
w/checks
\$4800.00

8101190385

Q

DUKE POWER COMPANY
OCONEE NUCLEAR STATION

REQUEST FOR RELIEF FROM ASME CODE SECTION XI REQUIREMENT
DETERMINED TO BE IMPRACTICAL

1. Component for which relief is requested:

a. Name and Number

Units 1, 2 & 3 Main Feedwater Check Valves are to be replaced; Valve Numbers FDW 37 and FDW 46

b. Function

The Main Feedwater System supplies water to the Steam Generators where it removes heat from the Reactor Coolant System. The check valves to be replaced act as containment isolation valves for the Main Feedwater System and to prevent Steam Generator blowdown upon loss of feedwater discharge pressure.

c. ASME Section III Code Class

Equivalent Class 2

d. Valve Category

Check

2. ASME Section XI requirement that has been determined to be impractical:

ASME Boiler and Pressure Vessel Code Section XI, 1980 Edition. Article IWC 5000, System Pressure Tests.

3. Basis for requesting relief:

There are no isolation valves downstream of these check valves in the feedwater system. Performing a hydrostatic test would require one of two approaches for line isolation.

The first approach would pressurize the entire secondary side of the Steam Generator, the Main Feedwater lines, and the Main Steam lines. Isolation could possibly be accomplished by the Turbine Stop Valves in the Main Steam lines and the Feedwater Control and/or Isolation Valves in the Feedwater Lines; however, the potential for adequate leaktightness of these valves is not good due to the designed application and size of these valves. The potential for damage to the Main Steam System exists due to the heavier static loads created by a water solid system.

A second approach for performing a hydrostatic test involves removing all 32 four inch risers from each feedwater header on each of the two Steam Generators. Blank flanges would then have to be installed on the header. Radiation exposure to personnel would be high and additional potential for leaks would be created. While this method of isolation would be

superior from a leaktightness standpoint, isolation at the other end of the line with the Feedwater Control and/or Isolation Valves again may prove unattainable.


A hydrostatic test is generally performed to assure leaktightness of welds and to indicate gross flaws or incomplete work. While hydrostatic tests are valuable for initial assurance of leaktightness, they often cannot offer insight into future weld failure due to the propagation of internal weld defects. For this reason, it is felt that a 100% radiograph of a weld offers a superior assurance of a qualified weld.

4. Alternate examinations:

A 100% radiographic examination of both welds on each valve would be performed and an inservice leak test at operating pressure and temperature will be conducted. An appropriate surface examination will also be completed.

5. Implementation:

These examinations will be carried out at the time of valve replacement during the 1981 refueling outage on each unit.



FROM EMERG. FDW PUMP (PO-121A-U)(E-10)

FROM WET LAMP RECIRC. PUMP (PO-115)(K-1)








SEE NOTE 2


EMERG. FEED HOR.

STEAM GEN. 10"

14" RING HOR.

WAT	NORW	CPU
21400	1300	PSIA
1181	977	PSIA
880	880	°F





SEE NOTE 2

SEE NOTE 2

MAX	NORM	MIN
2100	1300	60
1181	977	8.5
480	480	0.7

FROM EMERG.
FDW PUMP
(PO-11A-U(1-Q))

FROM AUX.
SR. PUMP
(PO-11A(1-R))

FROM OTSG
REG. PUMP
(PO-13A(1-K)-4)

FROM NITROGEN
BLANKETING
M-51
(PO-127(B)(1-3))

FROM EMERG.
FDW PUMP
(PO-11A-U(1-Q))

DRAIN TO
NORMAL SLUMP

SLUMP RE
PUMP

VENT TO
M.D.
(PO-07A-1)
(6-4)

FDW-16
FS/170B/1

FDW-13
FS/170B/1

FDW-236
66-002

FDW-239
66-002

FDW-240
66-002

FDW-146
66-003

FDW-148
66-003

FDW-149
66-003

FDW-142
FS/170B/1

FDW-143
FS/170B/1

FDW-144
FS/170B/1

FDW-140
66-003

FDW-138
66-003

FDW-138
FS/170B/1

FDW-138
FS/170B/1

FDW-137
FS/170B/1

FDW-133
FS/170B/1

FDW-134
FS/170B/1

FDW-146
66-003

FDW-148
66-003

FDW-149
66-003

FDW-142
FS/170B/1

FDW-143
FS/170B/1

FDW-144
FS/170B/1

FDW-236
66-002

FDW-239
66-002

FDW-240
66-002

FDW-289

FDW-249

FDW-248

FDW-246

FDW-247

FDW-248

FDW-249

FDW-248

FDW-249

FDW-248

FDW-249

FDW-248

FDW-249

FDW-248

FDW-249

FDW-248

FDW-249

FDW-248

FDW-249

FDW-248

FDW-249

FDW-248

FDW-249

FDW-248

FDW-249

FDW-248