

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8103240393 DOC. DATE: 81/03/19 NOTARIZED: NO
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co.
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co.
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co.

DOCKET #
~~5000269~~
 05000270
 05000287

AUTH. NAME: PARKER, W.O. AUTHOR AFFILIATION: Duke Power Co.
 RECIP. NAME: STOLZ, J.F. RECIPIENT AFFILIATION: Operating Reactors Branch 4
 DENTON, H.R. Office of Nuclear Reactor Regulation, Director

SUBJECT: Forwards "Evaluation of Transient Nuclear Instrumentation Power Range Flux Error," in response to NRC 810114 ltr.

DISTRIBUTION CODE: A001S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1+33
 TITLE: General Distribution for after Issuance of Operating License

NOTES: AEOD, Ornstein: 1cc. 05000269
 AEOD, Ornstein: 1cc 05000270
 AEOD, Ornstein: 1cc 05000287

ACTION:	RECIPIENT ID CODE/NAME		COPIES		RECIPIENT ID CODE/NAME	COPIES	
			LTTR	ENCL		LTTR	ENCL
ACTION:	ORB #4	BC 04	13	13			
INTERNAL:	D/DIR, HUM	FAC08	1	1	DIR, DIV OF LIC	1	1
	I&E	06	2	2	NRC PDR	1	1
	O&L	11	1	0	OR ASSESS BR 10	1	0
	REG. FILE	01	1	1			
EXTERNAL:	ACRS	09	16	16	LPDR	03	1
	NSIC	05	1	1			

MAR 25 1981

TOTAL NUMBER OF COPIES REQUIRED: LTTR

40 38
 39 ENCL 31

DUKE POWER COMPANY

POWER BUILDING

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242

WILLIAM O. PARKER, JR.
VICE PRESIDENT
STEAM PRODUCTION


March 19, 1981

TELEPHONE: AREA 704
373-4083

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: J. F. Stolz, Chief
Operating Reactors Branch No. 4

Re: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287



Dear Sir:


In response to a Staff letter dated January 14, 1981, please find attached a report, prepared by Duke Power, entitled "Evaluation of Transient Nuclear Instrumentation Power Range Flux Error". This report is submitted as the Duke evaluation of the potential for and consequences of the error in the transient contribution of the high flux trip setpoint to be greater than the currently assumed 2% FP error, for certain transient conditions.

The transient contribution to the error in the high flux trip setpoint has been investigated to identify the source and magnitude of the error, and to determine the impact of the error on the transient analyses documented in the Oconee FSAR. Our evaluation confirms that the two concerns identified by Babcock & Wilcox, overcooling transient induced errors and low worth rod ejection transient induced errors, can exceed the 2% error currently assumed. Utilizing plant data from several test programs, the magnitude of the error for overcooling transients has been quantified. For the rod ejection transient the magnitude of the error has been analytically quantified.

A review of the affected transients was undertaken and plant specific analyses were performed to determine the impact of the flux error. The approach taken in the plant specific analyses was to select the appropriate assumptions to enhance the flux error effect and maximize the resulting core power level. This approach provides a conservative evaluation of the worst case transient response.

The results of the worst case plant specific analyses show that even when a conservative set of assumptions are used, the worst transient response does not result in any increase in fuel failures beyond that already documented in the FSAR. Therefore, the present accident and transient analyses, and the Technical Specification limits derived from them, remain valid.

Very truly yours,


William O. Parker, Jr.

RLG:pw

Attachment

8103240393
P

A001
S
1/1