



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

September 4, 2015

Vice President, Operations  
Entergy Nuclear Operations, Inc.  
P.O. Box 110  
Lycoming, NY 13093

SUBJECT: JAMES A. FITZPATRICK NUCLEAR POWER PLANT – INTERIM STAFF  
RESPONSE TO REEVALUATED FLOOD HAZARDS SUBMITTED IN  
RESPONSE TO 10 CFR 50.54(f) INFORMATION REQUEST – FLOOD-  
CAUSING MECHANISM REEVALUATION (TAC NO. MF6106)

Dear Sir or Madam:

The purpose of this letter is to provide a summary of the U.S. Nuclear Regulatory Commission (NRC) staff's assessment of the re-evaluated flood-causing mechanisms described in the March 12, 2015 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML15082A250), flood hazard reevaluation report (FHRR) submitted by Entergy Nuclear Operations, Inc. (Entergy, the licensee) for James A. FitzPatrick Nuclear Power Plant (FitzPatrick), as well as supplemental information resulting from requests for additional information and audits.

By letter dated March 12, 2012, the NRC issued a request for information pursuant to Title 10 of the *Code of Federal Regulations*, Section 50.54(f) (hereafter referred to as the 50.54(f) letter) (ADAMS Accession No. ML12053A340). The request was issued as part of implementing lessons learned from the accident at the Fukushima Dai-ichi nuclear power plant. Enclosure 2 to the 50.54(f) letter requested licensees to re-evaluate flood-causing mechanisms using present-day methodologies and guidance. Concurrently, with the reevaluation of flooding hazards, licensees were required to develop and implement mitigating strategies in accordance with NRC Order EA-12-049, "Requirements for Mitigation Strategies for Beyond-Design-Basis External Events" (ADAMS Accession No. ML12054A735). On March 30, 2015, the Commission provided Staff Requirements Memoranda (SRM) (ADAMS Accession No. ML15089A236) to COM-SECY-14-0037, "Integration of Mitigating Strategies for Beyond-Design-Basis External Events and the Reevaluation of Flooding Hazards," dated November 21, 2014 (ADAMS Accession No. ML14309A256), affirming that licensees need to address the reevaluated flooding hazards within their mitigating strategies for beyond-design-basis external events.

The NRC staff has reviewed the flood hazard information submitted by the licensee and has summarized the results of the review in the tables provided as an Enclosure to this letter. Table 1 provides the current design-basis flood hazard mechanisms. Table 2 provides the reevaluated flood hazard mechanisms; however, the reevaluated hazard mechanisms bounded by the current design-basis (Table 1) are not included.

The staff has concluded that the licensee's reevaluated flood hazards information, as summarized in Enclosure 1, is suitable for the assessment of mitigating strategies, developed in


response to Order EA-12-049 (i.e., defines the mitigating strategies flood hazard information described in guidance documents currently being finalized by the industry and NRC staff) for FitzPatrick. Further, the NRC staff has concluded that the licensee's reevaluated flood hazard information is a suitable input for other assessments associated with Near-Term Task Force Recommendation 2.1 "Flooding". The NRC staff plans to issue a staff assessment documenting the basis for these conclusions at a later time.

In addition, NEI 12-06 "Diverse and Flexible Coping Strategies (FLEX) Implementation Guide" is currently being revised. This revision will include a methodology to perform a Mitigating Strategies Assessment (MSA) with respect to the reevaluated flood hazards. Once this methodology is endorsed by the NRC, flood event duration parameters and applicable flood associated effects should be considered as part of the FitzPatrick MSA. The NRC staff will evaluate the flood event duration parameters (including warning time and period of inundation) and flood-related associated effects developed by the licensee during the NRC staff's review of the MSA.

As stated above, Table 2 of the enclosure to this letter describes the reevaluated flood hazards that exceed the current design-basis. In order to complete its response to the information requested by Enclosure 2 to the 50.54(f) letter, the licensee is expected to submit an integrated assessment or a focused evaluation, as appropriate, to address these reevaluated flood hazards, as described in NRC letter, "Coordination of Request for Information Regarding Flooding Hazard Reevaluation and Mitigating Strategies for Beyond Design Bases External Events" (ADAMS Accession No. ML15174A257). This letter describes the changes in the NRC's approach to the flood hazard reevaluations that were approved by the Commission in its SRM to COMSECY-15-0019, "Closure Plan for the Reevaluation of Flooding Hazards for Operating Nuclear Power Plants" (ADAMS Accession No. ML15209A682).

If you have any questions, please contact me at (301) 415-2915 or e-mail at Victor.Hall@nrc.gov.

Sincerely,

A handwritten signature in black ink, appearing to read "Victor E. Hall". The signature is written in a cursive style with some loops and flourishes.

Victor E. Hall, Project Manager  
Hazards Management Branch  
Japan Lessons-Learned Division  
Office of Nuclear Reactor Regulation

Docket No. 50-333

Enclosure:  
Summary of Results of Flooding  
Hazard Re-Evaluation Report

cc w/encl: Distribution via Listserv

ENCLOSURE:

SUMMARY TABLES OF  
REEVALUATED FLOOD HAZARD LEVELS

**Table 1. Current Design Basis Flood Hazards for Use in the MSA**

<b>Mechanism</b>	<b>Stillwater Elevation</b>	<b>Waves/ Runup</b>	<b>Design Basis Hazard Elevation</b>	<b>Reference</b>
<b>Local Intense Precipitation</b>	Not included in DB	Not included in DB	Not included in DB	FHRR Table 4-1
<b>Streams and Rivers</b>	Not included in DB	Not included in DB	Not included in DB	FHRR Table 4-1
<b>Failure of Dams and Onsite Water Control/Storage Structures</b>	Not included in DB	Not included in DB	Not included in DB	FHRR Table 4-1
<b>Storm Surge</b>				
Storm Surge	254.1 ft USLS35	7.9 ft	262 ft USLS35	FHRR Table 4-1
Storm Surge at Screenwell	254.0 ft USLS35	1.0 ft	255 ft USLS35	FHRR Table 4-1
<b>Seiche</b>	Not included in DB	Not included in DB	Not included in DB	FHRR Table 4-1
<b>Tsunami</b>	Not included in DB	Not included in DB	Not included in DB	FHRR Table 4-1
<b>Ice-Induced Flooding</b>	Not included in DB	Not included in DB	Not included in DB	FHRR Table 4-1

**Table 1. Current Design Basis Flood Hazards for Use in the MSA**

<b>Mechanism</b>	<b>Stillwater Elevation</b>	<b>Waves/ Runup</b>	<b>Design Basis Hazard Elevation</b>	<b>Reference</b>
<b>Channel Migrations/Diversions</b>	Not included in DB	Not included in DB	Not included in DB	FHRR Table 4-1

Note: Reported values are rounded to the nearest one-tenth of a foot.

**Table 2. Reevaluated Flood Hazards for Flood-Causing Mechanisms for Use in the MSA**

<b>Mechanism</b>	<b>Stillwater Elevation</b>	<b>Waves/ Runup</b>	<b>Reevaluated Hazard Elevation</b>	<b>Reference</b>
<b>Local Intense Precipitation</b>	272.8 ft USLS35	Minimal	272.8 ft USLS35	FHRR Table 4-1 and FHRR Appendix A
<b>Streams and Rivers</b> Unnamed Stream	272.8 ft USLS35	Not applicable	272.8 ft USLS35	FHRR Table 4-4
<b>Storm Surge</b> PMSS + PMP + Waves	252.8 ft USLS35	15.2 ft	268.0 ft USLS35	FHRR Sect 3.4.3 & Table 4-1 FHRR Table 4-1

Note 1: The licensee is expected to develop flood event duration parameters and applicable flood associated effects to conduct the MSA. The staff will evaluate the flood event duration parameters (including warning time and period of inundation) and flood associated effects during its review of the MSA.

Note 2: Reevaluated hazard mechanisms bounded by the current design basis (see Table 1) are not included in this table.

Note 3: Reported values are rounded to the nearest one-tenth of a foot.

If you have any questions, please contact me at (301) 415-2915 or e-mail at Victor.Hall@nrc.gov.

Sincerely,

*/RA/*

Victor E. Hall, Project Manager  
Hazards Management Branch  
Japan Lessons-Learned Division  
Office of Nuclear Reactor Regulation

Docket No. 50-333

Enclosure:  
Summary of Results of Flooding  
Hazard Re-Evaluation Report

cc w/encl: Distribution via Listserv

DISTRIBUTION:

PUBLIC	JLD R/F	RidsNRRJLD Resource
VHall, NRR	LQuinn-Willingham, NRO	RidsNroDsea Resource
RidsNrrDorlPl1-1 Resource	RidsNrrDorl Resource	RidsNrrPMFitzPatrick Resource
RidsRgn1MailCenter Resource	RidsNrrLASLent	RidsOgcMailCenter Resource
RidsOpaMail Resource	RidsAcrcAcnw_MailCtr Resource	CCook, NRO
ARivera-Varona, NRO	KErwin, NRO	ACampbell, NRO
MWillingham, NRO	RRivera-Lugo, NRO	BHarvey, NRO
MShams, NRR		

**ADAMS Accession No.: PKG ML15238B540; LTR: ML15238B537; ENCL: ML15229A023 \*via email**

OFFICE	NRR/JLD/JHMB/PM*	NRR/JLD/LA*	NRO/DSEA/RHM2/TR*	NRO/DSEA/RHM2/BC*
NAME	AMinarik	SLent	LHibler	ARivera-Varona
DATE	08/28/15	08/27/15	08/17/15	08/17/15
OFFICE	NRR/JLD/JHMB/BC	OGC*	NRR/JLD/JHMB/PM	
NAME	MShams	SClark	VHall	
DATE	08/28/15	08/14/15	09/04/15	

**OFFICIAL RECORD COPY**