



**NOTES:**

1. OPERATING MODE REPRESENTED BY BOLD LINES
2. NORMAL TURBINE ROOM SUMP PUMP DISCHARGE TO YARD DRAIN.
3. TURBINE ROOM SUMP SHARED BETWEEN UNITS 1 & 2.
4. PIPING COVERED BY CIVIL/ENVIRONMENTAL DIVISION SPECIFICATION NO. OSS-01.01.00-00-0000 AND/OR ITEM NO. 120.
5. THE ORIGINAL ISSUE OF THIS DRAWING IS BASED ON PO-133A, REV. 27.
6. 1/2" THRU 18" SCH. = 40
7. STAINLESS STEEL (PS-15L) MAY BE SUBSTITUTED FOR PIPE SIZE 1/2" THRU 8".
8. SAMPLE PUMP IS PROVIDED ON SKID.

LINE NO.	DUKE CLASS	DESIGN PRESS
1	NOTE 4	-
2	NOTE 4	-
3	F	50 PSIG
4	F	50 PSIG
17	G	50 PSIG