

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9606180016 DOC.DATE: 96/06/10 NOTARIZED: NO
FACIL:50-270 Oconee Nuclear Station, Unit 2, Duke Power Co.
AUTH.NAME AUTHOR AFFILIATION
HAMPTON,J.W. Duke Power Co.
RECIP.NAME RECIPIENT AFFILIATION
Document Control Branch (Document Control Desk)

DOCKET-#
05000270

SUBJECT: Provides NDE info requested by NRC during recent conference call re SG three month rept addendum eddy current data for pilled tubes.

DISTRIBUTION CODE: A001D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 6
TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-2 LA LABARGE,D.	1 1 1 1	PD2-2 PD	1 1
INTERNAL:	ACRS	1 1	<u>FILE CENTER</u> 01	1 1
	NRR/DE/EMCB	1 1	NRR/DRCH/HICB	1 1
	NRR/DSSA/SPLB	1 1	NRR/DSSA/SRXB	1 1
	NUDOCS-ABSTRACT	1 1	OGC/HDS2	1 0
EXTERNAL:	NOAC	1 1	NRC PDR	1 1

NOTE TO ALL "RIDS" RECIPIENTS:
PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
ROOM OWFN 5D-5(EXT. 415-2083) TO ELIMINATE YOUR NAME FROM
DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 13 ENCL 12

C
A
T
E
G
O
R
Y
1
D
O
C
U
M
E
N
T

Duke Power Company
Oconee Nuclear Generation Department
P.O. Box 1439
Seneca, SC 29679

J. W. HAMPTON
Vice President
(803)885-3499 Office
(803)885-3564 Fax



DUKE POWER

June 10, 1996

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Subject: Duke Power Company
Oconee Nuclear Station, Unit 2
Docket No. 50-270
Steam Generator Three Month Report
Addendum: Eddy Current Data for Pulled Tubes

This letter provides the non-destructive examination (NDE) information which was requested by the NRC staff during a recent conference call. In addition, this information is provided as an addendum to the Steam Generator three month report which was dated June 5, 1996. The NDE information in Attachment 1 provides the results of the field eddy current depth measurements which were determined using bobbin, rotating pancake coil and plus point eddy current probes for the four tubes prior to their removal from the 2A Steam Generator.

The data describes the notable axial indications seen on the four tubes that were removed. Since relatively few indications were seen in the lower tube sections, the data only shows the notable indications that were seen above the 10th tube support plate. A more detailed eddy current exam is currently being completed under laboratory conditions. The results of the laboratory NDE and destructive examinations will be provided to the NRC when the data is available.

170054
9606180016 960610
PDR ADOCK 05000270
P PDR

ADDI

If there are any questions about this information, please contact Michael Bailey at (864) 885-4390.

Very Truly Yours,

 for

J. W. Hampton, Site Vice President
Oconee Nuclear Station

MEB

Attachment

xc: D. E. LaBarge, Project Manager
ONRR

P. E. Harmon, Senior Resident Inspector
Oconee Nuclear Station

S. D. Ebnetter, Regional Administrator
Region II

ONS 2-A

Bobbin

RPC

RPC

Plus PT

Plus PT

Tube	TSP Loc	Elevation	%TW
27-62	14th	15.47	49
		16.19	36
		16.78	65
		17.25	62
		17.53	83
		18.06	22
		18.48	36
		19.34	52

Length	%TW
3.18	39-57
1.08	46-61

Length	%TW
4.36	30-60

ONS 2-A			Bobbin	RPC	RPC	Plus PT	Plus PT
Tube	TSP Loc	Elevation	%TW	Length	%TW	Length	%TW
93-69	12th	9.45	36	1.73	54-76	1.57	30-50
		11.57	24	0.98	38-82	0.75	1-25
		16.39	71				
		16.81	1				
		20.61	68				
		21.75	49				
	14th	18.04	1	0.58	54-62	1.47	25-35
		19.24	7	0.91	65-71		

ONS 2-A		Bobbin		RPC	RPC	Plus PT	Plus PT	
Tube	TSP Loc	Elevation	%TW	Length	%TW	Length	%TW	
110-66	10th	18.28	20	0.72	61-79	0.5	1-7	
		19.36	12	0.57	66-83	0.74	25	
		20.33	3	0.81	36-57	0.37	1	
		21.33	46	0.4	62-66	0.77	7-25	
		21.63	35	0.84	58-68	0.81	1-35	
		22.77	4	0.81	53-71	0.65	1-25	
		23.66	7	1.61	46-74	0.61	14	
		24.71	26			0.71	1-25	
		25.68	20	0.44	54	0.37	7-25	
		26.15	36					
	27.93	12						
	32.56	24						
	32.98	37						
		13th	33	49	0.77	55-65	0.51	7-43
			34.15	65	0.5	44	0.37	20
		14th	0.31	47	0.94	42-57	0.8	14-35
			1.51	26	0.7	42-47	0.53	30-53
			2.73	32	0.7	26-47		
			3.46	24	0.5	37		
			4.29	28				
		6.67	30					

ONS 2-A		Bobbin		RPC	RPC	Plus PT	Plus PT
Tube	TSP Loc	Elevation	%TW	Length	%TW	Length	%TW
119-59	10th	5.68	1	3.14	32-46	2.8	43-65
		6.81	1	1.75	49-51	1.31	39-86
		7.5	18	1.75	2-39	1.49	53-69
		8.06	13				
		9.03	39				
		9.39	52				
		10.22	64				
		12.13	52				
		12.43	28				
		13.65	43				
		14.1	18				
		14.51	43				
		14.95	49				
	15.45	15					
	15th	32.9	67	1.05	65-68	1.22	46-67
		35.42	77	1.19	49-57	3.84	50-67
		35.73	1	3.7	49-76	0.74	60
		36.62	46	2.23	72-80	1.43	55
		37.4	46	7.24	35-65	6.45	43-74
37.7		64					
38.73		46					
39.01		71					
39.48		43					
39.92		55					
40.84		37					
41.09		60					
41.45		1					
42.73	15						
43.65	67						
44.68	24						
46.5	37						