

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9203120120 DOC. DATE: 92/03/02 NOTARIZED: NO DOCKET # 05000270
 FACIL: 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co.
 AUTH. NAME: HAMPTON, J.W. AUTHOR AFFILIATION: Duke Power Co.
 RECIP. NAME: RECIPIENT AFFILIATION: Document Control Branch (Document Control Desk)

SUBJECT: Forwards Relief Request 92-05, requesting relief from ASME Boiler & Pressure Vessel Code Section XI for Unit 2 Core Flood pressure retaining tie-in welds due to impracticality of inservice insp. W/one oversize drawing.

DISTRIBUTION CODE: A047D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 12
 TITLE: OR Submittal: Inservice Inspection/Testing/Relief from ASME Code

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTRR ENCL	RECIPIENT ID CODE/NAME	COPIES LTRR ENCL
	PD2-3 LA WIENS, L	1 0 2 2	PD2-3 PD	1 1
INTERNAL:	ACRS	6 6	NRR/DET/ECMB 9H	1 1
	NRR/DET/EMEB 7E	1 1	NUDOCS-ABSTRACT	1 1
	OC/LFMB	1 0	OGC/HDS2	1 0
	REG FILE	1 1	RES MILLMAN, G	1 1
	RES/DIR/ETB	1 1		
EXTERNAL:	EG&G BROWN, B	1 1	EG&G RANSOME, C	1 1
	NRC PDR	1 1	NSIC	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTRR 22 ENCL 19

R
I
D
S
/
A
D
D
S

Duke Power Company
Oconee Nuclear Generation Department
P.O. Box 1439
Seneca, SC 29679

J.W. HAMPTON
Vice President
(803)885-3499 Office
(704)373-5222 FAX



DUKE POWER


March 2, 1992

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Subject: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287
Second Ten Year Interval
Request for Relief No. 92-05

Pursuant to 10 CFR 50.55a, please find the attached request for relief number 92-05 from the requirements of Section XI of the ASME Boiler and Pressure Vessel Code (with Addenda through Winter 1980). This request is being submitted due to the impracticality of inservice inspection as required by the code. The attached request concerns the inservice inspection being performed during the second ten year interval. I am requesting approval on this request as soon as possible.

Very truly yours,


J. W. Hampton

Attachments

rr9205

xc: Mr. S. D. Ebnetter
Regional Administrator, Region II

Mr. Heyward Shealy, Chief
Bureau of Radiological Health, SC

Mr. L. A. Wiens
Project Manager, ONRR

Mr. P. E. Harmon
Senior Resident Inspector, ONS

9203120120 920302
PDR ADOCK 05000270
Q PDR

AD47

Duke Power Company
Oconee Nuclear Station
Second Ten Year Interval
Request for Relief No. 92-05

I. Component for Which Relief is Requested:

(a) Name and Number:

Unit 2 Core Flood pressure retaining tie-in welds associated with 2CF-20 and 2CF-22, Core Flood Tank Drain Line Block Valves

(b) Function:

Valves through which Core Flood Tanks A & B can be drained for maintenance.

(c) ASME Code Class:

ISI Class B, Duke Class B

(d) IWV-2200 Valve Category:

N/A

II. Reference Code Requirement that has been Determined to be Impractical:

ASME Boiler and Pressure Vessel Code Section XI, 1980 Edition (with Addenda through Winter 1980) Article IWA-5211(d) which requires that the pressure retaining components within each system boundary shall be subject to system pressure tests under which conditions visual examination VT-2 is performed to detect leakages may be conducted in conjunction with a system hydrostatic test during a plant shutdown at a pressure above nominal operation pressure or system pressure for which overpressure protection is provided; and Article IWC 5210(2) which requires a system hydrostatic pressure test for each system or portions of systems and for repaired or replaced components, or altered portion of systems.

III. Basis for Requesting Relief:

During implementation of NSM 22853, valves 2CF-20 and 2CF-22 were replaced. In order to perform hydrostatic tests of these tie-in welds as required by code, both Core Flood Tanks along with associated non-isolable piping would require being filled with demineralized water in excess of 2800 Cu.Ft. We propose that it is impractical to hydro the 2A and 2B Core Flood Tanks to allow for these hydrostatic tests since the information gained would not be time, cost or dose effective.

IV. Alternate Examination:

Inspect welds (shown on Sheets II and III of III attached) at normal operating pressure and perform an alternate non destructive examination (PT) in lieu of hydrostatic test. Normal operating pressure (NOP) of the Core Flood Tanks is 600 ± 25 psig. Design pressure is 700 psig. See also attached OFD 102A-2.3.

V. Evaluation of Acceptability of Proposed Alternate Testing with Respect to the Level of Quality and Safety as well as Public Health and Safety:


An inservice or system leakage test per IWA-5211(a) (described as a system leakage test conducted following opening and reclosing of a component in the system after pressurization to normal operating pressure) and surface examination of the welds (PT) will result in assurance of integrity of the new welds comparable to information gained by performing a hydrostatic test. The health and safety of the public and the safety of the system is not adversely affected by the alternate testing.

V. Implementation Schedule:

End of Cycle 12 refueling outage. February-March, 1992.

Station _____ Unit _____ Rev. _____ File No. _____ Sheet _____ Of _____
 Subject NSM 22853 - CF TIE-IN WELDS REQUEST FOR RELIEF
 By TWJ Date 2-19-92

Prob No. _____ Checked By _____ Date _____



REF OFD-102A-2.3

SYSTEM 53A(1)(3)(5)(6)(7) UNIT 2 R.B. CLASS A,B,C,E CRES/304H, 316H SHEET 8

PS.601,2 PS.6014

PS.1501.3
PS.1501.4

B31.1
B31.7

* ATTACH. WELDS: 48A, 32Z,
42Z, 42ZA

REACTOR VESSEL

NOT
CODE

{ SYSTEM 53A(1) CRES/316H
49,50,63 14"φX1.250" (CLASS A) } "1"

{ SYSTEM 53A(3) CRES/304H
32,59-61,42-48,42A 14"φX1.250" (CLASS A) } "1"

{ 32A-32C (CLASS A NDT) 1"φX.250" (CLASS C) } "1"

{ SYSTEM 53A(5) CRES/304H
34-36 14"φX1.250" (CLASS B) } "5"

{ 85,90,93,95,100, 1"φX.250" (CLASS C) } "0"
85 NDT CODE "6"

{ SYSTEM 53A(6) CRES/304H
31 10"φX1.000 (CLASS A) } "1"

{ SYSTEM 53A(7) CRES/304H
39,40,37,39A 14"φX.375" (CLASS B) } "5"

{ 120, 121, 124,125 2"φX.154" (CLASS B) } "6"

{ 121, 124,125 1"φX.250 (CLASS E) }
2"φX.154 (CLASS E)

REV	CHANGES	WELD NOS	OMIT WELDS
5			
50.			41,33,38
			101-103,116
			102A,103A
			117,118
			See WTR 78
			112,122,51,241,175

14"φ10" φ WIP P.2
OTHER WIP P.1 & P.8
REF. DWGS. 1478A,B,1479D


*Note: Attachment Weld
32Z is made over weld
32A

CLASS B - 100% RT ALL BUTT WELDS. 100%
MT/PT ALL FILLET, SOCKET, SEAL, ATTACHMENT,
AND BRANCH WELDS. NOTE: ANY WELD 1" AND LESS
IN DIAMETER IS CLASS C OR E.

PART II OF III

CLASS A - 100% RT AND 100% MT/PT
ALL BUTT WELDS. 100% RT & 100% MT/PT
ALL BRANCH CONNECTIONS OVER 4" DIAMETER,
100% MT/PT ALL FILLET, SOCKET, SEAL,
ATTACHMENT, AND BRANCH CONNECTION WELDS.

CLASS C & E - RT 1 WELD FOR EVERY 10
BUTT WELDS A WELDER MAKES OVER 4" DIAMETER,
1 WELD FOR EVERY 10 FILLET, SOCKET, SEAL,
ATTACHMENT, OR BRANCH WELDS A WELDER
MAKES OVER 4" DIAMETER.




~~28~~
6862

SYSTEM 53A(1)(3)(5)(6)(7) UNIT 2 R.B. CLASS A,B,C,E CRES/304;316H SHEET 8
304 316


DEF 102A 2.3

* ATTACH. WELDS: 67A, 53A, 54Z, 106Z, 54AZ, 108Z



PART III OF III

- { SYSTEM 53A(1) CRES/316 H } "1"
51, 52, 64 14" φ X 1.250" (CLASS A)
- { SYSTEM 53A(3) CRES/304 H } "1"
53-57, 62 14" φ X 1.250" (CLASS A)
- { SYSTEM 53A(5) CRES/304 H } "5"
65, 66, 67B, 68, 69 14" φ X 1.250" (CLASS B)
- { SYSTEM 53A(6) CRES/304 H } "1"
58 10" φ X 1.000" (CLASS A)
- { SYSTEM 53A(7) CRES/304 H } "5"
70-72 14" φ X .375" (CLASS B)
- 71A, 105-110, 104A, 127 2" φ X .154" (CLASS B) } "5"
128, 129 2" X .154" (CLASS E)



FOR INFORMATION ONLY

ISO. REV. NO.	CHANGES WEID NOS	OMIT WELDS
20/TSC	54B, 54C	119
21/TSC	122, 112, 509, 35K	112-115, 104
22/TSC	REINSTATE 54B, 54C	67, 74
23/TSC	54B, 54C	74
24/TSC	123, 100, 900, 309, 10	21
25/TSC	111, 112A, 115A	23
26/TSC	127, 129, 107, 988	15, 15C

CLASS A - 100% RT AND 100% MT/PT
ALL BUTT WELDS, 100% RT & 100% MT/PT
ALL BRANCH CONNECTIONS OVER 4" DIAMETER.
100% MT/PT ALL FILLET, SOCKET, SEAL, ATTACHMENT, AND BRANCH CONNECTION WELDS.

CLASS C & E - RT 1 WELD FOR EVERY 10 BUTT WELDS A WELDER MAKES OVER 4" DIAMETER. 1 WELD FOR EVERY 10 FILLET, SOCKET, SEAL, ATTACHMENT, OR BRANCH WELDS A WELDER MAKES OVER 4" DIAMETER.

CLASS B - 100% RT ALL BUTT WELDS, 100% MT/PT ALL FILLET, SOCKET, SEAL ATTACHMENT, AND BRANCH WELDS. NOTE: ANY WELD 1" AND LESS IN DIAMETER IS CLASS C OR E.

* Note: Attachment welds 54Z is made over weld 54A
* Note: System Classification "C" applies to material Requirements only (A.N.D.)

REF. DRWG. 1478A,B, 1479D

D.L.A. Rev 15 CK By K.W. [Signature] 28 JAN 72

Rev (29) 12/5/91