

# ACCELERATED DOCUMENT DISTRIBUTION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9306140247      DOC. DATE: 93/06/07      NOTARIZED: NO      DOCKET #  
 FACIL: 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co.      05000270  
 AUTH. NAME      AUTHOR AFFILIATION  
 HAMPTON, J.W.      Duke Power Co.  
 RECIPIENT NAME      RECIPIENT AFFILIATION  
                                  Document Control Branch (Document Control Desk)

SUBJECT: Submits rept on steam generator tube plugging & repair.

DISTRIBUTION CODE: A001D      COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1  
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES		
		LTR	ENCL		LTR	ENCL	
	PD2-3 LA	1	1	PD2-3 PD	1	1	/
	WIENS, L	2	2				A
INTERNAL:	ACRS	6	6	NRR/DE/EELB	1	1	D
	NRR/DRCH/HICB	1	1	NRR/DRPW/OTSB	1	1	D
	NRR/DSSA/SPLB	1	1	NRR/DSSA/SRXB	1	1	S
	NUDOCS-ABSTRACT	1	1	OC/LEDGB	1	0	
	OGC/HDS2	1	0	<u>REG FILE</u> 01	1	1	
EXTERNAL:	NRC PDR	1	1	NSIC	1	1	

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
 ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 21 ENCL ~~19~~ 0

Duke Power Company  
Oconee Nuclear Site  
P.O. Box 1439  
Seneca, SC 29679

J. W. HAMPTON  
Vice President  
(803)885-3499 Office  
(803)885-3564 Fax



**DUKE POWER**

June 7, 1993


U.S. Nuclear Regulatory Commission  
Attention Document Control Desk  
Washington, DC 20555

Subject: Duke Power Company  
Oconee Nuclear Station  
Docket No. 50-270  
Unit 2, EOC 13 Refueling Outage  
Steam Generator Tube Plugging and Repair 30 Day Report

Pursuant to Oconee Technical Specification 4.17.6(a), the following is the report on the number of tubes plugged or repaired during the Unit 2, EOC 13 Refueling Outage.

Steam Generator "A" had 35 tubes removed from service by plugging. Steam Generator "B" had 79 tubes removed from service by plugging. No tubes were sleeved in either Steam Generator. The plugging was completed on May 24, 1993.

Very truly yours,

  
J. W. Hampton  
Site Vice-President

xc: Mr. S. D. Ebnetter  
Regional Administrator, Region II  
U. S. Nuclear Regulatory Commission

Mr. P. E. Harmon  
Senior NRC Resident Inspector  
Oconee Nuclear Station

Mr. Heyward G. Shealy  
Bureau of Radiological Health  
SC Dept. of Health & Environmental Control  
2600 Bull St.  
Columbia, SC 29201

9306140247 930607  
PDR ADOCK 05000270  
PDR

Aool  
1/10