

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9805050265 DOC. DATE: 98/04/29 NOTARIZED: NO DOCKET #
 FACIL: 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270
 AUTH. NAME AUTHOR AFFILIATION
 MCCOLLUM, W.R. Duke Power Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards LER 98-001-00 re mfg error which resulted in possible operations of SG w/Eddy current test indications in excess of TS limits. Event considered to be of no significance w/respect to health & safety of public.

DISTRIBUTION CODE: IE22T COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2+11
 TITLE: 50.73/50.9 Licensee Event Report (LER), Incident Rpt, etc.

NOTES:

| | RECIPIENT ID CODE/NAME | COPIES LTR ENCL | RECIPIENT ID CODE/NAME | COPIES LTR ENCL |
|-----------|------------------------|-----------------|-------------------------|-----------------|
| | PD2-2 PD | 1 1 | LABARGE, D | 1 1 |
| INTERNAL: | ACRS | 1 1 | AEOD/SPD/RAB | 2 2 |
| | AEOD/SPD/RRAB | 1 1 | FILE CENTER | 1 1 |
| | NRR/DE/ECGB | 1 1 | NRR/DE/EELB | 1 1 |
| | NRR/DE/EMEB | 1 1 | NRR/DRCH/HHFB | 1 1 |
| | NRR/DRCH/HICB | 1 1 | NRR/DRCH/HOLB | 1 1 |
| | NRR/DRCH/HQMB | 1 1 | NRR/DRPM/PECB | 1 1 |
| | NRR/DSSA/SPLB | 1 1 | NRR/DSSA/SRXB | 1 1 |
| | RES/DET/EIB | 1 1 | RGN2 FILE 01 | 1 1 |
| EXTERNAL: | L ST LOBBY WARD | 1 1 | LITCO BRYCE, J H | 1 1 |
| | NOAC POORE, W. | 1 1 | NOAC QUEENER, DS | 1 1 |
| | NRC PDR | 1 1 | NUDOCS FULL TXT | 1 1 |

NOTE TO ALL "RIDS" RECIPIENTS:
 PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

C
A
T
E
G
O
R
Y
1
D
O
C
U
M
E
N
T



Duke Power Company
A Duke Energy Company

Oconee Nuclear Site
P.O. Box 1439
Seneca, SC 29679

W. R. McCollum, Jr.
Vice President

(864) 885-3107 OFFICE
(864) 885-3564 FAX

April 29, 1998

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Subject: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287
Licensee Event Report 270/98-01, Revision 0
Problem Investigation Process No.: 2-098-1617

Gentlemen:

Pursuant to 10 CFR 50.73 Sections (a) (1) and (d), attached is Licensee Event Report 270/98-01, concerning a manufacturing error which resulted in the possible operation of a steam generator with Eddy Current Test indications in excess of Technical Specification limits.

This report is being submitted in accordance with 10 CFR 50.73 (a) (2) (i) (B). This event is considered to be of no significance with respect to the health and safety of the public.

Very truly yours,



W. R. McCollum, Jr.

Attachment

9805050265 980429
PDR ADOCK 05000270
S PDR

Document Control Desk

April 29, 1998

Page 2

cc: Mr. Luis A. Reyes
Administrator, Region II
U.S. Nuclear Regulatory Commission
61 Forsyth Street, S. W., Suite 23T85
Atlanta, GA 30303

Mr. D. E. LaBarge
U.S. Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
Washington, D.C. 20555

INPO Records Center
700 Galleria Parkway, NW
Atlanta, GA 30339-5957

Mr. M. A. Scott
NRC Resident Inspector
Oconee Nuclear Station