



Duke Energy Corporation

Oconee Nuclear Station
P.O. Box 1439
Seneca, SC 29679
(864) 885-3107 OFFICE
(864) 885-3564 FAX

W. R. McCollum, Jr.
Vice President

January 21, 1999

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Subject: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287
Licensee Event Report 270/96-07, Revision 2
Problem Investigation Process No.: 3-096-2566


Gentlemen:

Pursuant to 10 CFR 50.73 Sections (a) (1) and (d), attached is Licensee Event Report 270/96-07 Revision 2, concerning the technical inoperability of the Low Pressure Injection System for an Appendix R Scenario.

A Planned Corrective Action to perform a one time test to verify proper operation of the Appendix R Damage Repair Valve Control Panel was submitted in Revision 1 of this report. The proper wiring configuration has been verified to match the as-built design documents. Since the one time test will not provide any additional information related to the acceptability of the current wiring configurations, it is not necessary. The corrective actions to prevent the inadequate work practice root cause have been completed.

Revision 2 to this report is being submitted in accordance with 10 CFR 50.73 (a) (2) (v) (B). This event is considered to be of no significance with respect to the health and safety of the public.

Very truly yours,


W. R. McCollum, Jr.

IE22 /

Attachment

9901280108 990121
PDR ADOCK 05000270
S PDR

Document Control Desk

Date: January 21, 1999

Page 2

cc: Mr. Luis A. Reyes
Administrator, Region II
U.S. Nuclear Regulatory Commission
61 Forsyth Street, S. W., Suite 23T85
Atlanta, GA 30303

Mr. D. E. LaBarge
U.S. Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
Washington, D.C. 20555

INPO Records Center
700 Galleria Parkway
Atlanta, GA 30339-5957

Mr. M. A. Scott
NRC Resident Inspector
Oconee Nuclear Station