

PMTurkeyCOLPEm Resource

From: Comar, Manny
Sent: Friday, August 28, 2015 8:32 AM
To: Thomas, Vaughn; Chuang, Tze-Jer
Cc: Burkhart, Lawrence; TurkeyCOL Resource
Subject: FW: RE: Revised write-up
Attachments: FPL Letter L-2014-130 Dated 05-9-2014 NRC RAI Letter No. 064 (eRAI 6544) Voluntary Submittal

FYI

From: Franzone, Steve [mailto:Steve.Franzone@fpl.com]
Sent: Friday, August 28, 2015 7:53 AM
To: Comar, Manny
Cc: TurkeyCOL Resource; Maher, William; CHILDRESS, ELWOOD
Subject: [External_Sender] RE: Revised write-up

Manny

The Rev 2 listed below was in error. It should have been listed as "TPG-GW-GLR-002, Rev. 1". I have attached the RAI response which we submitted last year after the NRC Audit.

Sorry for the confusion.

Thanks

Steve Franzone

NNP Licensing Manager - COLA

"The most important key to achieving great success is to decide upon your goal and launch, get started, take action, move." ~ Brian Tracy

561.694.3209 (office)

754.204.5996 (cell)

"This transmission is intended to be delivered only to the named addressee(s) and may contain information that is confidential and /or legally privileged. If this information is received by anyone other than the named addressee(s), the recipient should immediately notify the sender by E-MAIL and by telephone (561.694.3209) and permanently delete the original and any copy, including printout of the information. In no event shall this material be read, used, copied, reproduced, stored or retained by anyone other than the named addressee(s), except with the express consent of the sender or the named addressee(s).

From: Franzone, Steve
Sent: Thursday, August 27, 2015 12:25 PM
To: 'Comar, Manny'
Cc: TurkeyCOL Resource; Maher, William; CHILDRESS, ELWOOD
Subject: RE: Revised write-up

The two questions from the staff are paraphrased as follows:

- Provide the results of the edge and corner impacts of aux building walls
- Demonstrate the adequacy of the roof slabs subject to hurricane missile impact

Manny

Here is Westinghouse's initial response for the staff's questions. Please let me know if we still need a clarification call.

"For the first question, the results of edge and corner missile impacts on Aux building walls is presented in Table 6 of the TPG-GW-GLR-002, Rev. 2 report, "Supplement toRAI-6544"

For the second question, the story for vertical hurricane loads is as follows:

- The DCD presents tornado wind speed and missile spectra that are specified for the design of safety-related structures in Tier 1 Table 5.0-1. Vertical Tornado speed is noted as 74 mph.
- Reg. Guide 1.221 presents hurricane wind speed and missile spectra, including specifying the vertical hurricane missile velocity as 26 m/s (equal to 58 mph).
- The response to RFI 282[internal reference] presents the vertical kinetic energy from the AP1000 design tornado missiles in Table 2-1a and the Turkey Point 6 and 7 hurricane missiles in Table 2-1b.
- A comparison of the vertical kinetic energies from the tornado missiles shows that the AP1000 design tornado missiles bound the kinetic energies of the Turkey Point 6 and 7 hurricane missiles. The AP1000 design is adequate for vertical Turkey Point hurricane loads.
- (Even though missile #2 in each table is different, the kinetic energy of the AP1000 design tornado missile is more than 1.5 times that of the Turkey Point 6 and 7 hurricane missile)”

Any questions, please call.

Thanks

Steve Franzone

NNP Licensing Manager - COLA

“The most important key to achieving great success is to decide upon your goal and launch, get started, take action, move.” ~ Brian Tracy

561.694.3209 (office)

754.204.5996 (cell)

“This transmission is intended to be delivered only to the named addressee(s) and may contain information that is confidential and /or legally privileged. If this information is received by anyone other than the named addressee(s), the recipient should immediately notify the sender by E-MAIL and by telephone (561.694.3209) and permanently delete the original and any copy, including printout of the information. In no event shall this material be read, used, copied, reproduced, stored or retained by anyone other than the named addressee(s), except with the express consent of the sender or the named addressee(s).

From: Comar, Manny [<mailto:Manny.Comar@nrc.gov>]

Sent: Wednesday, August 26, 2015 10:34 AM

To: Franzone, Steve

Cc: TurkeyCOL Resource

Subject: Revised writeup

This is an EXTERNAL email. Exercise caution. DO NOT open attachments or click links from unknown senders or unexpected email.

Steve:

Revised writeup for the review.

Thanks

Manny Comar

Senior Project Manager

Nuclear Regulatory Commission

Office of New Reactors

301-415-3863

Manny.comar@nrc.gov

Hearing Identifier: TurkeyPoint_COL_Public
Email Number: 1081

Mail Envelope Properties (664692338d0546d5adf5bfd07aabd4ca)

Subject: FW: RE: Revised write-up
Sent Date: 8/28/2015 8:31:31 AM
Received Date: 8/28/2015 8:31:38 AM
From: Comar, Manny

Created By: Manny.Comar@nrc.gov

Recipients:

"Burkhart, Lawrence" <Lawrence.Burkhart@nrc.gov>
Tracking Status: None
"TurkeyCOL Resource" <TurkeyCOL.Resource@nrc.gov>
Tracking Status: None
"Thomas, Vaughn" <Vaughn.Thomas@nrc.gov>
Tracking Status: None
"Chuang, Tze-Jer" <Tze-Jer.Chuang@nrc.gov>
Tracking Status: None

Post Office: HQPWMSMRS05.nrc.gov

Files	Size	Date & Time
MESSAGE	4575	8/28/2015 8:31:38 AM
FPL Letter L-2014-130 Dated 05-9-2014 NRC RAI Letter No. 064 (eRAI 6544) Voluntary Submittal		
2942763		

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: