JmB-016

Dockets Nos. 50-269, 50-270 and 50-287

Mr. Hal B. Tucker Vice President - Nuclear Production Duke Power Company P. O. Box 33189 422 South Church Street Charlotte, North Carolina 28242

Dear Mr. Tucker:

ł,

SUBJECT: GENERIC LETTER 83-28: Item 1.2, POST-TRIP REVIEW (DATA AND INFORMATION CAPABILITY)

REGARDING: Oconee Nuclear Station, Units 1, 2 and 3

We have reviewed your letter dated November 4, 1983 and February 27, 1986 responding to Generic Letter 83-28, "Required Actions Based on Generic Implications of Salem ATWS Events." Briefly, Item 1.2 requires licensees to have the capability to record, recall and display data and information to permit diagnosing the causes of unscheduled reactor shutdowns before restart and to ascertain the proper functioning of safety-related equipment.

We conclude that the Post-Trip Review Data and Information Capability (Item 1.2) at the Oconee Nuclear Station is acceptable. The details of our evaluation are contained in the Safety Evaluation.

Sincerely,

HE Ediser

John F. Stolz, Director PWR Project Directorate #6 Division of PWR Licensing-B

Enclosure: As stated

cc w/enclosure: See next page

			DISTRIBUTION Docket File NRC PDR L PDR PBD-6 Rdg FMiraglia OGC-MNBB 9604 EJordan		ACRS-10 BGrimes JPartlow HPastis RIngram Gray File NThompson SWest	CMcCracken JKramer GEdison
ABD-6 HPastis;jak 6 / 9 /86 B60916 EDR 4		PBD-6 CMcCracken 9//6/86	PBD-6 GEdison 9/11 /86	PBD-6 JStolz 9/1 /8	HIZ IN	

H

PDR

Mr. H. B. Tucker Duke Power Company

cc: Mr. William L. Porter Duke Power Company P. O. Box 33189 422 South Church Street Charlotte, North Carolina 28242

J. Michael McGarry, III, Esq. Bishop, Liberman, Cook, Purcell & Reynolds 1200 Seventeenth Street, N.W. Washington, D.C. 20036

Mr. Robert B. Borsum Babcock & Wilcox Nuclear Power Generation Division Suite 220, 7910 Woodmont Avenue Bethesda, Maryland 20814

Manager, LIS NUS Corporation 2536 Countryside Boulevard Clearwater, Florida 33515

Senior Resident Inspector U.S. Nuclear Regulatory Commission Route 2, Box 610 Seneca, South Carolina 29678

Regional Administrator U.S. Nuclear Regulatory Commission 101 Marietta Street, N.W. Suite 3100 Atlanta, Georgia 30303

Mr. Heyward G. Shealy, Chief Bureau of Radiological Health South Carolina Department of Health and Environmental Control 2600 Bull Street Columbia, South Carolina 29201

Office of Intergovernmental Relations 116 West Jones Street Raleigh, North Carolina 27603

Honorable James M. Phinney County Supervisor of Oconee County Walhalla, South Carolina 29621 Oconee Nuclear Station Units Nos. 1, 2 and 3

Mr. Paul F. Guill Duke Power Company Post Office Box 33189 422 South Church Street Charlotte, North Carolina 28242

