

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8605060120 DOC. DATE: 86/04/29 NOTARIZED: NO DOCKET #  
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269  
 AUTH. NAME AUTHOR AFFILIATION  
 TUCKER, H. B. Duke Power Co.  
 RECIP. NAME RECIPIENT AFFILIATION  
 DENTON, H. R. Office of Nuclear Reactor Regulation, Director (post 851125  
 STOLZ, J. F. PWR Project Directorate 6

SUBJECT: Forwards info supplementing 860424 submittal re Unit 1 vessel shell-to-flange weld indications, per NRC request. Info shows primary stress limits of Section III, Article NB-3000 satisfied.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 / ENCL 1 SIZE: 2  
 TITLE: OR Submittal: General Distribution

NOTES: AEOD/Ornstein: 1cy.

05000269

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	PWR-B ADTS		1	0		PWR-B EB		1	1
	PWR-B PEICSB		2	2		PWR-B FOB		1	1
	PWR-B PD6 PD 01		5	5		NICOLARAS, H		1	1
	PWR-B PEICSB		1	1		PWR-B RSB		1	1
INTERNAL:	ADM/LFMB		1	0		ELD/HDS4		1	0
	NRR/DHFT/TSCB		1	1		NRR/ORAS		1	0
	<u>REG FILE</u> 04		1	1		RGN2		1	1
EXTERNAL:	24X		1	1		EG&G BRUSKE, S		1	1
	LPDR 03		1	1		NRC PDR 02		1	1
	NSIC 05		1	1					
NOTES:			1	1					

TOTAL NUMBER OF COPIES REQUIRED: LTTR 25 ENCL 21

DUKE POWER COMPANY

P.O. BOX 33189  
CHARLOTTE, N.C. 28242

HAL B. TUCKER  
VICE PRESIDENT  
NUCLEAR PRODUCTION

TELEPHONE  
(704) 373-4531

April 29, 1986

Mr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Attention: Mr. John F. Stolz, Project Director  
PWR Project Directorate No. 6


Subject: Oconee Nuclear Station  
Docket Nos. 50-269, -270, -287

Dear Sir:

By letter dated April 24, 1986, Duke Power Company (Duke) submitted information that was requested by the NRC during an April 21, 1986 meeting concerning the Oconee Unit 1 Reactor Vessel Shell-to-Flange weld indications. During the review of this information the NRC requested information that would show that the primary stress limits of Section III, Article NB-3000 are satisfied, assuming a local area reduction of the pressure retaining membrane that is equal to the area of the indication.

To this end, attached is information that shows that the Primary Stress Limits of Section III, Article NB-3000 have been satisfied.

Very truly yours,



Hal B. Tucker

PFG:slb

Attachment

xc: Mrs. Helen Pastis  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dr. J. Nelson Grace, Regional Administrator  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30323

Mr. J. C. Bryant  
NRC Resident Inspector  
Catawba Nuclear Station

8605060120 860429  
PDR ADOCK 05000269  
P PDR

AD001  
1/1

AS PART OF THE REQUIREMENTS OF THE ASME, B & PV CODE, SECTION XI, SUBARTICLE IWB-3610, IT IS NECESSARY TO SHOW THAT THE PRIMARY STRESS LIMITS OF SECTION III, ARTICLE NB-3000 ARE SATISFIED ASSUMING A LOCAL AREA REDUCTION OF THE PRESSURE RETAINING MEMBRANE THAT IS EQUAL TO THE AREA OF THE DETECTED INDICATION(S).

THE CODE STRESS REPORT WAS UTILIZED TO :

1) SHOW THAT THE FLAWS WERE BEYOND THE REQUIRED AREA OF REINFORCEMENT FOR THE INLET AND OUTLET NOZZLE HENCE CONFIRMING ADDITIONAL THICKNESS EXIST BEYOND THAT REQUIRED AND,

2) EXTRACT THE PREVIOUSLY DETERMINED PRIMARY STRESSES TO ASSESS THE EFFECTS OF THE FLAWS ON THE CROSS SECTION

CALCULATED BELOW ARE THE CODE ADJUSTED STRESSES:

$$P_L = 12.7 \left( \frac{12}{12 - 2.99} \right) = 16.9 \text{ ksi} < 40 \text{ ksi ALLOWABLE}$$

$$P_L + P_B = 26.9 \left( \frac{12}{12 - 2.99} \right) = 35.8 \text{ ksi} < 40 \text{ ksi ALLOWABLE}$$