

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8612230232 DOC. DATE: 86/12/15 NOTARIZED: NO DOCKET #
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287
 AUTH. NAME AUTHOR AFFILIATION
 TUCKER, H. B. Duke Power Co.
 RECIP. NAME RECIPIENT AFFILIATION
 DENTON, H. R. Office of Nuclear Reactor Regulation, Director (post 851125
 STOLZ, J. F. PWR Project Directorate 6

SUBJECT: Describes mods made to emergency plan & implementing procedures to correct deficiencies identified during review of Rev 85-2, per NRC 861029 request. Lists changes to plan as agreed upon during 861205 meeting. Rev will be distributed.

DISTRIBUTION CODE: A045D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2
 TITLE: OR Submittal: Emergency Preparedness Plans, Implement'g Procedures, C

NOTES: AEOD/Ornstein: 1cy. S. West, NRR: 1cy. 05000269
 AEOD/Ornstein: 1cy. S. West, NRR: 1cy. 05000270
 AEOD/Ornstein: 1cy. S. West, NRR: 1cy. 05000287

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	PWR-B PD6 LA		1	0		PWR-B PD6 PD		1	1
	PASTIS, H	01	1	1					
INTERNAL:	IE/DEPER/EPB	06	2	2	IE/DEPER/IRB	12	1	1	
	<u>REG FILE</u>	04	1	1	RGN2		1	1	
EXTERNAL:	LPDR	03	1	1	NRC PDR	02	1	1	
	NSIC		1	1					
NOTES:			2	2					

TOTAL NUMBER OF COPIES REQUIRED: LTTR 13 ENCL 12

DUKE POWER COMPANY

P.O. BOX 33189
CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

TELEPHONE
(704) 373-4531

December 15, 1986

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Mr. John F. Stolz, Project Director
PWR Project Directorate No. 6

Subject: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287
Emergency Plan Deficiencies

Dear Sir:

As requested in an October 29, 1986 letter from the NRC/OIE to Duke Power Company, this letter describes modifications which have been made to the Emergency Plan and implementing procedures to correct deficiencies which were identified during a review of Revision 85-2. In a meeting between Duke Power and NRC staff on December 5, 1986, the following changes to the Emergency Plan (Volume A) and Procedure RP/O/B/1000/01 were agreed upon.

- (1) Insert Loss of the Control Room as both an Alert and Site Area Emergency.
- (2) Delete from the Unusual Event category Loss of Most of all annunciators in the Control Room for more than 15 minutes.
- (3) Add Loss of 2 or more Control Room statalarms for more than 15 minutes as an Alert.

These changes have been made and copies of the revision will be distributed by as Revision 86-3 (Volume A) and 86-7 (Volume C).

If there are further questions, please contact us.

Very truly yours,


Hal B. Tucker

WHM/47/slb

8612230232	861215
PDR	ADOCK 05000269
F	PDR

A045
11

Mr. Harold R. Denton, Director

December 15, 1986

Page 2

xc: Ms. Helen Pastis
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Mr. J. C. Bryant
NRC Resident Inspector
Oconee Nuclear Station