

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8708040114 DOC. DATE: 87/07/29 NOTARIZED: NO DOCKET #
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287
 AUTH. NAME AUTHOR AFFILIATION
 TUCKER, H. B. Duke Power Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Provides addl info to 870728 ltr re mods to confirmatory order. Analyses performed for all DBAs identified in FSAR for each unit & attending single active failures. No adverse impact on public health.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: OR Submittal: General Distribution

NOTES: AEOD/Ornstein: 1cy. 05000269
 AEOD/Ornstein: 1cy. 05000270
 AEOD/Ornstein: 1cy. 05000287

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-3 LA	1 0	PD2-3 PD	5 0
	PASTIS, H	1		
INTERNAL:	ARM/DAF/LFMB	1 0	NRR/DEST/ADE	1 1
	NRR/DEST/ADS	1 1	NRR/DEST/CEB	1 1
	NRR/DOEA/TSB	1 1	NRR/PMAS/ILRB	1 1
	OGC/HDS2	1 0	REG FILE 01	1 1
	RES/DE/EIB	1 1		
EXTERNAL:	EG&G BRUSKE, S	1 1	LPDR	1
	NRC PDR	1 1	NSIC	1
NOTES:		1 1		

TOTAL NUMBER OF COPIES REQUIRED: LTTR 21 ENCL 0

DUKE POWER COMPANY

P.O. BOX 33189
CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

TELEPHONE
(704) 373-4531

July 29, 1987

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D. C. 20555


Subject: Oconee Nuclear Station
Docket Nos. 50-269, 50-270, 20-287
Confirmatory Order Modifications

Dear Sir:

This letter is written to provide additional information to the July 28, 1987 letter from Duke Power to the NRC concerning modifications to the Confirmatory Order for Oconee Nuclear Station. Analyses have been performed for all of the design basis accidents identified in the FSAR for each unit and their attending single active failures. This review confirmed that with assumed lake water temperatures up to 85°F and appropriate reductions in power levels, there will be no adverse impact on the public health and safety beyond that identified in the FSAR.

Please contact us if further questions exist regarding this matter.

Very truly yours,



Hal B. Tucker


WHM/67/sbn

xc: Dr. J. Nelson Grace
Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Ms. Helen Pastis
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Mr. Heyward Shealy, Chief
Bureau of Radiological Health
S.C. Department of Health and
Environmental Control
2600 Bull Street
Columbia, South Carolina 29201

Mr. J. C. Bryant
NRC Resident Inspector
Oconee Nuclear Station



*A001
1/0*