

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8708210149 DOC. DATE: 87/08/14 NOTARIZED: NO DOCKET #
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287

AUTH. NAME AUTHOR AFFILIATION
 TUCKER, H. B. Duke Power Co.
 RECIPIENT NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Concludes that control room intake should be relocated.
 Reanalysis of assumptions & SRP Section 6.4 operator
 occupancy factors indicates distance for acceptable
 dispersion to be 13 meters from any containment surface.

DISTRIBUTION CODE: A003D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: OR/Licensing Submittal: Suppl 1 to NUREG-0737(Generic Ltr 82-33)

NOTES: AEOD/Ornstein: icy. 05000269
 AEOD/Ornstein: icy. 05000270
 AEOD/Ornstein: icy. 05000287

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-3 LA	1	PD2-3 PD	7
	PASTIS, H	1		
INTERNAL:	ARM/DAE/LFMB	1	NRR/DLPQ/HFB	1
	<u>REQ FILE</u> 01	1	RES DEPY GI	1
	RES/DE/EIB	1		
EXTERNAL:	LPDR	1	NRC PDR	1
	NSIC	1		
NOTES:		1		

TOTAL NUMBER OF COPIES REQUIRED: LTTR 18 ENCL 0

DUKE POWER COMPANY

P.O. BOX 33189
CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

TELEPHONE
(704) 373-4531

August 14, 1987

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Subject: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287
Control Room Habitability

Gentlemen:

By letter dated January 8, 1987 Duke responded to a November 24, 1986 NRC safety evaluation concerning NUREG-0737 Item III.D.3.4 "Control Room Habitability." Within the response, Duke proposed conducting a test program to develop site specific atmospheric dilution factors in lieu of relocating the intake structure.

Based upon further consideration of the applicable Murphy-Campe methodology, Duke has concluded that the Unit 1 and 2 control room intake and the Unit 3 control room intake should be relocated. Reanalysis utilizing all previously transmitted assumptions and accepting Standard Review Plan (SRP) Section 6.4 operator occupancy factors has indicated that the calculated distance for acceptable dispersion is at least thirteen (13) meters from any containment surface to the control room intake.

Prior to relocation of the control room intakes, Duke would need to obtain NRC concurrence on the acceptability of this relocation. Given NRC concurrence prior to November 15, 1987 Duke will provide a schedule for implementation of modifications to relocate the control room intakes to the NRC by January 1, 1988. Otherwise, Duke will provide the schedule within 60 days following NRC concurrence.


Duke will continue to work with the Staff in seeking final resolution to this NUREG-0737 item.

Very truly yours,

Hal B. Tucker/PREF

Hal B. Tucker

PJN/216/jgc
Attachment



*A003
1/0*

Document Control Desk

August 14, 1987

Page 2

xc: Dr. J. Nelson Grace
Regional Administrator
U.S. Nuclear Regulatory
Commission - Region II
101 Marietta St. NW
Suite 2900 - Atlanta, GA 30323

Ms. Helen Pastis
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Mr. J.C. Bryant
NRC Resident Inspector
Oconee Nuclear Station