## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

· ·		
ACCESSION NBR:	8709110399 DOC. DATE: 87/09/04 NOTARIZED: NO	DOCKET #
FACIL: 50-000	Generic Docket	05000000
50-269	Oconee Nuclear Station, Unit 1, Duke Power Co.	05000269
50-289	Three Mile Island Nuclear Station, Unit 1, General Pu	05000289
AUTH. NAME	AUTHOR AFFILIATION	
WILGUS, W. S.	Babcock & Wilcox Operating Plants Owners Group	
RECIP. NAME	RECIPIENT AFFILIATION	
MIRAGLIA, F.	Associate Director for Projects (Post 870411)	

SUBJECT: Responds to NRc 870819 inquiry re practice of B&W plant owners of utilizing planned reactor trips to affect once through steam generator cleaning.Practice used only once at TMI-1 under controlled conditions.

DISTRIBUTION CODE: GOO6D COPIES RECEIVED:LTR \_ ENCL O SIZE: \_ TITLE: Babcock & Wilcox (B&W) Owners Group Correspondence

NOTES: AEOD/Ornstein: 1cy. R. Conte: 1cy. AEOD/ORNSTEIN: 1cy. 05000269 05000289

	RECIPIENT	COPIES	RECIPIENT	COPIES
	ID CODE/NAME	LTTR ENCL	ID CODE/NAME	LTTR ENCL
INTERNAL:	ACRS	6 4	AEOD DIR	1 1
	AEOD/DSB	1	AEOD/DSP/TPAB	1
	ARM/DAF/LFMB	1	CENTRAL FILE 01	1 [1
	NRR DEAGAZIO, A	1	NRR DICK, G	1 1
	NRR EDISON, G	1	NRR KALMAN, G	1 1
	NRR PASTIS	1	NRR PAULSON, W	1
	NRR ROOD, H	1	NRR SILVER, H	1
	NRR/DEST/ADE	1 D	NRR/DEST/ADS	1 0
	NRR/DEST/CEB	1 1	NRR/DEST/ELB	1
	NRR/DEST/ICSB	1 1	NRR/DEST/MEB	1
	NRR/DEST/MTB	1	NRR/DEST/PSB	1
	NRR/DEST/RSB	1	NRR/DEST/SGB	1
	NRR/DLPQ/HFB	1	NRR/DLPQ/QAB	1
	RES DEPY GI	1 1	RES/DE/EIB	1 1
	RGN1	1 1	RGN2	1
	RGN3	1 1	RGN4	1
	RGN5	1 1		
EXTERNAL:	*LPDR 50-302	1 1	*LPDR 50-312	1 1
	*LPDR 50-313	i l	*LPDR 50-346	1 1
	*LPDR 50-460	i I.	*LPDR OCONEE	1 1
	*LPDR50-289/320	2 2	*LPDR50-329/330	1 1
	NRC PDR	1	NSIC	1 🖠
NOTES:		4 4		

TOTAL NUMBER OF COPIES REQUIRED: LTTR 53 ENCL

·(

## THE OWNERS GROUP

Arkenses Power & Light Company Duke Power Company Florida Power Corporation GPU Nuclear Corporation Secramento Municipal Utility District

Oconee 1, 2, 3 Crystal River 3 TMI-1 Rancho Seco

ANO-1



Toledo Edison Company Tennessee Valley Authority Washington Public Power Supply System Babcock & Wilcox Company

Davis Besse Bellefonte 1, 2 WNP 1

Working Together to Economically Provide Reliable and Safe Electrical Power

Suite 220 7910 Woodmont Avenue Bethesda, Maryland 20814 (301) 951-3344

1-004

September 4, 1987

Mr. Frank Miraglia Associate Director for Projects Office of Nuclear Reactor Regulation Nuclear Regulatory Commission Washington, DC

Dear Mr. Miraglia:

<u>8709110399</u> 870904

ADOCK 05000269

PDR

PDR

Subject: B&W Owners Group Review of Planned Plant Trips

This is in response to your letter of August 19, 1987 to the B&W Owners Group. In that letter, you questioned the practice of some B&W plant owners utilizing planned reactor trips to affect Once Through Steam Generator (OTSG) performance. You state several owners are performing such practices; that it is perceived by you as the means selected by the owners for the "cleaning" of the OTSGs for the life of plant; and that such practices appear contrary to the B&W Owners Group SPIP objectives.

During a recent meeting of the B&W Owners Group, we did review the questions which you have raised. The practice referred to has been performed by one of the B&W owners (GPU Nuclear, TMI-1) and performed one time. As an Owners Group, we believe there may be some misconceptions on the part of the NRC Staff. First, none of the owners, including GPU Nuclear, believe that any of the current practices used to affect crude deposition and steam generator performance are viewed as long term solutions to the basic problem. The long term solution is unanimously viewed as infrequent but periodic chemical cleaning of the steam generators. Individual owners, working both independently and with other Mr. Frank Miraglia September 4, 1987 Page 2.

industry groups, are pursuing the final chemical cleaning approach. The first B&W unit (Duke, Oconee) will be chemically cleaned this Fall and other owners have joined with EPRI in final process qualification for alternate chemical cleaning techniques. Depending upon the individual status of each owner in preparing for cleaning, current plant schedules for refueling, and other considerations, all owners are not in a position to immediately chemically clean but probably most will be by the early 1990s.

During what is expected to be a limited interval between now and when a fully qualified chemical cleaning process is available, the owners that have experienced steam generator power limitations have available two principal techniques for interim relief. One of these techniques is referred to as "water slap," involving pulsed nitrogen injection into the secondary side of the generator, while the plant is shut down, to dislodge and clear the metal oxides affecting blockage. This technique has been used at the Oconee, Crystal River and Arkansas Unit 1 plants. The other approach was the one planned trip of the plant performed by GPU Nuclear at TMI. Each of these approaches has met with variable degrees of success and neither, as mentioned earlier, is viewed as a long term or life of plant A number of other approaches have been tried process. without success.

We have briefly reviewed the trip selection process as performed by GPU Nuclear. That process involved a review of the alternatives, the performance of a detailed safety assessment, specific training, and the performance of the trip under controlled conditions, with plant procedures, and with extra operating and technical staff support present. The trip itself, in many respects, is very similar to planned trips or tests conducted routinely during startup of new plants. Such a planned sequence of events is not viewed by the Owners Group as contradictory to the SPIP program which addresses the reduction of post trip complexity and <u>unplanned</u> trips. Unplanned trips generally stem from operator or maintenance error, or equipment failure, and are circumstantially not the same as a carefully controlled plant evolution. Mr. Frank Miraglia September 4, 1987 Page 3.

Frank Miraglia ember 4, 1987 3. In summary, long term actions are underway to chemical-lean steam generators, and in the interim. efficient ly clean steam generators, and in the interim, efficient operation of the OTSGs is important to overall plant performance. We, as the Owners Group, do not plan to use reactor trip as the methodology to short term cleanliness of the OTSG. In fact, most of our group do not employ the method. Interim steps have been used to deal with generator fouling on a temporary basis including the water slap process and the single occasion of a reactor trip and they have only been applied after careful consideration of alternatives, under controlled conditions and after specific safety The decision making process seems appropriate. We reviews. trust this letter provides you with the information requested.

Very truly yours

Walter S. Wilgus Chairman B&W Owners Group

WSW/lmh

USNRC-DS PB1 SEP 11 A 9-30

1. - <del>2.</del> - 4. - **1**.