

Docket Nos.: 50-269, 50-270  
and 50-287

NOV 11 1987

Mr. H. B. Tucker, Vice President  
Nuclear Production Department  
Duke Power Company  
422 South Church Street  
Charlotte, North Carolina 28242

Dear Mr. Tucker:

Subject: Generic Letter 83-28, Item 2.1 (Part 2: Vendor Interface  
Programs - RTS Components )  
(TACS 66302/66303/66304)

Re: Oconee Nuclear Station, Units 1, 2, and 3

Generic Letter 83-28, Item 2.1 (Part 2); required all licensees to confirm that they have established an interface with either the nuclear steam system supplier or with the vendors of each of the components of their reactor trip system. This interface program should include: (1) periodic communication between the licensee and the vendor, and (2) a system of positive feedback which confirms receipt by the licensee of transmittals with technical information.

We have enclosed our safety evaluation and our consultant's report, EG&G-NTA-7765. We find your responses acceptable and therefore, consider Item 2.1 (Part 2) to be complete. Item 2.1, Part 1, equipment classification was found acceptable by our September 28, 1987 letter.

Sincerely,

Helen N. Pastis, Project Manager  
Project Directorate II-3  
Division of Reactor Projects I/II

Enclosure: As stated

cc: See next page

DISTRIBUTION:

Docket File  
Local PDR  
PDII-3 Reading  
HPastis  
EJordan

PRC System  
NRC PDR  
MDuncan  
ACRS(10)  
JStone

PDII-3/DRPI/II  
HPastis/rad  
11/3 /87

PDII-3/DRPI/II  
MDuncan  
11/3 /87

PDII-3/DRPI/II  
Acting Director  
11/3 /87

8711100126 871111  
PDR ADOCK 05000269  
P PDR

Mr. H. B. Tucker  
Duke Power Company

Oconee Nuclear Station  
Units Nos. 1, 2 and 3

cc:

Mr. A. V. Carr, Esq.  
Duke Power Company  
P. O. Box 33189  
422 South Church Street  
Charlotte, North Carolina 28242

Mr. Paul Guill  
Duke Power Company  
Post Office Box 33189  
422 South Church Street  
Charlotte, North Carolina 28242

J. Michael McGarry, III, Esq.  
Bishop, Liberman, Cook, Purcell & Reynolds  
1200 Seventeenth Street, N.W.  
Washington, D.C. 20036

Mr. Robert B. Borsum  
Babcock & Wilcox  
Nuclear Power Generation Division  
Suite 220, 7910 Woodmont Avenue  
Bethesda, Maryland 20814

Manager, LIS  
NUS Corporation  
2536 Countryside Boulevard  
Clearwater, Florida 33515

Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
Route 2, Box 610  
Seneca, South Carolina 29678

Regional Administrator, Region II  
U.S. Nuclear Regulatory Commission  
101 Marietta Street, N.W., Suite 2900  
Atlanta, Georgia 30323

Mr. Heyward G. Shealy, Chief  
Bureau of Radiological Health  
South Carolina Department of Health  
and Environmental Control  
2600 Bull Street  
Columbia, South Carolina 29201

Office of Intergovernmental Relations  
116 West Jones Street  
Raleigh, North Carolina 27603

Honorable James M. Phinney  
County Supervisor of Oconee County  
Walhalla, South Carolina 29621