

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8801050320 DOC. DATE: 87/12/23 NOTARIZED: NO DOCKET #
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
 AUTH. NAME AUTHOR AFFILIATION
 TUCKER, H.B. Duke Power Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards "Data Package for 1987 UT Results of Oconee Unit 1 Reactor Vessel Flange-to-Shell Weld."

DISTRIBUTION CODE: A047D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 17200
 TITLE: OR Submittal: Inservice Inspection/Testing

NOTES: AEOD/Ornstein: 1cy. #6 05000269

see Reports

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	PD2-3 LA		1	0		PD2-3 PD #10-14	5	5	
	PASTIS, H	#5	1	1					
INTERNAL:	AEOD/DOA	#7	1	1		AEOD/DSP/TPAB #4	1	1	
	ARM/DAF/LFMB		1	0		NRR/DEST/MEB #3	1	1	
	NRR/DEST/MTB #8		1	1		NRR/PMAS/ILRB #2	1	1	
	OGC/HDS2		1	0		<u>REG FILE</u> #7	1	1	
	RES/DE/EIB #9		1	1					
EXTERNAL:	LPDR		1	0		NRC PDR	1	0	
	NSIC		1	0					

NOTES: 1 1
Change PDR Ltr Encl
 LPDR 1 0
 NSIC 1 0

TOTAL NUMBER OF COPIES REQUIRED: LTTR 20 ENCL 14
17

RIDS / ADDS

DUKE POWER COMPANY

P.O. BOX 33189

CHARLOTTE, N.C. 28242

HAL B. TUCKER

VICE PRESIDENT
NUCLEAR PRODUCTION

TELEPHONE
(704) 373-4531

December 23, 1987


U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D. C. 20555

Subject: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287
Unit 1 Reactor Vessel Flange-to-Shell Weld
Inservice Inspection Results

Dear Sir:

For your information, please find attached a report describing the results of the Ultrasonic Examination of the Reactor Vessel Flange-to-Shell Weld for Unit 1. The primary objective of the Ultrasonic Examination was to produce several independent sets of data to make the determination of whether the twenty-two (22) previously recorded indications represented flaws or non-relevant conditions. The data obtained were evaluated and it was conclusively determined that the twenty-two (22) indications recorded during the 1986 examination represented geometric reflectors caused by the flange conditions. Please be advised, that Duke has received authorization from Babcock and Wilcox (B&W) to release B&W Document No. 11835505A-0, entitled "1987 Report of Ultrasonic Examination Results from the Oconee Nuclear Station Unit 1 Reactor Vessel Flange" dated October 1987, for the NRC Staff internal use only.

Very truly yours,



Hal B. Tucker

PFG/1148/sbn

Attachment

: (w/o Attachment)
Dr. J. Nelson Grace, Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Mr. J. C. Bryant
NRC Resident Inspector
Oconee Nuclear Station

Ms. Helen Pastis
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8801050320 871223
PUR ADDOCK 05000269
DCD

Change: PDR 1 0
NPDR 1 0
NSIC 1 0
Ltr. Encl

A047
|||

PROPRIETARY INFORMATION

NOTICE

THE ATTACHED DOCUMENT MAY CONTAIN "PROPRIETARY INFORMATION" AND SHOULD BE HANDLED AS NRC "OFFICIAL USE ONLY" INFORMATION. IT SHOULD NOT BE DISCUSSED OR MADE AVAILABLE TO ANY PERSON NOT REQUIRING SUCH INFORMATION IN THE CONDUCT OF OFFICIAL BUSINESS AND SHOULD BE STORED, TRANSFERRED, AND DISPOSED OF BY EACH RECIPIENT IN A MANNER WHICH WILL ASSURE THAT ITS CONTENTS ARE NOT MADE AVAILABLE TO UNAUTHORIZED PERSONS.

COPY NO. _____

DOCKET NO. _____

CONTROL NO. _____

REPORT NO. _____

REC'D W/LTR DTD. _____

PROPRIETARY INFORMATION