

PUBLIC SUBMISSION

As of: 8/25/15 4:20 PM
Received: August 20, 2015
Status: Pending_Post
Tracking No. 1jz-8ko2-jush
Comments Due: August 20, 2015
Submission Type: Web

Docket: NRC-2015-0171

Applications and Amendments to Facility Operating Licenses and Combined Licenses Involving No Significant Hazards Considerations

Comment On: NRC-2015-0171-0001

Biweekly Notice; Applications and Amendments to Facility Operating Licenses and Combined Licenses Involving No Significant Hazards Considerations

Document: NRC-2015-0171-DRAFT-0002

Comment on FR Doc # 2015-17651

*7/21/2015
SO FR 43123*

Submitter Information

Name: Erica Gray

Address:

406 Glendale Dr.
Henrico, VA, 23229

Email: veggielady@yahoo.com

2

RECEIVED

2015 AUG 25 PM 4: 23

RULES AND DIRECTIVES SEARCH

General Comment

Re: VIRGINIA ELECTRIC AND POWER COMPANY, DOCKET NO. 50-339, NORTH ANNA POWER STATION, UNIT NO. 2, LOUISA COUNTY, VIRGINIA

Date of amendment request: May 22, 2015. A publicly-available version is in ADAMS under Accession No. ML15147A029.

Description of amendment request: The proposed license amendment would revise Technical Specification 3.8.1, "AC Sources Operating," to delete Note 1 to Surveillance Requirement (SR) 3.8.1.8 to remove the limitation that excludes Unit 2 from the verification test requirement.

Unit 2 did not have an alternate offsite feed for the emergency buses.

Why did it take them this long to meet this requirement?

<http://pbadupws.nrc.gov/docs/ML1514/ML15147A029.pdf>

SUNSI Review Complete

Template = ADM - 013

E-RIDS= ADM-03

Add= L. Rosewicz (4483)