

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8802020131 DOC. DATE: 88/01/27 NOTARIZED: NO DOCKET #
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
 AUTH. NAME TUCKER, H. B. AUTHOR AFFILIATION Duke Power Co.
 RECIP. NAME RECIPIENT AFFILIATION Document Control Branch (Document Control Desk)

SUBJECT: Forwards update to util 880118 ltr re once-through steam generator tube plugging & repair. Plugging & repair for end of Cycle 10 refueling outage completed on 871023 w/number of tubes repaired by sleeving listed incorrectly.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: OR Submittal: General Distribution

NOTES: AEOD/Ornstein:1cy. 05000269

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME	L	T	ENCL		ID CODE/NAME	L	T	ENCL
	PD2-3 LA	1		0		PD2-3 PD	5		0
	PASTIS, H	1							
INTERNAL:	ARM/DAF/LFMB	1				NRR/DEST/ADS	1		
	NRR/DEST/CEB	1				NRR/DEST/MTB	1		
	NRR/DEST/RSB	1				NRR/DOEA/TSB	1		
	NRR/PMAS/ILRB	1				OGC/HDS2	1		
	<u>REG FILE</u> 01	1				RES/DE/EIB	1		
EXTERNAL:	LPDR	1				NRC PDR	1		
	NSIC	1							
NOTES:		1		1					

0

TOTAL NUMBER OF COPIES REQUIRED: LTR 21 ENCL 18

DUKE POWER COMPANY

P.O. BOX 33189
CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

TELEPHONE
(704) 373-4531

January 27, 1988


U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D. C. 20555

Subject: Oconee Nuclear Station, Unit 1
Docket No. 50-269
OTSG Tube Plugging and Repair

Gentlemen:

By letter dated January 18, 1988, Duke Power Company submitted information concerning the Oconee Unit 1 steam generators, pursuant to Oconee Nuclear Station Technical Specification 4.17.6(a). The steam generator plugging and repair for the Unit 1 End of Cycle 10 refueling outage was completed on October 23, 1987, however the number of tubes repaired by sleeving was incorrect. The "A" OTSG had a total of 265 tubes repaired by sleeving. The "B" OTSG had a total of 204 tubes repaired by sleeving.

Very truly yours,



Hal B. Tucker


PJN/1275/sbn

Attachment

xc: Dr. J. Nelson Grace, Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Ms. Helen Pastis
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Mr. P. H. Skinner
NRC Resident Inspector
Oconee Nuclear Station



9001
1/0