[7590-01]

NUCLEAR REGULATORY COMMISSION
[Docket Nos. 50-269, 50-270, 50-287, 50-289, 50-302, 50-312, 50-313]

ARKANSAS POWER AND LIGHT COMPANY [Arkansas Nuclear One, Unit No. 1]

SACRAMENTO MUNICIPAL UTILITY DISTRICT [Rancho Seco Nuclear Generating Station]

FLORIDA POWER CORPORATION
[Crystal River Unit No. 3 Nuclear Generating Plant]

DUKE POWER COMPANY
[Oconee Nuclear Station, Units Nos. 1, 2 and 3]

GENERAL PUBLIC UTILITIES NUCLEAR CORPORATION [Three Mile Island Nuclear Station, Unit No. 1]

REQUEST FOR ACTION UNDER 10 CFR 2.206

Notice is hereby given that, by a Petition dated June 11, 1985,

John F. Doherty requested issuance of an order under 10 CFR 2.202 to

the licensees of the following Babcock and Wilcox facilities to show

cause why the operating licenses for those facilities should not be

suspended or revoked until the problem identified in IE Information Notice

85-38 is resolved: Arkansas Nuclear One, Unit No. 1; Rancho Seco Nuclear

Generating Station; Crystal River Unit No. 3 Nuclear Generating Plant;

Oconee Nuclear Station, Units Nos. 1, 2 and 3; and Three Mile Island Nuclear

Station, Unit 1. The IE Notice concerned loose parts which had been found to

obstruct certain control rod drive mechanisms at the Davis-Besse facility of

the Toledo Edison Company.

The Petition is being treated pursuant to 10 CFR 2.206 of the Commission's regulations and, accordingly, appropriate action will be taken on the request within a reasonable time. A copy of the Petition is available for inspection in the Commission's Public Document Room, 1717 H Street, N.W., Washington, D.C. 20555 and at the local public document room for each

affected facility as follows:

Arkansas Nuclear One, Unit No. 1 Tomlinson Library Arkansas Tech University Russellville, Arkansas 72801

Rancho Seco Nuclear Generating Station Sacramento City-County Library 828 I Street Sacramento, California

Crystal River Unit No. 3 Nuclear Generating Plant Crystal River Public Library 668 N.W. First Avenue Crystal River, Florida

Oconee Nuclear Station, Units Nos. 1, 2 and 3 Oconee County Library 501 West Southbroad Street Walhalla, South Carolina

Three Mile Island Nuclear Station, Unit No. 1 Government Publications Section State Library of Pennsylvania Education Building Commonwealth and Walnut Streets Harrisburg, Pennsylvania 17126

Dated at Bethesda, Maryland, this 17th day of July 1985.

FOR THE NUCLEAR REGULATORY COMMISSION

Harold R. Denton, Director

Office of Nuclear Reactor Regulation

Mr. J. M. Griffin Arkansas Power & Light Company

Arkansas Nuclear One, Unit 1

cc: Mr. J. Ted Enos, Manager Licensing Arkansas Power & Light Company P. O. Box 551

Little Rock, Arkansas 72203

Mr. John M. Griffin, Senior Vice President of Energy Supply Arkansas Power & Light Company P. O. Box 551 Little Rock, Arkansas 72203

Mr. James M. Levine, General Manager Arkansas Nuclear One P. O. Box 608 Russellville, Arkansas 72801

Mr. Nicholas S. Reynolds Bishop. Liberman, Cook, Purcell & Reynolds 1200 Seventeenth Street, NW Washington, D.C. 20036

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
Suite 220, 7910 Woodmont Avenue
Bethesda, Maryland 20814

Resident Inspector U.S. Nuclear Regulatory Commission P. O. Box 2090 Russellville, Arkansas 72801

Regional Administrator, Region IV U.S. Nuclear Regulatory Commission Office of Executive Director for Operations 611 Ryan Plaza Drive, Suite 1000 Arlington, Texas 76011

Mr. Frank Wilson, Director
Division of Environmental Health
Protection
Department of Health
Arkansas Department of Health
4815 West Markham Street
Little Rock, Arkansas 72201

Honorable Ermil Grant Acting County Judge of Pope County Pope County Courthouse Russellville, Arkansas 72801 Mr. W. S. Wilgus Florida Power Corporation

cc: Mr. R. W. Neiser Senior Vice President and General Counsel Florida Power Corporation P. O. Box 14042 St Petersburg, Florida 33733

Nuclear Plant Manager Florida Power Corporation P. O. Box 219 Crystal River, Florida 32629

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
Suite 220, 7910 Woodmont Avenue
Bethesda, Maryland 20814

Resident Inspector U.S. Nuclear Regulatory Commission Route #3, Box 717 Crystal River, Florida 32629

Regional Administrator, Revion II U.S. Nuclear Regulatory Commission 101 Marietta Street, Suite 3100 Atlanta, Georgia 30303

Mr. Ulray Clark, Administrator Radiological Health Services Department of Health and Rehabilitative Services 1323 Winewood Blvd. Tallahassee, Florida 32301

Administrator
Department of Environmental Regulation
Power Plant Siting Section
State of Florida
2600 Blair Stone Road
Tallahassee, Florida 32301

Attorney General Department of Legal Affairs The Capitol Tallahassee, Florida 32304 Crystal River Unit No. 3 Nuclear Generating Plant

Bureau of Intergovernmental Relations 660 Apalachee Parkway Tallahassee, Florida 32304

Mr. Wilbur Langely, Chairman Board of County Commissioners Citrus County Inverness, Florida 36250

Mr. Walter S. Wilgus
Vice President, Nuclear Operations
Florida Power Corporation
ATTN: Manager, Nuclear Licensing
& Fuel Management
P. O. Box 14042; M.A.C. H-3
St. Petersburg, Florida, 33733

Mr. J. Williams Toledo Edison Company

cc:
Donald H. Hauser, Esq.
The Cleveland Electric
Illuminating Company
P. O. Box 5000
Cleveland, Ohio 44101

Mr. Robert F. Peters Manager, Nuclear Licensing Toledo Edison Company Edison Plaza 300 Madison Avenue Toledo. Ohio 43652

Gerald Charnoff, Esq. Shaw, Pittman, Potts and Trowbridge 1800 M Street, N.W. Washington, D.C. 20036

Paul M. Smart, Esq. Fuller & Henry 300 Madison Avenue P. O. Box 2088 Toledo, Ohio 43603

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation
Division
Suite 200, 7910 Woodmont Avenue
Bethesda, Maryland 20814

Resident Inspector U.S. Nuclear Regulatory Commission 5503 N. State Route 2 Oak Harbor, Ohio 43449

Regional Administrator, Region III U.S. Nuclear Regulatory Commission 799 Roosevelt Road Glen Ellyn, Illinois 60137 Davis-Besse Nuclear Power Station Unit No. 1

Ohio Department of Health ATTN: Radiological Health Program Director P. O. Box 118 Columbus, Ohio 43216

Attorney General
Department of Attorney
General
30 East Broad Street
Columbus, Ohio 43215

Mr. James W. Harris, Director Division of Power Generation Ohio Department of Industrial Relations 2323 West 5th Avenue P. O. Box 825 Columbus, Ohio 43216

Mr. Harold Kahn, Staff Scientist Power Siting Commission 361 East Broad Street Columbus, Ohio 43216

President, Board of Ottawa County Port Clinton, Ohio 43452

Mr. Joe Williams
Vice President, Nuclear
Toledo Edison Company
Edison Plaza - Stop 712
300 Madison Avenue
Toledo, Ohio 43652

Mr. H. B. Tucker Duke Power Company Oconee Nuclear Station Units Nos. 1, 2 and 3

cc: Mr. William L. Porter Duke Power Company P. O. Box 33189 422 South Church Street Charlotte, North Carolina 28242

Mr. Hal B. Tucker Vice President - Nuclear Production Duke Power Company P. O. Box 33189 422 South Church Street Charlotte, North Carolina 28242

J. Michael McGarry, III, Esq.
Bishop, Liberman, Cook, Purcell & Reynolds
1200 Seventeenth Street, N.W.
Washington, D.C. 20036

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
Suite 220, 7910 Woodmont Avenue
Bethesda, Maryland 20814

Manager, LIS NUS Corporation 2536 Countryside Boulevard Clearwater, Florida 33515

Senior Resident Inspector U.S. Nuclear Regulatory Commission Route 2, Box 610 Seneca, South Carolina 29678

Regional Administrator U.S. Nuclear Regulatory Commission 101 Marietta Street, N.W. Suite 3100 Atlanta, Georgia 30303

Mr. Heyward G. Shealy, Chief Bureau of Radiological Health South Carolina Department of Health and Environmental Control 2600 Bull Street Columbia, South Carolina 29201

Office of Intergovernmental Relations 116 West Jones Street Raleigh, North Carolina 27603

Honorable James M. Phinney County Supervisor of Oconee County Walhalla, South Carolina 29621 Mr. R. J. Rodriguez Sacramento Municipal Utility District Rancho Seco Nuclear Generating Station

cc:
Mr. David S. Kaplan, Secretary
and General Counsel
Sacramento Municipal Utility
District
6201 S Street
P. O. Box 15830
Sacramento, California 95813

Thomas Baxter, Esq. Shaw, Pittman, Potts & Trowbridge 1800 M Street, N.W. Washington, D.C. 20036

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
Suite 220, 7910 Woodmont Avenue
Bethesda, Maryland 20814

Resident Inspector/Rancho Seco c/o U. S. N. R. C. 14410 Twin Cities Road Herald, California 95638

Regional Administrator, Region V U.S. Nuclear Regulatory Commission 1450 Maria Lane, Suite 210 Walnut Creek, California 94596

Director
Energy Facilities Siting Division
Energy Resources Conservation &
Development Commission
1516 - 9th Street
Sacramento, California 95814

Mr. Joseph O. Ward, Chief Radiological Health Branch State Department of Health Services 714 P Street, Office Building #8 Sacramento, California 95814

Mr. Joseph Findaro California State Office 444 North Capitol Street, N.W., Suite 305 Washington, D.C. 20003

Sacramento County Board of Supervisors 827 7th Street, Room 424 Sacramento, California 95814

Ms. Helen Hubbard P. O. Box 63 Sunol, California 94586

Mr. Ronald J. Rodriguez Assistant General Manager, Nuclear Sacramento Municipal Utility District 6201 S Street P. O. Box 15830 Sacramento, California 95813 Mr. Henry D. Hukill GPU Nuclear Corporation

cc: Mr. R. J. Toole O&M Director, TMI-1 GPU Nuclear Corporation Middletown, Pennsylvania 17057

Richard J. McGoey Manager, PWR Licensing GPU Nuclear Corporation 100 Interpace Parkway Parsippany, New Jersey 70754

Mr. C. W. Smyth
TMI-1 Licensing Manager
GPU Nuclear Corporation
P. O. Box 480
Middletown, Pennsylvania 17057

G. F. Trowbridge, Esq. Shaw, Pittman, Potts & Trowbridge 1800 M Street, N.W. Washington, D.C. 20036

Ivan W. Smith, Esq., Chairman Atomic Safety and Licensing Board U.S. Nuclear Regulatory Commission Washington, D.C. 20555

Sheldon J. Wolfe, Esq., Chairman Atomic Safety and Licensing Board U.S. Nuclear Regulatory Commission Washington, D.C. 20555

Mr. Gustave A. Linenberger, Jr. Atomic Safety and Licensing Board U.S. Nuclear Regulatory Commission Washington, D.C. 20555

Dr. James Lamb, III Administrative Judge 313 Woodhaven Road Chapel Hill, North Carolina 17514

Mr. David Hetrick Administrative Judge Professor of Nuclear Energy University of Arizona Tucson, Arizona 85721 Three Mile Island Nuclear Station Unit No. 1

Mr. Richard Conte Senior Resident Inspector (TMI-1) U.S.N.R.C. P.O. Box 311 Middletown, Pennsylvania 17057

Regional Administrator, Region I U.S. Nuclear Regulatory Commission 631 Park Avenue King of Prussia, Pennsylvania 19406

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
Suite 220, 7910 Woodmont Avenue
Bethesda, Maryland 20814

Governor's Office of State Planning and Development ATTN: Coordinator, Pennsylvania State Clearinghouse P. O. Box 1323 Harrisburg, Pennsylvania 17120

Mr. Earl B. Hoffman
Dauphin County Commissioner
Dauphin County Courthouse
Front and Market Streets
Harrisburg, Pennsylvania 17101

Dauphin County Office of Emergency Preparedness Court House, Room 7 Front and Market Streets Harrisburg, Pennsylvania 17101

Mr. David D. Maxwell, Chairman Board of Supervisors Londonderry Township FRD#1 - Geyers Church Road Middletown, Pennsylvania 17057

Mr. Thomas M. Gerusky, Director Bureau of Radiation Protection Pennsylvania Department of Environmental Resources P. O. Box 2063 Harrisburg, Pennsylvania 17120 cc:
Thomas Y. Au, Esq.
Office of Chief Counsel
Department of Environmental Resources
505 Executive House
P. O. Box 2357
Harrisburg, Pennsylvania 17120

Mr. Bob Stein, Director of Research Committee on Energy P. O. Box 11867 104 Blatt Building Columbia, South Carolina 29211

Ms. Jane Lee 183 Valley Road Etters, Pennsylvania 17319

Ms. Marjorie M. Aamodt Mr. Norman Aamodt 200 North Church Street Parkesburg, Pennsylvania 19365

Ms. Louise Bradford TMIA 1011 Green Street Harrisburg, Pennsylvania 17102

Mr. Marvin I. Lewis 6504 Bradford Terrace Philadelphia, Pennsylvania 19149

Mr. Chauncey Kepford Ms. Judith H. Johnsrud Environmental Coalition on Nuclear Power 433 Orlando Avenue State College, Pennsylvania 16801

Mr. Bruce Molholt Haverford College Haverford, Pennsylvania 19041

Mr. Donald E. Hossler 501 Vine Street Middletown, Pennsylvania 17057

Mr. Ad Crable Lancaster New Era 8 West King Street Lancaster, Pennsylvania 17602 Sen. Allen R. Carter, Chairman Joint Legislative Committee on Energy P. O. Box 142 Suite 513 Senate Gressette Building Columbia, South Carolina 29202

Ms. Frieda Berryhill, Chairman Coalition for Nuclear Power Plant Postponement 2610 Grendon Drive Wilmington, Delaware 19808

William S. Jordan, III, Esq. Harmon, Weiss & Jordan 20001 S Street, N.W. Suite 430 Washington, D.C. 20009

Lynne Bernabei, Esq. Government Accountability Project 1555 Connecticut Ave., N.W. Washington, D.C. 20009

Michael W. Maupin, Esq. Hunton & Williams 707 East Main Street P. O. Box 1535 Richmond Virginia 23212

Jordan D. Cunningham, Esq. Fox, Farr and Cunningham 2320 North 2nd Street Harrisburg, Pennsylvania 17110

Ms. Ellyn R. Weiss Harmon, Weiss & Jordan 2001 S Street, N.W. Suite 430 Washington, D.C. 20009

Michael McBride, Esq. LeBoeuf, Lamb, Leiby & McRae Suite 1100 1333 New Hampshire Avenue, N.W. Washington, D.C. 20036 cc:

Atomic Safety & Licensing Board Panel U.S. Nuclear Regulatory Commission Washington, D.C. 20555

Atomic Safety & Licensing Appeal Board Panel (8) U.S. Nuclear Regulatory Commission Washington, D.C. 20555

Docketing and Service Section Office of the Secretary U.S. Nuclear Regulatory Commission Washington, D.C. 20555

Mr. Henry D. Hukill, Vice President and Director - TMI-1 GPU Nuclear Corporation P. O. Box 480 Middletown, Pennsylvania 17057 Mr. J. T. Beckham, Jr. Georgia Power Company

Edwin I. Hatch Nuclear Plant, Units Nos. 1 and 2

cc:

G. F. Trowbridge, Esq. Shaw, Pittman, Potts and Trowbridge 1800 M Street, N.W. Washington, D.C. 20036

Mr. L. T. Gucwa Engineering Department Georgia Power Company P. O. Box 4545 Atlanta, Georgia 30302

Mr. H. C. Nix, Jr., General Manager Edwin I. Hatch Nuclear Plant Georgia Power Company P. O. Box 442 Baxley, Georgia 31513

Mr. Louis B. Long Southern Company Services, Inc. P. O. Box 2625 Birmingham, Alabama 35202

Resident Inspector U.S. Nuclear Regulatory Commission Route 1, P. O. Box 279 Baxley, Georgia 31513

Regional Administrator, Region II U.S. Nuclear Regulatory Commission, 101 Marietta Street, Suite 3100 Atlanta, Georiga 30303

Mr. Charles H. Badger Office of Planning and Budget Room 610 270 Washington Street, S.W. Atlanta, Georgia 30334

Mr. J. Leonard Ledbetter, Commissioner Department of Natural Resources 270 Washington Street, N.W. Atlanta, Georgia 30334

Chairman Appling County Commissioners County Courthouse Baxley, Georgia 31513 Mr. J. T. Beckham, Jr. Vice President - Nuclear Generation Georgia Power Company P. O. Box 4545 Atlanta, Georgia 30302 Mr. E. G. Bauer, Jr. Philadelphia Electric Company

cc: Mr. Eugene J. Bradley Assistant General Counsel Philadelphia Electric Company 2301 Market Street Philadelphia, Pennsylvania 19101

Troy B. Conner, Jr., Esq. 1747 Pennsylvania Avenue, N.W. Washington, D.C. 20006

Thomas A. Deming, Esq. Assistant Attorney General Department of Natural Resources Annapolis, Maryland 21401

Philadelphia Electric Company ATTN: Mr. R. Fleishmann Peach Bottom Atomic Power Station Delta, Pennsylvania 17314

Mr. M. J. Cooney, Superintendent Generation Division - Nuclear Philadelphia Electric Company 2301 Market Street Philadelphia, Pennsylvania 19101

Mr. Anthony J. Pietrofitta, General Manager
Power Production Engineering
Atlantic Electric
P. O. Box 1500
1199 Black Horse Pike
Pleasantville, New Jersey 08232

Resident Inspector U.S. Nuclear Regulatory Commission Peach Bottom Atomic Power Station P.O. Box 399 Delta, Pennsylvania 17314

Regional Administrator, Region I U.S. Nuclear Regulatory Commission 631 Park Avenue King of Prussia, Pennsylvania 19406 Peach Bottom Atomic Power Station, Units 2 and 3

Mr. R. A. Heiss, Coordinator Pennsylvania State Clearinghouse Governor's Office of State Planning and Development P.O. Box 1323 Harrisburg, Pennsylvania 17120

Mr. Thomas M. Gerusky, Director Bureau of Radiation Protection Pennsylvania Department of Environmental Resources P.O. Box 2063 Harrisburg, Pennsylvania 17120

Mr. Albert R. Steel, Chairman Board of Supervisors Peach Bottom Township R. D. #1 Delta, Pennsylvania 17314

> Mr. Edward G. Bauer, Jr. Vice President and General Counsel Philadelphia Electric Company 2301 Market Street Philadelphia, Pennsylvania 19101

June 11, 1985

UNITED STATES OF AMERICA NUCLEAR REGULATORY COMMISSION

Before the Director of Nuclear Reactor Regulation

In the Matter of:

ARKANSAS POWER & LIGHT CO.
(Arkansas Nuclear One Station, Unit 1)
SACRAMENTO MUNICIPAL UTILITY DIST.
(Rancho Seco Station, Unit 1)
FLORIDA POWER CORP.
(Crystal River Station, Unit 3)
DUKE POWER CORPORATION
(Oconee Station, Units 1, 2, & 3)
GENERAL PUBLIC UTILITIES NUCLEAR CORP.
(Three Mile Island Station, Unit 1)

Docket No. 50-313

Docket No. 50-312

Docket No. 50-302

Docket Nos. 50-269, 50-270, 50-287 Docket No. 50-289

JOHN F. DOHERTY'S PETITION/REQUEST FOR SHOW CAUSE ORDER

Pursuant to 10 CFR 2.206 of the Commission's Rules of Practice, John F. Doherty, of 318 Summit Ave., Apt. #3, Brighton, Massachusetts 02135, (617) 232-3853, now files this Petition/Request for Show Cause Order under 10 CFR 2.202, to the Director of Nuclear Reactor Regulation, seeking that the Director institute a consolidated proceeding or proceedings to suspend or revoke the operating license for the Arkansas Nuclear One Station, Unit 1; Rancho Seco Station, Unit 1; Crystal River Station, Unit 3; Oconee Stations, Units 1, 2, & 3; and Three Mile Island Station, Unit 1, by serving the respective Licensees, Arkansas Power & Light Co., Sacramento Municipal Utility District, Florida Power Corporation, Duke Power Corporation, and General Public Utilities Nuclear Corporation, an Order to Show Cause why the said operating Licensee should not have its Operating License suspended or revoked until such time that it inspects

8506130316 850611 PDR ADDCK 05000269 G PDR and (based on the result of the inspection) corrects its facilities for the hazardous condition explained below.

Basis for the Petition/ Request:

The basis for this request for action is from Inspection and Enforcement Notice No. 85-38 -dated May 21, 1985, and received by Petitioner on June 1, 1985, and addressed to all utilities holding an operating license for nuclear power facilities designed by the Babcock & Wilcox Corporation (B & W). All such facilities are pressurized water reactors (PWRs) having control rods above the fuel zone in the reactor pressure vessel. As described in Notice No. 85-38, the Davis-Besse Nuclear Plant, a B. & W. PWR, on inspection following the failure on two occaisions (March 16, 1985 and March 21, 1985) for its control rod E-3, revealed a broken locking spring in the control rod drive mechanism (CRDM) at core location M-5, and four locking springs not in their normal and correct locking position. The CRDM at location E-3 had shown a broken locking spring and not all pieces of the spring were believed recovered. In addition, pieces described as from a maintainance tool used the previous year were found in the CRDM. It thus appears the CRDMS at locations E-3 and M-5 at Davis-Besse had broken locking springs in them and that the CRDM's at E-3 and C-7 (also noted in Notice No. 85-38) have both been blocked (at different times) by a common mode phenomena.

^{1/}Titled, "Loose Parts Obstruct Control Rod Drive Mechanism" (Attached)

plant might well have had a SCRAM in which two control rods could not have been driven into the core due to jamming of the CRDMs by loose parts such as those described in the notice. The usual technical specifications or Commission Regulatory Guides require that it be possible to bring the reactor core sub-critical with a single control rod stuck fully out. However, in the case where two control rods are stuck out it appears it may not be possible to bring the core to sub-criticality without the use of a back up system such as one designed to introduce boron into the circulating coolant in greater quantity than in normal operation.

Notice No. 85-38 states that the, "spring failures are considered to be a potential common mode failure that could affect the reactor trip function because . . . (of) (2) the liklihood for out-of-position springs to be broken when the control rod is fully withdrawn; and (3) the potential for a broken spring to cause the control rod to jam." This point (3) evidently includes jamming when a rod is signaled to drop or enter the fuel zone in response to an anticipated operating transient such as a turbine stop, high steam generator water level, loss of feedwater heater, recirculation pump trip, high flux signal, or main steam isolation valve closure.

^{2/} Notice No. 85-38, page 2.

Common mode failures are of great concern if they may compromize the automatic reactor protection system of a PWR. A common mode failure in an automatic reactor protection system was found at the Kahl (VAK) reactor, a Boiling Water Reactor, in July of 1965. There a bonding agent on scram relays became sticky after two weeks of use and a "routine test revealed that there had been a period of time in which SCRAM would not have been initiated if it had been required. The concern here is that in the interval required to stop fissioning through the redundant means available, the transient excess reactivity in the core will result in local fuel melting. The possibility of two adjacent control rods failing to insert, while somewhat remote in a two rod insertion failure due to GRDM jamming, would cause the most severe fuel melting with that level of rod insertion failure.

It is evident from Notice No. 85-38, that the springs may break or relocate in an CRDM in any of the B. & W. plants subject in this Petition/Request, and evidently no inspections for broken or dislocated springs which might jam the descent of a control rod into a PWR core have been made in the current operating B. & W. plants other than the <u>Davis-Besse Nuclear Plant</u>. Nor is it, in view of the conditions found at that plant, an unreasonable suspicion that an upcoming SCRAM (one prior to the next scheduled outage) may well produce a more than one rod out of the

^{2/&}quot;Technical note: The Kahl Relay Common Mode Failure", Nuclear Safety, Vol. 20(5), Sept-Oct. 1979, pp. 579-81.

core situation. It is a sensible caution to realize two or more rods stuck out of the core in a severe operating transient might well produce a local fuel melt particularly if the rods are contiguous or nearly so.

While true a boron introducing system may be expected available as a back up to the SCRAM system, General Design Criterion 26(10 CFR 50, Appendix A, Criterion 26) would appear to require both these systems, (SCRAM and back-up) be fully available to protect against reactivity insertion. In addition, the Criterion certainly strongly suggests that operation with one system reasonably suspected to be not fully capable of performing its full task would violate that Criterion.

Moreover, permitting continued operation of these B. & W. plants despite the jamming problem described in Notice No.85-38, would appear contrary to General Design Criterion 29 (40 CFR 50, Appendix A, Criterion 29). If these plants continue in operation the probability of the protection and reactivity control systems accomplishing their safety functions is decreased in the face of a more than one rod jammed out by CRDM parts situation as described in Notice No. 85-38. By requiring the utility owners (Licensees) of the aforementioned B. & W. plants to eliminate this cause of jamming would bring the plants in closer compliance with General Design Criterion 29.4/

^{4/}Criterion 26 and 29 are used here in the sense that they show good practice. The subject plants were believed designed in compliance with the two criteria and it makes sense the plants should operate only while fully providing what the criteria call for for functioning plant hardware.

Conclusion

Based on the information provided in Information and Enforcement Notice No. 85-38 and other material in this Petition/Request, Petitioner hereby requests the Director of Nuclear Reactor Regulation to issue an order requiring these 5 Licensees to show cause why the nuclear plants under their control should not be shutdown until such time as an inspection (and repairs as indicated) of the Control Rod Drive Mechanisms is accomplished, be issued.

Respectfully,

John F. Doherty

SSINS No.: 6835 IN 85-38

UNITED STATES NUCLEAR REGULATORY COMMISSION OFFICE OF INSPECTION AND ENFORCEMENT WASHINGTON, D.C. 20555

May 21, 1985

IE INFORMATION NOTICE NO. 85-38: LOOSE PARTS OBSTRUCT CONTROL ROD DRIVE MECHANISM

Addressees:

All utilities with pressurized water reactor (PWR) nuclear power facilities designed by Babcock & Wilcox (B&W) and holding an operating license (OL) or a construction permit (CP).

Purpose:

This information notice is provided to alert recipients of a potentially significant problem pertaining to loose parts that can obstruct and prevent motion inside of control rod drive mechanisms. It is expected that recipients will review the information for applicability to their facilities and consider actions, if appropriate, to preclude a similar problem occurring at their facilities. However, suggestions contained in this information notice do not constitute NRC requirements; therefore, no specific action or written response is required.

Description of Circumstances:

In 1981 at the Davis-Besse Nuclear Plant. a locking spring broke in a control rod drive mechanism (CRDM) in core location (1-7) and became wedged against the control rod, preventing if from operating. The cause was not determined at that time. During the 1984 outage, the locking springs were inspected and none appeared broken or in the wrong position. On March 16, 1985, the control rod in core location (1-3) would not drop into the core on demand and had to be driven downward by control room personnel. This control rod was tested during an outage on March 21, 1985, and jammed after three cycles of operation.

Inside of this CRDM were foreign objects and a broken locking spring. The foreign objects were pieces of a set screw from the handling tool used during the 1984 outage that had lodged in the CRDM and prevented the drive screws from being disengaged. The locking spring (a flat tee-shaped device with a riveted tab) was broken at the tee and the upper rivet hole. The upper portion of the broken spring was not found and is believed to be inside of the CRDM.

Further examination of all of the mechanisms revealed a broken locking spring in core location W-5. In addition, four springs were not in their normal locking position. During operation there is no means of detecting broken springs or foreign objects in the CRDM. Exercising the control rod will allow loose pieces to move.

IN 85-38 May 21, 1985 Page 2 of 2

The most likely cause of the spring failures is that the unit went into service with some of the locking springs not in their correct position. The present assembly procedure has the maintenance technician determining that the spring is in the correct position by "feel" through a long handling tool. If this process is not successful, the reactor will be placed in operation with the spring out of position. When the control rod is fully withdrawn, an out-of-position spring will hit the inside of the torque tube cap and snap when sufficiently loaded. This was confirmed by the appearance of the spring failures which were brittle, intergranular fractures. In addition, examination of the inside of the cap showed a gouge in the tapered portion near the bottom and an indentation on the bottom surface.

Spring failures are considered to be a potential common mode failure that could affect the reactor trip function because (1) four springs at Davis Besse were found not to be in their normal position and two others were broken; (2) the likelihood for out-of-position springs to be broken when the control rod is fully withdrawn; and (3) the potential for a broken spring to cause the control rod to jam.

Ine corrective action by Davis-Besse Nuclear Plant was to replace all of the out-of-position spring assemblies and to verify by visual examination that the springs were in their correct positions. Consideration is being given to adding this verification as a regular part of the maintenance procedures. The B&W Owners Group has notified their members that there were failed locking springs at Davis-Besse in the control rod drive mechanisms.

No specific action or written response is required by this information notice. If you have any questions about this matter, please contact the Regional Administrator of the appropriate regional office or this office.

Edward/L. Jordan, Director Division of Emergency Preparedness

and Engineering Response Office of Inspection and Enforcement

Technical Contact: P. Cortland, IE

301-492-4175

Attachment: List of Recently Issued IE Information Notices

LIST OF RECENTLY ISSUED IE INFORMATION NOTICES

Information Notice No.	Subject	Date of Issue	Issued to
85-37	Chemical Cleaning Of Steam Generator At Milestone 2	5/14/85	All pressure water reactor facilities holding an OL or CP
84-55 Sup. 1	Seal Table Leaks At PWRs	5/14/85	All power reactor facilities holding an OL or CP
85-20 Sup. 1	Motor-Operated Valve Failures Due To Hammering Effect	5/14/85	All power reactor facilities holding an OL or CP
85-36	Malfunction Of A Dry-Storage, Panoramic, Gamma Exposure Irradiator	5/9/85	All licensees possessing gamma irradiators
84-52 Sup. 1	Inadequate Material Procurement Controls On The Part Of Licensees And Vendors	5/8/85	All power reactor facilities holding an OL or CP
85-35	Failure Of Air Check Valves To Seat	4/30/85	All power reactor facilities holding an OL or CP
85-34	Heat Tracing Contributes To Corrosion Failure Of Stainles Steel Piping	4/30/85 s	All power reactor facilities holding an OL or CP
84-84 Rev. 1	Deficiencies In Ferro- Resonant Transformers	4/24/85	All power reactor facilities holding an OL or CP
85-33	Undersized Nozzle-To-Shell Welded Joints In Tanks And Heat Exchangers Constructed Under The Rules Of The ASME Boiler And Pressure Vessel Code	4/22/85	All power reactor facilities holding an OL or CP
85-32 ·	Recent Engine Failures Of Emergency Diesel Generators	4/22/85	All power reactor facilities holding an OL or CP

OL = Operating License CP = Construction Permit