								- FU			REVISI	ON ·
			C	ERTIFIC	ATION O	F ENGI	NEERING	G CÁLCI	ULATION			
ST	ATION A		NUMBER	-0	conee	2	Unit	, ا د	2, +.3	-		
ТІТ		CALCULA		Room	Hert-	<u>чр (</u>	Falcul	- tion	for	Station	B I	
<u> </u>	· · ·				· · · · ·	, 					D/q	<u>cka</u>
FORM 101.1 REVISION 1 CERTIFICATION OF ENGINEERING CALCULATION STATION AND UNIT NUMBER Ocease Units 1,2,3 TITLE OF CALCULATION STATION AND UNIT NUMBER Ocease Units 1,2,3 TITLE OF CALCULATION CALCULATION NUMBER OCEASE Units 1,2,3 TITLE OF CALCULATION CALCULATION NUMBER Ocease Units 1,2,3 TITLE OF CALCULATION ORIGINALLY CONSISTING OF: PAGES THROUGH 4/3 TOTAL MICROFICHE ATTACHMENTS TOTAL MICROFICHE ATTACHMENTE MAD CONDITION THE I CALCULATION/ANALYSIS YES ID NO M THESE ENGINEERING CALCULATION SOLED ON THE OLICENTIFY THAT THE ABOVE <td< td=""></td<>												
OR	IGINALL	Y CONSIS	STING OF						· · · · ·		· · · · ·	
PAC	GES	. /		-		T 1 11		4	2		•	
TOT				5.			HOUGH		<u> </u>	· · · · · · · · · · · · · · · · · · ·		
TOT		IMES	1	TVDC		IOIAL M	IICROFIC	HE ATTAC	HMENTS			
		011123	· · ·		TCALCUL	_ATION/A	NALYSIS	YES	NO			
TUC				TYPE	I REVIEW	FREQU						
EST,	ABLISH	ED PROC	G CALCU	LATIONS (COVER Q				IS. IN ACC	ORDANC	E WITH	
CAL	CULATI	ON HAS B	BEEN ORI	GINATED,	CHECKE	D OR API	PROVED	AND I CEI AS NOTEI	RTIFY TH D BELOW	AT THE A	BOVE	
ORIC	GINATED	ву 🛵	1 0. A	eming -	/DX	Havel	D	ATE 6	-16-9:	2/11	6 9 -	
CHE	CKED B	Y	RS	Lyta			Ū		6/24/9			
APP	ROVED	BY	SZ)	2ucher	<u> </u>		0		(3 - 1) = -1	52	. <u> </u>	
							U/	AI C				
IŞSU	ED TO 1		AL SERVI	CES DIVIS								
ISSU RECI	IED TO T EIVED B		AL SERVIO	CES DIVIS			D/	ATE				
ISSU RECI VICF	IED TO 1 EIVED B ROFICHE	ECHNICA Y TECHN	AL SERVIO IICAL SER MENT LIS	CES DIVIS RVICES DI	SION VISION		D/ D/	ATE				
ISSU RECI MICF		ECHNICA Y TECHN E ATTACH	AL SERVIO IICAL SEF MENT LIS		SION VISION 	SEE	D/ D/ FORM 101	ATE ATE 1.4				
ISSU REC MICF	EIVED B ROFICHE CALCL	ECHNICA Y TECHN ATTACH	AL SERVIO		SION VISION X No ACHMENTS (SEE Vol)	D/ FORM 101	ATE ATE I.4 JMES	ORIG	СНКД	APPR	ISS
ISSU RECI MICF IV. D.	IED TO T EIVED B ROFICHE CALCL REVISED	ECHNICA Y TECHN E ATTACH ILATION PAG DELETED	AL SERVIO IICAL SER MENT LIS IES (VOL) ADDED		SION VISION No ACHMENTS (DELETED	SEE VOL) ADDED		ATE ATE I.4 JMES ADDED	ORIG	CHKD DATE	APPR DATE	ISS DA REC DA
ISSU RECI VICF	JED TO T EIVED B ROFICHE CALCL REVISED	ECHNICA Y TECHN E ATTACH JLATION PAG DELETED	AL SERVIO IICAL SER MENT LIS IES (VOL) ADDED		SION VISION No ACHMENTS (DELETED	SEE VOL) ADDED		ATE ATE I.4 JMES ADDED	ORIG DATE	CHKD DATE	APPR DATE	ISS DA RE(DA
ISSU RECI MICF	JED TO T EIVED B ROFICHE CALCL REVISED	ECHNICA Y TECHN E ATTACH JLATION PAG DELETED	AL SERVIO IICAL SER MENT LIS IES (VOL) ADDED		SION VISION No ACHMENTS (DELETED	SEE VOL) ADDED	D/ FORM 101 VOLU DELETED	ATE ATE I.4 JMES ADDED	ORIG DATE	CHKD DATE	APPR DATE	ISS DA REC DA
	JED TO T EIVED B ROFICHE CALCL REVISED	ECHNICA Y TECHN E ATTACH JLATION PAG DELETED	AL SERVIO		SION VISION ACHMENTS (DELETED	SEE VOL) ADDED		ATE ATE I.4 JMES ADDED	ORIG DATE	CHKD DATE	APPR DATE	ISS DA REC DA
	JED TO T EIVED B ROFICHE CALCL REVISED	ECHNICA Y TECHN E ATTACH JLATION PAG DELETED	AL SERVIO		SION VISION ACHMENTS (DELETED	SEE I VOL) ADDED	FORM 101	ATE ATE I.4 JMES ADDED	ORIG DATE	CHKD DATE	APPR DATE	
	JED TO T EIVED B ROFICHE CALCL REVISED	ECHNICA Y TECHN E ATTACH JLATION PAG DELETED	AL SERVIO		SION VISION ACHMENTS (DELETED	SEE I VOL) ADDED		ATE ATE I.4 JMES ADDED	ORIG DATE	CHKD DATE	APPR DATE	ISS DA REC DA
	JED TO T EIVED B ROFICHE CALCL REVISED	ECHNICA Y TECHN E ATTACH JLATION PAG DELETED	AL SERVIO		SION VISION ACHMENTS (DELETED	SEE I VOL) ADDED	FORM 101	ATE ATE I.4 JMES ADDED	ORIG DATE	CHKD DATE	APPR DATE	
	JED TO T EIVED B ROFICHE CALCL REVISED	ECHNICA Y TECHN E ATTACH JLATION PAG DELETED	AL SERVIO		SION VISION ACHMENTS (DELETED	SEE I VOL) ADDED	D/ FORM 101 VOLU DELETED	ATE ATE I.4 JMES ADDED	ORIG DATE	CHKD DATE	APPR DATE	
	JED TO T EIVED B ROFICHE CALCL REVISED	ECHNICA Y TECHN E ATTACH JLATION PAG DELETED	AL SERVIO		SION VISION ACHMENTS (DELETED	SEE I VOL) ADDED	D/	ATE ATE I.4 JMES ADDED	ORIG	CHKD DATE	APPR DATE	
	JED TO T EIVED B ROFICHE CALCL REVISED	ECHNICA Y TECHN E ATTACH JLATION PAG DELETED	AL SERVIO		SION VISION ACHMENTS (DELETED	SEE I VOL) ADDED	FORM 101	ATE ATE I.4 JMES AODED	ORIG DATE	CHKD DATE	APPR DATE	
	JED TO T EIVED B ROFICHE CALCL REVISED	ECHNICA Y TECHN E ATTACH ILATION PAG DELETED	AL SERVIO		SION VISION ACHMENTS (DELETED	SEE I VOL) ADDED	D/	ATE	ORIG DATE	CHKD DATE	APPR DATE	
		ECHNICA Y TECHN E ATTACH JLATION PAG DELETED	AL SERVIO		SION VISION ACHMENTS (DELETED	SEE I VOL) ADDED	FORM 101	ATE ATE I.4 JMES ADDED	ORIG DATE	Снкр Date		
		ECHNICA Y TECHN E ATTACH JLATION PAG DELETED	AL SERVIO		SION VISION ACHMENTS (DELETED	SEE I VOL) ADDED	D/	ATE ATE I.4 JMES ADDED	ORIG DATE	Снкр Date		
		ECHNICA Y TECHN E ATTACH JLATION PAG DELETED	AL SERVIO		SION VISION ACHMENTS (DELETED	SEE I VOL) ADDED	D/ FORM 101 VOLU DELETED	ATE ATE I.4 JMES ADDED	ORIG DATE	Снк D DATE	APPR DATE	

OSC-4747 Page / of 43 6-11-92 *104*

1.0 <u>PURPOSE</u>

The purpose of this calculation is to determine the temperature rise in the Control, Electrical Equipment, Cable and Control Battery Rooms at the Oconee Nuclear Station during a station blackout. The reliability of equipment and controls in these areas could become a problem if the temperature rises are excessive.

2.0 <u>QA CONDITION</u>

This calculation is QA Condition 1. The operation of certain equipment and controls within these areas is necessary to bring the units to a safe shutdown during a station blackout.

3.0 <u>DESIGN METHOD</u>

The temperature rise within a room is due to more energy being generated within a room than is being conducted into and through the boundaries of the room. This excess energy is absorbed by the air (this neglects energy absorbed by equipment within the room) raising the temperature of the room. Energy being generated within a room is determined from the total kilowatts of energy being used by equipment which continues to operate within the room during a station blackout. (In the case of the Control Rooms, this value is higher during the first 30 minutes than during the next 3.5 hours due to load shedding.) Areas surrounding the room are assumed to be at a constant temperature and standard heat transfer equations are used to determine the amount of heat energy conducted through the walls. Energy is also absorbed by the walls and ceiling of the room.

To be consistent with NUMARC 87-00 (Reference 8.3), the floor is assumed to absorb no energy.

The following method is used to determine the temperature rise within a room during a station blackout.

Step 1: Determine the amount of energy available for heating up air mass in room.

The general heat transfer equation is:

 $Q_{air} = Q_{gen} - Q_{out} - Q_{conc}$

OSC-4747 Page 2 of 43 6-11-92 /DH

where:

 Q_{air} = energy absorbed by the air in the room (Btu) Q_{gen} = energy generated within the room (Btu)

- Q_{out} = energy transferred out of the room by conduction (Btu)
- Q_{conc} = energy absorbed by the walls and ceiling (Btu)

The amount of energy being generated within the room is:

 \dot{Q}_{qep} =3.41(Btu/hr·W) · (ElectricalEquipmentHeatLoad(Watts))

Step 2: Determine the amount of energy conducted through the room boundaries.

The equation representing the energy being transferred through the walls is:

$$\dot{Q}_{out} = \sum UA\Delta T = T_{air} \Sigma UA - \Sigma UA T_{surr}$$
, Btu/hr

where:

U = the overall heat transfer coefficient for the boundary (Btu/hr·ft².°F)

A = the surface area of the boundary (ft²)

 ΔT = difference between the room temperature (T_{air}) and the assumed temperatures of the surrounding areas (T_{surr}).

Step 3: Determine the final steady state room temperature $(T_{air,ss})$.

The final steady state room temperature can be determined by setting

 $\dot{Q}_{gen} = \dot{Q}_{out}$

or:

$$T_{air,ss} = \frac{\dot{Q}_{gen} + \Sigma UAT_{surr}}{\Sigma UA}$$

OSC-4747 Page 3 of 43 6-11-92 //DH

If this final steady state room temperature is less than the allowable maximum room temperature then the calculation can be ended. If not, continue on to the next step.

step 4: Assume an average room air temperature for the desired time interval (Tair,avg(assumed)).

step 5: Determine the amount of energy absorbed by the room boundaries (ie. walls and ceiling) (Q_{conc}).

The amount of energy absorbed by the boundaries is a function of the following:

- a) Boundary (concrete) volume (ft³)
- b) Concrete conductivity (1.0 Btu/hr·ft·°F) Reference 8.1.

c) Thermal diffusivity (0.036 ft²/hr) Reference 8.1.

d) Air film convection coefficient (1.47 Btu/hr·ft²·°F for walls and 1.64 Btu/hr·ft²·°F for ceiling)

e) Temperature difference between the boundary and the average room air temperature. (The initial boundary temperature will be assumed to be the average of the initial room temperatures on each side of the boundary.)

f) Length of time at which the energy transfer takes place. (hr)

Knowing these values, the amount of energy absorbed by the boundaries can be determined graphically (Reference 8.2). This graph uses a value for L which is equal to 1/2 the wall/ceiling thickness. For the case where a wall is constructed of hollow concrete blocks, L is set to one inch which is approximately the shell thickness of the block.

The maximum amount of energy which the concrete boundary can absorb (Q_0) can be determined from:

 $Q_o = \rho_{conc} V_{conc} C_{p, conc} \Delta T$

where:

 $\rho_{\rm conc}$ = density of concrete (140 lb/ft³)

OSC-4747 Page 4 of 43 6-11-92 *NDH*

 V_{conc} = volume of concrete (ft³)

 $c_{p,conc}$ = heat capacity of concrete (0.20 Btu/lb·°F) ΔT = assumed average room temperature - initial boundary temperature (°F)

The graph in Reference 8.2 will yield a value of Q/Q_o which is the amount of energy absorbed by a wall as a percent of the maximum possible absorption. This graph assumes that an equal amount of energy is being transferred from each side. To take into account heat transfer from one room into the wall it is assumed that

$$Q_{conc} = \frac{Q/Q_o}{2} (Q_o)$$

Step 6: Determine the room air temperature at the end of the time interval.

With Q_{gen} , Q_{out} , and Q_{conc} known, Q_{air} can be determined from the equation in step 1. The room temperature at the end of the specified period of time can be found from the following equation.

$$T_{air} = \frac{Q_{air}}{\rho_{air} V_{air} C_{p,air}} + T_{air,i}$$

where:

 Q_{air} = energy absorbed by the air in the room (Btu) ρ_{air} = density of air (lb/ft³) V_{air} = volume of room (ft³) $c_{p,air}$ = heat capacity of air (Btu/lb·°F) T_{air} = room air temperature (°F) $T_{air,i}$ = initial room air temperature (°F)

To account for part of the room volume taken up by equipment, a factor of 80% of the internal room volume will be used to determine the amount of air in the room.

Step 7: Determine the function which describes the room air temperature between the start of the blackout event and the final steady state air temperature.

OSC-4747 Page 5 of 43 6-11-92 /0#

For the time between the start of the blackout event and before the room reaches a steady state condition, the temperature of the room can be determined by the following method.

From the equation in step 2 it can be seen that

 $\frac{dQ_{air}}{dt} = f(T_{air,ss} - T_{air})$

because when $T_{air} = T_{air,ss}$; $dQ_{air}/dt = 0$.

On the other hand, the equation in step 6 shows that

$$\frac{dQ_{air}}{dt} = f\left(\frac{dT_{air}}{dt}\right)$$

Setting these last two equations equal to each other gives

$$C_{a}(T_{air,ss}-T_{air})=C_{b}(\frac{dT_{air}}{dt})$$

or.

$$\frac{dT_{air}}{T_{air,ss} - T_{air}} = dt \cdot \frac{C_a}{C_b}$$

Setting $c_1 = c_b/c_a$ where c_1 is a constant which controls the rate of temperature change, and integrating both sides gives:

$$\int \frac{dT_{air}}{T_{air,ss} - T_{air}} = \int \frac{dt}{c_1}$$

Integrating the above equation yields:

OSC-4747 Page & of 43 6-11-92

10H

 $-\ln(T_{air,ss} - T_{air}) = \frac{t}{C_1} + C_2$

where:

 c_2 = constant of integration

At t = 0, $c_2 = -\ln(T_{air,ss}-T_{air,i})$

This yields an equation of the form:

$$\ln \frac{(T_{air,ss} - T_{air,i})}{(T_{air,ss} - T_{air})} = \frac{t}{c_1}$$

Inserting the value of T_{air} from step 6 allows one to solve for $c_1. \label{eq:classical_state}$

$$c_1 = \frac{t}{\ln \frac{(T_{air,ss} - T_{air,i})}{(T_{air,ss} - T_{air})}}$$

Step 8: Determine the calculated average room temperature for the time period.

At this point the average air temperature over the time period can be calculated by the equation:

 $T_{air,avg} = \frac{\int_{0}^{t} T_{air} dt}{\int_{0}^{t} dt}$

After integrating the above equation it becomes the following:

 $T_{air,avg} = \frac{T_{air,ss}(t) + (T_{air,ss} - T_{air,i})(c_1)(e^{\frac{-t}{c_1}} - 1)}{t}$

OSC-4747 Page 7 of 43 6-11-92 /04

The calculated average room temperature is then compared to the assumed room temperature selected in step 4. If they are more than 0.5°F apart a new average room temperature is assumed and the process is repeated beginning with step 5.

This iterative process is done using the software EXCEL. Output from this program is included in section 9.0 of this calculation. The terms used in the EXCEL spreadsheet are as follows:

Tair, avg(assumed) = assumed average room air temperature Time = Length of heat-up period Tair, ss = Steady state room air temperature at time = ∞

Tair, i = Initial room air temperature at time = 0

Qgen = Internal heat generation

Qout = Heat conducted through the walls

Qair = Heat absorbed by the air

Qconc(total) = Heat absorbed by the concrete walls and ceiling.

Tair(t) = Final room air temperature at end of the time period calculated from step 6 of Design Method

C1 = Constant calculated from step 7 of Design Method

Tair,avg(calc) = calculated average room air temperature from step 8 of Design Method (Used to check against assumed average room air temperature)

4.0 <u>CODES AND STANDARDS</u>

4.1 NUMARC 87-00, "Guidelines and Technical Bases for NUMARC Initiatives Addressing Station Blackout at Light Water Reactors"

5.0 DESIGN INPUTS

ANSI N45.2.11 has been reviewed, and all applicable design inputs are documented in the appropriate sections.

6.0 FSAR CRITERIA

Section 9.4.1 of the FSAR covers the Control Room Ventilation System, however its contents do not apply to this calculation.

7.0 ASSUMPTIONS

7.1 See attachment 2 for assumed temperatures of room boundaries and surrounding areas.

OSC-4747 Page 8 of 43 6-11-92 /DH

- 7.2 Floors do not absorb any energy.
- 7.3 Equipment within the room does not absorb any energy.
- 7.4 No energy passes though doorways.
- 7.5 Volume of air within a room is 80% of internal room volume to account for space taken up by equipment.
- 7.6 Sheetrock within the Control Rooms does not absorb energy.
- 7.7 Load shedding within the Control Rooms takes place 30 minutes after the start of a station blackout.

8.0 <u>REFERENCES</u>

- 8.1 ASHRAE Handbook, Fundamentals, 1989, Chapter 22, Table 4.
- 8.2 Holman, J. P., <u>Heat Transfer</u>, 1976, Fig. 4-16.
- 8.3 NUMARC 87-00, Guidelines and Technical Bases for NUMARC Initiatives Addressing Station Blackout at Light Water Reactors.
- 8.4 Letter from J H Bryan to B J Dolan dated June 11, 1992 specifying electrical equipment heat loads (Attachment 1).
- 8.5 Drawing 0-1024-03, Unit 1 Electrical Equipment Room
- 8.6 Drawing 0-1024-09, Unit 3 Electrical Equipment Room
- 8.7 Drawing 0-1025-02, Unit 1 Cable Room
- 8.8 Drawing 0-1025-07, Unit 3 Cable Room
- 8.9 Drawings 0-1026-02,03 Unit 1 & 2 Control Room
- 8.10 Drawing 0-1026-05 Unit 3 Control Room
- 8.11 OSSD-0210.16-09 Control Room and Administration Building Air Conditioning System Description
- 8.12 OSC-592, Oconee 1, 2, & 3 Mechanical Calculations
- 8.13 OSC-615, Containment Temperature Rise During Hot Shutdown and Loss of A. C. Power

OSC-4747 Page 9 of 43 6-11-92 /04

8.14 Note from L. S. Underwood on hydrogen generation of batteries (Attachment 3)

9.0 <u>CALCULATION</u>

9.1 Control Rooms

The calculations which follow are based on full station blackout loads for the first 30 minutes into the event. At this time, all nonessential loads are manually stripped thus greatly reducing the internal heat generation and the corresponding peak temperature. Satisfactory temperatures cannot be maintained in the Control Rooms without load stripping.

9.2 Cable and Electrical Equipment Rooms

The calculations which follow for the Cable and Electrical Equipment Rooms are based on full station blackout loads. Even though reference 1 indicates that load stripping can be accomplished in these rooms, it is not necessary for obtaining satisfactory temperatures.

9.3 Control Battery Rooms

There is no internal heat generation for these rooms during a station blackout.



•

Station_		Unit	Rev	File N	lo	Sheet <i>[t</i>]	Of <u></u> 43
	·····			Ву⁄	OKIE	Date 🤇	16/92
Prob No	. <u> </u>	-4747	Check	ed By		Date	
$- \underline{\nu}$	4175142	CONTROL R	on (T = T	74 ° INT	ME Erual = 0-30 n	NINUTES
		5/1 / -					
	9 gen = (256 7 CBTU/	Co. Arus	= 128287	7 BTI	into event.	/
¥	Q =	EUAST = -	The SUA	- EUAT			
			RESISTANCE			RTU	
SECTION	THICKNESS	Are was	AIR Gyps	um CARPET F	ACOUST AIR UG	-A or) ACH	2) Tour (OF
10-	42"	.68 3.36	.68 .50		68 0.	168 373	95
-16	42	- 68 3.30				212 341.	8 95
<u>-2a</u>	121		.68 .50		68 0.	28/ 373	
- 20	//2//	-68 -76	-68 -			431 341.	8 110
26	47"	-68 3.36	.68 -		0.	212 150.	2 9
4a	42"	.68 3.36	.68 .54	<u> </u>	68 0.	168 80	. 95
46	42"	.68 3.36	.68 -		o.	212 73.3	95
5-4	42"	.68 3.36	.68 .50		68 0.	168 373	120
56	42"	-68 3.36	.68 -		0.	212 341.8	120
6a	42"	-68 3.36	.68 .5		68 0.	68 373	120
66	42"	.68 3,36	.68 -		0.	212 34/08	120
-7a-	42"	.68 3.36	-68 -56		68 0.	168 80	95
76	42"	68 3,36	- 88 -		0,	212 73.3	95
80	.4/2 	.68 3,30	10 -		0	168 169	9,
9.	12."	68 96	.68 .56	-	68 0.	281 373	110
96	. /2"	.68 .%	.68 -	_	6.	431 341.8	110
10a	42"	.68 3.36	.68 .56		68 0.	168 373	25
106	42"	.68 3,36	.68 -		0.	212 34/.8	95
Fior	. 12"	.92 .96		1.23	92 0.	248 8/13	100
CEILING	g"	.61 .64	.61 -	. – 2	2.50 .61 0.	201 8/13	95
				·			-1 - 4 1 0
*	refere 7	to unil sectio	for f	on to drop	tin ceiling	2 Sibiere atte	chment 4 for
	ne/jers 7	of wall seels	n por de	open cail	ing po not	Jaiagram of	up !! section

Unit	Rev	File No	Sh	eet_//Of4
······	By		D	ate6/16/92
1	_ Checked By	/	D	ate
			. ,	-
- 95) + (.21	2)(341.8)(TAIN	- 95) + (.	281) (373) (TAI	
ne-110) + (.16	8) (164) (TAIR	- 95) + (.;	212) (156.3) (TA	r - 95
1e- 95) + (-2	12)(72.3)(TAIR	- 25 + (./	$(8)(373)(T_{A})$	e-120)
j ₁ − /20) + (.6	(8)(373)(TAIR	-120) 4 (021-	:12)(341.8) (TA	120)
- 95) + (.2	12)(73.3)(TAIR	-25] + (0/0	$(8)(164)(7_{0})$	1e = 25]
10-95) # (12	$(373)(T_{AH})$	e-110) + (.)	431) (34/08) (7	AIR -116
(n - 95) + (n - 2)	212/(341.8)(T _{AH}	$e^{-7\Gamma} + (e^{-2})$	248) (8/13) (7	AIR=100)
Ale= 15)				
404111	and le			
787636	BIOIN			
				*
, + EUA TSU,	<u> </u>			
204				
575 + 48	1636			
784/				
F				
		·		
ry concret	z i		· · · · · · · · · · · · · · · · · · ·	
			-	
	1 4 + 1		1 1-1-	
pread shie	t that for	Cours for	- Calculation	
m /2	Mal abre	y ion ari	they of which	uste.
2/2	= +++1	7. 2. 0	0 X 80	all in the second
0000000	= 10.000	213		
	Unit Unit = 95) + (.2) = 95	Unit Rev. By Unit Rev. By Checked By Checked By $(-2)^{2} + (.212)(341.8)(7)$ $(-2)^{2} + (.212)(341.8)(7)$ $(-2)^{2} + (.212)(72.3)(7)$ $(-2)^{2} + (.212)(72.3)(7)$ $(-2)^{2} + (.212)(7)(7)(7)(7)(7)(7)(7)(7)(7)(7)(7)(7)(7)$	$ \underbrace{ \text{Unit} } \text{Rev.} File No.} \\ File No.} \\ By \\ A \\ A \\ \hline \\ Checked By \\ \hline \\ \hline \\ PS) + (.212)(241, 2)(T_{AIR} - 9s) + (. \\ (.48)(144)(T_{AIR} - 9s) + (. \\ (.48)(144)(T_{AIR} - 9s) + (. \\ (.48)(144)(T_{AIR} - 9s) + (. \\ (.48)(273)(T_{AIR} - 160) + (. \\ (.58)(273)(T_{AIR} - 9s) + (. \\ (.58)(273)(T_{AIR} - 160) + (. \\ (.58)(273)(T_{AIR} - 9s) $	$ \underbrace{ \text{Unit} } \text{Rev.} File No.} \text{Sh} \\ \underline{ \text{By} } \text{A} \text{K} \text{H} \\ \underline{ \text{Checked By} } \text{D} \\ \underline{ \text{Checked By} } \text{Checked By} \\ \underline{ \text{Checked By} \\ \underline{ \text{Checked By} } \text{Checked By} \\ \underline{ \text{Checked By} \\ \underline{ \text{Checked By} } \text{Checked By} \\ \underline{ \text{Checked By} \\ \underline{ \text{Checked By} \\ \underline{ \text{Checked By} } \text{Checked By} \\ \underline{ \text{Checked By} \\ \text{$

			•		• •				_		
Unit 1&2 (Control Ro	om(30 min)	-	Tair,avg	(assumed) =	95.3F		Time =	0.5hr		
								Tair,ss =	164F		
								Tair,ss-Tair,i =	90F		
			h'AT	he		4	Twall,i -	•			
Section	L	⁺ h	K2	K	Volume	Twall,i	Tair,avg	Qo	Q/Qo	Q/Qo/2	Qconc
1	1.75	1.47	0.039	2.57	2503	85	10.3	721865	0.01	0.005	3609
2	0.5	1.47	0.039	0.74	715	92	3.3	66066	0.05	0.025	1652
3	1.75	1.47	0.039	2.57	1099	92	3.3	101548	0.01	0.005	508
• 4	1.75	1.47	0.039	2.57	536	85	10.3	154582	0.01	0.005	773
. 5	1.75	1.47	0.039	2.57	2503	97	-1.7	-119143	0.01	0.005	-596
6	1.75	1.47	0.039	2.57	2503	97	-1.7	-119143	0.01	0.005	-596
7	1.75	1.47	0.039	2.57	536	85	10.3	154582	0.01	0.005	773
8	1.75	1.47	0.039	2.57	1099	92	3.3	101548	0.01	0.005	508
9	0.5	1.47	0.039	0.74	715	92	3.3	66066	0.05	0.025	1652
10	1.75	1.47	0.039	2.57	2503	85	10.3	721865	0.01	0.005	3609
floor	0.5	0.465	0.004	0.23	8113	87	8.3	1885461	0 ·	0	0
ceiling	0.33	1.64	0.048	0.54	5355	85	10.3	1544382	0.07	0.035	54053

Qconc(total) = 65945

Qgen = 128287 Qout = -11368

Qair = 73710 .

Tair(t) = 113F

C1 = 0.8803

Tair,avg(calc) = 95.3F

J. 050-5/2 / 21. 192 240H

Static	on_					•			Ur	nit		_ R	lev.			File	e No	.				<u> </u>	_SI	heet	t	13	Of	
ອບມີເອ	:01_														By.			ÛK	ΪÆ				C	Date		6/10	19	2
Prob	No	•		0	SC	- L	174	17_				Cł	necl	(ed	By								_ [Date	;	1.	,	
									Τ	1	1								Τ.	İ								
	Ur	17	ŝ	1 \$ 0		Cor	TI	UL	R	bom		2	AIR	=	74	F)		_	TNT	m E ERU	AL.	2	0-	45	mic	ίστ	<u> </u>	
				-							F			<u> </u>														
		φ	en :	∔ ∙	256	57	7 <u>5</u> 17	BTU BTU	<u> k</u>		1	er.	Fe 3	st.	30	m to	inu	1	Li In	nlo	1e	veri	z)					-
		999	len-		76,														7/1									
	• •	Ģ	gen	=	(2	<u> </u>	75	BT	名)	Lo.	<u></u>	form)	+ 1	96	619	BT	7 h.	¥0	25	hor	he)						
		9	gen	=	1	72,	44	2	187	tu																	<u> </u>	
4		ġ.		=	48	47	T		-	482	165	6	BT	0/4	h		<u>_</u> a	s	Je	Ine)							
	•													/			 				[
	• •			 			99e	~. ⁻	ج ج	107	+750) 2rr								· .				 .				
			A	e, s.	\$			٤	UA																			
		 	-		<u> </u>	[z	56,-	75	2	<u>+)+</u>	26	61	16	<u>(</u>	+	484	65	6										L
			AIR	<u>, 55</u>	-		<u> </u>	 			481	17	 					<u> </u>										-
		-	TAIR	55.	=		14	2	°F	1																		
										T a 															 			
C)	Δ.	1	1																					
	er	geg J	al	Ko	100	d.	rt.	. <u>c</u>	The	lel		•																
			e.p	L.	to	2	te	sp	he	ad	sto	et	t	at	Po	200	une	A		cal	aul	t	on	9	7	AIR	(t)_
			fp	t	tin	2-	in_	Ħ	5-1	Rea	t	ab	con,	E L	n	al	fili	ty.	of	200	in	ret	p.		·			
	4		Cor	trol		INTO		Jol.	me	=	= >	bla	1s	100rs	2	olu	mo	x		80			1	Au	nia		2.12	2
										=		25,0	200	4	23													
						 						•																
										<u> </u>														· ·				
							·																					
																 .						1						
						ļ				<u> </u>																		
							[.												.						·			

Unit 1&2 Co	ontrol Roor	n (45 minu	tes)	Tair,avg	(assumed) =	97.3F	•	Time =	0.75hr		-
- i								Tair,ss =	151F		
					·	· ·		Tair,ss-Tair,i =	77F		
			6.00	42			Twall,i -				
Section	L	h		ĸ	Volume	Twall,i	Tair,avg	Ωο	Ω/Ωο	Q/Qo/2	Qconc
1	1.75	. 1.47 .	0.058	2.57	2503	85	12.3	862033	0.01	0.005	4310
2	0.5	1.47	0.058	0.74	715	92	5.3	106106	0.07	0.035	3714
3	1.75	1.47	0.058	2.57	1099	92	5.3	163092	0.01	0.005	815
4	1.75	1.47	° 0.058	2.57	536	85	12.3	184598	0.01	0.005	923
5	1.75	1.47	0.058	2.57	2503	97	0.3	21025	0.01	0.005	105
6	1.75	1.47	0.058	2.57	2503	97	0.3	21025	0.01	0.005	105
7	1.75	1.47	0.058	2.57	536	85	12.3	184598	0.01	0.005	923
8	1.75	1.47	0.058	2.57	1099	92 `	5.3	163092	0.01	0.005	815
9	0.5	1.47	0.058	0.74	715	92	5.3	106106	0.07	0.035	3714
10	1.75	1.47	0.058	2.57	2503	85	12.3	862033	0.01	0.005	4310
floor	0.5	0.465	0.006	0.23	8113	87	10.3	2339789	0	. 0	- 0
ceiling	0.33	1.64	0.073	0.54	5355	85	12.3	1844262	0.07	0.035	64549

Oconc(total) = 84284

 $(\tilde{\gamma})$

L h L h

1-1 - 1-1-1-3

Ogen = 152442

Qout = -9782

Qair = 77940

Tair(t) = 115 F

C1 = 0.97412

Tair,avg(calc) = 97.2F

Form 00184 (R4-88)

_Unit_____ Rev.____ File No.____ Sheet 15 Of 43 Station. Subject ____ NKH ____ By____ Prob No. 0.5C-4747 Checked By_____ Date _____ TIME = 0-60 MINUTES Are = 74 °F) UNITS 1 + 2 CONTROL Room 258, 575 BTU/hu event) Jen Jen Op pist 30 minutes for 30 minutes - 4 for 76,619 BTO/ A Ξ (253, 575 BTV R.) (0.5 hours) + (96,619 BTV Co. Show • 176,597 BTU 9 gen ¥ 484656 BTO/A 4847 TAIR (ax 9 Dut gen + EUA TSUr TAIR, SS. SUA (256, 575 et (2) + 96, 619 et (2) + 48465C TAIR, 55. 4847 TAIR, SS = 136 °F Energy aborbed by concrete about that follows calculation of for 2 TAIR (t) of concrete hat almonstron the refer Volumo = tolo Control 8.12 x .80 2 3 losbod

Unit 1&2 C	ontrol Ro	om(1 hr)		Tair,avg	(assumed) =	94.53F		Time =	1hr		· _
								Tair,ss =	144F		
								Tair,ss-Tair,i =	70F		
			h2 AT	46			Twall,i -				
Section	L	h.		k	Volume	Twall,i	Tair,avg	Qo	Ω/Ωο	Q/Qo/2	Qconc
1	1.75	1.47	0.078	2.57	2503	85	9.53	667900.52	0.02	0.01	6679
2.	0.5	1,47	0.078	0.74	715	92	2.53	50650.6	0.1 ·	0.05	2533
3	1.75	1.47	0.078	2.57	1099	92	2.53	77853.16	0.02	0.01	779
4	1.75	1.47	0.078	2.57	536	85	9.53	143026.24	0.02	0.01	1430
5	1.75	1.47	0.078	2.57	2503	97	-2.47	-173107.48	0.02	0.01	-1731
6	1.75	1.47	0.078	2.57	2503	97	-2.47	-173107.48	0.02	.0.01	-1731
7	1.75	1.47	0.078	2.57	536	85	9.53	143026.24	0.02	0.01	1430
· 8	1.75	1.47	· 0.078	2.57	1099	92	2.53	77853.16	0.02	0.01	779
9	0.5	1.47	0.078	0.74	715	92	2.53	50650.6	0.1	0.05	2533
10	1.75	1.47	0.078	2.57	2503	85	9.53	667900.52	0.02	0.01	6679
floor	0.5	0.465	0.008	0.23	8113	87	7.53	1710544.92	0	0	0
ceiling	0.33	1.64	0.097	0.54	5355	85	9.53	1428928.2	0.16	0.08	114314

 Ω conc(total) = 133693

50

4747

2 ° [

143

Qgen = 176597

Qout = -26469

94.6F

Qair = 69373

Tair(t) = 111F

C1 = 1.3514

Tair,avg(calc) =

DUKE POWER COMPANY

Subje	ect																				11)]							,1		
	i	•															By	'			ĽД	₩-				(Jate	;	6/1	619	2
Prob	No		_0	20		- 4	7	47						C	hec	keo	t By	/						-		(Date)	<u></u>		
						T									Τ	1											<u> </u>	T		<u> </u>	
	UN	17.	5	/ ŧ	2		C	27)	TP	b	,	R	200	m	1	To		7	7	404	F)		Ta	ME	UAI	=	0	-2-	40	min	10
																															Ē
	Ę) gez	=	Z	56,	1	7	_	107	h		- (p	-	ais	t	30	2	in	ute	<u>.</u>	int	þ.	مرد	"t)			_	· 	ļ
	_Ğ	gen	3		9.6	,6	19	i L	171	h		_(1	n	30		up.	te.	4		4	An	un	L)						_	
	•									A-	, ,										0-7-13						-	_	<u> </u>	<u> </u>	+
	••	4	Ser	<u> </u>	$ \langle$	2	Ś	5	2	1	ά,	X	p.s	ho) +	4	26-	61	9	T	1)(3.5	ho	urs.					+	
•		-\$	C 0.	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~		4	6	6,	45	4	_	-13	Fe	<u>ل</u>	+		-									-		+		+	
-	-		<u> </u>			+-																			. 						-
	/									•								· 7	,				0	0				+			
		4	007	r		48	24	7_	Z _A	ne-	+	, y	48.	465	6	B	TY	K			(a	L.	Lref,	ore	 		-		· · ·		
									1			• ,		<u> </u>				-									- <u> </u>	+		+	
			T	<u> </u>			=		9	gei	2	+	-2		1 <u>4</u> .		spri	<u>-</u>										-	+	+	
		-	H	R,	55.							Z	U,	1												. .				+	
								5	25	2	17	<	BT	12	1	125	-) -	+	92	61	9 3	TY/	1/	87	A	+	48	46	56	1	$\left \right $
		1	AI	e, s	s.	Ŧ	Ì	€_		<u> </u>						18	47		14	101	/	<u> </u>			14						
																	ľ														
		,	TA	p—.		F		2	24	%	4															·				_	
				<i>C</i> ₁ .	/ S.		+-	,			=						_				 	 	ļ			ļ	_				ļ
_					ļ												<u>.</u>	·				ļ					<u> </u>	<u> </u> .		_	<u> </u>
	En	ergy		ba	nl	ed	U	lry	L_C	on	cle	te	5:					_					.			<u> </u>			·		
		[_			<u> </u>							-	ļ,										·	1	A			<u> </u>		<u> </u>
			A	<u>fe</u>		to	2	L	E.	0.	1	-	L.	22	201	7	t.	Y	P		LUN A		pr	Co	lu	la	tion	19	4-7	AIR	1
			-	lp	le	n	W	ī -	in,	2	70	<u>,</u>	Ko	at	a	<u>lbc</u>	24	٧Z	wh	2.0	pla	al.		1	con	per 1	<u>ato</u>			-	
		-+		^ _	1	1		1		5	10				5	4	4				1							1		. (<u> </u>
			(vn	110	1	R	00			24	лл	e-	=		ota		זפונ	2	<u>-1/</u> 3	Scu	me	X				$\frac{1}{1}$	хp	une.	<u>ہے</u>	
	-							· · · · ·						-					-	,				1	· · .		-	1			+
	- .								•	-					-	- <u> </u> .													1		
						1																									
																								·							
																					<u> </u>	<u> </u>		ļ			_		-		-
							1								ĺ		1	.						1							1

•

Unit 1&2 Co	ontrol Roo	m(4 hours)		Tair,avg(as	sumed) =	96.32F		Time =	4hr		
· .								Tair,ss =	129F		·
	2							Tair,ss-Tair,i =	55F		
			h'ar	42			Twall,i -	· ·			
Section	ΓL.	h	<u>k</u> *	T	Volume	Twall,i	Tair,avg	Qo	Q/Qo	Q/Qo/2	Qconc
1	1.75	1.47	0.311	2.57	2503	85	11.32	793351	0.08	0.04	31734
2	0.5	1.47	0.311	0.74	715	92	4.32	86486	0.3	0.15	12973
3	1.75	1.47	0.311	2.57	1099	92	4.32	132935	0.08	0.04	5317
4	1.75	1.47	0.311	2.57	536	85	11.32	169891	0.08	0.04	6796
. 5	1.75	1.47	0.311	2.57	2503	97	-0.68	-47657	0.08	0.04	-1906
6	1.75	1.47	0.311	2.57	2503	97	-0.68	-47657	0.08	0.04	-1906
7	1.75	1.47	0.311	2.57	536	85	11.32	169891	0.08	0.04	6796
8	1.75	1.47	0.311	2.57	1099	92 .	4.32	132935	0.08	0.04	5317
·9	. 0.5	1.47	0.311	0.74	715	92	4.32	86486	0.3	0.15	12973
10	1.75	1.47	0.311	2.57	2503	85	11.32	793351	0.08	0.04	31734
floor	0.5	0.465	0.031	0.23	8113	87	9.32	2117168	Ò	0	0
ceiling	0.33	1.64	0.387	0.54	5355	85	11.32	1697321	0.42	0.21	356437

Qconc(total) = 466265

Qgen = 466454

Qout = -71172

Qair = 71361

Tair(t) = 112F

C1 = 3.49579

Tair,avg(calc) = 96.4F

51 21 20 21 21 20 21 1999

.

Station	Unit R	lev File No	Sheet_ <u>/</u> 9_Of_'
		By/ <i>D</i> .#	Date6-16-92
Prob No. 05C-474	7 Cł	necked By	Date
Unit 1 Cable	Room ($T_{A'R,c} = 74 \circ F$	
Qgen = 140,205	Btulhr	Qgr, = 140,205 (4	Ars = 560, 820 Bry
QuIT = EUAL	$T = T_{A,R} \leq$	UA- EUATS-	
	Res: stores		
Section Thickness	Air Wall	Air U (hr ft	$\frac{1}{2}$ F A $(F + 2)$ T_{surr} $(°F$
Aux Wall 42'	,68 1.72	68	781 120
4ux his (1(black) 8	-68 1.72	68 , 32	105 95
Pen Wall (block) 8"	.63 1.72	63 .32	140 110
Pen Woll 12"	,63 ,76 ,	68	940 110
Ceiling 12'	,72 ,87 .	61 .46	2765 110
Assume no heat ?	reaster bet	hits 1	+ 2 cable rooms
Qour = (,40 * 276	5) (TAIN-10	0) + (.21 + 31)	+, 32 = 105) (TAIR - 9
+ (,46* 2765	1,32 * 140 + .	43 * 940) (TAIR	-//0)
+ (,32 + 781	$CT_{alla} = 120$		
<u> </u>	A'R 100	- 70 (/ Arr - 1)	5 7 1120 (1 AVR - 110
+ 250	(TAIR - 120	n)	
0 = = 2// (T_{1} $ D_{2}$ $-$	600 Rtu 1/	
<u> </u>			

.

Stati Subi	on_								Un	it_		_ R	lev.			File	e No	o					_SI	neet	<u> </u>	10	Of	4.
										•				-	Ву		10	1,4					C)ate	_6	-16	< - ?	72
Prob	No	•	\mathcal{O}	52	- 4	174	17					Cł	necl	ked	By								C	Date				<u>,</u>
														Ur	;+	/	C	- 6	(<u> </u>	20	Par.	C	on T	-				
			_			.·		- 5	- /)	4:	<u> </u>					<u> </u>		ļ										
·	TA	IR,		=	-	7		-			1 3 0	-	ļ	ļ						-								
						<u> </u>	<					ļ			ļ			ļ	ļ									<u> </u>
						48	3:	6	43	23	60	b				<u> </u>		-										
				=			<u> </u>	31	16	-	· ·							. 										
								ļ										. .										
															. 													
	AL	a, s	5	=		14.	5	E							<u> </u>					. 	· ·							
																			-									-
		 r					•		/	_			~				<u></u>		ļ									 .
<u> </u>	0/	См	e	0	f	O_{i}	<u>h.' 7</u>	¢	(C e	* 6	e_	<u> </u>	Ðm				-										<u> </u>
									/				-		-		$ \gamma $		-				_	7				-
<u> </u>		V	=	<		67	+7	<u>+</u>	((/.	75		+	2 (0.	80	γ	=	K 7	7	77		(7	`				-
												-																-
				<u> </u>												-												
													-															
																					<u> </u>							
																												-
				1		+											•											
			 .			-																					• .	
				1							-																	
							<u> </u>								<u> </u>													
								·																				
			·										<u> </u>															
	·																											
														,							•							
		,												·														
	·																											
	-		`ر																	.								
								·																				

Unit 1 Cabl	<u>e Room</u>			Tair,avg	(assumed) =	108.09F		Time = Tair,ss = Tair as Tair i =	4hr 145F		
Section	L ·	h	h xr	hL k	Volume	Twall,i	Twall,i - Tair,avg	Qo	Q/Qo	Q/Qo/2	Qconc
1	1.75	1.47	0.311	2.57	1088	85	23.09	703413.76	0.1	0.05	35171
2	0.08	1.47	0.311	0.12	130	97	11.09	40367.6	0.9	0.45	18165
3	0.08	1.47	0.311	0.12	17	85	23.09	10990.84	0.9	0.45	4946
4	0.08	1.47	0.311	0.12	23	92	16.09	10361.96	0.9	0.45	4663
5	0.5	1.47	0.311	0.73	940	92	16.09	423488.8	0.3	0.15	63523
Floor	0.33 、	1.09	0.171	0.36	1825	80	28.09	1435399	0	0	0
Ceiling	0.5	1.64	0.387	0.82	2765	74	34.09	2639247.8	0.3	0.15	395887

Qgen = 560820

Qout = 12833.8

Qair = 25631

Oconc(total) = 522355

7474-250

-16

-92

d

21 07 43

AssumedT 105.5F

C1 = 2.70857

Tair(t) = 129F

Tair,avg(calc) = 107.9F

۰,

DUKE POWER COMPANY

Station		Unit	Rev File No	Sheet_22_Of
Subject <u></u>	·····	· · · · · · · · · · · · · · · · · · ·	By	H Date <u>6-16-9</u> 2
Prob No	OSC-4747	(Checked By	Date
11+	1 El-4		Raan	$(T, \cdot, \cdot, \beta, \epsilon)$
	$\frac{1}{1}$ $\frac{1}$	<u> </u>	phen nor	
á,e	n = 65,353	Btu/hr	Q704 = 6533	-3(4hr)= 261410 Btu
J			J	
- Qon	= EUADT	- TAIR Z	UA - EUAT	sum .
		Resistence	Bry	
Section	Thickness A	F.1 W-11 A.	$r \qquad Q (hr fr) r$	$\int \frac{A(4t^{4})}{2} \int \frac{1}{2} $
) Aux [](13	1218 (1218)		s 42	
Terbine Well	34.6 4" *	<u>a 76</u> 5	8 48	540 /20
Floor	8"	2 2.88 ,9	2 21	2782 95
Ceiling	/2", 6	.1 .64 .6	54	2782 105
			· · · · · · · · · · · · · · · · · · ·	
* Neglect	8" well be	hind 4" u	wall separating	equipment room
from th	- Turbine 1	Ry laling	This is conser	uapue since the
20°F	cissumed (the Iu	rbine Building	is higher Then
The	verage Te	mperature.		
Assun	no hert	trans fer	between (In: ts 1+2
eq-,1	smeut rooms.			
Rout -	(.2/+2782	F.32 # 17	407,437 55	$\frac{-2}{\left(\left(A_{12} - \frac{7}{5}\right)\right)}$
+	- (54 - 2782	$T_{10} =$	105)+(48+	(740)(740 - 120)
Quit =	1378 (TAIR	- 95) + 15	02 (TAI- 105) 1	-259 (TAIR-120)
Rour	= 3139 TAIR	- 3/7	700 Btu /h	
	·			

•

.

Static	on_								Un	it		R	ev.			File	e No	o					_Sł	nee	t_2	3	Of	4
ວບນັງຄ															By_		1 Ø	#-					_ C)ate	6	-1	6 - 9	72
Prob	No.	·	C	<u>) </u>	<u> -</u>	4-	74	7				Cł	necl	ked	By_								C	Date	;			
													4	ln:	+	/ .	E1	pet		Eg	· · p	R	100	,	can	1		
_							84		51	A 7								<u> </u>			Ľ.				ļ			
	7.	12,	5	=		17					54	\square								 					•			
				-			<																					
									ic																			
				=		10%	120		3 /			.																
				-			3	13	7																			
						1																						
	\mathcal{T}	10	5 4	- =	/	31	•	F											<u> </u>									
=					<u> </u>		É	=					 															
				ŕ														<u> </u>						<u> </u>				
	1/				<u> </u>	1		1)	14	1		T			5			Ra										
		01		E			- (<u>n</u>	<u> </u>	/		<u> </u>	• < /		-7		· · ·		<u> </u>				<u> </u>					
																								<u> </u>				
			1	20			. 3	$\left \right $		0	1	1		-	$\overline{1}$		2	1.		-	0	, 3						
	V	-	2	12	12	4	<i>f</i>	[/	2_	++	/	(<	<u>P.</u>	8 <	ノ	-	/	6	10	7	+	<u> </u>						
					ļ		ļ														-							
_							 	. 					[<u> </u>										
																		ļ										
							ļ																					
		•									· ·																	
													х. Т															
				ł																			İ					
																										·		
+ +					ļ											•		 .							.			<u> </u>
						<u>,</u>													· ·									
									-				<u> </u>		· .				· ·					-	-			
					ļ														L					···	L			L

DUKE POWER COMPANY

ι

<u>Unit 1 Equ</u>	ipment Ro	<u>.</u>		Tair,avg	(assumed) =	100.02F		Time = Tair,ss =	4hr 131F	· .	6 74.
0			h2 AT	hL			Twall,i -	l air,ss-l air,i =	45F		
Section	L	h	k [⊾]	k	Volume	Twall,i	Tair,avg	Qo	Q/Qo	Q/Qo/2	Qconc
1	0.08	1.47	0.311	0.12	290	91	9.02	73242	0.9	0.45	32959
2	0.5	1.47	0.311	0.74	552	91	9.02	`139413 [,]	0.3	0.15	20912
· 3	0.08	1.47	0.311	0.12	90	103	-2.98	-7510	0.9	0.45	-3379
Floor	1.5	1.09	0.171	1.64	8346	91	9.02	2107866	0	0	Ö
Ceiling	0.33	1.64	0.387	0.54	1836 _.	80	20.02	1029188	0.42	0.21	216130

Qconc(total) = 266621

-16-92 29-24 of 43 56-4747

Qgen= 261412

Qout = -22949

Qair = 17740

Tair(t) = 111F

C1 = 4.9626

Tair, avg(calc) = 100.1F

.

Subje	ect_											n	ev.		Bv	-lie	- NC	ο Δν	ų.	·			יפ_ 		 	-16		 7 ז
Prob	No	•	0_	९ ८	- 4	17	47					Cł	eck	(ed	By_				¥				_ C)ate	 	, .		
																			7	Ine								
	$\underline{\nu}$	NI	<u>7</u>	3		On	2TA	201		100	m		TAI.	c, i	= (240	F)	-	17/1	TER	JAL	-	0	-30	roi	du:	25	
		0			17	h 4	111	n	Tisl	1.				0	Est	2	2	in c			s.t	E d	100 00	(\mathbf{x})				
	4	7	Jen		1-70	· ·						1		1														
		G	GRU	=	11	10,	411	BTU	the	1/0	5	l	÷)															•
		Q	gen	=	8	s,z	06	BTO																				
		,				, 				 										 		•						
		Q	DUT-	=	z	υr	07			ATA	12	UA		ج	UA	Tsc	rr.											<u> </u>
	· ·													•														
	SK.									Έs	STI	NC	E		0						BTU							.
TION	<u> </u>	Тніс	KAE	55	_A	R	ωr	L.	ALI	e 6	ypsi	m	CARI	ET-	TI	UST. E	_ <i>A</i> /	R	Ű	(7	-je	F)		A (Jt.	2)	T _s	μm
Ja-		1	12."		•	8	?:	36	- 6	}	.56						6	\$		0.	168			2	36		7	5
16		- 1	/z''		.6	8	3.	36	- 68	2	-		-					-		0.	212		-	47	4.1	ļ	2	15
24	y y	 	8"		4	8	1.7	z	6		-56					-	.6	8		0.	231			60	8			15
26~			<u>8″</u>		-6	8	1.7	2	-68	}	-				-			†		0.	325	[55	7.1			75
<u> </u>			<u>2"</u>			8	3,3	36	•6	<u>8</u>	156		-		-	-	•6	8		0.	16.8			-8	<u> </u>			15
26			¥2 '		6	2	3.3	•	- 6 5	£			-							0.0	212			13	13		X	5
4/à			2		•6	8	503		-06	8	• 56		· ·					¥ 		0.	768			S	56			
76			72		e(8 (G		36	-263	۲		<u> </u>				_				0.	10	1		4	11.1 1/2			
Ja-			<u>יבו</u> עכיי			28 10	202	2/	4ء_ ر	e e		•						,e		0.,	217			7:	र		7	
10			42". 42".			0	2	36		0		ł	-			_	.6	8		0.	168			16	4		9	5
6b		1	12"			68	3.	36	,6	8	-		_			۲.				0.2	12			150	5.3		9	5
7.			2"			68	.9	6		8	.5	6				-		68		0.0	81			3	73			10
76			2"			8		6	ak	8		ļ	_	-				<u> </u>		0.4	31			34	1.8			10
-LOOK			2 ⁴			2	?	6	-	-	_		1.2	3		-	.9	2		0.	248			58	96	ļ		65
EIUN	G		8"			1	.6	4		/					2.	60		¢1	+	0.0	01			5	196		9	15
							•						 					<u> </u>			_			· ·			<u> </u>	
}	* "		efe.	a	to	w	all	se	tio	h.	ho.	-4	los		to	dro	جرم	in	co e	ling)	Ref	breit	Le_	att	aiky	, ent	15
	"	<u> </u>	ief	le-	to	ţ.u	pl	6.20	ti	<u>tr</u>	h	h	dr	p=	tra_	Kail	lug	t	1	on	15	dia	que	m.	f	yall	Re	ti
**	<u> </u>	8"	fi	e	rat	ēd.	co	res	te	ł	for,	K	(4	ho!	lor)				Ĺ					1			
	ļ		[<u> </u>							-		·		<u> </u>				
	ļ																		 .									<u> </u>
E E	1	1	1				1		1	1	1	1	1	i		ł	1	1	1	1	1	· ·	1	1	1	1	1	11

 Station_______Unit_____ Rev._____ File No.______Sheet <u>26</u> Of <u>43</u>
 Subject _____ By______ Date _______ Date _______ Prob No. _________ 05C- 4747 ______ Checked By______ _____ Date _____ = (0.148) 536) (Tore - 75) + (0.212) (491.1) (Tore - 85) + (0.231) (608) (Tore - 95) 900T + (0.325) (557,1) (TAIN - 95) + (0.168) (80) (TAIR - 95) + (0.212) (78.3) (TAIR + 25) + (0.168) ((36) (TA12-120) + (0.212) (491.1) (TA12-120) + (0.168) (20) (TA12-25) + (0.22) (73.3) (TAIR-95) + (0.168) (164) (TAIR-95) + (0.212) (150.3) (TAIR-9F) + (D. 281) 373) (TARE-1/0) + (D. 431 (341.8) (TARE-110) + (D. 248) (5896) (TARE-105) + (0.201/5896)(7/10=9+) 900T = 3720 The - 377220 ATU/1 ggen + SUAATSO AIR SS ZUA 170,411 + 377,220 = TAIR, SS 3726 147°F = AIRSS Energy absorbed by concrete : fort that follow aber to the ation . in the heat alsonation alitity TAIR (t) Pactorin Volume = total room volume 10 Seren Control P. 8.12 X 80 = 51605 pt 3

					·	,						
			•									•
				•			N	•				
,												
Unit 3 Control Ro	om (30) minutes)		Tair.avc	a(assumed) =	94 62F		Time -	0 506-	,		-
					,(000011100)	0 1.021		Tair ss =	1545			
								Tair.ss-Tair i =	80F		• •	
			hiat	46			Twall,i -		001			
Section L	-	h .	<u>k-</u>	K	Volume	Twall,i	Tair,avg	Qo	Q/Qo	$\Omega/\Omega_0/2$	Ocone	
1 1.7	75	1.47	0.039	2.57	3595	85	9.62	968349	0.01	0.005	4842	
2 0.0	83	1.47	. 0.039	0.12	193	85	9.62	51986	0.28	0.14	7278	· ·
3 1.7	75	1.47	0.039	2.57	536	85	9.62	144377	0.01	0.005	722	
· 4 · 1.7	75	1,47	0.039	2.57	3595	97	-2.38	-239571	0.01	0.005	-1198	
5 1.7	75	1.47	0.039	2.57	536	85	9.62	144377	0.01	0.005	722	
6 1.7	75	1.47	0.039	2.57	1099	85	9.62	296027	0.01	0.005	1480	
7 0.	5	1.47	0.039	0.74	715	92	2.62	52452	0.05	0.025	1311	÷
floor , 0.	5	0.465	0.004	0.23	5896	90	4.62	762707	0	0	0	
ceiling 0.3	33	1.64	0.048	0.54	3927	85	9.62	1057777	0.09	0.045	47600	
									Qcc	onc(total) =	62757	
			·			•					•	
				Ogen –	85206	Dout -	10000	0-1-	04700			
				agen –	03200	000l =	-12333	.Qair =	34782			
• .					Tair(t) =	111F						
	•				L				•			
								· .				
C1 = 0.792	212	х. <u>н</u>			. Tair,	avg(calc) =	94.7F		t			
								•			· .	
		,										
										·		
· · ·					•	-						
		• •						•				
											P	6,6
		•									۲. ۲	24
							· · · ·				0	19

050-4747 2014 6/16/92 6/16/92

DUKE POWER COMPANY

;

Static Subie	on_ ect							_Ur	nit_	•	F	lev.			File	e No	o					_S	hee	t_2	28	01	f
														By.		() <i>K_</i>	ĮĻ.				(Date	,	6/1	6/9	,
Prob	No.		_C	SC	-4	174	1				C	hec	ked	By.								[Date	9	· _		_
	UN	17 3	3 (200	Teo	4_1	Coo,		4-	Are	=	74	νĘ				77	mE ERU	de -	= (2	5	mi	07	ES_		
		Ô			<u> </u>		0	-11		1	0		-+		-	e			-			· 					
		9 ge	~ =		26	5	BTI	Y L V L		7	ha	3	jel Dra	30	ter al	time	4 4	A	acce	$\frac{1-e_{\nu}}{2}$	ent	Ŋ					
							-			/																	
		Jge	<u>_</u> =	. [(,	170,	411	PT.	f.h.)(<u>þ.</u> 5	ho)	+	6	2,6.	5-1	RTY	k)	0.0	54	ocu	k)	. 	. 			-
_		9 3	= = n	=	100	8-	10		3TL	1	-	-															
	\$	ð.	=	: 3	72	6-	1		-3	77:	220		370	11	L	7	as	1.	e la								<u>.</u>
		- 100	<u>π</u>																								
_	-	•				-	Ġ	gen	+		1	AD	150	r				ļ	 						<u> </u> .		+
			ATA	e <u>3</u> 5	-	1			2	0	A							•							-		
				,			1	70,	411	(.	言)	+	62	,65	5-(14	\sum	4	377	25	0						
			AIA	ی کے ہ	-	• —						37	26														
_			\downarrow		-		1-		0																		
			AAI1	e 55		=		5.7		-													·				
	Ên	rigy	al	ron	led		In J	co	ne	ete																	
			D	2	4		14					1.~	L 5	11	F	0.1	1/		1		1	1	1		1	-	1
				har	fori	kg.	in	4	ta	A	eat	F a	bo	ra	tio		al	le	t	0	co	cer	to			'A1,	e
								. 1					1														
			en	tel.	la	m	2	lus	ne_	=		ola	5	1027	n -	256 3	frace	- X	- 8	20		<u>.</u>	nof	ere	nes	- 8	
												1,0	6- 0 -	1	Ł										<u>.</u>		
_																											
																					• .						
				·															•								
																									1		

		+J minutes	<u>,</u>	rair,avç	(assumed) =	94.726		Time = Tair,ss =	0.75hr 146F		
			13.0				Twall i -	Tair,ss-Tair,i =	72F		
Section	L	h	k at	K	Volume	Twall,i	Tair,avg	Qo	Q/Qo	0/00/2	Oconc
1	1.75	1.47	0.058	2.57	3595	85	9.72	978415	0.01	0.005	4892
2	0.083	1.47	0.058	0.12	193	85	9.72	52527	0.45	0.225	11819
3	1.75	1.47	0.058	2.57	536	85	9.72	145878	0.01	0.005	729
4	1.75	1.47	0.058	2.57	3595	97	-2.28	-229505	0.01	0.005	-1148
5	1.75	1.47	0.058	2.57	536	85	9.72	145878	0.01	0.005	729
6	1.75	1.47	0.058	2.57	1099	85	9.72	299104	0.01	0,005	1496
7	0.5	1.47	0.058	0.74	715	92	2.72	54454	0.08	0.000	2178
floor	0.5	0.465	0.006	0.23	5896	90	4.72	779215	0	0.04	2170
ceiling	0.33	1.64	0.073	0.54	3927	85	9.72	1068772	0.12	0.06	64126
•	•										,

Qconc(total) = 84822

Qgen = 100870

Qout = -18220

Qair = 34268

Tair(t) = 111F

C1 = 1.05678

Tair,avg(calc) = 94.7F

050-116/21 July $L = L_{L}$ 543

Form 00184 (R4-88)

Static Subic	on_ ect				. <u> </u>	•			_Ur	nit_		F	lev.			File	e No	0	·			<u> </u>	_SI	hee	t	30	_ 01	<u> </u>
															By			OK,	ĮĮ.			•	C	Date		6/1	6/7	13
Prob	No.		(<u>05</u>	<u>C-</u>	-4	74*	1				C	hec	ked	By		•						(Date	•			
	Ű	<u>)</u> ,7		2	Co	DT	ROI	, 	<u>Por</u>	m		TA	ie, i	= ;	74 %	E)			1	T IN NTE	nE reur	4=	0)-6	6	n in	17	<u>e</u> s
		$\dot{\boldsymbol{\boldsymbol{\delta}}}$		2	17			P-	1.5/		/	lon	1	-+	1 7	<u> </u>	e	1-	E	to	2.0	4			-		<u></u>	╞
		<u>J</u>	en en	Ξ.	6	1.	55	BT	1/-	h	Ľ	6		20-	m	t	4 'a -	4	ho	us.)	he j						
						ĺ			ľ	$\frac{1}{1}$											Í			<u> </u>				
	_	9	en		(_/	120	41	B	10/2	4)(þ.s	12	-)+	1()	12,	655	BTU	the	Ľ	5-	hou	es)	-				
	.1	9)en	U		22	کرم ا	3.	_ك 	B	τu						+											-
	₹	ġ		Ξ	3	72	6	7		3	27	220		BTC	11	1.	1		le	for								
·		•					<u>.</u>	1												ĺ								
		•		/				ģ,	en	4	ΣU	n.	50	r														+
			-A	R, S	5					<u>s</u> .0	A						5											-
_			70	-]		2	170	41	(も)	+	62	,65	1	2)	- [73	77	220					1.			
				e, s	د							3:	720	k														-
-				_	-	_		0-				<u> </u>																
			-/ A	4R,	55-	-	1	5.4		-																		-
	En	eng	y	al	Rer	le	d	2y		me	no?	e	• •															
				<u></u>		1-	4	e			1	. 1	4	4	-+-	- /	2 11). D		0	1~					-
			_7.54	Par	Jo Jo	in		e n	the second	iea	Reid	1 L	se st	-la	al	1 Dr		In	the second	er.	2	Ken	10.0	100	1	É	/ Ai	e-
_				/		V	[¥	7								
		•	-4	un	hol	R	oon	1	V.J.	wind		=	Lot	L	100		sl	um	د)	<u>(</u>	<u> 20</u>		; ^	fe	en	e	8.	2
												=	5.50	6.O.	Í	£							• • •				i	
															,													
							- <u>-</u>	,						-:											•			
								•												•		•						
																												ĺ

Unit 3 Cont	rol Room (1 hour)		Tair,avg	(assumed) =	94.35F		Time =	1hr		
,								Tair,ss = Tair ss-Tair i =	142F		
			Leat	41			Twall,i -				
Section	L ·	h	<u>k</u> -	K	Volume	Twall,i	Tair,avg	Qo	Q/Qo	Q/Qo/2	Oconc
1	1.75	1.47	0.078	2.57	3595	85	9.35	941171	0.01	0.005	4706
2	0.083	1.47	0.078	0.12	193	85	9.35	50527	0.5	0.25	12632
3	1.75	1.47	0.078	2.57	536	85	9.35	140325	0.01	0.005	702
4	1.75	1.47	0.078	2.57	3595	97	-2.65	-266749	0.01	0.005	-1334
. 5	1.75	1.47	0.078	2.57	536	85	9.35	140325	0.01	0.005	702
6	1.75	1.47	0.078	2.57	1099	85	9.35	287718	0.01	0.005	1439
7	0.5	1.47	0.078	0.74	715	92	2.35	47047	0.1	0.05	2352
floor	0.5	0.465	0.008	0.23	5896	90	4.35	718133	0	0	0
ceiling	0.33	1.64	0.097	0.54	3927	85	9.35	1028089	0.17	0.085	87388
				Ogen =	116534	Qout =	-25672	Qair =	33620		
	•		• •								
C1 =	1.3277				Tair,	avg(calc) =	94.3F				
		. •.									
							•				
			· ·						• .		Pg.
							,				$\frac{1}{2}$

050-4747 10K/4 10K/4 10K/4 10K/4 10K/4 12 12 12 12 12

Unit_____ Rev.____ File No._____ Sheet 32 Of 43 Station_ Subject _____ _____ By_______ Date_____6/16/72 ____ Date ____ TIME ENTERVAL = 0-240 MINUTES UNIT 3 CONTROL COM (TAIR = 740F) for fist 20 minute 170, 411 BTU/ Re into event) gen 62,655 BTJ/ hu 30 minutes -= Igen 00 Que = (170, 411 BTO/A) (0.5 Bound) + (62,655 BTO/A) 3.5 hours Pjent 304,499 BTU Sobr = 3726 The - 377220 BTU/h (as De ggen + EUAATSorr AIR, 55 SUA = [170,411 (.125) + 62 655 (.875) 7 + 377220 TAIR, 55 3726 °F = TATR, 55 122 Energy conciste : abour led ly leet that follower po ation of 12. the least absorption about in TAIE (t) putoing ton Volume = total room zolima X.80 Control spere -8.12 = 11,605 pt 3

nit 3 Cont	rol Room (4	4 hours)		Tair,avç	(assumed) =	95.46F		Time =	4hr		
						•	, ,	Tair,ss = Tair,ss-Tair,i =	134F 60F		
			4 SAT	61			Twall,i -				
Section	L	h	<u>k-</u>	Ť	Volume	Twall,i	Tair,avg	Qo	Q/Qo	Q/Qo/2	Qcond
1	1.75	1.47	0.311	2.57	3595	85	10.46	1052904	0.08	0.04	42116
2	0.083	1.47	0.311	0.12	193	85	10.46	56526	0.9	0.45	25437
3	1.75	1.47	0.311	2.57	536	85	10.46	156984	0.08	0.04	6279
4 ·	1.75	1.47	0.311	2.57	3595	97	-1.54	-155016	0.08	0.04	-6201
5	1.75	-1.47	0.311	2.57	536	85	10.46	156984	0.08	0.04	6279
6	1.75	1.47	0.311	2.57	1099	85	10.46	321875	0.08	0.04	12875
7	0.5	1.47	0.311	0.74	715	92	3.46	69269	0.3	0.15	10390
floor	0.5	0.465	0.031	0.23	5896	90	5.46	901380	0	0	C
ceiling	0.33	1.64	0.387	0.54	3927	85	10.46	1150140	0.45	0.225	258781
									Qco	nc(total) =	355958

Qair = 34685

Tair(t) = 111F

C1 = 4.08462

Tair,avg(calc) = 95.7F

م 33 of 1/3 26/2 147

Statio Subjo	on_ ect_								_Un	nit		F	lev.			File	e No	0					S	hee	t_ <u>3</u>	74	Of	_4
Prob	ı No	•	C	، کـ <	<i>C</i> -	4	74	17				Cł	nėc	 ked	By By		10	0∉		<u> </u>			C (Date Date	<u> </u>	-/6	<u></u>	72
	1		1	1										1							1	, T						
-								·								1								ļ	 		•	<u> </u>
	V	n i t		<u>}</u>	C	<u>6</u> k	<u> </u>	Rao	m		(_7	Air	i	=	74	F)						ļ						
						<u> </u>				. 								-				·						-
		<u> </u>	:	10	7,-	54	4	Rt.	<u> </u>			Q		=	10'	7.5	41	(4	hr) =	43	01	64		+4	· ·		<u> </u>
					-		\downarrow			6	+ ,	<u> </u>	 					-										-
_	2	047	; :		AIR	<u> </u>	<u>} (</u>		-	2		A	1 14	*														
		•								Res	1-1		+		7	6	tu	$\pm\gamma$				5)	
Jee A	7.01	, , ,,			<u> / h</u>	ic kr	es.	<u>4.</u>	Air	h	<u>/-//</u>	<u>A;</u>	<u>}</u>		<u>[</u>]	r ft	2 %		<u> </u>	<u>A (</u>	++	2		<u>/</u>		(*/	1	
1	r W	a//				42			.68	2	36	, 6	8			,2,				5	52				95			
1 1	n	<u>« </u> /oi	1		\vdash	12	4		.68	· ,	76	, 6	8			,73				7	28				95			
The 1			ek) 01)		0			,68	/.	12	,6	8			32				· .	28				75			<u>``</u>
P	11	~ //	2/04/	×/		0			.08	<u>/</u> ,	12	,0	•			47		 		79	0				~~			
FA		~ //				8"		<u> </u>	<u></u>		6	10	5			, 73 4 4				40					10			
	• /•	~				11"			12	, 6 G	7		×			41		 .		17-	- 8		<u> </u>		00			
	•	}					-		/0/	_ / /						/6				77	38			/				
	·												-															
á.	uT.	:	(,	40,	49	ه د) (T.	2 -	10	0)	+	(.4	6#	49	r-a	+ .	47	4	-0-	,)	17		- 11	0			<u> </u>
			<u> </u>						۰									/~			<u>'</u>		7/2	1				
		$ \neq $	(,	21	+ 5	52	+	,43	*	92	8 +	,3	2 *	112	8) (T,	in	- 7	5-)							
												·								,								•
		+		32	¥	74	0		$\mathcal{T}_{\mathbf{r}}$	- IR	- /	20							•									
Q.	<u></u>	=	19	8	3 ((TA)	k -	10	,)	<u>+</u> '	25	33	(T,	A	- //	0) +	٤	7.	<u> </u>	T	IR	-	75)		
										<u>\</u>																		
	_	+	3	0]		TA	<u>/ -</u>	-/	20	凵																		
9	04	<u>r</u>		ء ک	<u>5 7</u> .	3	7. a	IR	-	5	7	<u>5</u> Z	70	>		BI	י _ط	14	<u>,</u>									
		-+																										
+									.																			
+																												
			<u> </u>													·												
+																												
																	1											

Sta ['] Sul	tion biect								Ur	nit_		F	lev.			File	e No	o					_SI	heet		32	_ Of	4
		' <u> </u>								•					By		1	ØД					C	Date	6	-/4	2 -	9:
Pro	b No	o	C	<u>ی د</u>	<u> </u>	4	7 4	17				CI	hec	ked	By			· .			.		[Date	;			
															\mathcal{O}_{i}	1, <i>+</i>	3		- -	<i>[/e</i>	R	0 = ~	-	PH	<i>t</i> .			
							·	<u> </u>							Ĺ													
	7	AIR	2 2	=		φγ,	* < •		2	$\bigcup_{i=1}^{n}$		s cr,	r															
		_						2	ρ	4	ļ		_								`							
						19	26	19	4		5	77	b					-		·			-				<u> </u>	
				=					6	5			Ĕ										ļ					-
				<u> </u>						,			-					-				ļ						
								-															ļ	<u>.</u>				-
+		rra,	<u></u>	=	/	<u>3</u> °	7	\vdash																				-
						-												•.			<u> </u>							
-		-							-					-														+
+	_V.	0/4	<u> </u>		<u>s 7</u>			• +	ک	-		61	e	Re	204	¢											<u> </u>	-
-									-													-		ļ			 	
-			4	19	~ .	- /	- 3	1	11	7				$\frac{1}{2}$	0								C-	3				-
	<i>v</i>	1=		/ / \					(1,	13	+		-(-	<u>,</u>	9		/ -		15	6	<u> </u>	.	τ					-
	_																				<u> </u>							\vdash
+																												
+																					·							<u> </u>
			1										<u> </u>															
																							· ·					
					•								<u> </u>															
			-								 				ļ													
									•																			<u> </u>
.		+					•													 								
	<u> </u>												·															
			. 										ļ	ļ														
		+											 															<u> </u>
																			ļ									
													· .	 														<u> </u>
-		<u> </u>						<u>.</u>																				
1	l												1	1	·			l	1					ł			1 1	

Unit 3 Cable	Room			Tair,avg	(assumed) = 3	96.2F		Time = Tair,ss = Tair,ss-Tair,i =	4hr 139F 65F		_ `
			h"x7	46			Twall,i -				
Section	L	h	k-	K	Volume	Twall,i	Tair,avg	· Qo	Q/Qo	Q/Qo/2	Qconc
1	1.75	1.47	0.311	2.57 ⁻	1932	. 85	11.2	605875	0.1	0.05	30294
2	0.5	1.47	0.311	0.74	928	85	11.2	291021	0.3	0.15	43653
3	0.08	1.47	0.311	0.12	188	85	11.2	58957	0.9	0.45	26531
4	0.08	1.47	0.311	0.12	157	97	-0.8	-3517	0.9	0.45	-1583
5	0.5	1.47	0.311	0.12	587	92	4.2	69031	0.9	0.45	31064
Floor	0.33	1.09	0.171	0.36	3272	80	16.2	1484179	0	0	. 0
Ceiling	0.5	1.64	0.387	0.82	4958	74	22.2	3081893	0.3	0.15	462284

Qconc(total) = 592243

772-4747

Ô

36

7

43

Qgen = 430164

Qout = -194414

Qair = 32335

Tair(t) = 113F

C1 = 4.44973

Tair,avg(calc) = 96.1F

.

Static Subic	on_					<u> </u>			Un	it_		_ F	lev.			File	e No	o. <u> </u>					_Sł	neet	3	7	_ Of	<u> </u>
		•													By.		4	Dh	ł				C	ate	6	-/6		72
Prob	No	•	C	ک (<u> </u>	4	74	7				CI	necl	(ed	By.								_ C	Date				
	(Un:	+	3	E	1-0	tr	, 'e =	1	E	. .	рм	en7	_/	200	-	(TA	R, i		8	6	° F	2				
	2	Pge	4	-	74,	90	0	B.+	-/	br		(Ra	en	- 7	4	70	0	4	4	:	29	9€	50	0	BI	44	
	C	204	7.	= / _A ;	5	UA	-	2	U	A 7	114											 .						
· · ·									Æ	01	·+-						Ø	#11										
Sec	tion III				<u>_</u>	hie	kn	is_		in	Wal	11 1	1	-	U	(h.	- <i>f</i> 1	1 0/	<u> </u>		4 (f +	2	7	s uri		PF)	<u> </u>
\rightarrow A.	wa ix	Val	/~~~			0 /2	,		,	8	, 1. , 96	¢ ,	68				. 3 1	3	:		12	20 72			c	75		
Turk	W	11(1	Black)		4'	*			68	,71'		68				, 48	3			ک	76			/:	20		
F	lao. ilin	a				36				2 5/	2.88		72				21	/			32	21				ۍ و د د		
		1																										
t See	= /	701	<u> </u>	40	le	r	<u> </u>	1 <u>n</u>	+ /	4	:/-e	.+	E	7 ~,'	P	<i>R</i> .,	m	C	-/.	 								
ġ.	чŤ	=	(,;	21+	- 3.	215	+	, 3	2 *	120	5 +	. 4	3*	12	72)(_7	AIR	-	7)						
		+				7/5	_)	(τ		- /		-1	4				~	74	17	7			20)				
								<u> </u>					, 			<u> </u>	2	<u> </u>										
ą.	-1	-	12.	60		TAIR	~ <	75) +	- /*	230	ه ($\left[\mathcal{T} \right]$	I.A.	-/·	25)	+	27	6	(7)	AIR	-1	2 -				
· Ź	047	=	3	77	12	T,	+/ R	-	33	5	10	с O		B7	4	h												
	_																								•		`	
		•						•									•						•					
															· ·													
																• .												
·																			1								j	ļ

Ståtie Subje	on_ ect_								_ Uı	nit_		F	Rev.	, <u> </u>		Fil	e N	o					S	hee	t	88	_ 0	f
						·									By		10	4					I	Date	6_6	-/6	; _ c	72
Prob	No	•		0.	ے ک	-	47	74	7			С	hec	ked	By		<u>-</u>	•						Date	e			
							Τ			T		1	0	2, 1	f J	3	FI	ee'	A.	E-			400	in .	~~	_n ≁		
		<u> </u>				;				47	_									ť	-/							
	7 ₄	a,		F -		191	- n 7	51	71			1		. 	<u>.</u>					<u> </u>		. 		ļ				
			ļ				1		17						<u> </u>				-	_				-	ļ			
_					9	15.	7.	51	-3	35	10	D				-												
				=		•	3	2-	12	-					-											-		+
					+														· ·	-						-		+
	7.				12	9	٩F															<u> </u>			·			+
=		1(,)	F			<u> </u>	÷										. .				 			+				+
																					1		+					
	Va	10	Me	0	4	6	Ini	+	3	E	le	· / .	1	F7			Ro	m										
						·	ļ							(
				-	<u> </u>			<u> </u>							-			ļ			. 		<u> </u>			ļ		<u> </u>
		V	÷ ,	42	1/5	1 /	17	1_(12	<u>}</u>	£7	μ(0	, 8	0	-	3	0	8	64	1 +	<u> </u>	3		-		-	
							+		-														· ·					<u> </u>
-						·			<u> </u>								-							 				-
			_																								 	
							; 																					-
				<u> </u>				1														:						<u> </u>
																												<u> </u>
_	·						ļ						. 															
																						ŀ 	 					ļ
			. <u></u>	-									•					ļ								۰.		
	-								. 																			

						. . .											·		·									
++																					_							
			-																									

Unit 3 Equ	ipment R	oom		Tair,avg	(assumed) =	100.44F	, ··	Time =	4hr		
.						•		Tair,ss = Tair,ss-Tair,i =	129F 43F		
			627	62			Twall,i -			•	
Section	L	h	-k-	k	Volume	Twall,i	Tair,avg	Qo	Q/Qo	Q/Qo/2	Qconc
1	0.08	1.47	0.311	0.12	20	. 91	9.44	5286	0.9	0.45	2379
2	0.5	1.47	0.311	0.74	1272	91	9.44	336215	0.3	0.15	50432
3	0.08	1.47	0.311	0.12	96	103	-2.56	-6881	0.9	0.45	-3097
Floor	1.5	1.09	0.171	1.64	9645	91	9.44	2549366	0.0	0.40	-3037
Ceiling	0.33	1.64	0.387	0.54	2121	80	20.44	1213891	0.42	0.21	254917

Qconc(total) = 304632

Ogen = 299600

Qout = -25841

Tair,avg(calc) = 100.6F

Qair = 20810

Tair(t) = 111F

C1 = 4.4614

•

•

.

16-92 + 43

56-4242

Static Subje	on_ ect_		~					<u>.</u>	_Ur	nit_		_ F	lev.			File	e N	o		•			_S	hee	t	70	_ Of	- 4,
						<u> </u>									By		10	4						Date	6	-16	- 9	2
Prob	No.	<u> </u>	C	2 <	<i>C</i> -	- 4	74	17				CI	nec	ked	Ву		-						(Date	, 			
				-			T	1	1		1					<u> </u>	1				1			1	1		<u> </u>	
_		\mathcal{C}	- +		1	R	#			R				7	+		-	74	• =									
				/ •	Í		<u>*//</u>		<u> </u>		000		+-\				<u> </u>	1	/								<u> </u>	
	4		, =	_ <	Þ			1		1				-				-										
		/				•																						
	4	204	<u>r</u>	[AIR	٤	U	4	+	٤	UA	T.		<u>.</u>					<u> </u>									
												Ra																
5	ct.	01				T	<u>К. с</u>	kne	s	<u> </u>	Air	10	10/1				v	Ĺ	- 7 1	1.0/		4	(1	7-	<u>L</u>	T.s.,	r (۰F
xt-	.'or	ω_{-}	//				. 5	? "			68		64	2	5		<u> </u>	-	63	-			16	8			2	
Aux	<u> </u>		/,	\ \			6	• · · ·		-	68	<u>'</u> ,	64	.6	8			ļ.,	50	\$	<u>.</u>		15	6			7 J	-
	<u>~// (</u>	IS TO	ck L)			9		<u> </u>		68	<u> </u> .	72	,6	?	ļ		-1	32				12	0			/ 0	
	L/1	(R	lork	.)			8	•				1.	72	, 6					32				78	2		,	73	
F	000						81				12		7	,92	P				40				060	\$ {		<	75	
Ce	:1:	19					8"			, e	\$1	,6	4.	61					54			/	266			Ċ	25	
		<i>J</i>							. 																			
Q	0-7	<u>-</u>	<u>(</u> 6	r-r	/69	i +	,50	* /-	26.	+ ,-	32 *	48	0 +	, 32	*	72	+	, 4	٥¥,	106	6 + ,	54	+1	060)(Tai	<u>n</u> –	71
				-			10	-)						<u> </u>							 			
		-+	-(52	* /	20	Щ		AIR	-	// <	<u>p</u>					<u> </u>											
											 				-													
Â	047		./	46	\$2	(TAIA	- ~	75)	+	23	201	7	- A IR	-1	10)								 ·		
						,																						
9	0-7			6	92	_(TA	ir,) .		16	54	19	0														
			-																									
	-	.			<u>्</u>	9 + 1	-+	٤	01	-7.	11																	
	AIR	<u>, z r</u>			_		٤	UA														•						
	<u>.</u>																<u> </u>											
					4	2	+	16	419	70.				•														
	Æ IR	<u>م د</u>					14	<u> </u>	2																			
	T																											
																					·							

Sta Su	atic bje	on_ ect_				•				Un	nit		_ A	ev			File	e No	D					_SI	nee	t_4	'/	_ 01	4
Pro	ob	No	•	C	د (<u>c</u> -	4	74	7				Cł	necł		By By			10	4				C C)ate Date	- <u>-</u>	<u>/</u>	6 -	<u>92</u>
Ţ													1	6	on	tro	, ,	B	7-7		Ro	0 ~		<i>c</i> .	n T				
		A.	بـ ۾	s :		9	7	- 7-		<		12	27	-7-														`````	
	- 11		0														· · · · ·												
	/+	γ -	ero P	<i>J</i> •			01	ce	A T 1	† /	10,	h		/ 0	-	0	. 3								1-4			2	
		47		~ 9		9	5					4	7. Ø		4 4 4	<i>+</i>				-(7	hr	د ~			rch	· ~		
	4			p.					. +			-	-	+	4	8						2 6	2	0	4				
		<u> </u>				<u>с</u>					, on			06	۲	f+	² (12	£7)			· ·				• •		
	ک	<u>, n</u>	(e		1 <u>4</u>	,	5	/e	5	, ,	l_	2 7	e	+	,		~ :	~	 	ر ج	5	n e		(12	 	2.			
		<u> </u>	<u>n c</u>	<u> </u>		• <i>T</i> =					2			c ^ <	- 2				<u>40</u>	<u>۴.</u>									
		%	<u>_</u>	n c		4	10	66	(. 8 - (5	=		0	-	7 7	0												
				1	•				• 4		£		14				4						t.	- 10	~ #				
			~~p	/0			>	9 -						2															
								<i>a</i>			-														a				
											· · · · · · · · · · · · · · · · · · ·																		

. •

9)

OSC-4747 Page 42 of 43 6-11-92 /04

10.0 <u>CONCLUSIONS</u>

The room temperatures determined by the method in section 3.0 of this calculation are shown in the table below. These are the expected temperatures four hours after the beginning of a station blackout unless otherwise indicated.

Room	<u>T (°F)</u>
Unit 1&2 Control Rooms	115 ¹
Unit 1 Cable Room	129
Unit 1 Elect. Equip. Room	111
Unit 3 Control Room	111
Unit 3 Cable Room	113
Unit 3 Elect. Equip. Room	111
Control Battery Rooms	97 ²

Notes:

¹Unit 1&2 Control Room temperature is maximum at 45 minutes after the blackout begins.

²This is the final steady state room temperature for the Control Battery Room. The temperature four hours after the start of a station blackout will be less than this.

The Unit 2 Cable and Electrical Equipment Rooms had less internal heat generation than the Unit 1 Rooms. Because of this the temperatures in the Unit 2 rooms are expected to be less than the temperatures determined for the Unit rooms. All three of the Control Battery Rooms are similar in construction and none have any internal heat generation. Therefore, all three rooms can expect similar temperature rises.

NUMARC 87-00 (Reference 8.3) provides an alternative method for calculating the steady state room temperature following a station blackout. This method was not utilized since it could not account for load stripping at an intermediate time step prior to steady state conditions being met. It can also be seen from this calculation that steady state conditions have yet to be met at the end of the 4 hour blackout period. This method is used however below as a quick check to determine if the steady state conditions would still fall below this maximum allowable temperatures in each of the room. It used the following correlation to calculate this final temperature.

 $T_f = (Q/A)^{3/4} + T_i$

OSC-4747 Page 43 of 43 6-11-92 /DH-

where:

T_i = initial wall temperature (°C) (use initial room temp)

Q = internal heat generation (Watts)

A = surface area of walls and ceiling (m^2)

 $T_f = final$ steady state room temperature (°C)

As a check the following table shows the room temperatures to be expected using this method.

Room	<u>T;(°C)</u>	<u>Q (watts)</u>	<u>A (m²)</u>	<u>T_f(°C)</u>	$T_{f}(^{\circ}F)$
Unit 1&2 Control	23	34,197 ¹	1239	35	. 95
Unit 1 Cable	23	41,116	469	52	126
Unit 1 Equipment	30	19,165	522	45	113
Unit 3 Control	23	22,324 ¹	971	34	93
Unit 3 Cable	23	31,537	845	38	100
Unit 3 Equipment	30	21,965	482	48	118
Control Battery	23	0		23	74

Note:

1The internal heat generation used for the Control Rooms is the average rate over the 4 hour period taking into account load stripping. The actual final room temperatures can be expected to be higher since the actual load is concentrated over the first 30 minutes.

The above table shows that the method used in Section 3.0 of this calculation is sometimes more conservative than the NUMARC method and in other cases it is not. In either case the predicted temperatures are always lower than the maximum allowable temperatures indicated in attachment 1 of this calculation.



Attachment #1 OSC - 4747 104. 6-16-92 Page 1 of 11

June 11, 1992

B. J. Dolan, Manager Mechanical/Nuclear Engineering

Attention: D. K. Harrelson J. D. Heminger

Subject:

Oconee Nuclear Station Electrical Equipment Heat Loads For Station Blackout Response File OS-243-A

Per your request, Oconee Electrical Design has completed summaries of the electrical equipment heat loads in the control rooms, cable rooms, and equipment rooms at Oconee. Please note that the worst case of the conservative, priliminary estimates used in the SBO heat calculations enveloped the computed heat loads. Therefore, the heat calculations using the estimated electrical equipment heat loads offers an extra measure of conservatism and confidence.

The data shown on the attachment were derived from the "OSC-2790: Oconee A & B Chiller HVAC Calculations" revision 10 and the J. C. Mumford memo to M. M. Self, dated July 13, 1989. The results are shown in two columns. The first column reflects the heat loads at time zero of the SBO event; the second column reflects the loads manually stripped from the non-essential KI, KX, & KU panelboards at 30 minutes into the event.

The NUREG 87-00 established the criterion for temperatures in the Control Rooms not exceed 120 degrees F. The temperature limits for the Equipment Rooms are noted in OSSD-0129.01-03 to be 137 degrees F. According to the manufacturer's data, the Control Battery Room should be maintained below the maximum operating temperature of 107 degrees F during charging which will prevent electrolyte boiling. However, during discharging, the performance of the batteries actually improves with temperature increases of unspecified limits. Since no specific temperature data exists for battery discharging conditions, the temperature limit of 107 degrees F will be assumed for the SBO event.

If you have any questions or comments, please call Jay Bryan at 373-3329.

aut

J. H. Bryan Design Engineer Oconee Electrical Design Engineering

Attachment

cc: D. M. Jamil S. L. Nader M. E. Patrick Central Records

ONS/Reg. Compliance

Station OCONEE	Unit	<u>/: Z</u> Rev Fil	e NoSheet/O	f10
UDJECT <u>ELECTRICA</u>	<u>L EQUIPMEN</u>	T HEAT LO	4DS	
	ON_BLACKOUT	Ity, V	AY. BRYAN. 6-10-92	
rot <u>Residence</u> in a	· · · · · · · · · · ·	tot (not trot) N		
			$\frac{4\pi e_{chn} e_{n+1}}{2\pi} \frac{4\pi}{2}$	
	•	•	1DH 6-16-92	
			page 2 of 11	
Unit 13 2	CONTROL ROOM	WATTS	After 30 min	
(Om PlaTER	101	11950		
contrater	101	3429 . 600		
	102	3015	C + ret Joon /	'-13 +2
	7 0 1	4950		
	7.01	7730		- - .
	200	2015		5-84
~		34.4	~	
Unit Board	Unil	1.80	180	
	Un 7	400. 180	180	
Vert. Bd	Unl	915	9,5	
	11- 7	915	915	
Aux Bach Bd	4n. 2 Un 1	Loo 97	100 97	
	40.Z	100 97	100 97	
Un ¿Aux Bd	4n.1	1654	1654	
	Ur.Z	1654	1654	
Elect. Catl Bd	41.1	750 + 450	750 + 450	
	Un.Z	750 +450	750 +450	
NI/RPS	Un.1	4800 + 180	4800 + 180	
· · ·	Un.Z	4800 - 180	4800 - 180	
Ics	4n-1	5400 + 420	0	
	Un. 2	5400 + 420	0	
· •••	· · · · ·			
ES Lab.	Un. 1	1010	1010	
	Un.Z	1010	10 10	·
ĸz	4n.1 4 Z	700	700	
Aux Cab.	Unil	2600	2600	
	Un. 2	2600	2600	
• • • • • • • • • • • • • • • • • • •	· <u></u>	· · · · · · · · · · · · · · · · · · ·	· · · · · · · · · · · · · · · · · · ·	
Fire Detect.		1000	0	

3

DUKE POWER COMPANY

.

StationUnit	Rev File No.	Sheet_1Of_10
	<u>.</u>	
		Attachmont + 7
		056-4747
UNIT 1 = 2 Control Room	kont.)	104 6-16-92
	WATTS	$\begin{array}{c} 1 \circ j \in \underline{3} \circ F \underline{11} \\ \text{After 30 min.} \end{array}$
Data-Net Un.1	700 + 850	0
Un. 2	700 + 850	O
	• •	
Iccm Cab. Un. 1	500	500
Un.2	500	500
Electr. Un.1	200	200
42.2	200	200
Transient Mon. U. 1	1000	1000
Un. Z	100 0	1000
Computer 45000 Equip		
сри	1500	D
Anx	1500	0
LCS	776	0
CRT.s	234	0
Matrix Printer	213	Ø
Eng/OP Ponel	44	0
1/0 Cab.	776	Ø
MH Disk	1406	0
Video lopier	542	0
Computer 4020 Equip		
CPU	1460	0
Ημχ	776	0
Vet Video	515	0
Fort. Kanel	88	0
Pert. Printer	213	6
Line printer	496	0
Kewrder	1/7	<i>O</i>
Floppy Digk	686	
······		
<u> </u>		

DUKE POWER COMPANY

Station		Unit	Rèv	File No	Sheet_3Of_/0
·	· ·			By	Lite
Large Mr.			Contractor	1	,
	х				Atlacknest # 1
		,			104 6-16-92
_	UNIT 1:2	CONTROL	ROOM	(cont.)	Page 4 of 11
	· .			Watts	After 30 min
	PERF. STATION	s #1		362	0
		# Z		362	0
	Ta	ble +1		486	0
	Tai	ble #2		486	0
. '	•				•
	South Entrance	Vert. Bd	'	762	762

TOTAL UNIT 1:2 Equipment Heat Load 75,242 At onset of SBO: <u>82,100</u> W

After load stripping at t = 30 minutes 28,334 W

Station_	UCONEE	Unit_		Rev	File No	D		Sheet <u>4</u>	Of_
ubject_	Electrica /	Equipment	Heat	Loads	For	Station	Black	04+	•
				<u> </u>	JAY	BRYAN		Dete 6 - 11-	9Z
ch Ne	• · · · • · · · · · · ·	· · · · · · · · · · · · · · · ·	`.	$a \in I \times C \cap [X]$	• • • • • • •	n y katalapan ar - n -		, , , , ,	
						. •	۱ مه # ۸ رک	(m=n + #)	
				•			10H	6-16-92	
	UNIT I	CABLE ROU	om .				Paya	5 of 11	,
		·				Watts		After 3	0 -
· .	LIGHTS	(assumes b	50% re	eduction)		11,500		11,50	0
	м. С						•		
	Computer	Cab. 181,21	EI, 10	51., 261,2		20,286	•	0	
		64, 264, III	, 2II	1,119,21	9	. • .			
		:				· ·			
	Turb. Supe	er. Panel				500		. 0	
								•	
	Events Re	corder				300		300	
						•	·		
	EHC Cab.	. :				1500		1500	
	Transduc	er Cab.		•	·	600		600	
	ESGLC					500		500	
•					•				
	Switch 4	gic				400		400	
		-							
	Plant TV	•				9 30		ð	
	•			•		•			
	Statalarm	Cab.	•			500		300	•
	Load Freq	•				600		600	
	/							·	·
	Cables		•		2500	5000	302	1750#	• .
	-	· · ·							
·	ES Term	Cab.				400		400	
				• .			·		
						43.5.		17:00	
		. <u>-</u>			-	41. 10		11,600	
		· · · · · · · · · · · · · · · · · · ·			- • -	71,116	1	000,00	
	· · · · · · · · · · · · · · · · · · ·							17,350	

.

.

.

ect <u>Electrical Equipment Heat Loads For</u>	Station Black	out.
	Y DRYAN	
e NC - Constant and the second design of the second second second second second second second second second sec	A _t	to chargent # 1
		56-4747
UNIT EQUIPMENT ROOM	1 P.	0A 6-16-72
	Watts	After 30 min
9.3 KVA Static Inverters IDZA, IDIB, IDIC, IDID	5600	3733
Iso. Diodes	1300	743
DC Distr. Cntr IDCA : IDCB	565	565
25 KVA Inverter IKU	3000	0
Cables	2500 30	7. 1750
Lighting (assumes 507. reduction)	6200	6200 9000
	34965	15,791
	19,165	12,991

DUKE POWER COMPANY

Station <u>OLONEE</u> Unit Rev. Unit Rev. Unit Unit LOAD	_ File No	Sheet6Of
	JH Bryan	6-11-92
net No.	• •	
	Atter	charact # 1
	10 H	6-16-92
UNIT Z CABLE ROOM	. Pa	1 = <u>7 + 11</u>
	Watts	After 30 min.
Lights (assumes 50% reduction)	10.900	10,900
Turb. Super. Cab.	500	0
Events Recorder	300	300
EHC Cab.	1500	1500
Transducer Cab.	600	600 _
ESGLC	500	500
Switch Logic	400	400
Statalarm Cab.	500	300
Load Freq.	600-	0
Cables Cassumes 507. reduction) 2500 707	1750
	17,700	16,250
ES Term. Cab.	406	400

18,100

.

16.650

Station_ <u>UCONEE</u> Unit Hev File No		Sheet Of
Subject <u>ELECTRICAL EQUIPMENT HEAT LOADS FOR</u>	<u>3. B. O.</u>	
By_JHBryd	in	Date _6-11-92
Prob No Checked By	11-44	Date
	OSC-	+ + 1747
	10H C.	-16-92
UNIT Z EQUIPMENT ROOM	Page_	8 07 11
	Watts	Atter 30 mil
Lighting (assumes 50% reduction)	6200	6200
7.3 KVA Inverteis 2DIA, 2DIB,	5600	3733
ZDJC, ZDID, ZKI, ZKX		
T_{e} D_{e} J_{e}		
LSO. JIOAES	1500	
NO DIAL C. H. INA & INAR	615	CI E
DC DISTR. CATE. LDCA : LDCB	76 3	560
20 KVA Tour tan 2 KV	2000	· · · · · · · ·
LJ KVA LAVATTER ZKU	3000	
Calles lass as 602 and the	707.	
Cables (assumes suit realition)	2300 -	1150
	: .	· · · · · · · ·
		· <u> </u>
	19.165 W	12.991
	· · · · · · · · · · · · · · · · · · ·	
	· · · · · · · · · · · · · · · · · · ·	
	· · · · ·	• •
	· · · ·	
		· · · · · · · · · · · · · · · · · · ·
	·	
· · · · · · · · · · · · · · · · · · ·	•	
		i

Station_	UCONEE ELECTORE	Unit	Rev	File No		Sheet 8	Of_//
subject	CLECTRICAL	EQUIPMEN.	<u>, мент Ц</u> I	HDS FOR BV JAY BI	<u>>tation B</u> Ryan	Date 6-11-1	2
Prob Ma			Checked	- ; <u>- * a / </u> Rv		Date	
100 140.			Uneckeu	оу	Attachner	Date	
					050-4	1747	
	UNIT 3	ONTROL R	nn		104 6	-16-72	··· :
				· · · · · · · · · · · · · · · · · · ·	Page	7- of 11	•
· · · · · · · · · · · · · · · · · · ·			WA	TTS	After 3	0 min	2
: · ·	COMPUTER		/3.8	50	0	* * * *	
-					· · · · ·		
(Unit Control	BJ.	7.17	+ 450	11 6.7	•	
}	Aux Bench B	d.	360	, ,	360	•	
sumes 2	Aux Bench Bd	Typers	105	-	105	۰۰ ر ۱۰ ۱۰	
duction	Vertical Bd		1500		1500		
	NI / RPS		4800	0 + 180	0		
	·:	· · ·	: •			•	
•	Ics	·	540	0 + 420	5820	· :	
	Future Cab.		3000)	3000		
	ES Cab.	·	1010)	1010		
	RZ	ł	350	0	350		
				×			
	Aux Cab.		2600)	2600		
		. ,		· .	·		
•	Data - Net	•	700	+ 850		·····	
		· · · · · · · · · · · ·	n An an			: <u></u>	
•	ICCM Cal	b	500	?	500		
	El	ect.	20	O	200	• • • • • • • • •	
÷.,	• • • • • • • • • • • • • • • • • • • •			· · · · ·	·	<u> </u>	
	Iransient. 1	Monitor	1000		1000	· .	
•		, F				· · · · · · ·	
	13000 Lomp	outer Equip	. 6771		<i>O</i>	· · · · · · · · · · · · · · · · · · ·	
• • •	· · · · · · · · · · · · · · · · · · ·	· · · · · · · · · · · · · · · · · · ·	· · · · · · · · · · · · · · · · · · ·		· .	····	÷
· • •	4020 Comp	uter Equip.	4229	۱۰۰ <u>م</u> اند المراجع المراجع المراجع المراجع المراجع المراجع المراجع المراجع المراجع المراجع المراجع المراجع الم مراجع المراجع ال	0		
,			2/:		······································		
	Jouth Enti	rance Vert. B	Dd. 162		762	· · · · · · · · · · · · · · · · · · ·	
			77,97	1 W	18 374 V		
·					i		

itation	CONEE	Unit	_ Rev	File N	0	Sheet9Cf
ubjeci_ <i>E</i>	ELECTRICAL	EQUIPMENT	HEAT	LOADS	FOR S.B.C)
	· · · · · · · · · · · · · · · · · · ·	··· ······ ··· ··· ··· ··· ··· ··· ···	· · · ·	JH	BRYAN	6-11-92
. 4.,	UNIT 3	CABLE ROOM	n		Atterch OSC 104 D	ment #/ -4747 6-16-92
					· · · · ·	
·				>	Watts	After 30 mi
	Lights la	ssumes 30 7.	reductie		15.275	15,275
	EHC Cab.	•			500	500
	Events Reco	rder		·	1800	1800
:	E S C L C		•			
					500	5700
	Switch Logic	<u>.</u>			400	400
	Ū					
,	ES Term.	Ceb.			400	400
	Plant TV				9 20	^
					1 30	U
	Statalarm				500	300
	Load Freg.				600	600
	Turk Sugar	Cab			34.0	0
	(- v · v · v · y · e ·		· .			U
	Computer	Cab.			7000	0
		-	•	\	-	707.
	(ables (as	sumos 507. r	eduction.		2500 -	
	Misc. Cabin	ets (ref. JCM le	+ter)		772	772
		• • • •		-		•
				•	31.537 W	Z1,797 W

DUKE POWER COMPANY

Station	Oconee Unit Rev.	File No.		_Sheet_/0_Of_/0
Subject_	ELECTRICAL EQUIPMENT HEAT	LOADS FO	R. S.B.O.	
		By_JH_Br	yan	6-11-92
we do		:	· · ·	
		×	Attachme	ent #1
		•	050-4	1747
· · ·	UNIT 3 EQUIPMENT ROOM		1/01+ G-	11 - 7 2
· .	•		Page -	<u>//</u> 8 · <u>//</u>
•			Watts	After 30 min.
· · ·	Lights lassumes 50%. reduction)	9000	9000
·				
	9.3 EVA Inverters 3DIA, 3DIB,		5600	3783
	SDIC, SDID, 3KI, 3KX			,
		•		
	Iso. Diodes		1300	743
	DC Distr. Cotr 3DCA : 3 DCB	,	565	565
	25 KVA Zoverter 3KU		3000	0
			7	6 7.
	Cables (assumes 50% reduction)		2500 -	- 1750
	· · ·			,

21,965

15,791 W

S	tati ubi	on_ ect								Un	it_		R	lev.		<u> </u>	File	e No)					_S	hee	t		_ Of_	
		- ut _														By.								_ C	Date				
Pı	rob	No	•										Cł	necl	ked	By.								[Date)			
										A	<u>tt a</u>	2	hm	e	h 7		2			0.	sc	- 0	17	4-	2				
													-		<u> </u>					1.	04	6	\$-,	16-	92	2			
					A	22	u	hε	d		T_{-}	<u>e n</u>	<u>np</u>	er	<u>a</u> -	<u>tu</u>	re	2.5			ρ.	7 -		1	e +	1			
																							-						
						. 	-																						
										-		<u> </u>	-	<u> </u>			<u>.</u>	0.5											
											14	R, C	<u> </u>	<u> 11R,</u>	AVO	=	75	- - -				· · ·	r.						
															~	Tw:	8.	r° F							<u> .</u>	<u> </u>	-		
							 								¥										<u>⊢</u> ₽.	en .	Roc	an	
							eTu	- 9	TF		201	tre	,	200	a						€-	Iw, p	- 72	F	Ara		TAI	R, AYO	6
	Τu	r bir	e	Bui,	P				TAIR	i =	7	·F		TAIA	AVE	= /	10	F*			ł	TuyA	= 8	54		- //			
	Τ,	ir, c	`= /	20%	-										×7	2 =	74	°F											
	TA.	R, AV	= /	200	F																	_							
							~/u	= 9	7°F		C.	ble	R	om				ļ.,			← /	w, p	= 9	2°F	A	4x.	Bu	ild.	'n
								<u> </u>	TAIL	, i =	7	4.F		AIR,	AVE	= /c	55	' ۶*	T .		~ 7	W, A	- 8-	*	TAIR	, i	TA	R,A	16
							<u> </u>	<u> </u>					<u> </u>		F	<u>T~ -</u>	80	۶°F								= '	95	°F	
_							e T	L = 1	0.7°F	<u> </u>											4 -	Tw, I	• - <	78 1	F				
							ļ	[<u> </u>	Lec	7.	Equ	<u>р.</u>	Roo.	<u>n</u>		*			<u> </u>			1			-		
									TAI	e, i	- 8	16 %	<u> </u>	an,	eve =	10	20°1	F				w, A	= 7						
•				·			<u> </u>								×	/ =	91	+		.	,								
·					 -			+			ļ																		
						· ·			7			$\overline{\tau}$		=	9.0	°F							 .						
									AL	K, L			, ~ ~	Ī												•			
					Tw	= 1	n. +	-/	A	SSU	mp	l	И	1.11	$\frac{1}{2}$	e; [,	~ y	7-	emp	<u> </u>									
				7	w,	p =		<i>'</i> ,		/	<u> </u>		<u> </u>	11	["			<i>''</i>	A	/ -	c-•A	+	10	Pe	4	Ro	m	
				7	u, 1	=		, .		,	,		<u> </u>	/,	ļ	• •			"	A.	j.a	<u></u> -	+	70	Au	x_	Bu	12	
				×										ļ							·				. 				
_				.*	TAi	4,40	6	tem	per	atu	1=5		1251		and a	10.	c 7	he		(• •	fro	1,	٢,	66		E	lec	¢.	
_			•		Eq	ام زر	n en	+	<i>R</i> • .		- ·	are	4	sec	0	75	<u>ca</u>	ele	ca / e	. Ye		00	lu.	Fo	- 1	hea	F		
					tr	91 1	f.	<u>></u> ^	.73	9	Lj	90	en	<i>†</i>	9/	29	5	7	he.	se	1-	n b	er:		er-e	0.	h / j		
-					es	T:n	7	<u>fe</u> s		ad		hay	<u> </u>	¥::	<i>[</i>	pr n	<i>f1</i>	om	f.	he	4	110	- /	1	Air,	AV	6		
\downarrow					95	r un	ed	4	+ /.	at +	r	<u> </u>	1 le.	1/9	10	ď	in	57	tep	55.	- 4	- 8	3	07	th	24			

Attachment 3 056-4747 104 6-16-92 Page 1 of 1

L.S. anderwood 5-14-92

Hydrogen generation with batteries at full charge

Assume T= 100°F

 $C = \frac{FC \times AH}{1000} \times K \times N$

C= ft³ of hydrogen per hour FC = Float current per 100A-It in ma A:H : amp hours @ 8-hr rate K = 0.016 ft³ N = Number of cells

FC = 11 ma per 100 AH 38 hr rate x Z (100°-777)= 33.7 ma per 100 AH AH = 1850 amp. hoors $38 \text{ hr rate } N = 120 \text{ cells per room (60 cells | better$ C = 33.7 ma x 1850 A.H x 0.016 Ft³ x 120100 100 :

C=1.198 ft³ hydrogen per hour per bottery room (2 batteries) when batteries are on float (power is available to chargers) generation will be reduced during a blackout when batteries are not being charged.





ATTACHMENT V

HISTORICAL SSF UNAVAILABILITY

YEAR	ORIGINAL	REVISED *
1985	2.7%	2.3%
1986	4.3%	3.2%
1987	3.7%	3.2%
1988	3.3%	2.8%
1989	13.0%	11.7%
1989**	N/A	3.6%
1990	3.9%	2.4%
1991	N/A	1.0%
1992	N/A	4.0%

Difference from the original due to treatment of operable/standby rather than available

**

×

Unwatering not considered for comparison

Historical availability has averaged 96.175%

CORE DAMAGE FREQUENCY - CDF

SSF UNAVAILABILITY & UNRELIABILITY	CHANGE IN CDF
5%	Base Case (4E-06)
8%	Increase < 1E-06
11%	Increase < 1E-06

ATTACHMENT VI

OCONEE NUCLEAR SITE STANDBY SHUTDOWN FACILITY DIESEL GENERATOR RELIABILITY PROGRAM

1.0 <u>PURPOSE</u>:

The SSF Diesel Generator program is intended to provide a high availability and reliability in accordance with good operating and maintenance practices. With maintaining an availability greater than 95% and ensuring high reliability, the intention is that the D/G will be "there for use" when needed.

This program will trend the inoperability, unavailability and the trigger values as defined by 10CFR50.63, NSAC-108 and NUMARC 87-00 Rev. 1 document. This information once compiled will be compared to industry standards and ensure we are meeting our equipment operability and regulatory commitments.

The SSF D/G is designed to provide electrical support for the equipment necessary to maintain the Oconee Units in stable hot shutdown conditions following a "Fire/Flood/Sabotage" event as described in 10CFR50, Appendix "R" and as a alternate means of maintaining hot shutdown in the event there is a "Loss of Offsite Power" in combination with the loss of both Keowee Hydro units as reviewed by the station blackout submittal to the NRC for 10CFR50.63.

2.0 **DEFINITIONS**:

2.6

- 2.1 Operability: Refers to Tech Spec definitions and requirements.
- 2.2 Availability: Measured by the number of hours the equipment is able to perform its function if called upon.
- 2.3 Reliability: Measured by the number of successful starts in a given period.
- 2.4 Load Demand: Counts as one load and one start demand.

1

2.5 Idle Start: The D/G is started and maintains a speed of 450 rpm within an acceptable range.

Auto-Idle Start: Demonstrate proper start from standby conditions and verify that the required design voltage and frequency is attained. For these tests, the SSF D/G can be IDLE started and reach rated speed on a prescribed schedule that is selected to minimize stress and wear.

2.7 Loaded Run:

Demonstrate \geq 3100 kW continuous rating of the SSF D/G, for an interval of not less than 1 hour after equilibrium has been attained. This test mav be accomplished by synchronizing the generator with Unit-2 Main Feeder Bus. The loading and unloading of the SSF D/G during these test should be gradual and based on a prescribed schedule that is selected to minimize stress and wear.

2.8 Emergency Start Test: Demonstrate that the SSF D/G Emergency starts from the standby condition and verify it reaches required voltage and frequency within acceptable limits and time. The generator should be loaded with the SSF ASWP placed in recirc. and separated from Unit-2 main feeder bus and run for greater than 1 hour.

2.9 Desoup Run: This is a loaded run of the SSF D/G for greater than 30 minutes at greater than 1600kW to ensure all unburned fuel is removed from the exhaust system. The loading and unloading of the SSF D/G during these test should be gradual and based on a prescribed schedule that is selected to minimize stress and wear.

3.0 <u>FORMULAS</u>:

- 3.1 Reliability = (Start Reliability) x (Load Reliability)
- 3.2 Start Reliability = $\frac{\# \text{ of Successful Starts}}{\text{Total } \# \text{ of valid demands to start}}$
- 3.3 Load Reliability = <u># of successful load-runs</u> Total # of valid demands to load

4.0 <u>DATA ACCEPTANCE and TESTING CRITERIA</u>:

- 4.1 A START is <u>not</u> counted if:
 - 4.1.1 An operator error that would not have prevented the D/G from being restarted and brought to load in a few minutes without corrective maintenance.
 - 4.1.2 A failure to start in the control room provided the D/G could be started locally.
 - 4.1.3 An incorrect trip signal that would not be operative in the emergency start mode.
 - 4.1.4 A malfunction of equipment that would not be operative in the emergency start mode.
 - 4.1.5 Minor water leaks and minor oil leaks that would not preclude operation of the D/G in an emergency.
 - 4.1.6 Intentional termination of the test because of alarmed or observed abnormal conditions that would not have ultimately resulted in significant emergency generator damage or failure.
 - 4.1.7 A failure to start because a portion of the starting system was disabled for test purposes, provided it is followed by a successful start with the starting system in its normal alignment.

4.2 A LOADED RUN is <u>not</u> counted if:

- 4.2.1 An operator error that would not have prevented the D/G from being restarted and brought to load in a few minutes without corrective maintenance.
- 4.2.2 An incorrect trip signal that would not be operative in the emergency start mode.
- 4.2.3 A malfunction of equipment that would not be operative in the emergency start mode.
- 4.2.4 Minor water leaks and minor oil leaks that would not preclude operation of the D/G in an emergency.
- 4.2.5 Intentional termination of the test because of alarmed or observed abnormal conditions that would not have ultimately resulted in significant emergency generator damage or failure.
- 4.2.6 A failure to load because a portion of the generator system was disabled for test purposes, provided it is followed by a successful loading with the generator system in its normal alignment.

4.3 Troubleshooting Test:

- 4.3.1 Troubleshooting tests during corrective maintenance (after a failure) should not be counted as demands or failures, except for the final successful test.
- 4.3.2 Test to discover the cause of a prior failure are not valid demands.
- 4.3.3 Test to prove the failed component has been repaired are not valid demands.
- 4.4.4 Test performed immediately after the D/G overhaul need not be considered valid.

4.4 Acceptable Data Values:

4.4.1 The standard for our SSF D/G to maintain is:

- 4.4.1.1 Availability of greater than 95%.
- 4.4.1.2 Reliability which does not exceed the double trigger value of 5/50, 8/100 demand failures from 10CFR50.63.
- 4.4.2 If the D/G exceeds the standard trigger value of 3 out of 20 demand failures then immediately corrective action should ensure common cause failure is not occurring.
- 4.4.3 If the D/G exceeds the double trigger value immediately a form of root cause analysis evaluation should occur to identify and correct the problem.

5.0 <u>Corrective Action Testing</u>:

- 5.1 The D/G shall demonstrate satisfactory performance after any repair which could affect its operability .
- 5.2 The D/G shall not be tested in any way beyond its design basis without a written engineering review.

6.0 <u>Surveillance Testing</u>:

Periodic surveillance testing must demonstrate continued capability and reliability of the SSF D/G to perform its intended function. The SSF D/G is considered operable if all monthly, quarterly and annually testing is current and satisfactorily complete by this program and Technical Specifications.

- 6.1 Monthly: Monthly testing of the SSF D/G shall demonstrate reliability per an Auto-Idle start.
- 6.2 Quarterly: Every quarter the SSF D/G shall be Auto-Idle started and Load tested.
- 6.3 Annually: Annually the SSF D/G shall demonstrate the capability by performing the following tests:

6.3.1 Auto-Idle Start.

6.3.2 Loaded Run.

6.3.4 Emergency Start Test.

7.0 <u>Maintenance and Surveillance Program</u>:

- 7.1 The preventative maintenance and surveillance program on the SSF Diesel Generator and associated equipment required for operation will be per the manufacturers (OM.351-164) and Electro-Motives Owners Group recommendations based upon industry historical data.
- 7.2 Deviations will be allowed from the programs as described in step 7.1, due to specific Oconee Nuclear Site's design, installation and the D/G's intended purpose.
- 7.3 Maintenance activities shall not be planned when either or both Keowee units are not available.
- 7.4 The Component Engineers shall maintain and trend D/G parameter data for equipment degradation / unreliability.
- 7.5 Unwatering of the Unit-2 CCW Intake piping should be kept to a minimum to ensure maximum SSF availability.

8.0 <u>Data Trending</u>:

8.1 Data Sources:

8.1.1 Unit 2 Unit Supervisors Logbook Diesel Generator Logbook

8.1.2 WMS Work Request Database

8.1.3 Completed Operations and Performance Procedures

- 8.2 Reliability information will be monitored and kept current by the System Engineer. This will require maintaining records on the SSF availability and operability times, recording reliability, trending equipment performance as recorded by the Testing Technicians and parameter monitoring program by the Component Engineers.
- 8.3 Operability time periods will be determined upon the definitions in the Technical Specifications and in the Operations Management Procedures.
- 8.4 Availability time periods will be determined as defined by INPO and in step 2.2.
- 8.5 Reliability will be calculated based on the last 20, 50, and 100 attempted starts and/or loaded runs of the D/G. These values, once calculated by Section 3.0, will be compared to the current acceptance criteria.
- 8.6 Assumptions on "Historical Data", prior 1/92, were made to complete the the SSF D/G Database. The following are the assumptions made when exact times could not be found in historical data.
 - 8.6.1 Tagouts for D/G PM's began at time 0500.
 - 8.6.2 Other equipment tagouts affecting D/G start time were at 0800.
 - 8.6.3 D/G Quarterly and Monthly PM's last 10 hours.
 - 8.6.4 Descup Procedure last 1 hour.
 - 8.6.5 Loaded Run performance testing last 1.5 hours.
 - 8.6.6 Descup and Loaded Runs performance testing last 2.5 hours.
 - 8.6.7 D/G becomes Available at the time of D/G start following PM's.
 - 8.6.8 D/G becomes Available at the time of D/G following known repairs.
 - 8.6.9 D/G becomes Operable when D/G is returned to Standby mode.
 - 8.6.10 Concurrent component failures causing a start failure count as one failure.

5

8.6.11	Concurrent component failures causing a load run failure count as one failure.
8.6.12	A start failure and a load run failure during the same test each count as separate failures.
8.6.13	Demands and failures during tests following maintenance where no failure was being repaired are generally valid(i.e. can be considered not valid where it is certain that the maintenance work itself caused the failure, and it is detected before returning the D/G to service).



ATTACHMENT VII

Historically, Keowee availability has been maintained in accordance with INPO PPIP methodology. In order to meet the recommendations of NUMARC 87-00, Appendix D, the following will be implemented at Oconee:

- 1) An accountable individual assigned to maintain reliability, availability and trigger value comparisons.
- 2) Development of reliability figures utilizing existing Keowee data.
- 3) Define the Keowee reliability and availability nomenclature in the program.
- 4) Define the data acquisition roles in terms of positions for program consistency which is independent of specific personnel.
- 5) Define Keowee subcomponents and support systems.
- 6) Develop the methodology within the program to document action required and that taken based on trigger values.
- 7) Establish and maintain Keowee equipment failure history.
- 8) Develop a Keowee reliability data system for access to reliability / availability figures, and equipment failure history.

Programs are in place which perform the required testing, maintenance, and data acquisition. Problem reporting and close out processes which ensure resolution are in use, with the information retained and retrievable in data bases. In order to meet Appendix D, the current activities will be defined in a Keowee specific program and reliability / availability numbers will be generated.