

# **Official Transcript of Proceedings**

## **NUCLEAR REGULATORY COMMISSION**

Title:                   Advisory Committee on Reactor Safeguards  
                              US-APWR Subcommittee

Docket Number:     (n/a)

Location:             Rockville, Maryland

Date:                  Thursday, August 20, 2015

Work Order No.:     NRC-1832

Pages 1-457

NEAL R. GROSS AND CO., INC.  
Court Reporters and Transcribers  
1323 Rhode Island Avenue, N.W.  
Washington, D.C. 20005  
(202) 234-4433

## DISCLAIMER

### UNITED STATES NUCLEAR REGULATORY COMMISSION'S ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

US-APWR SUBCOMMITTEE

+ + + + +

THURSDAY

AUGUST 20, 2015

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Subcommittee met at the Nuclear  
Regulatory Commission, Two White Flint North, Room  
T2B1, 11545 Rockville Pike, at 8:30 a.m., John W.  
Stetkar, Chairman, presiding.

COMMITTEE MEMBERS:

JOHN W. STETKAR, Meeting Chairman

RONALD G. BALLINGER, Member

DENNIS C. BLEY, Member

DANA A. POWERS, Member

JOY L. REMPE, Member

STEPHEN P. SCHULTZ, Member

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

GORDON R. SKILLMAN, Member

DESIGNATED FEDERAL OFFICIAL:

GIRIJA S. SHUKLA

ALSO PRESENT:

ROBERT HALL, MHI

MIKE JUNGE, NRO

SAMUEL S. LEE, NRO

KENJI MASHIO, MHI

PAUL PIERINGER, NRO

RYAN SPRENGEL, MNES

WILLIAM WARD, NRO

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

## CONTENTS

Opening Remarks and Objectives.....	4
Staff Introduction.....	6
Discussion of the US-APWR DCD Chapter 18 and Topical Report MUAP-07007-P.....	14
Discussion of the US-APWR DCD Chapter 18 and Topical Report MUAP-07007-P.....	76
Discussion of the SERs Related with US-APWR DCD Chapter 18.....	136
Opportunity for Public Comment.....	327
Subcommittee Discussion.....	328
Adjourn	

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

P-R-O-C-E-E-D-I-N-G-S

8:35 a.m.

CHAIRMAN STETKAR: -- the Water Reactor Subcommittee. I'm John Stetkar, chairman of the subcommittee meeting. ACRS members in attendance are Steve Schultz, Dennis Bley and Ron Ballinger. We will be joined sometime this morning by Joy Rempe and Dana Powers, and perhaps Dick Skillman.

Mr. Girija Shukla of the ACRS staff is the designated federal official for the meeting. The subcommittee will discuss the safety evaluation reports associated with DCD Chapter 18, Human Factors Engineering, and Topical Report MUAP-07007-P, Human System Interface System Description. The DCD applies for the US-APWR design certification, and the topical report applies for the general HIS interface. We'll hear presentations from Mitsubishi Heavy Industries, Mitsubishi Nuclear Energy Systems, and the NRC staff.

The subcommittee will gather information, analyze relevant issues and facts, and formulate proposed positions and actions, as appropriate, for deliberation by the full committee. Your rules for participation in today's meeting have been announced as part of the notice of this meeting

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 previously published in the Federal Register. Parts  
2 of this meeting may need to be closed to protect  
3 proprietary information for Mitsubishi or other  
4 parties. I'm asking the NRC staff and the Applicant  
5 to identify the need for closing the meeting before  
6 we enter into such discussions, and then to verify  
7 that only people with the required clearance and need  
8 to know are present.

9 We'll work through that as we get into  
10 various topics. A transcript of the meeting is being  
11 kept and will be made available, as stated in the  
12 Federal Register notice. Therefore, we request that  
13 participants in this meeting use the microphones  
14 located throughout the meeting room when addressing  
15 the subcommittee. The participants should first  
16 identify themselves and speak with sufficient clarity  
17 and volume so that they may be readily heard. A  
18 telephone bridge line has also been established for  
19 this meeting.

20 To preclude interruption to the meeting,  
21 the phone will be placed in a listen-in mode during  
22 the presentations and committee discussions. We'll  
23 open the bridge line later to see if there any members  
24 of the public who want to make comments regarding the  
25 proceedings. Please silence your cell phones during

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the meeting. I'll also alert those of you who we've  
2 not seen for a while that we have a little bit of a  
3 different protocol. The microphones on your desk up  
4 front there, they're very, very, very sensitive.  
5 They cause problems especially with the bridge line  
6 when they're on. What we're doing is we're keeping  
7 them off unless you're speaking.

8 To turn them on, just press -- there's a  
9 little area right in front of you that says "Push,"  
10 really isn't a push button, but if you push on it,  
11 the little green light will come on, so try to  
12 remember to do that. We'll chastise you  
13 appropriately if you don't do that. That helps both  
14 our recorder because it's not so much crashing in his  
15 ears, and in particular, folks on the bridge line  
16 because they're really sensitive. With that, we'll  
17 now proceed with the meeting. I call upon Bill Ward,  
18 from New Reactors, to open the proceedings.

19 MR. WARD: Thank you, John. Good  
20 morning, everybody. My name is Bill Ward. I'm the  
21 lead project manager for the US-APWR design  
22 certification. At this time, the review is in what  
23 we call the slowdown. MHI is focused on supporting  
24 a Japanese restart, so we're doing just a few  
25 chapters. Chapter 18 was the first that we wanted

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 to move forward. We also are working on 7 and 18,  
2 so it's not a full review at this time. What we are  
3 reviewing is certainly very active. We'd like to  
4 thank the subcommittee for having us here today to  
5 present Chapter 18 on human factors engineering or  
6 HFE, and the reference topical report. This is the  
7 final technical chapter of the APWR design  
8 certification to go through Phase 3.

9 Although this is Phase 3, the SER for  
10 Chapter 18 was written with no open items. I think  
11 that's a measure of the success of the support image  
12 I provided in answering our questions throughout the  
13 long review. We hope we can answer all of your  
14 questions just as well today. Remaining in the  
15 review for Phase 2/Phase 3 is Chapter 1, Seismic and  
16 Fukushima Related, and some sections of Chapter 14.  
17 We have MHI and NRC HFE technical staff here this  
18 morning, as well as someone supporting I&C work.

19 They're here to answer your questions,  
20 as well as make presentations. I can introduce them  
21 later. We wanted to say that we find it particularly  
22 helpful, at the end of the session, to restate any  
23 specific actions or questions you may have, so we can  
24 write them down. We'll certainly review the  
25 transcripts when they become available. At this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 point, I think I'll turn it over to Ryan.

2 CHAIRMAN STETKAR: Bill, I don't know  
3 whether -- I know we're going to talk about, I think,  
4 the topical report first. I guess I'll ask you now,  
5 and maybe you want to postpone the answer until we  
6 talk about the DCD chapter review. The version of  
7 the DCD Chapter 18 that we received for review is  
8 Revision 4 --

9 MR. WARD: Correct.

10 CHAIRMAN STETKAR: -- of the design  
11 certification design control document. That version  
12 of Chapter 18 explicitly refers to both the topical  
13 report, but a much earlier revision of the topical  
14 report, and to several technical reports which were  
15 not included in the staff's review. The staff  
16 reviewed different technical reports and, indeed,  
17 much later revisions of several technical reports.

18 I got really confused about what the ACRS  
19 is being asked to review at this subcommittee meeting  
20 because the things that are cited in the staff's SER  
21 are not cited in the design control document chapter  
22 that we were asked to review, which leads us to a  
23 real disconnect, in terms of what is the supporting  
24 information? You may want to hold off -- so I'm  
25 really curious about what we, the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       subcommittee -- granted, we are only the  
2       subcommittee, but if this comes to the full ACRS, the  
3       full ACRS needs to have a coherent set of  
4       documentation and an SER written to that  
5       documentation, and we don't have that right now,  
6       quite honestly.

7               MR. WARD: Actually, Revision 4 of the  
8       DCD is the latest revision. Revision 5 is in  
9       process, and I have a working copy of that, MHI does.  
10      The various reference reports have been updated as  
11      we went through. They don't reflect in Revision 4  
12      of the DCD, but they are being reflected in Revision  
13      5.

14             CHAIRMAN STETKAR: That would be really  
15      good if we had Revision 5 of the DCD with that  
16      traceable (Simultaneous speaking).

17             MR. WARD: Because of the slowdown, it's  
18      not been issued, but what we could do is see if we  
19      can get a copy of what Revision 5 looks like at this  
20      point.

21             CHAIRMAN STETKAR: It's kind of late for  
22      this subcommittee meeting and the hundreds of pages  
23      of material that I know I read through to do that.  
24      I'm pretty annoyed that we're in this situation. For  
25      the subcommittee, we're focused on more technical

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 information, and it's annoying that we're in a  
2 situation that we're in. But I will tell you that  
3 if it comes to the full committee, we need a coherent  
4 set of documentation. We need a version of the  
5 design control document that points to the operable  
6 supporting technical reports that indeed were used  
7 to support that version of the -- and we need a safety  
8 evaluation that points to that version of the design  
9 control document and the applicable technical reports  
10 (Simultaneous speaking).

11 MR. WARD: I understand the problem.  
12 Let me assure you that all the technical reports we  
13 provided are the latest versions.

14 CHAIRMAN STETKAR: Oh, they are, once I  
15 found them.

16 MR. WARD: The only thing that was not  
17 necessarily the latest version is the fact that it  
18 was Rev. 4 of the DCD, and it may refer to earlier  
19 versions of technical reports. But all the reports  
20 we provided, the topical report -- the safety  
21 evaluation was written to all the latest topical and  
22 technical report versions and to the RAI response,  
23 which provided where changes were being made in the  
24 DCD.

25 CHAIRMAN STETKAR: All right.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. WARD: I can work with MHI to provide  
2 a --

3 CHAIRMAN STETKAR: If you want an ACRS  
4 letter -- now the topical report, I believe, is  
5 consistent. We are working toward Revision 6 of  
6 MUAP-07007-P. That seems to be referenced  
7 consistently, in terms of the SER of the topical  
8 report, and obviously the topical report is that  
9 version. If that comes to the full committee, I  
10 think we're clear on what it is, in fact, the  
11 committee's being asked to review, but not right now,  
12 in the case of the information we have on the DCD  
13 itself, Chapter 18.

14 MR. SPRENGEL: Okay, this is Ryan  
15 Sprengel with MNES. I'll maybe bring that discussion  
16 up in more detail when we get to the Slide 4. It's  
17 near the beginning of the presentation.

18 CHAIRMAN STETKAR: I just wanted to get  
19 it out of the way at the beginning here because it  
20 sounds like it's procedural, and in my cases it is,  
21 but it's very, very important, especially for the  
22 ACRS as a full committee, to be very clear on what  
23 it is that the members are being asked to review, so  
24 there's no uncertainty about disconnects between  
25 supporting information in technical reports versus

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 what's cited in the (Simultaneous speaking).

2 MR. WARD: I just want to emphasize that  
3 the safety evaluation reports were written to the  
4 latest versions of all the technical reports. They  
5 were provided. The only thing that was not  
6 necessarily the latest was the DCD Chapter 18. We  
7 were uncertain about whether or not we should provide  
8 a draft copy of Revision 5 of the chapter. We were  
9 relying on the REI responses to sort of bring Chapter  
10 18 up to date.

11 CHAIRMAN STETKAR: You said, Bill, you  
12 provided them. I found them in ADAMS once I had the  
13 report numbers, but --

14 MR. WARD: I provided the DCD with all  
15 the reports.

16 CHAIRMAN STETKAR: Okay, maybe we had an  
17 internal problem.

18 MR. WARD: Okay.

19 CHAIRMAN STETKAR: Sorry. I found all  
20 of the technical reports. They were all in ADAMS,  
21 once I had the numbers and could go look up the  
22 revision numbers and things. Okay. We did receive  
23 the confirmation of Rev. 4 of the DCD. Anyway, it's  
24 difficult because it appears that some technical  
25 reports that are cited in the DCD have died and gone

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 away. They were revised, and then they died and went  
2 away. It subdivided into other technical reports.  
3 It's pretty difficult (Simultaneous speaking).

4 MR. WARD: That's true. Some were  
5 formally withdrawn. I provided that letter  
6 withdrawing those, as well.

7 CHAIRMAN STETKAR: Okay. I didn't see  
8 that, either. Okay, we'll have to check internally.  
9 Maybe we have a problem. Sorry about that.

10 MR. WARD: That's fine.

11 CHAIRMAN STETKAR: But it is -- we still  
12 need to get it cleaned up and to the full Committee.

13 MR. WARD: It's part of the difficulty  
14 of being in the slowdown here.

15 CHAIRMAN STETKAR: By the way, while  
16 we're talking about programmatic things here, does  
17 the staff and MHI want a letter from the ACRS? Until  
18 this point, we have written letters -- they're  
19 interim letters because of the stage of the review  
20 that we've gone through, but we have written interim  
21 letters on all the other chapters that have come  
22 before us up to this point, with the exception of 1,  
23 and I think two sections of Chapter 3 that you  
24 mentioned that still haven't come before the  
25 subcommittee or the full committee.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           Do you want letters from the ACRS on both  
2           this section of the DCD, Chapter 18, and probably,  
3           more importantly, the topical report? If you do,  
4           we'll need to work on a schedule to make that happen  
5           at some point.

6           MR. WARD: Yes, we do.

7           CHAIRMAN STETKAR: You do? Okay. We'll  
8           have to plan for that among ourselves. We'll do that  
9           offline, once we decide a little bit better what it  
10          may entail. So that we can get some of this  
11          procedural/programmatic things out of the way, at  
12          least, do any of the other members have any comments  
13          or questions that you want to ask/make at this time?  
14          With that, we'll let Ryan start. Ryan.

15          MR. SPRENGEL: Ryan Sprengel, MNES,  
16          again. I'm glad to be back. We've been going, just  
17          at a slower pace, as Bill mentioned. We are still  
18          definitely interested in getting an ACRS letter not  
19          only for Chapter 18, but also for the HFE topical  
20          report.

21          With me today, Kenji Mashio and Bob Hall,  
22          as well as Yamashita-san on the end, and some  
23          additional participants from Japan over the bridge  
24          line, as well as in the audience. A brief overview.  
25          Basically, we'll give some introductory information

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 and the structure of our material, followed by the  
2 US-Basic HSI, covered mostly from the topical report,  
3 and then the HFE program management plan, which is  
4 focused more on the DCD application, as well as the  
5 implementation plans or technical reports that were  
6 mentioned. First section brings us to the area that  
7 was already brought up. We have been well aware of  
8 the potential for disconnect between a submitted DCD,  
9 which is kind of a fixed moment in time and does not  
10 necessarily happen excessively because that can  
11 create even more confusion by continually revising  
12 the DCD.

13 What we've done in the past is submit  
14 what we call update tracking reports, which pull  
15 together the markups that we've committed to in REI  
16 responses. Over some time, we have a number of REI  
17 responses, and we would submit an update tracking  
18 report pulling all those changes together. That, in  
19 turn, can lead to a potential confusion once those  
20 build up because they're just the changed pages. So  
21 the Item No. 2 is our update tracking report, the  
22 last one submitted, and that had just the changed  
23 pages.

24 To facilitate the review -- and the  
25 intent would have been to facilitate your review, as

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 well -- we submitted Item No. 3 there in 2014. That  
2 was a little bit different, in that we submitted  
3 basically what would be future DCD Rev. 5. We  
4 cleaned it up, and it would look like the future DCD  
5 Rev. 5. It was submitted to the NRC, and it should  
6 be available to you. That would show basically the  
7 current state of the design certification document.  
8 That is the version that the staff's SER refers to.

9 CHAIRMAN STETKAR: Is that -- is it in  
10 ADAMS? Because if I searched on -- I don't remember  
11 the MUAP number of the DCD. The last revision I  
12 could find in ADAMS was Rev. 4.

13 MR. SPRENGEL: That is accurate.

14 CHAIRMAN STETKAR: I didn't have the UAP,  
15 but it's typically not filed in ADAMS under your UAP.  
16 It is?

17 MR. SPRENGEL: That's correct, sorry.

18 CHAIRMAN STETKAR: Your UAP  
19 (Simultaneous speaking).

20 MR. SPRENGEL: It is not logged into  
21 ADAMS using our UAP, but the UAP number is part of  
22 the document title, so it's also -- it is searchable.

23 CHAIRMAN STETKAR: If I knew what that  
24 was, I could've searched on that, but I didn't.

25 PARTICIPANT: Right, that would've been

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 helpful.

2 MR. SPRENGEL: My understanding of how  
3 the staff have incorporated this document is that it  
4 has become a confirmatory item to make sure that the  
5 changes that have been submitted as part of that -- a  
6 draft Rev. 5 actually get rolled into Rev. 5. It's  
7 part of our QA and document control process --

8 CHAIRMAN STETKAR: Even that's not  
9 documented in the SER for Rev. 4. There's  
10 nothing -- it is?

11 MR. WARD: Yes, I think there's a single  
12 confirmatory item.

13 MR. PIERINGER: There's a confirmatory.  
14 Paul Pieringer. There's a confirmatory item for the  
15 ITAAC, which is Chapter (Simultaneous speaking).

16 CHAIRMAN STETKAR: For the ITAAC.  
17 That's the only one.

18 MR. PIERINGER: There's not a  
19 confirmatory item in Chapter 18. Our thought was  
20 that every chapter has to update to Rev. 5, and that  
21 there was a generic confirmatory item. But I don't  
22 believe, from talking to Bill, that exists either,  
23 so we do not have the confirmatory item you were  
24 looking for.

25 CHAIRMAN STETKAR: The only confirmatory

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 item, you're right, is the one on the ITAAC. I  
2 didn't interpret that as -- it's a typical  
3 confirmatory item, closing out -- I think it's V&V  
4 or something like that in the ITAAC process.

5 MR. WARD: I stand corrected.

6 MR. SPRENGEL: So Item No. 3 should  
7 address your specific concern, in terms of how the  
8 technical reports, topical report, and the DCD all  
9 fit together. That should be available to you  
10 through some process.

11 MEMBER BLEY: As of today, I'm  
12 just -- it'd be nice to have something like this as  
13 we begin to get ready for the next meeting, so we  
14 know what's there. This would let us go back and do  
15 better this time.

16 PARTICIPANT: Agreed. Okay.

17 CHAIRMAN STETKAR: The fact of the matter  
18 is we are where we are today. You'll hear  
19 substantive feedback from us on, I believe, the  
20 reports that you're going to pull up on these next  
21 two slides.

22 MR. SPRENGEL: That last --

23 CHAIRMAN STETKAR: It was an ordeal.

24 MR. SPRENGEL: That last summary markup  
25 did not change anything. It was really just pulling

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 together the other changes. All the information is  
2 still the same. It's just in an easier to process  
3 format. With that, you already did bring up about  
4 the shifting of use of technical reports. You are  
5 correct that some of the technical reports, in  
6 concert with the staff review, some of those reports  
7 were withdrawn as no longer necessary to support the  
8 review and application. So the list we have here on  
9 this page, and then the subsequent page, shows the  
10 complete set of topical and technical reports. The  
11 topical we'll look at separately next, and then the  
12 technical reports are numerous. The changes have  
13 been made.

14 This is a kind of very clean approach,  
15 we think, that has worked very well for the review,  
16 after a significant amount of effort on our part  
17 cleaning them up, organizing them. We'll go through  
18 some of how the format is very consistent within them  
19 to try to facilitate the communication and  
20 understanding of those documents. This page, and  
21 then the next, will list the number of technical  
22 reports, the implementation plans that we'll go  
23 through in some more detail, in terms of what those  
24 are and how they were created.

25 Then the last section is two internal

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 documents that we had, and we provided those for  
2 audit for the staff, one a number of years ago, and  
3 one last year, for the Style Guide and the OER.  
4 We've already touched on one of our areas, the  
5 topical report, 07007, looking for documentation of  
6 what the US-Basic HSIS is, and of course, looking for  
7 approval from the NRC on that. Through the  
8 development of it, we've documented the genesis of  
9 it, where the basic foundation came from in Japan on  
10 developing over to the US-Basic HSIS, including the  
11 simulator, which some have attended and gone through  
12 demonstrations at. That process will be gone over  
13 again, as well, here today and how we use the  
14 simulator in our development process.

15 Also, of course, this is the top point  
16 of our program, leading further down to the  
17 implementation plans that we'll discuss as part of  
18 the support of the design control document through  
19 some connections with all the documents. Technical  
20 reports, I'm mainly looking at the eight  
21 implementation plans, but we also have the HFE  
22 program management plan, as well. We'll kind of  
23 summarize all this information.

24 I know the staff, of course, will present  
25 their review and conclusions on it which, from our

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 understanding, is a very positive result, in terms  
2 of the final work that we ended up with and submitted.  
3 I mentioned our cleanup process. Part of it was  
4 standardizing how the documents are formatted to,  
5 again, make it easier for the communication of  
6 information, and also the review of it. These  
7 sections are applied throughout the PMP, as well as  
8 the eight implementation plans, again, to standardize  
9 how we're communication information and getting that  
10 provided to the staff for review. There's two  
11 caveats. One of those is they tie into the changes  
12 that were already mentioned. Two areas, the  
13 procedure development and the training program, were  
14 shifted, in terms of the responsibility for review  
15 on the staff side.

16 So that review is credited as part of  
17 Chapter 13. As a reminder, Chapter 13 has gone  
18 through Phase 5, so that review is a little further  
19 along than most of our chapters. We're in a good  
20 position with that chapter. The other area that had  
21 a change was the HPM area. That became a COL item  
22 that would be the responsibility for the COL to  
23 submit. That's one that based on where we were, and  
24 through the process of going into a slowdown mode,  
25 that has not been pursued yet by a COL applicant.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: Ryan -- I'll let you  
2 get through this before I ask. I have a leading  
3 question that you may not want to answer  
4 (Simultaneous speaking).

5 MR. SPRENGEL: Those are our favorite.  
6 I mentioned the two other areas. Of course, we had  
7 the Style Guide that we provided and the OER results.  
8 Those were two documents internal to MHI not  
9 submitted on the docket, but available for audit, and  
10 the staff's audit report is available. In terms of  
11 what is remaining, ITAAC has already been mentioned.  
12 We'll show that table. There were some changes to  
13 our ITAAC for this area. Then we have a number here,  
14 seven areas that we'll be submitting results summary  
15 report.

16 When we look back to the content of the  
17 IPs, one of the areas is the result summary report.  
18 There's detail contained within the IPs that we'll  
19 provide in a review that basically commit to what  
20 will be contained. It's very clear, in terms of what  
21 the process is and what will be provided in the future  
22 in these different areas.

23 CHAIRMAN STETKAR: That gives me an in  
24 to ask a leading question. I, personally, was  
25 misguided. I read the DCD chapter first, and I went

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 and read the technical reports that were referred to  
2 in the DCD chapter before I went to the SER because  
3 that's just the way I do things. Should have done  
4 it reverse because I wound up reading a whole bunch  
5 of stuff twice. What I noticed, though, in some of  
6 the technical reports that are cited in DCD Rev. 4  
7 that either have been withdrawn, or have been  
8 subdivided in some cases, there were some results  
9 available in those previous technical reports that I  
10 found interesting and useful. I'll talk about some  
11 of them later. Those seem to have been all purged  
12 from the current technical reports, which are, I  
13 think, wholly focused on implementation plans, as you  
14 mentioned. You said the format has been laid out  
15 such that there is a section for results, should they  
16 be available.

17 That obviously was a conscious decision  
18 to remove that information. Was it prompted by the  
19 staff, or did you guys make it? That's the leading  
20 point of my question. Because we've gone from  
21 something, in my opinion, that actually had some  
22 supporting technical content, to now something that  
23 is much more just programmatic and plan oriented, in  
24 terms of the material available, both for our review  
25 of the DCD and the supporting technical reports and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the staff's review of those technical reports, in  
2 other words, signing off that yes, it sounds like the  
3 programs and plans are okay, but not looking at any  
4 actual results.

5 MR. HALL: Bob Hall, contractor to  
6 Mitsubishi. That change was done intentionally, and  
7 it was done intentionally because we got into  
8 confusion during a review cycle as to what we were  
9 supplying? We're living within the NUREG-0711  
10 world, which has two sets of documents that get  
11 submitted, plans and results. When you saw that  
12 outline that we had up, where it talked about  
13 results, that was simply the content of the results  
14 report, not results of the analysis. The thought  
15 was to separate them because the results that were  
16 included in some of the implementation plans were  
17 illustrative examples, incomplete, and pull them  
18 apart and put everything into the results summary  
19 reports when, in fact, they're presented. An example  
20 of that would be the early OER report had results in  
21 it --

22 CHAIRMAN STETKAR: Yes, it did.

23 MR. HALL: -- but now it's two pieces.  
24 The implementation plan -- the documents you reviewed  
25 are exactly what 0711 asks for, the plan of how to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 do it. Those results were the audited document that  
2 Ryan showed up on his list of documents. It was into  
3 a results-type report, two separate documents. That  
4 was the intent of doing it, just to clearly  
5 distinguish process versus results.

6 CHAIRMAN STETKAR: What that does, from  
7 the ACRS's perspective, is that it removes the  
8 technical content from our review. We're now asked  
9 to review process, rather than content. Because, as  
10 I said, I was misguided. I reviewed the references  
11 in the DCD. I had a few questions on the operating  
12 experience and how it was relevant and things like  
13 that. Now I can't ask those questions because, for  
14 example, we don't have that operating experience. We  
15 will, in fact, never see it because it's not  
16 completed until after the COL is issued, as best as  
17 I can tell, in terms of the phased approach. That's  
18 apparently the way people want to run the process,  
19 and I guess we have to live within that. It's just  
20 annoying. You may hear about that.

21 MR. PIERINGER: Paul Pieringer, NRC.  
22 That's just one bad side effect of the DAC process.  
23 We're trying to change that. I'll go into more  
24 detail during my presentation.

25 CHAIRMAN STETKAR: See, Paul, but you're

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       introducing the DAC process, where it didn't exist  
2       previously. We had technical information available  
3       to support part of the design. We had it. You're  
4       now introducing stuff that will become, whether you  
5       want to call it DAC or ITAAC. You are now pushing  
6       things out into that world that, at least the ACRS  
7       has been trying to advocate, ought not to happen. If  
8       the staff is trying to do that, you're going to hear  
9       about it.

10               MR. PIERINGER: Okay.

11               MR. LEE: This is Sam Lee from the  
12       licensing group. Thank you for that comment. We  
13       appreciate the comment. Please understand, for the  
14       record, that this is a Commission policy that we're  
15       following. This is not a staff's unilateral decision  
16       to go this route.

17               CHAIRMAN STETKAR: Your turn.

18               MEMBER BLEY: Oh, come on. The whole  
19       business with DAC was put in place -- we've written  
20       a bunch of letters on this in the past -- as a stop  
21       gap because information wouldn't be available. If  
22       information's available, then putting it off until  
23       later isn't even in the spirit of where DAC came  
24       from.

25               CHAIRMAN STETKAR: Just for the record.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 By the way, although I had questions, I found a lot  
2 of that stuff really useful because I could  
3 see -- although some of it was illustrative, some of  
4 it was identified as perhaps incomplete, you complete  
5 the process. It was pretty useful information.

6 MR. SPRENGEL: I think one of the  
7 challenges is the iterative nature. Some of the  
8 intent is not to just strip away that detail. It's  
9 to not present that detail as a final product, I  
10 guess, because it's not. We understand your  
11 challenge, and I think we'll continue to discuss that  
12 and hope to address maybe some of those concerns.  
13 ITAAC was mentioned. There was changes. I know the  
14 staff will present some more detail on those changes,  
15 so we've displayed the final two ITAAC for this  
16 related area coinciding with parts of the kind of  
17 staged process that we're following.

18 Finally, pulling all this together in  
19 kind of a graphical image here, we have the topical  
20 report, of course, that we've presented, as well as  
21 the DCD area, which includes the technical reports  
22 with the implementation plans, as well as the PMP.  
23 Following the licensing phase, we'll, of course,  
24 implement those plans and, ultimately, document the  
25 results in the results summary report, which will be

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 available for staff through docketing, auditing, or  
2 inspection space. We will now transition into the  
3 topical report area, and Kenji Mashio will present.

4 MR. MASHIO: My name is Kenji Mashio,  
5 from MHI. I'm engineering manager. I'm going to go  
6 through the Basic HSI features described in --

7 CHAIRMAN STETKAR: Kenji, if you can  
8 either move to the microphone a little closer or  
9 speak a little louder, it will help our transcript.

10 MR. MASHIO: I'm going through the Basic  
11 HSI features described in the Topical Report  
12 MUAP-07007. The document structure includes the  
13 following document subject, which includes concept  
14 of operation and control room and display overview  
15 and display navigation, operational VDU display,  
16 safety VDU, alarms.

17 CHAIRMAN STETKAR: Kenji, please be  
18 careful to speak up because our transcript picks up  
19 off the microphones. We have a lot of trouble  
20 following it later.

21 MR. MASHIO: Okay. This subject  
22 continues on the next slide.

23 CHAIRMAN STETKAR: Before you get into  
24 the technical concepts, I want to make sure that I  
25 understand, at least. The US-Basic HSI that we're

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 being asked to review under the topical report is not  
2 the US-APWR HSI. Is that correct?

3 MR. SPRENGEL: That is correct.

4 CHAIRMAN STETKAR: Thank you. That's  
5 important because it's too easily confused between  
6 are we accepting, in the topical report, the US-APWR  
7 HSI versus what I think, in my mind, as the HSI shell,  
8 if you will. I want to make sure that we're all  
9 clear that during the topical report, we're thinking  
10 about a generic framework or shell or however you  
11 want to characterize it, and not the US-APWR. When  
12 we get into Chapter 18, it then morphs from the shell  
13 to become somewhat more specialized to US-APWR. Is  
14 that fair, Ryan? If it's not, make sure we clearly  
15 understand it because it's a little bit -- there's a  
16 gray area in that transition.

17 MR. SPRENGEL: Yes. I think the only  
18 thing I hesitate about is the use of the word generic  
19 because it's a very detailed shell. There are a lot  
20 of pieces, I agree, that will be refined and  
21 specified for the US-APWR. There is a stage going  
22 on, but we have a pretty strong foundation, I think.

23 CHAIRMAN STETKAR: But I call it generic  
24 in the sense that you're asking for approval of the  
25 topical report, such that that -- if you have a better

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 term, use it -- such that that shell --

2 MR. SPRENGEL: The generic application.

3 CHAIRMAN STETKAR: Thanks.

4 MR. SPRENGEL: That's correct.

5 CHAIRMAN STETKAR: The generic  
6 application could be used, for example, in upgrading  
7 the existing analog instrumentation control systems  
8 for an operating nuclear power plant in the United  
9 States with -- and it's clear that it is linked -- to  
10 the MHI digital I&C system that is implemented, from  
11 the operator's perspective, through this generic  
12 interface, if I've characterized that correctly.

13 MR. SPRENGEL: That is correct.

14 CHAIRMAN STETKAR: That's why I'm  
15 characterizing it generically. I could take the old  
16 analog stuff in Operating Plant X in the United  
17 States, provided that there is a topical report  
18 endorsing the supporting I&C framework, replace the  
19 relays and switches and whatever with that digital  
20 framework, and tear out the guts of the control room  
21 and put this new interface in the control room. I'd  
22 have to specialize it, obviously, for the parameters  
23 at that plant, but that's why I'm calling this a  
24 generic. It's not (Simultaneous speaking).

25 MR. SPRENGEL: Right. The only caveat

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 is right now, the application of the HSIS is  
2 connected to our digital I&C application, as well,  
3 which, as you know, is right now not being pursued  
4 for other applications licensing. You're  
5 (Simultaneous speaking).

6 CHAIRMAN STETKAR: There was an if.

7 MR. SPRENGEL: Yes.

8 CHAIRMAN STETKAR: There was an if in  
9 there, and it was an important if.

10 MR. SPRENGEL: There is some additional  
11 licensing work that would be needed on the digital  
12 I&C side to use this HSIS for operating plants.

13 CHAIRMAN STETKAR: But again, from the  
14 ACRS perspective, from our review perspective, it's  
15 important for us to think about MUAP-07007 in that  
16 generic context, that it isn't necessarily -- it is  
17 being proposed for use for US-APWR as part of the  
18 design certification, but we need to think about it,  
19 also, in its potentially broader context because it  
20 could be -- they're asking for that safety evaluation  
21 of the topical report that could, in principle, be  
22 used for other applications, other operating plants.

23 MR. SPRENGEL: Yes, that's correct.

24 CHAIRMAN STETKAR: If the digital I&C  
25 topicals were approved. It's subtle, but it's really

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 important for us when we start thinking about asking  
2 questions because it's too easy to morph into what  
3 we know about US-APWR, rather than staying kind of  
4 one step back a little bit.

5 MEMBER BLEY: Does that imply for us that  
6 we need to look at this piece of what we're seeing  
7 today as something we might want to write a separate  
8 letter on?

9 CHAIRMAN STETKAR: We have to write a  
10 separate letter on it because there are two safety  
11 evaluations. There's a safety evaluation on the  
12 topical report, and there's a separate safety  
13 evaluation on DCD Chapter 18 for US-APWR.

14 MEMBER BLEY: So we should keep that  
15 separate (Simultaneous speaking).

16 CHAIRMAN STETKAR: That's why I asked  
17 earlier. There will be two letters written from the  
18 ACRS on these topics. That's because we get into  
19 technical details in the subcommittee. I wanted to  
20 make sure we're thinking about it that way. Sorry,  
21 get to your second slide now.

22 MR. MASHIO: So, the subject also  
23 includes computer-based procedures, large display  
24 panel, automatic checking of actuations, and diverse  
25 system panel, and also, as appendix, history of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 development of Japanese PWR main control room by  
2 Mitsubishi and the Japanese PWR power utilities, HFE  
3 V&V experience in Japan, which is described in  
4 Appendix B, and US-Basic HSI evaluation program,  
5 which is described in Appendix C.

6 MHI used the foundational elements of  
7 Japanese-Basic HSI as a starting point to create  
8 US-Basic HSI, applying the combinations of design  
9 review, redesign, and design validations through  
10 phased implementation. Appendix A contains  
11 information about Japanese-Basic HSIS and  
12 development history. MHI started developing digital  
13 HSI control room with Japanese utility from late  
14 1980s. In development process, MHI also referred to  
15 oversee HFE regulatory industry requirement  
16 guidelines, including NUREG-0711, 0700. It is noted  
17 0711 revisions was issued in 1994, and updated during  
18 the development. MHI checked the design in  
19 comparison with updated regulation industry  
20 requirement on the HFE guidelines. Iterative  
21 process of design, test and operation was applied in  
22 each development phase, and then I&C integration  
23 system variation was conducted as a final event  
24 process in Japan. The Japanese HSI has been  
25 introduced in the latest construction plant in Japan,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Tomari Unit 3, and the MCR modernization at Ikata  
2 Unit 1.

3 CHAIRMAN STETKAR: Is that the extent of  
4 the actual applications of this? You have it  
5 installed only in Ikata Units 1 and 2?

6 MR. MASHIO: Ikata Unit 1 and 2 is MCR  
7 modernization. This is --

8 CHAIRMAN STETKAR: But those are the only  
9 units in Japan that have this system installed and  
10 operating, is that correct?

11 MR. MASHIO: Yes, and they're also --

12 CHAIRMAN STETKAR: When was --

13 MR. MASHIO: (Simultaneous speaking) new  
14 plant.

15 CHAIRMAN STETKAR: I understand, but the  
16 new plants are not operating yet. I'm trying to find  
17 out what actual operational experience we have for  
18 these.

19 MR. MASHIO: Actually, for the Tomari  
20 industry is a new construction, co-construction.  
21 This Tomari Unit 3 was applied using this type of HSI  
22 system.

23 CHAIRMAN STETKAR: I'm asking you how  
24 many unit years of operation do you have using this  
25 system -- actual unit years of operation -- operators

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 sitting in a control room, with a plant operating at  
2 power, using this interface, how many unit years do  
3 you have?

4 MR. MASHIO: Okay, this is  
5 three -- Tomari Unit 3.

6 CHAIRMAN STETKAR: Is that operating?

7 MR. MASHIO: It was operating, yes.

8 CHAIRMAN STETKAR: It was operating?

9 MR. MASHIO: (Simultaneous speaking).

10 CHAIRMAN STETKAR: How long did it  
11 operate before March 2011 with this system in place?

12 MR. MASHIO: I don't -- you have to  
13 remember the Tomari Unit 3 starting date was --

14 PARTICIPANT: 2009.

15 MR. MASHIO: Yes, 2009 it ran from.

16 CHAIRMAN STETKAR: So about two years?

17 MR. MASHIO: Two-three years, yes.

18 CHAIRMAN STETKAR: When was it installed  
19 in Ikata Units 1 and 2?

20 MR. MASHIO: One year later.

21 CHAIRMAN STETKAR: Pardon?

22 MR. MASHIO: 2008 or '09.

23 CHAIRMAN STETKAR: I think it was 2008  
24 to -- I actually know about it, but I wanted to get  
25 it on the record. Basically, we have about maybe

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 six years of operating -- six unit years of operating  
2 experience with this system. Okay, thank you.

3 MR. SPRENGEL: Real quick, I do want to  
4 highlight one of our focuses is that we're discussing  
5 the development of the US-Basic HSIS, which is not  
6 the same as the Japanese-Basic HSIS. The development  
7 path is related, but they are not the same.

8 CHAIRMAN STETKAR: The only reason I  
9 bring this up is that the DCD, in particular, and to  
10 some extent the topical report, if I read the words  
11 and, in fact, I look at these screens, it leads me  
12 to believe that there is extensive operating  
13 experience with this system and, in fact, there  
14 isn't.

15 MR. SPRENGEL: I understand.

16 CHAIRMAN STETKAR: That's what I want to  
17 get on the record.

18 MR. SPRENGEL: Understand.

19 CHAIRMAN STETKAR: Thank you.

20 MEMBER BLEY: I have a much more general  
21 question. Although the development of this system,  
22 from your notes here, relied on guidance from the US,  
23 in terms of the new regs, it was developed  
24 specifically for the Japanese operators in Japanese  
25 plants. As we migrate that concept to the US-APWR,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 are we just translating labels, or is there any  
2 difference in the way -- cultural differences in the  
3 way we operate in the US compared to in Japan that  
4 would lead to other kinds of changes in the way this  
5 interface is designed and will operate?

6 MR. SPRENGEL: We will specifically  
7 address how the changes were made and put in place.  
8 I think a little bit later in the presentation we'll  
9 address your specific question related to how that  
10 (Simultaneous speaking).

11 MEMBER BLEY: Will that be in this  
12 presentation or somebody else's?

13 MR. SPRENGEL: In this presentation.  
14 That's correct. I think, actually -- let's put it  
15 off. We'll address that specific question, in terms  
16 of how the conversion happened and what happened.

17 CHAIRMAN STETKAR: Part of the  
18 difference is the Japanese plants are only two safety  
19 trains and (Simultaneous speaking).

20 MEMBER BLEY: I'm interested in what they  
21 have to say on this, yes.

22 CHAIRMAN STETKAR: I mean the bigger  
23 issues that you ask about are much more relevant.

24 MEMBER BLEY: Yes.

25 MR. SPRENGEL: Okay, I have that specific

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 question.

2 MR. MASHIO: The next slide shows the  
3 structure of HSIS. The Japanese HSIS, as applied in  
4 United States, is comprised with the following: Basic  
5 HSIS and HSI inventory, which means controls,  
6 displays, alarms are features we developed as a part  
7 of the plant-specific analysis phase of the HFE  
8 design program.

9 MEMBER BLEY: Not to make you nervous,  
10 but I'm having trouble hearing you again, so if you  
11 could speak up a little bit.

12 MR. MASHIO: Yes. The Japanese HSIS, as  
13 applied in United States, is comprised of the  
14 following: the first is the Basic HSIS, and the  
15 second is the HSI inventory. The inventory means  
16 controls, displays, alarms, every contents. Those  
17 contents will be developed as a part of the  
18 plant-specific analysis phase of the HFE design  
19 program. This HSI inventory is developed as a part  
20 of the US-APWR DC, in accordance with the US-APWR HFE  
21 program.

22 CHAIRMAN STETKAR: Kenji, when you talk  
23 about the HSI inventory, I sometimes get confused  
24 about what that means. I understand that particular  
25 parameter values are a plant-specific design, so, for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 example, pressures and temperatures and flows. But,  
2 for example, in MUAP-0700-P, there is, in fact, a  
3 list of parameters that are displayed on the large  
4 display panel, which I consider the HSI inventory.  
5 Because those parameters are listed in the topical  
6 report, am I to believe that those, in fact, are  
7 fixed? In other words, that is the inventory, and  
8 only those parameters will be displayed on the large  
9 display panel. Is that correct, or is it not  
10 correct?

11 MR. MASHIO: Yes, basically -- for  
12 example, the LGP physical display area is defined  
13 what parameter is displayed from Type A and B is  
14 displayed using the unique combination, but the  
15 actual contents of that information may be changed,  
16 based on the plant specification. So this concept  
17 and the definitions such as Type A and B parameter  
18 will be displayed using the unique combination, is  
19 defined in the Basic HSI. But the actual number of  
20 the variable parameters may be changed, based on the  
21 plant-specific application.

22 CHAIRMAN STETKAR: I'm still a bit  
23 confused. What I'm looking for is -- I don't know  
24 if you're going to talk about this later, so I'll ask  
25 you now. Because I do want to get set of what is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 fixed, in terms of what we're reviewing under the  
2 topical report, and what is variable, that will be  
3 applied in a plant-specific application, whether it's  
4 US-APWR or Operating Plant X.

5 In the topical report, there is a list  
6 of variables that are displayed on the large display  
7 panel, for example. I don't want to read them  
8 off -- I can -- things that are -- RCS  
9 subcooling -- they're parameter values -- RCS  
10 subcooling, reference levels, pressurizer, so forth.  
11 Because they're in the topical report, I'm assuming  
12 that those, indeed, are the list of things that are  
13 fixed.

14 Because if they weren't fixed, we're not  
15 certifying it. The reason I ask is that list in  
16 Topical Report Rev. 6 is substantially different from  
17 the list that's cited in the US-APWR DCD, for  
18 example. I went through all of these. I've got two  
19 pages of these parameters. I've got questions about  
20 why things were added, why things were removed. So  
21 I need to understand, for my review of just the  
22 topical report, what is it that we're reviewing?  
23 What are we saying is okay? If you're telling me  
24 that we don't know what that is, I'm telling you that  
25 I can't review that.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. PIERINGER: This is Paul Pieringer.

2 CHAIRMAN STETKAR: I don't know how the  
3 staff did it, but that's the question to the staff  
4 later. I'm trying to understand what it is that  
5 we're being asked to review because there are certain  
6 things that are clearly documented in this topical  
7 report, that list of parameters being one thing that  
8 I personally interpret as part of the HSI inventory,  
9 but I want to understand what you mean by the HSI  
10 inventory.

11 MR. MASHIO: Again, LDP fixed-display  
12 contents is like an individual boundary area, but in  
13 general, the soft control looks at ---- is a basic  
14 function, what content is up here in the soft  
15 control, such as a --

16 CHAIRMAN STETKAR: I'm not -- sorry,  
17 we're not understanding one another. I'm not talking  
18 about soft controls or nameplates. I'll give you a  
19 specific example. A parameter that exists in  
20 MUAP-07007-P Revision 5 -- I do this for the  
21 transcript -- is, for example, main feedwater header  
22 pressure. That is a parameter. That parameter does  
23 not appear in Rev. 6. That's not a soft control.  
24 It is simply a parameter that is available for the  
25 operators to examine. It's a parameter. It's a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 value. I don't care whether it's ten pounds. I  
2 don't care whether it's 100 MPa. I don't care the  
3 value, but it is a parameter that's listed. My  
4 question is are we being asked to review, under the  
5 topical report, the adequacy of that list of  
6 parameters?

7 MR. MASHIO: No.

8 CHAIRMAN STETKAR: Okay, then what are  
9 we being asked to review, and what is fixed, and what  
10 is not fixed, in terms of this HSI? I honestly want  
11 to know what it is we're being asked to review.

12 MR. HALL: The way we're defining  
13 parameters is very similar to what you're talking  
14 about, the inventory. Can you hear me if I sit back?

15 CHAIRMAN STETKAR: You're fine.

16 MR. HALL: American. I'm sorry, but  
17 that's me.

18 CHAIRMAN STETKAR: I do it, too.

19 MR. HALL: When you start looking  
20 at -- and you've read it, but we'll try to make it  
21 clear as we go through the process -- this process  
22 of moving from the basic to the US, that basic, which  
23 is the topical, is how things are displayed, where  
24 they're placed, how they're accessed, not the content  
25 of what's in it, but how the HSI functions. The

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 parameters are not simply -- the inventory is not  
2 simply changing the number, but what might be added  
3 or deleted from the basic design. Hopefully, it'll  
4 show later that the process we use to do that is all  
5 those topical, technical reports to modify the basic.  
6 So the basic design is looked at. The inventory on  
7 the basic design is looked at, and the task analysis  
8 does an independent evaluation. If, in fact,  
9 additional information is needed for the US-APWR, it  
10 is then added, but it's added to the template of what  
11 the basic design looks like. Did I confuse you more,  
12 or is that --

13 CHAIRMAN STETKAR: We're eventually  
14 going to converge, I think, here, but --

15 MR. HALL: Getting closer, I hope?

16 MEMBER BALLINGER: We're being asked to  
17 review the template?

18 MR. HALL: This generic, yes.

19 MEMBER SCHULTZ: The inventory we talk  
20 about here is an example? That is to say what's in  
21 the topical report as inventory is an example that  
22 is used and that will change?

23 MR. HALL: No, it's more than that  
24 because the basic HSI -- and perhaps we can just wait  
25 and go through what the process looks like. It comes

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 back to your how do we go from Japanese to the  
2 US-Basic design? The process uses the inventory you  
3 see in the topical report as the baseline for doing  
4 the calculations and analysis of is it adequate,  
5 should things be added, should things be deleted to  
6 the generic HSI. That's what the Human Factors  
7 program tries to do, at least all those technical  
8 reports.

9 MEMBER BLEY: One could look at the  
10 details of what's in the basic as an example of what  
11 the designers of the basic thought would be a  
12 representative set --

13 MR. HALL: Yes.

14 MEMBER BLEY: -- of indications,  
15 controls that we might need, but as specific?

16 MR. HALL: Yes.

17 MEMBER SCHULTZ: That's what I was trying  
18 to get to, exactly.

19 MR. HALL: That, then, because of the  
20 process that was used, came from the Japanese design.  
21 It started with this Japanese design, moved through  
22 a process, which we'll talk about, which included  
23 testing in the US, to this basic design topical  
24 report, and then moves forward by application of the  
25 technical reports to the final US-APWR.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   MEMBER BLEY: So we're really looking to  
2 say if the general layout, the way things work with  
3 each other, is a reasonable basic system for our  
4 operators to use in any application?

5                   CHAIRMAN STETKAR: I understand that at  
6 that level. On the other hand, I look at -- and I  
7 will refer to you on the record -- in MUAP-07007-P  
8 Rev. 6, Table 4.9-1, which is a -- I believe it's  
9 five pages long -- that lists all of these parameters  
10 and, furthermore, lists the reasons -- or at least  
11 in terms of Xs and columns, the reasons why they  
12 particularly were selected, plant power operation,  
13 cause of reactor trip, ESFAS actuation, post-accident  
14 monitoring, OK monitor, bypassed inoperable status,  
15 SPDS, those different functions. This gives me a  
16 broad -- me a view saying do I believe that this is  
17 an adequate inventory to satisfy those functions?

18                   Now from what I'm hearing you say, I can  
19 wipe this table completely blank and it doesn't mean  
20 anything because when I get to a specific  
21 application, somebody else can figure out what they  
22 want in there, so why do I have this in here, and  
23 what I am reviewing? If somebody adopts this saying,  
24 "I agree with this. This is a good table for me,"  
25 should we be reviewing technically, now, the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 completeness of this table? Follow me? Because  
2 this table, indeed, has morphed, in terms of the  
3 content and the actual Xs in the boxes, which I'm a  
4 little less interested in, from revision to revision  
5 of the topical report in ways that I couldn't quite  
6 understand in details. I get the concept of having  
7 a framework to see whether all of the pieces, in  
8 general, kind of hang together and talk to one  
9 another.

10 I've got questions at that level. But  
11 I'm trying to understand whether we're being asked  
12 to review, or whether we, the ACRS, eventually write  
13 a letter saying, "Indeed, we accept the staff's  
14 safety evaluation of this topical report," are we  
15 buying, now, into that technical content in this  
16 five-page table, this list of particular parameters  
17 and the functions that they satisfy as being the list  
18 on the fixed portion of the large display panel? I  
19 recognize anything else is Applicant or customer  
20 specified, in terms of operational VDUs or anything  
21 on the variable part of the display.

22 MR. SPRENGEL: I think the answer is  
23 still -- our answer is still the specific parameter  
24 lists and the, I guess, technical adequacy of them  
25 is not the portion of the review that we're looking

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 at. How those are displayed and, in the future, how  
2 we'll go through the process to identify that  
3 parameter list for the US-APWR, and then for any  
4 site-specific design --

5 CHAIRMAN STETKAR: We'll get into  
6 Chapter 18 for US-APWR, but the US-APWR doesn't make  
7 any changes to this. What you're saying is I can  
8 have technical comments on US-APWR Chapter 18 on this  
9 list because theoretically, it's been specialized to  
10 US-APWR. Is that correct?

11 MR. SPRENGEL: That's not correct.

12 CHAIRMAN STETKAR: That is not correct.

13 MR. SPRENGEL: We would apply the HFE  
14 process as defined from Chapter 18 perspective to  
15 develop the US-APWR HSI --

16 CHAIRMAN STETKAR: So the US-APWR list,  
17 this five-page table, basically looks like a blank  
18 matrix right now?

19 MR. SPRENGEL: No, that list would be a  
20 starting point. On that note, let us jump ahead to  
21 Slide 65 and go ahead and give a picture of this  
22 whole process. I think that'll give us some  
23 terminology to better discuss where these changes  
24 occur. Oh, 65 on my printed version. It is Slide  
25 64 on the PDF version.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 PARTICIPANT: It starts on 61.

2 MR. SPRENGEL: I think we can use this  
3 diagram.

4 MR. HALL: Okay, we've now jumped ahead  
5 to something I was going to present. You're going  
6 to see this described -- and Kenji, when we come back  
7 to the flow that we originally planned to do, he'll  
8 talk about this, too, but in different format. This  
9 represents the program of the HFE of what we've done  
10 and where we're going with it.

11 It addresses the question about  
12 inventory, and it addresses your question, Dennis,  
13 about how do we jump from Japanese to US? Before I  
14 look at the slide, let me address the first question,  
15 and then we'll see how it is in here. Moving from  
16 the Japanese HSI to the US-Basic design was a  
17 three-year process. It wasn't simply changing  
18 letters, numbers and Japanese to English and sizes  
19 of tables or touchscreens, etc., and saying that was  
20 the interface.

21 The basic HSI, which now represents the  
22 starting point from the US-APWR, was the result of a  
23 very extensive, human in the loop, simulator testing  
24 program. Mitsubishi built a simulator that was this  
25 simple conversation you're talking about, from

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Japanese to US. They built it. It sits at MEPPI,  
2 outside of Pittsburgh. Some members of the ACRS --

3 MEMBER BLEY: That's the one I saw  
4 (Simultaneous speaking).

5 MR. HALL: Okay, so that simulator was  
6 used. We developed --

7 MEMBER BLEY: The one we saw six-seven  
8 years ago was -- oh, thank you, John. The one we  
9 saw six or seven years ago was really just a mirror  
10 of the Japanese.

11 MR. HALL: That's correct, other than  
12 these simple (Simultaneous speaking). Yes, I agree.  
13 So the machine was built. It was verified that it  
14 worked right and that all the changes that had to be  
15 made early on were made. Then, in fact, we  
16 brought -- we developed a testing program. That  
17 testing program -- we're stealing some of my thunder  
18 from my presentation later -- that testing program  
19 (Simultaneous speaking) is it okay?

20 PARTICIPANT: Yes.

21 MR. HALL: -- basically underscored and  
22 was the root of our ISV program in the HFE side of  
23 the house, in these implementation plans.

24 CHAIRMAN STETKAR: For those of us who  
25 aren't familiar with the acronyms --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. HALL: Sorry, integrated system  
2 validation.

3 CHAIRMAN STETKAR: Thank you.

4 MR. HALL: That's the last element of the  
5 HFE process, the big test, the final exam. I'm  
6 sorry. We developed this ISV program. We brought  
7 in operators. Those operators came from the then,  
8 at that time, COL applicant, Luminant. They were  
9 qualified, licensed ROs and SROs. We brought them  
10 in as those functions, RO, SRO, and STA. We brought  
11 them in and ran tests with scenarios, collected the  
12 data, etc., and we ran two sets of tests. The first  
13 set of tests was given the Japanese design, with just  
14 translation, how does it work? We produced findings,  
15 and those findings were very, very specific to the  
16 design. We spent about a year redesigning the system  
17 to meet those --

18 MEMBER BLEY: Was there a report on that  
19 testing?

20 MR. HALL: There is a report. I don't  
21 know if it was issued to the NRC, however.

22 MEMBER BLEY: I don't think we've seen  
23 it.

24 MR. HALL: There's a Mitsubishi report.

25 MEMBER BLEY: I haven't seen it.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: I don't think we've  
2 seen anything on that first --

3 MR. HALL: Maybe it wasn't submitted  
4 (Simultaneous speaking).

5 CHAIRMAN STETKAR: It may have been  
6 submitted.

7 MR. HALL: No, I don't think we've --  
8 (Simultaneous speaking.)

9 MR. HALL: I have to apologize. That's  
10 really between Mitsubishi and NRC.

11 CHAIRMAN STETKAR: Yes, that's fine.

12 MR. HALL: A very detailed report was  
13 developed. You have to understand that at the very  
14 beginning of these tests we started to use this HED  
15 process, as defined by 0711. What it is is a  
16 findings tracking system that says everything that's  
17 found that's deficient from the human are going to  
18 go into this database, and it's going to track from  
19 those early tests all the way through the final  
20 completion of the whole plant, not just the HFE.

21 That's one of the integrating processes  
22 that are used in here to get HFE into the rest of the  
23 design process. It's a problem talking from HFE to  
24 a system designer to I&C. You're shaking your head.  
25 You know what I mean, Dennis. It's one of those

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 things. But those HEDs were generated starting with  
2 that first test. We ran the test, collected a lot  
3 of data. We can go into that later, if you want,  
4 how it was collected and what it is. We were not  
5 planning on doing that, so we could -- but I'll  
6 verbalize it, or Kenji can verbalize it.

7 CHAIRMAN STETKAR: We'll talk more about  
8 what's in Appendix D, which I think is the second --

9 MR. HALL: Yes. So a lot of HEDs, as  
10 you would expect, were developed. Those HEDs were  
11 then reviewed between the designers and an  
12 independent expert panel. The document talks about  
13 this. That independent expert panel had HFE people,  
14 I was on it, had utility people. Luminant people  
15 were on it, at that time, a potential client,  
16 designers. Kenji was on it. In fact, a Luminant  
17 person, their new plant startup manager, was the head  
18 of this independent panel, so it was really  
19 (Simultaneous speaking).

20 MEMBER BLEY: And you had operators on  
21 that panel?

22 MR. HALL: He was an SRO. He had an SRO  
23 background. He's the one that brought all the  
24 Luminant operators to the table. Those things were  
25 changed. Those things were redesigned, and then

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 changes made to the simulator. The simulator was  
2 changed -- some hardware, lot of software, and then  
3 it became somewhat of a patchboard. It became more  
4 of an experimental facility. We didn't cast new  
5 steel to hang stuff on it. Wires were run, PCs were  
6 used to fix -- change some of the design. If you  
7 looked at it at the end of the second set of tests,  
8 it looked more like a university research facility.  
9 Then we ran a second set of tests again --

10 MEMBER BLEY: Under that condition?

11 (Simultaneous speaking.)

12 MR. HALL: Oh, yes. If this was a  
13 console, instead of building another piece of steel  
14 and putting a video display in it, we put a table  
15 with a PC on it, a laptop on it or something.

16 CHAIRMAN STETKAR: Just to be clear, that  
17 second set of tests is what's documented in Appendix  
18 C --

19 MR. HALL: Yes.

20 CHAIRMAN STETKAR: -- Charlie, of the  
21 (Simultaneous speaking).

22 MR. HALL: Yes, but in not great detail.  
23 (Simultaneous speaking.)

24 CHAIRMAN STETKAR: No, but I just want  
25 to make sure that I understand the configuration.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. HALL: Yes, so we ran those tests and  
2 documented more HEDs. We decided which HEDs we fixed  
3 and, frankly, which ones we made worse, so what new  
4 ones were added. That second test with US  
5 operators -- and I'm talking about eight weeks long,  
6 ten hours a day, typical -- and the scenarios were  
7 training-level scenarios, so these were fairly  
8 detailed -- ended up in the design that is now being  
9 called basic HSI, so those tests. Now, let me come  
10 to the diagram.

11 PARTICIPANT: I learned a new word, by  
12 the way, in reading this. I had to look it  
13 up -- anthropometrics.

14 MR. HALL: Oh, okay.

15 PARTICIPANT: That's about time.

16 PARTICIPANT: It's about time  
17 (Simultaneous speaking).

18 PARTICIPANT: I wanted to ask one thing  
19 because --

20 MR. HALL: Does that answer your question  
21 kind of?

22 MEMBER BLEY: Almost there. One thing I  
23 thought you might have done, and it sounds like you  
24 didn't do, is look at what Japanese operating  
25 procedures look like, what US ones look like, what

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 the practice look like, what the training look like,  
2 and the difference. Instead of that, you jumped to  
3 the guys and saw how they dealt with it.

4 MR. HALL: Dennis, I love you. That's a  
5 good leading question. The answer is your  
6 interpretation is wrong. The original procedures we  
7 had were written by a US procedure team. The first  
8 sets were (Simultaneous speaking).

9 MEMBER BLEY: So they were like US  
10 procedures?

11 MR. HALL: US procedures, rudimentary  
12 CBP, lots of paper.

13 MEMBER BLEY: I'm sorry, CBP?

14 MR. HALL: Oh, I'm sorry, computer-based  
15 procedure. So it wasn't, the first one, an  
16 integrated system like we're now talking about only  
17 because we weren't mature enough to do that. We, in  
18 fact, found substantial differences between the  
19 machine, the way it was used with the US procedures,  
20 and the way the Japanese machine was built for  
21 Japanese operation.

22 We, early on, started seeing US operators  
23 tripping over certain parts of the design. Tripping  
24 over meant HED-ridden, okay? So on the procedure  
25 side. We, in fact, got to the point of Mitsubishi

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 brought over Mitsubishi operators to work on it. We  
2 sat and ran tests with the Mitsubishi operator, one,  
3 because that's the way it's run and our team and  
4 looked at the two and concluded that the way the  
5 Japanese run the machines is substantially different  
6 than the way we run the machine. A lot of -- not a  
7 lot, but a good portion of the HEDs and, therefore,  
8 changes in the things being displayed, how they're  
9 displayed, where they're placed, what the procedure  
10 does with them -- a lot of those changes from Test 1  
11 to Test 2, each change in HED, basically represented  
12 not problems or deficiencies in the Japanese plant,  
13 but the fact that we run them different.

14 We have a different operational culture.  
15 We play with the machine differently. We think  
16 differently about them. The model we have in here  
17 is different than the way the Japanese run it. So  
18 the second set of tests then tested the changes to  
19 comply with our way of running it, and then became  
20 the basic HSI.

21 I may add we spent, independent of these  
22 full-scale tests, a lot of time testing with US  
23 operators, specifically the computer-based procedure  
24 scheme to make sure that the CBP in the basic, and  
25 as it moves into the US-APWR, handles both this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 interface, which is digital, and the way we're  
2 familiar with running it, which is paper based.  
3 There is a disjoint between those. The CBP takes  
4 that into account to optimize this new digital system  
5 with the way we typically run a PWR plant. So the  
6 procedure side of it was looked at.

7 MEMBER BLEY: This really helps me.  
8 You're not a philanthropic organization, but the  
9 researcher side of me says the stuff you've described  
10 would make a really useful paper for people who look  
11 at operations across different cultures because  
12 that's a problem they don't fully understand by a  
13 long shot.

14 MR. HALL: Dennis, and I say ---- there's  
15 a number of papers out there that -- conference  
16 papers that were presented -- Kenji and myself and  
17 the rest of the team. Of course, as in any team,  
18 who was on top changed, but there's a whole series  
19 of papers. One of them -- because at the time, the  
20 thinking in the international community was you could  
21 take a plant -- let's say a French plant -- pick it  
22 up and stick it here and it'll work. You could take  
23 a US plant, stick it in Turkey, it'll work. The  
24 answer is absolutely not. There is a paper out  
25 specifically based on these tests that talks to that.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: If you guys could get us a  
2 key to some of those conference papers, that would  
3 be useful.

4 (Simultaneous speaking.)

5 MR. HALL: But Dennis, it's a conference  
6 paper. It's six pages long. So it gives some  
7 conclusions. It doesn't --

8 MEMBER BLEY: (Simultaneous speaking)  
9 some references?

10 MR. HALL: Yes, it does.

11 MEMBER REMPE: But to just make it more  
12 concrete to some of us who aren't in the field, could  
13 you give us one example that would -- a little more  
14 details about one example of a difference?

15 MR. HALL: Oh, sure, I can give you  
16 one --

17 MEMBER REMPE: Right now?

18 MR. HALL: Yes, one great example. The  
19 US operators, as you know, are rigidly locked into,  
20 in my interpretation, following the procedure. The  
21 procedure is it, Step 1, Step 2, Step 3. If what it  
22 says in Step 3 the plant doesn't achieve, you go into  
23 the second column of a PWR site chart and you do the  
24 recovery.

25 The Japanese use the procedure more the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 way we did probably 30 years ago. It's recommended  
2 practice. That makes the embedment of that procedure  
3 and how you use the systems very different. In the  
4 US, if it doesn't say to do something, even though  
5 it's displayed up on the screen -- the LDP -- in a  
6 big, bold red letter, if the procedure says don't go  
7 there, you cook through the procedures pretty  
8 quickly, or else you've got to decide whether you  
9 want to keep your license or not for moving away from  
10 that procedure. The Japanese don't have that  
11 attitude. They handle the problems as they come in.  
12 Because of that, the interface in Japan is different  
13 than the interface here. Does that -- at least one  
14 significant difference?

15 MEMBER REMPE: It helps, yes. Thank  
16 you.

17 MR. HALL: The answer's yes, I can get  
18 you some papers. This first report, which is very  
19 detailed, I don't know if it's available.

20 CHAIRMAN STETKAR: This has been -- I  
21 need to be a little cognizant of time, but we have  
22 all day.

23 MR. HALL: I'm sorry.

24 CHAIRMAN STETKAR: No, this is really,  
25 really useful. I'm not trying to (Simultaneous

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 speaking). We haven't seen, nor even had an inkling  
2 of any of this. What we've seen is something that  
3 says the Japanese-Basic design was examined for  
4 anthropometric -- differences in body sizes,  
5 differences in heights, differences, perhaps, in  
6 cultural use of procedures. A simulator was built.  
7 Eight crews were run through seven scenarios.

8 MR. HALL: That was Phase 1A, and you'll  
9 see that in what's coming up.

10 CHAIRMAN STETKAR: And they're  
11 documented in Appendix C of the -- that's all we've  
12 seen. We haven't heard about the Phase 1, if that  
13 was Phase 1, and all of the things that were changed.  
14 Now for the record, though, the -- and we see pictures  
15 of things. My sense is that the picture of the HSI  
16 that's published in the topical report, which I was  
17 led to believe is indeed the thing that the Phase 1A  
18 crews used for their scenarios, is not -- from what  
19 you said not quite exactly what they were actually  
20 using. Is that correct?

21 MR. HALL: Ask your question  
22 (Simultaneous speaking).

23 CHAIRMAN STETKAR: There's a photograph  
24 in there. It says --

25 MR. HALL: Of a clean panel.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   CHAIRMAN STETKAR:   -- of a nice, clean  
2     panel with displays, and not little PCs sitting on  
3     the side, and not wires running all over the place.  
4     The actual Phase --

5                   MR. HALL:    I know what you're saying.  
6     The photograph, not the sketches --

7                   PARTICIPANT:  (Simultaneous speaking.)

8                   MR. HALL:    The photograph of the  
9     simulator, itself, the hard photograph is of the one  
10    the ACRS saw initially, without all the wires and  
11    everything. The graphics of the displays and things  
12    like that, all the -- how figures are shown, how  
13    controllers are shown, that's the output of Phase 2  
14    testing. The picture in there -- and you're going  
15    to see it a little bit later -- is the first  
16    simulator. You're correct.

17                  CHAIRMAN STETKAR:    I'm trying to  
18    understand if I'm a licensed Comanche Peak operator  
19    and I'm summoned to Pennsylvania to spend a week at  
20    a facility and run through seven scenarios, what am  
21    I sitting in front of? Am I sitting in front of that  
22    nice, clean thing with displays, or I'm sitting in  
23    things that's got some PCs sitting on a desk and some  
24    little things up in the rafters, or what am I sitting  
25    in front of?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   MR. HALL:     Going to show you.     This  
2     photograph is the simulator in Pennsylvania, and it  
3     was what the system looked like for Phase 1A.   This  
4     is when it was just simply converted to US standards.  
5     This is the first -- this is what the first series  
6     of operators sat in front of.

7                   CHAIRMAN STETKAR:   Right, I got that.

8                   MR. HALL:     The second set of operators  
9     sat in front of the same machine, substantial changes  
10    on what the displays looked like, you know, software  
11    changes.   When I said a patchboard, there were not  
12    wires running all over the place, but let me give you  
13    an example, if I can.   Please stop me when I run out  
14    of time.

15                  CHAIRMAN STETKAR:   You're fine.   Don't  
16    worry.

17                  PARTICIPANT:     What phase does this  
18    represent?

19                  MR.    HALL:       This    represents    the  
20    results -- the sketch -- of Phase 1B, which is the  
21    basic HSI.

22                  CHAIRMAN STETKAR:   If I was a licensed  
23    operator at the Comanche Peak Station and was  
24    summoned to Pennsylvania to sit in a room for one  
25    week and run through seven scenarios, did I see a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 display that looks like this, or did I see a display  
2 that looks like that?

3 MR. HALL: First test this, second  
4 test --

5 PARTICIPANT: Those were also operators.

6 MR. HALL: -- second test that.

7 (Simultaneous speaking.)

8 MR. HALL: There were changes.

9 CHAIRMAN STETKAR: But this was actually  
10 implemented in a nice, clean fashion or not? For  
11 example, the operating procedure VDU has moved around  
12 a bit. Was that sitting on a PC, on a table, off to  
13 the side?

14 MR. HALL: Let me give you an example of  
15 one of the big changes.

16 CHAIRMAN STETKAR: The reason I'm  
17 addressing this is it's important for us to  
18 understand what's documented in Appendix C. That's  
19 why -- I'm trying to short-change some of our  
20 questions (Simultaneous speaking).

21 MR. HALL: I don't want to give you the  
22 wrong impression -- talking about the second test  
23 now.

24 CHAIRMAN STETKAR: What's documented in  
25 Appendix C?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. HALL: Right, that this was so  
2 changed with wires around and paper and tape, and  
3 that it was a horrible thing to work on. That wasn't  
4 the case. For example -- I can't really point to  
5 it --

6 (Simultaneous speaking.)

7 CHAIRMAN STETKAR: No, you can use a  
8 mouse. We have mice. We have rats, too, but  
9 (Simultaneous speaking).

10 MR. HALL: In the back, this is the STA  
11 and SRO. The SRO you'll see under this, the Phase 1  
12 testing. The simulator, as it came from Japan, has  
13 one, two, three screens, procedure, two system  
14 screens. One of the changes we found, a change that  
15 is significant to the industry testing again, when  
16 it comes to digital, sit-down control systems, is the  
17 SRO loses awareness of what the operator's doing.  
18 Think about this. In a conventional plant, the SRO  
19 says, "Do X." The operator stands up and walks over  
20 to Panel 3, whatever, where X is.

21 The SRO has an awareness of what the  
22 operator's about to do because she sees where it is.  
23 If the operator goes to Panel Y, instead of X, the  
24 SRO understands you went to the wrong place, please  
25 change. There's a check and balance in the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 conventional. You don't have it here. All the SRO  
2 sees is the back of the head of the RO. He has no  
3 idea what screens they're looking at.

4 We ran into problems with this wrong  
5 screen issue between the command of the SRO, even  
6 with three-peat being used -- everyone knows  
7 three-peat is? Even with it, we ran into problems  
8 every so often with the operator doing the wrong  
9 thing. HED was written. The solution for that was  
10 to give the SRO something for situation awareness.  
11 What we did was we put another screen right there.

12 PARTICIPANT: Point with your  
13 (Simultaneous speaking) Ryan's showing us.

14 MR. HALL: If you look at the picture,  
15 there's that other screen. We've put another screen  
16 right here. That other screen basically is a mirror  
17 of what screen the operator is on. So if the  
18 operator brings up Screen P32, it can be displayed  
19 on this new one. Remember, these are all  
20 touchscreens, so as the operator begins to touch on  
21 it, an X shows up showing is he on the right component  
22 or not? It's a beautiful check and balance for the  
23 SRO.

24 CHAIRMAN STETKAR: Bob, first I ever  
25 heard about that screen. It's not documented in the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 topical report.

2 MR. HALL: It's there.

3 (Simultaneous speaking.)

4 CHAIRMAN STETKAR: I didn't count the  
5 little things. My point is that the optical report  
6 describes very clearly the SRO and the STA has having  
7 three screens. Several of my questions, from an  
8 ex-operational perspective, on the topical  
9 report -- forget about US-APWR -- is the availability  
10 of displays to the control room team during an  
11 accident situation. Is there enough display  
12 capability available? Is there enough display and  
13 communications available among the nominal three  
14 people, or perhaps four people, who might be in  
15 there? In fact, I had questions, even before I heard  
16 this little story, about are there enough screens  
17 available to the STA and the SRO? Everything that I  
18 read, other than this little picture, which I guess  
19 I'll have to go find the figure number in -- said  
20 that the STA and the SRO had three screens in the  
21 topical report. I'll find it.

22 (Simultaneous speaking.)

23 MEMBER BLEY: That's not the issue. The  
24 issue is really understanding the tests that you did.

25 CHAIRMAN STETKAR: Understanding the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 tests that they did is part of it, but also  
2 understanding what it is that we're reviewing in this  
3 topical report because we are reviewing that  
4 interface. If it's something important that they  
5 added ---- you can almost see it. It is, indeed -- I  
6 just found it. It's Figure 4.3-3. There is a little  
7 fourth one there. That's not the issue, though. I  
8 get lost between Phases 1A and 1B. I'll just call  
9 it the second round of tests that are documented in  
10 Appendix C. We now know that the STA and the shift  
11 supervisor -- the SRO consoles had four screens on  
12 them.

13 MR. HALL: For the second set of tests.

14 CHAIRMAN STETKAR: For the second set of  
15 tests, what other differences were made for that  
16 second set of tests? Still have the same complement  
17 of safety VDUs and --

18 PARTICIPANT: You said they changed the  
19 software, so the actual screens on the other  
20 screens --

21 MR. HALL: The actual screens changed,  
22 the controllers changed, color coding changed. The  
23 alarm prioritization changed.

24 CHAIRMAN STETKAR: But all of that -- I  
25 recognize there were a lot of soft changes, I'll call

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       it that. I'm still trying to understand that if I  
2       walked into that facility as the operator, sitting  
3       down at the desk to run these scenarios, what I think  
4       I'm hearing you say, but I want to make sure that I  
5       understand it -- that I didn't have a little laptop  
6       sitting over on a corner that said look over here  
7       because we're eventually going to build this kind of  
8       display into the framework, or we haven't quite got  
9       this thing done, so you need to use a paper procedure  
10      for now, rather than the computer-based procedure,  
11      and you may have to toggle back and forth. I'm  
12      trying to understand it at that level, so I  
13      understand what the operators were facing.

14               MR. HALL: The principle changes were  
15      software driven, screen changes, etc. They were  
16      implementation of the CBP. Remember, I said the  
17      first time out we used a lot of paper procedures. We  
18      just weren't ready for the computer-based procedure  
19      yet. So the CBP was up and running.

20               CHAIRMAN STETKAR: It was up and running?

21               MR. HALL: It was up and running. In my  
22      memory -- and I've got to say in my memory because  
23      this is many years ago -- the only significant  
24      hardware change was the one I just completed  
25      describing, this extra screen. Rather than bending

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 metal and changing the structure of that back SRO/STA  
2 console, the only physical change was next to it was  
3 a desk with a PC screen on it that represented this  
4 new screen. So it wasn't like they were sitting in  
5 front of ten PCs or something like that.

6 CHAIRMAN STETKAR: That was only for the  
7 SRO/STA?

8 MR. HALL: Yes, that's the only physical  
9 change.

10 PARTICIPANT: That exact text of what  
11 you said is actually here.

12 PARTICIPANT: Oh, okay.

13 MR. HALL: Thank you.

14 PARTICIPANT: Which document?

15 MEMBER BALLINGER: The MUAP-07007-P,  
16 Rev. 6. I read it last night. I'm looking for it,  
17 it just came to me ---- the desk, and rather than  
18 bend metal literally is in the text.

19 PARTICIPANT: Okay, thanks.

20 MEMBER BLEY: Just for clarification  
21 when I go back and look at the transcript, the story  
22 you told, I expect in the interim, before you brought  
23 the operators back the second round, maybe it was  
24 more like a bread-boarding exercise of playing with  
25 different things to experiment on how you got to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 where you did.

2 MR. HALL: It's in the documents, and  
3 you'll hear Kenji talk about it, too. We used what  
4 we refer to as a PC design tool. I forget the exact  
5 name of it. A lot of things were done on things like  
6 this, and then implemented on the big simulator.

7 CHAIRMAN STETKAR: Ron, can you help me  
8 out, please? Because you said literally you read  
9 the words bend metal --

10 MEMBER BALLINGER: I'm trying to find it  
11 right now.

12 CHAIRMAN STETKAR: Okay. I want to make  
13 sure because I just searched on that and I couldn't  
14 find it.

15 MEMBER BALLINGER: I'm trying to find  
16 it, as well. I read it somewhere.

17 CHAIRMAN STETKAR: Apparently you didn't  
18 read it here. Let's be clear, on the record, of  
19 what's in a document because I don't personally  
20 recall that. It's not in that document.

21 MEMBER BALLINGER: It was 1:00 in the  
22 morning.

23 CHAIRMAN STETKAR: That's okay, but if  
24 we're going to cite things on the record, let's cite  
25 the right reference so I can find it.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 MEMBER SCHULTZ: Bob, I had a question  
2 on this process. You have it described in the middle  
3 for the transition to the US-APWR. How does that  
4 compare to what you have in the beginning of the  
5 chart there with the Japanese operator assessment?  
6 Did that also include the HSIS HED, and what does  
7 approximately 200 mean in the shorthand here?

8 MR. HALL: Again, Kenji can talk to more  
9 of that because it was done in Japan. I wasn't  
10 involved in it. But that series of tests were human  
11 in the loop tests that resulted in the Japanese HSI  
12 that are in Tomari, for example, and that were then  
13 imported and changed for our tests. What's listed  
14 there is -- Japanese operators, again, human in the  
15 loop tests that supported the original design of the  
16 HSI for the Japanese plant.

17 MEMBER SCHULTZ: With the outcome being  
18 the Japanese-Basic HSIS.

19 MR. HALL: That's correct.

20 MEMBER SCHULTZ: In that box is likely  
21 some of what is in the middle of the chart for the  
22 US-APWR?

23 MR. HALL: Yes, it is. That brings  
24 me -- I know I'm jumping a bit out of step, but can  
25 I --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: I want to get five  
2 minutes and we're going to take a break. You do have  
3 thunder later.

4 MR. HALL: Okay, let me just say this is  
5 iterative, this process. We'll talk about it later.

6 MR. SPRENGEL: Be careful with this.  
7 The blue portion is complete --

8 MR. HALL: Yes, right.

9 MR. SPRENGEL: The blue is --  
10 (Simultaneous speaking.)

11 MR. SPRENGEL: The HFE process, in  
12 general, is iterative, but we're now in the green  
13 phase.

14 MR. SPRENGEL: This comes back to what  
15 we are reviewing for the topical report. We're  
16 reviewing the blue guys.

17 MR. SPRENGEL: That is correct, which is  
18 complete.

19 CHAIRMAN STETKAR: The blue has that  
20 additional SRO/STA display?

21 MR. SPRENGEL: Correct.

22 CHAIRMAN STETKAR: For later, not for  
23 now. I want to understand because you said the  
24 purpose of that display -- because I didn't recognize  
25 it existed, so I'm going to be educated a bit. The

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       purpose of that display is to monitor the RO is doing.  
2       Now we can configure this, and one of my questions  
3       eventually is going to be for two RO operations, so  
4       I don't know how that display monitors what the two  
5       ROs are doing, plural. Just keep that for later. I  
6       just want to make sure we address that later. The  
7       other thing that I do want to come back to a bit is  
8       what started part of this discussion is that list of  
9       parameters that are documented in the topical report  
10      for display on the large display panel.

11               I'll give you the first example that led  
12      me into this is that in a previous incarnation, in  
13      Rev. 5 of the topical report, I said there's several  
14      parameters that I have listed here, but one that  
15      started me from the back end was if I were an  
16      operator, I'd be really interested in safety-related  
17      DC bus voltage. That, to me, on this plant, is a  
18      pretty important parameter that I'd like to know  
19      about. It's not listed in Rev. 6 of the MUAP as  
20      being a parameter on the large display panel. It  
21      was in Rev. 5. So someone made a conscious decision  
22      to remove that parameter in the list, in the topical  
23      report, which is the starting point for, as you said,  
24      for doing the HFE.

25               That is what prompted my notion of what

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       it is that we're reviewing, in terms of an inventory,  
2       which is what started this discussion an hour ago,  
3       and how we, taking a snapshot of that topical report  
4       design, the blue stuff in this particular  
5       overhead -- how we should be thinking about that set  
6       of things. I can understand, at one level, if it's  
7       only a vague suggestion of what might be eventually  
8       settled on as part of the green part of the process,  
9       but at least in the US-APWR DCD, up until now, there  
10      was no evidence of any changes in the green, at least  
11      to that level of the inventory. You may want to  
12      address that later. You may want to think about it.

13               MEMBER BLEY: Two little things. One,  
14      although it's complete now, the blue, getting to  
15      US-Basic, was iterative to get there -- was an  
16      iterative process to do everything in the blue. Two,  
17      that first round of testing, the report that came out  
18      of that, I don't know if staff has it. If staff has  
19      it, we would love to see a copy of it. We're very  
20      interested. If they don't have it, if it's possible,  
21      we'd like to see it. I don't know how that works,  
22      but in any case, Girija, we'd like to get that if we  
23      can.

24               MR. SPRENGEL: We'll look into that.

25               CHAIRMAN STETKAR: I hesitate to ask,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 but any of the other members have anything? Because  
2 eventually Kenji's going to get to Slide 3  
3 (Simultaneous speaking) but actually all of this  
4 discussion, I think, has been very, very good because  
5 it has answered, for me, several questions that I  
6 would have brought up in the mainstream. Anything  
7 else from any of the other members? If not, let's  
8 recess until 10:30.

9 (Whereupon, the above-entitled meeting  
10 went off the record at 10:13 a.m. and resumed at  
11 10:35 a.m.)

12 CHAIRMAN STETKAR: We are back in  
13 session. Eventually, Kenji will get to Slide 3, but  
14 did you guys have anything else that you wanted to  
15 say? I'm assuming you do.

16 MR. SPRENGEL: Yes. Yes. Follow-ups  
17 are my favorite, so we have a couple of things to  
18 touch back on and, hopefully, answer the questions.  
19 There's a few things that we'll push out.

20 In terms of the changes between Rev 5 and  
21 Rev 6, there was -- DC, bus voltage is an easier  
22 answer. The reason that that was a parameter on the  
23 list was because it was previously on our PAM list.  
24 That PAM List has been revised, or had been revised,  
25 and that's why it fell off. So that was a separate

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 review ongoing. The PAM List had been revised and  
2 submitted, as part of Chapter 7.

3 CHAIRMAN STETKAR: Part, no, this is for  
4 the MUAP, for the Topical Report. I'm still keeping  
5 us on the generic topical.

6 MEMBER BLEY: Are you saying that's why  
7 they took it off of that one, is because they took  
8 it off of the Chapter 7?

9 MR. SPRENGEL: Yes. The reason that it  
10 was showing up as a parameter, was because it was  
11 previously a PAM variable.

12 CHAIRMAN STETKAR: So -- Okay. But, I  
13 use it, I mean, I don't want to get into specific  
14 parameters, because we're going to talk hours about  
15 specific parameters, but there was an active decision  
16 about removing that particular parameter, is what  
17 you're telling me?

18 MR. SPRENGEL: That's correct.

19 CHAIRMAN STETKAR: Okay. As, I'm sure,  
20 there were active decisions about removing others and  
21 adding, you know, there's, there are things that  
22 appear in Rev 6 that weren't in Rev 5. There are  
23 things in Rev 5 that don't appear.

24 There's a large, when I say large I'm, a  
25 few dozen parameters that are, that are different.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 But after the decisions were made, I'm sure, for each  
2 one of them, some basis for changing them. That  
3 isn't my point.

4 MR. SPRENGEL: The question is still  
5 outstanding. And I have specific answers on these,  
6 so I think, let me continue to discuss and follow-up  
7 on the broader question, I think, is understanding  
8 what the current status of the inventory is for the  
9 Topical Report.

10 CHAIRMAN STETKAR: It --

11 MR. SPRENGEL: So let me --

12 CHAIRMAN STETKAR: Yes.

13 MR. SPRENGEL: -- defer that a little bit  
14 longer.

15 CHAIRMAN STETKAR: Yes, and how, the  
16 corollary to that is, I mean, there is a table that,  
17 for me, defines the inventory. It's that Table 4,  
18 whatever I sited, 4.9-1, I think it is, but don't,  
19 don't hold me to the number.

20 There is a table that lists, it's a long  
21 list of parameters and, I think, it's supposed to  
22 tell me both what the list is and why they're there,  
23 because there are the columns that says well, this  
24 is an SPDS function, or something.

25 And fine, I don't, at one level, I don't

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 particularly care what that list is. On the other  
2 hand, if I'm presented with that list, and if that  
3 list is, indeed, part of what the ACRS is reviewing  
4 and approving, as a reasonable list, for this generic  
5 HSI that's, that's more important for me, because  
6 then I need to think about that inventory doesn't  
7 make sense that it's a generic list.

8 In some sense, I don't care what happened  
9 previously, because we're reviewing Rev 6 of the  
10 Report. I just happen to have Rev 5, because it's  
11 what's referred to in the DCD Chapter 4, so I noticed  
12 the changes.

13 But more importantly for us, I'd like to  
14 understand how we should interpret that list, as part  
15 of our technical review?

16 MR. SPRENGEL: Right.

17 CHAIRMAN STETKAR: Because I was  
18 interpreting it as something that, indeed, was part  
19 of the blue and it should not change. You might add  
20 things, as part of the green, if you will, but you  
21 wouldn't wind, you wouldn't delete things from that  
22 list because it, it was essentially, what formed the  
23 framework for the US-Basic HSI.

24 MR. SPRENGEL: You know --

25 CHAIRMAN STETKAR: If that's not the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 case, we need to understand --

2 MR. SPRENGEL: Yes.

3 CHAIRMAN STETKAR: -- you know, that --

4 MR. SPRENGEL: I understand the question

5 fully --

6 CHAIRMAN STETKAR: Okay.

7 MR. SPRENGEL: -- and we will defer

8 that --

9 CHAIRMAN STETKAR: Okay.

10 MR. SPRENGEL: -- today, to continue that

11 discussion today.

12 CHAIRMAN STETKAR: Okay.

13 MR. SPRENGEL: One other item to touch

14 on, the discussion on the additional VDU screen at

15 the SRO and STA --

16 CHAIRMAN STETKAR: You're going to find

17 it, aren't you? Or you found it already?

18 MR. SPRENGEL: Oh no. It's not that

19 good of an answer.

20 (Laughter)

21 CHAIRMAN STETKAR: I was, I sure, I sure

22 hope not.

23 MR. SPRENGEL: Okay, so we -- this isn't

24 the best picture. We discussed the starting point --

25 CHAIRMAN STETKAR: Yes.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. SPRENGEL: -- for Phase 1, the  
2 activities that went on, so that's clear.

3 CHAIRMAN STETKAR: Yes.

4 MR. SPRENGEL: Everyone's seen this, so  
5 the Topical Report is having a perspective after  
6 that, the Phase 1 testing.

7 CHAIRMAN STETKAR: Yes.

8 MR. SPRENGEL: So that happened, the  
9 improvements were made, documented, and submitted,  
10 as part of the Topical Report. One of the areas that  
11 resulted in change was this third VDU -- there's an  
12 alarm VDU and --

13 CHAIRMAN STETKAR: -- yes, just, in case  
14 you put one on this one --

15 MR. SPRENGEL: -- the third VDU, yes.

16 CHAIRMAN STETKAR: -- you applied one on  
17 the desk, it's actually the fourth, but --

18 MR. SPRENGEL: It's --

19 CHAIRMAN STETKAR: -- or the fifth, but  
20 anyway, so yes.

21 (Simultaneous speaking)

22 MR. SPRENGEL: So there's an additional  
23 VDU that was added and it is, it's a, it's a streaming  
24 image of what the RO screens are, so it's not an  
25 OVDU, as you would typically imagine, in terms of,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       you know, diving through the screens of the systems,  
2       it is simply an image of the RO screens. Now with  
3       that, there's confusion on the face, there's also  
4       toggles in place that, basically, the SRO and STA can  
5       toggle between whatever screens.

6               CHAIRMAN STETKAR: Yes, because I was  
7       going to say, when you're talking, I mean, in  
8       principle, even if you bring up the, you can either  
9       have four operational VDUs, or six, if you can  
10      include the procedure one, down below.

11             MR. SPRENGEL: Right. So the additional  
12      VDU is, again, just a screen image of any selected --

13             CHAIRMAN STETKAR: Yes, selected --

14             MR. SPRENGEL: -- RO screen.

15             CHAIRMAN STETKAR: -- only one screen.

16             MR. SPRENGEL: Correct.

17             CHAIRMAN STETKAR: Only one screen.

18             MR. SPRENGEL: Right.

19             CHAIRMAN STETKAR: So you should take RO  
20      Number 1 Screen, Number 2, bring it up, to see what  
21      that person --

22             MR. SPRENGEL: And you can select between  
23      any of those.

24             CHAIRMAN STETKAR: Got it.

25             MR. SPRENGEL: Okay. But then --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: But that's not  
2 described in --  
3 MR. SPRENGEL: Okay.  
4 CHAIRMAN STETKAR: Sorry.  
5 MR. SPRENGEL: You're getting ahead.  
6 CHAIRMAN STETKAR: I'm sorry.  
7 MR. SPRENGEL: So that was one of the  
8 changes. Although, not view the significant,  
9 because it's not even, it's just a screen image. I  
10 mean, it's like a little video camera just blind,  
11 it's not a video camera, but it's just showing that  
12 image --  
13 MEMBER BLEY: That sounds --  
14 MR. SPRENGEL: -- there's more control --  
15 MEMBER BLEY: That sounds like an I&C  
16 person's --  
17 MR. SPRENGEL: Right.  
18 MEMBER BLEY: -- interpretation of  
19 what's significant. From a human factor's, or  
20 operational, point of view, I think it's --  
21 MR. SPRENGEL: Okay. That's --  
22 MEMBER BLEY: -- damn important.  
23 MR. SPRENGEL: -- correct. That's  
24 correct. That's correct. So --  
25 MEMBER BLEY: Right.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. SPRENGEL: -- with that, I want to  
2 recognize that we need to add that description.

3 (Simultaneous speaking)

4 CHAIRMAN STETKAR: You do, and the reason  
5 that I'm -- there are a couple of reasons that I'm  
6 whining about this so much. One, one reason is just  
7 what you just mentioned, is that the Topical Report  
8 should, in fact, accurately describe, and this figure  
9 is indeed in the Topical Report and it shows four  
10 little things up there.

11 I could argue that, maybe, I thought that  
12 the third one was the, was a different screen, but  
13 that's okay. It should accurately describe the  
14 configuration that, that we're being asked to review.

15 But, quite honestly, when I was reading  
16 through the Topical Report, from an operational  
17 perspective, as Dennis just mentioned, I still, and  
18 we'll talk about this later, had questions about the  
19 inventory of displays available to the control room  
20 team, especially in a configuration where you have  
21 an STA, an SRO, and one and only one RO.

22 Because when I thought about how people  
23 would be using the various displays, or could be  
24 using the various displays, from an operational and  
25 oversight perspective, supervisors trying to keep the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 bigger picture on what's going on, the operators  
2 being involved in trying to understand the plant  
3 evolution, as a function of time, and interfacing  
4 with the procedures and the systems, I started to  
5 quickly get, I thought, and may still be, limited in  
6 terms of the amount of displays available.

7 So for example, as Dennis said, from an  
8 I&C perspective, one more display sounds like a  
9 fairly minor change. To me, a couple more displays  
10 might be a big deal, because it might let me, as an  
11 operator, have a lot better confidence of things that  
12 I can glance over and have an understanding of what's  
13 going on. So that's one of the reasons why I'm  
14 personally kind of --

15 MR. SPRENGEL: Yes.

16 CHAIRMAN STETKAR: -- kind of invested  
17 in these numbers things here.

18 MR. HALL: A very quick response to your  
19 question. I've been told to keep it short, and I  
20 will. We did, in fact, look into that, and what  
21 you're describing is generally correct.

22 But rather than adding display surface  
23 area, a lot of what was done was create more efficient  
24 navigation tools, alarm tools, displays that combine  
25 things in the unique ways, so you don't need two

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 displays you can do it on one. So I think some of  
2 that's going to be addressed when Kenji goes through  
3 some more detail on what the HSI looks like.

4 CHAIRMAN STETKAR: Okay. Let's wait for  
5 that, because I've got a comment, but rather than  
6 doing it let's, since he pointed to Kenji, let's let  
7 him do that and bring that up, because I'll just  
8 telegraph it, you may want to think of it, as he goes  
9 through his slides.

10 I have a real problem with requiring the  
11 operators to toggle actively back and forth and  
12 select things to bring up in the heat of battle.  
13 That's personal preference, but --

14 MR. HALL: I understand.

15 CHAIRMAN STETKAR: But I think we've seen  
16 problems where people are forced to do that.

17 MR. SPRENGEL: Okay, another change that  
18 we want to highlight, as a result of the phased  
19 process. We saw on the diagram -- I lost it.

20 Okay, so one of the other changes that  
21 shows up on the layout that we're displaying here is  
22 the safety VDUs.

23 CHAIRMAN STETKAR: Yes.

24 MR. SPRENGEL: And you'll notice that  
25 there's a different number than was in the initial

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 implementation of the US-Basic simulator. So the  
2 additional two screens are the multi-divisional  
3 screens that we have specific section on, in the  
4 presentation and in the Topical Report.

5 CHAIRMAN STETKAR: Those I knew about  
6 and I was willing to, I understand what they are, why  
7 they're there, and I was willing to --

8 MR. SPRENGEL: Yes.

9 CHAIRMAN STETKAR: -- acknowledge the  
10 difference between the photograph and this picture,  
11 because this picture is clearly described and in the  
12 Topical Report.

13 MR. HALL: Yes.

14 MR. SPRENGEL: Agreed.

15 CHAIRMAN STETKAR: It was six screens  
16 off to the left.

17 MR. HALL: And those extra screens was  
18 result of the tests, when --

19 CHAIRMAN STETKAR: Yes.

20 MR. HALL: -- you're asking --

21 CHAIRMAN STETKAR: I --

22 MR. HALL: -- what unique changes --

23 CHAIRMAN STETKAR: Yes.

24 MR. HALL: -- were made, those were --

25 CHAIRMAN STETKAR: Yes, yes, yes that --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 MR. HALL: -- resulting of the test.

2 CHAIRMAN STETKAR: Yes.

3 MR. SPRENGEL: Wrapping that up, the  
4 additional VDUs will be acknowledged in the Topical  
5 Report and described, in terms of their purpose and  
6 functionality.

7 CHAIRMAN STETKAR: That would be great.

8 MR. SPRENGEL: Okay. I don't know where  
9 we are --

10 CHAIRMAN STETKAR: If Kenji wasn't so  
11 long-winded, you know, we could let him get to those,  
12 like, his third slide. We're on --

13 MR. SPRENGEL: I think --

14 CHAIRMAN STETKAR: We've covered the  
15 whole presentation. We're on, we're on, I believe --

16 MR. SPRENGEL: Nineteen, or 20.

17 CHAIRMAN STETKAR: -- 19, or 20, from our  
18 package.

19 MR. SPRENGEL: Yes. Let me, yes he just  
20 finished that one.

21 CHAIRMAN STETKAR: Yes, I think you were  
22 just starting to talk about this one, when somebody  
23 interrupted you. Sorry.

24 MR. MASHIO: Yes, and so --

25 CHAIRMAN STETKAR: Is your mic on, Kenji?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   MR. MASHIO: Oh. So we go back to the  
2                   2.4 our phase implementation. So Phase 1, more  
3                   generally speaking, in that using that diagram, Phase  
4                   1 in this Topical Report scope, it translates  
5                   Japanese-Basic HSI to the US-Basic HSI.

6                   Under Phase 2, the developing of  
7                   applications-specific program for the US-APWR  
8                   inventory feature the combined with the Basic HSIS  
9                   to yield an applications-specific design.

10                  And the Phase 3 is our confirms the  
11                  site-specific assumptions with the Phase 2 and/or  
12                  make minor site-specific changes to finalize  
13                  application design.

14                  And then, this 2.5 slide split output,  
15                  Phase 1 splits two ways, Phase 1a, Alpha, and Phase  
16                  1b, Bravo. Under Phase 1a, Alpha, incorporates email  
17                  changes, which are necessary to apply U.S. standard  
18                  design, as such as the language conversion.

19                  Oh, I'm sorry. Yes, actually, this Phase  
20                  1a, Alpha, modifications we've already covered. And  
21                  I'll just remark that in parallel to this conversion  
22                  we made, we also made improvement identified from the  
23                  completing OER program element of NUREG-711, which  
24                  include U.S. nuclear plant and the additional,  
25                  generic, digital HSI technology experience. So

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       those are OER conducted under NUREG performance issue  
2       to the Basic HSI portion.

3               CHAIRMAN STETKAR:     And, Kenji, as I  
4       understand it, some of that operational experience,  
5       it does say in that sub-bullet, it says additional  
6       generic. You also had operational experience from  
7       other types of industries --

8               MR. MASHIO:   Yes.

9               CHAIRMAN STETKAR:   -- not just nuclear  
10      plants, right?

11              MR. MASHIO:   Yes.

12              CHAIRMAN STETKAR:   Okay. Thank you.

13              MR. MASHIO:   So one comment Phase 1b,  
14      Bravo, so we, just move to this next slide. And  
15      in --

16              Yes. Two separate Phase 1 testing main  
17      control room safety was used to support dynamic  
18      testing for US-Basic HSIS. Additionally, static  
19      portable HSIS analysis tool on the personal computer  
20      platform was developed to support this phase screen  
21      navigation verification.

22              CHAIRMAN STETKAR:   Kenji.

23              MR. MASHIO:   Yes?

24              CHAIRMAN STETKAR:   I hate to hang up on  
25      this stuff, but the second bullet there talks about

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 eight crews, 22 people, Phase 1a.

2 MR. MASHIO: Yes.

3 CHAIRMAN STETKAR: That's what, I  
4 believe, is documented in the Topical Report, is that  
5 correct?

6 MR. MASHIO: Yes, I believe this --

7 CHAIRMAN STETKAR: Because I don't  
8 remember hearing about the five crews, ten people.

9 MR. MASHIO: Yes, this answer, as I'm  
10 taking this number to verify --

11 CHAIRMAN STETKAR: Well I can tell you,  
12 in the Topical Report, Appendix C and indeed, in the  
13 documents I could find, this notion of eight crews,  
14 22 people, I've even got the breakdown of number of  
15 ROs and SROs, seven scenarios, the thing that's  
16 called Phase 1a here is, is indeed, I believe, what's  
17 documented in the Topical Report. The five crews,  
18 ten people --

19 MR. SPRENGEL: Yes.

20 CHAIRMAN STETKAR: Oh yes.

21 MR. SPRENGEL: No that's --

22 CHAIRMAN STETKAR: The five crews, ten  
23 people, I don't know what that is. And if it's Phase  
24 1b, is that for the US-Basic, or is that somehow now  
25 a mix --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. HALL: Right.

2 CHAIRMAN STETKAR: -- of morphing to  
3 US-APWR?

4 MR. HALL: No. The, remember, when I  
5 was speaking, I said there were two sets of tests  
6 done that got us to the US-Basic, which is the subject  
7 of the topical.

8 CHAIRMAN STETKAR: Yes.

9 MR. HALL: These are the two sets of  
10 tests.

11 CHAIRMAN STETKAR: So --

12 MR. HALL: This first one, this Phase 1a  
13 was the first test I was talking about. The Phase  
14 1b that he's referring to --

15 CHAIRMAN STETKAR: Okay. Bob, you --

16 MR. HALL: -- is the second set of --

17 CHAIRMAN STETKAR: Now I'm suddenly,  
18 because I was trying to make pretty clear in my  
19 questions, and maybe I wasn't clear enough. So for  
20 the record, the thing that is documented in Appendix  
21 C of the Topical Report is Phase 1a.

22 MR. HALL: I think that's what Kenji's  
23 now checking, to find out what's in there.

24 CHAIRMAN STETKAR: Well that's what I'm  
25 trying to understand. Because what is documented in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the Topical Report is important for us to understand  
2 how operating crews interface with something, and we  
3 need to know what that something is, or was.

4 MR. HALL: The Topical Report is  
5 referencing 1a.

6 CHAIRMAN STETKAR: Okay. What is 1b?

7 MR. HALL: 1b is the second test of tests  
8 that I described earlier, before the break, that took  
9 the findings, the results of this testing, 1a testing  
10 that was done on the Japanese conversion, all the  
11 things we found that we needed to change, all those  
12 HEDs, the 1b, the second test listed here, is the  
13 second test I described. It was those changes made  
14 and then we tested those changes.

15 CHAIRMAN STETKAR: Two questions. Two  
16 questions, let me -- where is that documented and  
17 what is the purpose of the 1b in relationship to the  
18 US-Basic HSI?

19 MR. HALL: I can't tell you where it's  
20 documented.

21 MR. SPRENGEL: The results of 1b became  
22 the US-Basic HSIS. And the note on the bottom of  
23 the slide I am showing. So it resulted in,  
24 basically, the updated Topical Report, because the  
25 design was modified, as a result of it. We've talked

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 about the screen changed.

2 MEMBER BLEY: So just, but in Appendix  
3 C, which describes the testing, it only describes the  
4 Phase 1a testing. So there's nowhere in this  
5 document where we see the Phase 1b testing?

6 MR. SPRENGEL: That's an open question.  
7 So I can --

8 MEMBER BLEY: It looked very open.

9 CHAIRMAN STETKAR: The problem is, Ryan,  
10 I, up until right now, I thought -- and I had several  
11 questions about the phasing. I thought that I  
12 understood the phasing. I thought that the Phase 1a  
13 testing that's documented in the Topical Report  
14 brought us up to the US-Basic HSI, in the context of  
15 the picture that you had up earlier, what we can call  
16 now, the blue stuff. And that Phase 1b testing was  
17 part of the transition from that US-Basic to  
18 something that would eventually become the US-APWR.

19 MR. SPRENGEL: US-APWR.

20 CHAIRMAN STETKAR: That indeed, my  
21 interpretation was that Phase 1b was part of the  
22 green process, which is, has yet to be finished. I'm  
23 apparently wrong.

24 MR. SPRENGEL: You are wrong.

25 CHAIRMAN STETKAR: I'm willing to admit

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       that I'm wrong. But then, indeed, I don't think we  
2       have documented that Phase 1b. Because, the problem  
3       is that what's documented in the Topical Report,  
4       quite honestly, because we're all out of sequence now  
5       anyway, at the end of Appendix C I'm left with the  
6       impression that, essentially, all of the operating  
7       crews failed open on response to a tube rupture  
8       event, which quite honestly, in a complex scenario  
9       time sensitive actions is exactly where I was  
10      concerned about the configuration and number of  
11      displays available to operations.

12               And, indeed, they all failed open and it  
13      says we have a, we've created human engineering  
14      deficiencies and that's where it ends. So I'm, in  
15      the context of the US-Basic HSI, I was left with the  
16      opinion that there are fairly significant human  
17      engineering deficiencies that are yet to be resolved.

18               MR. SPRENGEL: Okay.

19               CHAIRMAN STETKAR: -- I was wrong.

20               MR. SPRENGEL: So let's review the slide  
21      displayed now. Phase 1 is the Topical Report scope.  
22      It is the blue. So --

23               CHAIRMAN STETKAR: It is the blue?

24               MR. SPRENGEL: The 1a, in terms of the,  
25      we reference iterative design, I mean, it was

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1       iterative in pieces, but we split 1a and 1b  
2       separately.

3               1a was, you know, right after the initial  
4       translation from the Japanese design to the US, we  
5       have some favorite terminology to refer to for that  
6       conversion. That is special because the, the  
7       additional changes needed were not necessarily  
8       expected.

9               I mean, maybe in hindsight we can say  
10      that a lot of those things, in terms of how the  
11      operators use the systems. You know, the hope is  
12      always like, like was said, the hope was let's, let's  
13      take the control room and just move it where ever and  
14      everyone use it the same.

15              Well, 1a, that testing and why it's kind  
16      of broken into two, was special in that we had to get  
17      over that hurdle of converting it to U.S. use. And  
18      then 1b got into, okay, now that it's usable we're  
19      going to continue to fine tune it and resolve the  
20      operating deficiencies separate from the country  
21      conversion.

22              The results of 1b then, were just  
23      integrated, in terms of the improvement to the HSI  
24      design and became what is the design that is  
25      presented in the Topical Report.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: So all of what you just  
2 described is the blue stuff on Bob's flowchart?

3 MR. SPRENGEL: That's correct.

4 MEMBER BLEY: Okay.

5 CHAIRMAN STETKAR: But there's no  
6 documentation of, I mean, you say ten, five crews,  
7 ten operators. I think that's what it said.

8 Ten persons. Five crews, ten people.  
9 So obviously, some people were on multiple crews,  
10 because -- you need at least 15 for five crews. So  
11 I'm not sure how blind a test that was. Will they  
12 run through several scenarios each? I mean, what  
13 was done in that 1b? Because that, to me, is the  
14 proof that thing that we're asked to review has had  
15 some measure of dynamic testing on your vernacular.

16 MEMBER SCHULTZ: Simplifying the  
17 question is, why isn't that documented in the  
18 Topical?

19 MR. HALL: Now let me answer the  
20 technical question. The 1a test did, in fact, have  
21 failures of the crews that we did not anticipate  
22 going into the testing, but that's what testing is  
23 about. The changes to the design, all crews passed  
24 the success criteria. So the changes were successful  
25 on things like steam generator tube rupture.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           The crews were broken down in Phase 1a,  
2           such that we had crews with a single RO and crews  
3           with this double RO. This, you know, because we  
4           wanted to see, did it make a difference in operating  
5           the plant.

6           CHAIRMAN STETKAR: Yes, I finally  
7           divined that. I didn't, you can't really understand  
8           that just reading it. But you can, if you read  
9           between the lines in many separate --

10          MR. HALL: Okay.

11          CHAIRMAN STETKAR: -- reports. But go  
12          on, that's --

13          MR. HALL: So that's what it was. And  
14          then, for Phase 1b, we only used two-person crews,  
15          because we saw no variation between the results of  
16          the two operators and the one operator.

17          So the first series of tests, some of  
18          them had --

19          CHAIRMAN STETKAR: I'm sorry. When you  
20          use the term operator, I think of individuals. So I  
21          have a shift technical advisor, a senior reactor  
22          operator, and a reactor operator, define what you  
23          mean by operator.

24          MR. HALL: The tests were Phase 1a SRO.  
25          Sometimes a single RO. Sometimes a double RO. We

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 did --

2 CHAIRMAN STETKAR: Never and STA?

3 MR. HALL: We ran, now, I know we ran,  
4 at least, one with an STA, but I think that might be  
5 it. I'd have to go back and check the record. Phase  
6 1 --

7 CHAIRMAN STETKAR: Is that the one that  
8 they won on, or the time that they succeeded?

9 MR. HALL: I can't answer the question,  
10 I don't know. The Phase 1b we tested really the  
11 minimum compliment, which is the SRO and RO. So it  
12 was one RO and the SRO. So Phase 1b only looked at  
13 the two people in the control room and --

14 CHAIRMAN STETKAR: Thank you.

15 MR. HALL: -- and both of them ran, the  
16 first one ran something like eight scenarios, the  
17 second one ran five, or seven, I'd have to go back  
18 into the record and pull out how many scenarios.

19 And these were full scope scenarios.  
20 Everything from something like a startup, which was  
21 a long duration, to typical type of accident  
22 response, including loss of oil, operational VDUs,  
23 and the need to move over to some of the other support  
24 systems.

25 It included things like, during scenarios

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       having screens freezes.   Because, you know, in a  
2       digital system that's one of the oh my Gods, is having  
3       a screen just freezing on you and you not know that  
4       the digits, the numbers you're looking at were not  
5       correct.   So.

6               MEMBER SCHULTZ:   The third bullet refers  
7       to the scenarios that were run in both Phase 1a and  
8       Phase 1b, the third bullet on this slide?

9               CHAIRMAN STETKAR:   No.   That's not what  
10      he said.

11              Certainly, it's Phase 1a, because that's  
12      what's documented in Appendix C, but Bob just --

13              MR. HALL:   Yes.

14              CHAIRMAN STETKAR:   -- told us that --

15              MR. HALL:   This --

16              CHAIRMAN STETKAR:   -- that not all seven  
17      scenarios were run through the other crews.

18              MEMBER SCHULTZ:   Okay.

19              MR. HALL:   Yes.   That's 1a is the -- and  
20      we ran additional scenarios for 1b, so it wasn't just  
21      the same sets of scenarios --

22              CHAIRMAN STETKAR:   Probably wouldn't get  
23      PhD for your --

24              MEMBER SCHULTZ:   Different ones, yes.

25              CHAIRMAN STETKAR:   -- for your testing

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 program, in terms of engineering a real test with  
2 this --

3 MR. HALL: Well, as I said, they're  
4 testing, this testing ended up coming into what the  
5 ISV is reported on in the Technical Report for ISV.  
6 So what's proposed there is the process refined here.

7 CHAIRMAN STETKAR: Yes, but the problem  
8 is, once you're set on a basic, I'll come back to  
9 this generic thing that's got a bunch of screens and  
10 a bunch of stuff on it, once you're set on that, it's  
11 pretty hard to make changes after that.

12 And if you haven't actively done some  
13 good testing on that, with real operators and real  
14 scenarios, it's hard to have confidence. Because,  
15 as I said, quite honestly, I didn't read Appendix C  
16 until I got to Appendix C.

17 And if you read some of the stuff that's  
18 written in here, I had many questions about the  
19 ability of the operators to use this interface, both  
20 with and without operational VDUs available in a real  
21 event.

22 And I got to Appendix C and everything  
23 that I was worried about was, indeed, fully  
24 corroborated. They had problems when they were faced  
25 with the only time sensitive complex scenario, the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       only one that was really time sensitive. They all  
2       failed. And now I'm being told here in this meeting  
3       that, okay, we fixed all of that and we ran, you  
4       know, five more crews on some subset of scenarios and  
5       they all did okay. There isn't a lot of confidence  
6       building here.

7                   MEMBER BLEY: And we don't know, we don't  
8       know what those set of scenarios were. Were they  
9       the simplest straightforward ones, like we often see  
10      in a simulator, or were they more complex ones that  
11      would have challenged them and challenged the  
12      interface? So we're sitting here a little deaf,  
13      dumb, and blind kind of spot.

14                   Just an aside, two recent things were the  
15      consideration, I think. There was a presentation at  
16      last year's RIC by the Halden folks, who did a series  
17      of experiments looking at different ways to engage  
18      the STA, and the results were maybe not surprising,  
19      if you have operational background. I think we're  
20      surprising to a lot of people. It's worth looking  
21      at those.

22                   And the other one, if we talk about  
23      complex scenarios, we'd always throw out the Robinson  
24      fire. Think about that. There you had, for about  
25      the first half-hour, only two guys in the control

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 room doing anything, and things got much harder with  
2 just having two people.

3 MR. SPRENGEL: We will take an action  
4 from the feedback. There was a sequence of events,  
5 and I think through our cleanup of the technical  
6 reports, one of them that was removed was a more  
7 detailed discussion of the Phase 1b. And I think  
8 there may -- 1b, yes.

9 So we'll take an action to review that  
10 information and consider how to add the detail, like  
11 1a, detailing what was done for the 1b effort into  
12 the Topical Report.

13 MR. HALL: All of our recent comments  
14 said, I'd like to reiterate that I think the story  
15 you walked us through on how you took the  
16 Americanized panel and worked through it to find  
17 potential problems was a really good story. I'm glad  
18 you did all that. I'm glad you told us about it.

19 And the thing you found about the problem  
20 with supervision with having people sitting at the  
21 panels, I think, is a crucial one for everybody who's  
22 looking at these kinds of designs and we really  
23 appreciate that.

24 MR. SPRENGEL: Thank you. One other  
25 highlight. And I don't think it'll necessarily

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1       answer any questions, but I just want to state it  
2       that, that the US-Basic HSI was not started from  
3       nothing.

4               And in terms of the flexibility of the  
5       screen and what's displayed there, that portion of  
6       the development happened with the development of the  
7       Japanese-Basic HSI.

8               So some of the concerns, in terms of what  
9       information is available, how it's displayed, whatnot  
10      that had already taken place, as part of the Japanese  
11      HSI effort.

12              And we didn't necessarily -- So I, again,  
13      I don't know that it will resolve any of the concerns,  
14      or questions, but I also don't want to leave the  
15      impression that that kind of work didn't happen.

16              CHAIRMAN STETKAR:     No, I understand  
17      that, Ryan.

18              MR. SPRENGEL:     Okay.

19              CHAIRMAN STETKAR:     And my perspective is  
20      from somebody who use to operate a nuclear power  
21      plant 35 years ago in the United States. And I've  
22      worked with operators, you know, since then. But  
23      not in Japan.

24              And I'm aware of those changes, but as I  
25      said, as I looked at the HSI from my perspective, a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 bit of my concern might have been a holdover from a  
2 different way that the Japanese operators are used  
3 to using those interfaces.

4 They may be more use to and more  
5 comfortable with toggling very, very quickly among  
6 several different displays and not feeling  
7 comfortable with continuous trend information, for  
8 example. A more rapid fire.

9 And I was, you know, I wasn't sure  
10 whether that might have been a holdover from Japan  
11 versus part, more of the consideration that Bob  
12 talked about, of really looking at the differences.

13 MR. HALL: Let me point out that, when  
14 Kenji gets through his slides, ask those questions.

15 CHAIRMAN STETKAR: Okay.

16 MR. HALL: Because, you got to remember  
17 in these machines, and it's not unique to the  
18 Mitsubishi design, they have these large display  
19 panels that show a lot of information and it removed,  
20 no, it removes a lot of the toggling you're talking  
21 about, requirement. It becomes a communication  
22 devise. So I would suggest --

23 CHAIRMAN STETKAR: All right.

24 MR. HALL: -- when Kenji gets to that  
25 slide of this quote LDP, large display panel, this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 might become clearer, or maybe ask that question  
2 again and we can walk through it.

3 CHAIRMAN STETKAR: And I really, like  
4 personally, this is subcommittee meeting, so I can  
5 say this, I personally like, very much, the idea of  
6 the large display panel and the information it  
7 conveys.

8 And it's a -- I also will acknowledge  
9 that it's not safety related. It's powered from  
10 non-safety related stuff and it might go away in the  
11 types of events where people can get into real  
12 trouble and that the operators will be left only with  
13 the safety-related displays. And I --

14 MR. HALL: And our tests --

15 CHAIRMAN STETKAR: And I tried to think  
16 about that, Paul.

17 MR. HALL: And our tests looked at loss  
18 of the large display panel in all operational systems  
19 gone, either frozen, or black, going to the safety  
20 panels.

21 Our tests also included safety panels  
22 going down. All digital loss and going over to the  
23 desk panel.

24 CHAIRMAN STETKAR: Yes, I feel a heck of  
25 a --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. HALL: So we had three, we had  
2 scenarios on --

3 MEMBER BLEY: Those tests would be really  
4 helpful for us, I think.

5 MR. SPRENGEL: We've captured the  
6 action.

7 MEMBER BLEY: Got you.

8 CHAIRMAN STETKAR: If you spoke more  
9 you'd remember, but we won't --

10 MR. MASHIO: No.

11 CHAIRMAN STETKAR: -- we actively won't  
12 let you speak.

13 MR. MASHIO: Okay, so -- yes. This our,  
14 this slide explains Operating Experience Review.  
15 And this resource include NUREG/CR-6400 and INPO  
16 database and also Japan Nuclear Technologies  
17 Institute, JANTI, Nuclear Information Archives,  
18 called NUCIA database, and also we, this also include  
19 our issues obtained from non-nuclear industries,  
20 similar HSIS technologies in U.S. and in Japan.  
21 Those findings were evaluated and included in the  
22 US-Basic HSIS.

23 And the concept of operation is addressed  
24 in the Section 4.1 in Topical Report. And the  
25 US-Basic HSIS addresses the following subject, crew

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 composition, roles and responsibilities, personnel  
2 interaction with plant automation, use of control  
3 room resources by crew members, methods used to  
4 ensure good coordination of crew member activities,  
5 including non-licensed operators, technicians, and  
6 maintenance personnel.

7 Operating crew composition. The normal  
8 MCR staffing consists of one RO and one SRO. And  
9 this normal MCR staff is supplemented by one  
10 additional SRO and one additional RO that will be at  
11 the plant to accommodate unexpected conditions.

12 CHAIRMAN STETKAR: Kenji, let me, let me  
13 stop you there. I hate to, hate to do this. But,  
14 again, in terms of the Topical Report, this is,  
15 indeed, the, the minimum crew that we're being asked  
16 to think about, right? So I'll ask you in a real  
17 event, if I have, perhaps, two ROs and two SROs in  
18 the control room, what do the two SROs do?

19 MR. MASHIO: One SRO is a supervisor  
20 position. And the one additional SRO is, this is a  
21 lower STA.

22 CHAIRMAN STETKAR: Who takes care of  
23 being the emergency director and calling all of the  
24 off-site personnel and handling all of those  
25 functions, coordinating other people, who might be

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 coming into the plant to help out during this event?

2 MR. MASHIO: We examine that HSI design  
3 inside the control room. And this, this scenario  
4 including those --

5 CHAIRMAN STETKAR: No, no, no, no.

6 MR. MASHIO: -- outside of the --

7 CHAIRMAN STETKAR: No, no. I'm sorry.  
8 I asked you, who among, I'll call them the two SROs,  
9 which one of those people handles all of those  
10 functions that are required, by law, in the United  
11 States, since we're, we're trying to get this  
12 implemented in the United States, which one of those  
13 two bodies performs all of those functions?

14 Off-site notification, performing the  
15 role of emergency director, looking at emergency  
16 action levels, coordinating with off-site  
17 responders, if I have a fire, if I have things like  
18 that, which one of those two people does that?  
19 Because one of them has to do it, by law. So I want  
20 to know, which one does it?

21 MR. HALL: Within the normal compliment  
22 there is, there are, the minimum crew, two in the  
23 control room, SRO and RO. There are these two  
24 additional individuals at the plant that are outside  
25 the plant that are expected, if needed, to come back

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 into the control room, one to take the position of a  
2 second RO, if needed, and then the second SRO. There  
3 is a third SRO that's a roving SRO that --

4 CHAIRMAN STETKAR: No, I'm, I'm sorry.  
5 That's an US-APWR design. That is not in this  
6 report. Do not confuse US-A --

7 MR. HALL: Okay. You're right.

8 CHAIRMAN STETKAR: -- PWR with this.

9 MR. HALL: You are correct. You are  
10 correct.

11 CHAIRMAN STETKAR: Indeed I am. I'm  
12 pretty happy with the US-APWR, but we're not talking  
13 about that. We're talking about the Topical Report.  
14 And that's why I, very clearly, want to keep those  
15 two subjects different. So now, in the Topical  
16 Report, minimum staffing, how do I handle that  
17 function?

18 MR. MASHIO: Yes, I do.

19 CHAIRMAN STETKAR: Okay.

20 MR. SPRENGEL: We'll leave that --

21 CHAIRMAN STETKAR: Okay.

22 MR. SPRENGEL: We'll follow-up on that  
23 item.

24 MR. MASHIO: Okay. So the HSIS is  
25 designed to support minimum MCR staffing described

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 above, and the space and the layout of the MCR are  
2 designed to accommodate the foreseen maximum number  
3 of operating and temporary staff.

4 And the staffing levels, staffing  
5 application IP, at handles further staffing levels  
6 for the US-APWR. And this slide shows a combination  
7 of who and where operator, crew, operator staff is  
8 sited in the, inside the control room.

9 ROs sit down at the operator console, and  
10 the SRO and the STA sit at the supervisor console and  
11 the STA console. And the feature located behind the  
12 operator console. And the MVP is located in front  
13 of the, both the members, crew members.

14 The computer-based HSI provide  
15 operational VDU, as the fundamental interface. So  
16 the operator monitors plant status and initiates  
17 actions from the VDU by touching or clicking on the  
18 appropriate sections of the screen.

19 The operators workload is significantly  
20 reduced by providing the relevant process control  
21 information in integrated displays on the VDUs and  
22 utilizing a compact console that minimizes required  
23 operator movement.

24 The HSI also provide operational support  
25 functions that utilize the computer to consolidate

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 large amounts of data into meaningful displays.  
2 Section 4.5, or 4.1, identifies further specific  
3 interface.

4 And our next slide Control Room Crew  
5 coordination with the HSIS. Control Room Crew  
6 coordination with the HSIS is described in each HSI  
7 design feature.

8 The Large Display Panel, LDP, provides  
9 Spatially Dedicated Continuously Visible, SDCV,  
10 information to the operation personnel to enhance  
11 situation awareness. That helps operations,  
12 operators maintain continuous awareness of the  
13 overall plant status and the critical status changes.

14 And the secondary purpose is to help the  
15 operations staff coordination and communication by  
16 providing a common visualization of plant  
17 information. The Operator Console provide all  
18 monitoring and control functions that are, feature  
19 available in the MCR, so that ROs can perform all  
20 operation tasks using the Operator Console from a  
21 seated position.

22 The Supervisor Console are located behind  
23 the RO, provides the same display set as those on the  
24 Operator Console, without control functions. The  
25 STA console provides the same display set as those

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 on the Operator Console, without control functions,  
2 as well.

3 Each console has paging phones and  
4 internal phones to communicate with local staff. The  
5 Maintenance console, which is temporary console,  
6 disconnect from the digital data communication bus  
7 during the normal plant operation, used to support  
8 an additional operator in MCR for tests during plant  
9 shutdown conditions and periodic inspections.

10 The tagging feature on the O-VDU and the  
11 physical tag for local component are also addressed  
12 to support maintenance activities between MCR crew  
13 and maintenance staff.

14 This picture, as we discussed, this is a  
15 US-Basic HSI simulator as noted. This picture shows  
16 our design feature in progress, during the phase of  
17 1 Alpha and does not reflect the finer designs.

18 CHAIRMAN STETKAR: So just, just make  
19 sure, because we're having a little side conversation  
20 here about being able to count to four, four, or  
21 five, which is pretty good for us. In the, after  
22 the Phase 1 Alpha, the Phase 1 Beta, or the US-Basic  
23 HSI, at the Supervisor Console there will be another  
24 display, a fifth display? I count five, because --

25 MR. SPRENGEL: Yes. That is correct.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: -- because the little  
2 flat thing on the bottom is the --

3 MR. SPRENGEL: Operating procedure, VDU.

4 CHAIRMAN STETKAR: -- is the operating  
5 procedure, VDU. So there'll be a fifth display off  
6 to the right. So the thing that you told me to count  
7 on before, actually should have had five on it?

8 MR. SPRENGEL: Yes.

9 CHAIRMAN STETKAR: Okay, thanks.

10 MR. MASHIO: Okay, the next topic is our  
11 Large Display Panel. And the first couple of slides  
12 gives LDP features. And LDP provide plant overview  
13 information to enhance MCR's staff awareness or plant  
14 status.

15 And LDP provides computer-aided operator  
16 support information, computer check-in, a relevant  
17 component status at reactor trip, ECCS containment  
18 activation, etc. And the second is the safety  
19 function status and bypass or inoperable status  
20 indication, BISI, along with safety signals,  
21 initiation single, such as a reactor trip, ECCS, or  
22 containment isolation signal.

23 CHAIRMAN STETKAR: I have a question,  
24 and I don't think I know the answer, because I get  
25 lost. The thing that Ryan was just pointing at, the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 bypass inoperable status indication. I know, I know  
2 that it is displayed, in fact, I know where it's  
3 displayed on the Large Display Panel. Is it  
4 available to the operators on the safety VDUs?

5 MR. MASHIO: The safety VDU, we, we don't  
6 know. Because we, this, our country's not  
7 implementing safety VDU, because this bypassing  
8 inoperable function is computer check-ins that are  
9 inoperable status. So computer --

10 CHAIRMAN STETKAR: Okay.

11 MR. MASHIO: -- plant computer is a no  
12 safety program, so it's not --

13 CHAIRMAN STETKAR: Okay, but I --

14 MR. MASHIO: -- our --

15 CHAIRMAN STETKAR: Okay, I'm a human  
16 being and an operator, and if all of my non-safety  
17 VDUs go dark, because the initiating event made it  
18 go dark, wouldn't the operators be interested in  
19 knowing what safety-related actuation signals are  
20 bypassed and inoperable, because those are  
21 safety-related signals that are bypassed, or  
22 inoperable, and why, why don't they have that  
23 information available to them?

24 MR. MASHIO: You --

25 CHAIRMAN STETKAR: For example, if Train

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 A didn't start, it would be useful for me to know  
2 that Train A didn't start because --

3 MR. SPRENGEL: Oh yes.

4 CHAIRMAN STETKAR: -- it was, it was  
5 bypassed and I can, maybe, do something to correct  
6 that, or maybe it didn't start because, oh, the pump  
7 broke. My response might be much different under  
8 either of those conditions.

9 MR. SPRENGEL: Okay, so we'll follow-up  
10 on that.

11 So just to clarify, the question is, one,  
12 we'll confirm that the BSIS information is not  
13 displayed on the safety VDUs and --

14 CHAIRMAN STETKAR: I could, I -- you  
15 know --

16 MR. SPRENGEL: -- the second follow-on  
17 question is --

18 CHAIRMAN STETKAR: Why?

19 MR. SPRENGEL: -- why?

20 CHAIRMAN STETKAR: I'm pretty sure that  
21 it's not, but I couldn't find anything justifying it.

22 MR. SPRENGEL: You --

23 CHAIRMAN STETKAR: Well no, I couldn't  
24 find anything definitive that said it's not, but I  
25 didn't, because I didn't find anything definitive --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. SPRENGEL: That said --

2 CHAIRMAN STETKAR: -- that said that it  
3 is, I'm --

4 MR. SPRENGEL: The second question is --

5 CHAIRMAN STETKAR: I'm pretty sure that  
6 it's not, and if it's not, why not, you know?

7 MEMBER BLEY: The happy answer would be,  
8 you missed it, it's there.

9 MR. SPRENGEL: We'll get back to you.

10 MR. MASHIO: Okay. So next slide show  
11 the display configuration in LDP. LDP contains pics  
12 on the variable display areas on 100 inches diagonal  
13 screens.

14 Three of these screens are dedicated to  
15 the fixed display area, and the fourth screen is  
16 variable area of where there's plant information and  
17 the plant display on the operational VDU display can  
18 be displayed.

19 The contents of the variable display can  
20 be selected from the Operator Console and from the  
21 Supervisor Console, thereby helping the operator  
22 staff command awareness on the communication.

23 CHAIRMAN STETKAR: Kenji, the variables  
24 display, I'm really, really critical. You guys, most  
25 of you know my personality by now, so we'll get over

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       that.

2                   The variable display area, anybody can  
3       bring up anything, any of the three, two, or three,  
4       bodies in the control room, can bring up anything on  
5       the variable display area. Are there, is that just  
6       done, as part of the crew operations dynamics,  
7       somebody says hey, bring up X?

8                   One of the concerns I had is, if I'm the  
9       shift supervisor and I want to see something, and I  
10      think it's important to everybody, I throw it up  
11      there. And the RO says, whoa, I want to see  
12      something else and I throw it up there. Suddenly,  
13      you've got a bunch of stuff going up and down on the  
14      variable display area, again, in not normal  
15      operations, or slow trend, things where, where things  
16      are happening kind of fast and you might want to  
17      check on things.

18                   Is there someone who has to actively take  
19      control over that area?

20                   MEMBER BLEY: Or is it possible for  
21      someone, shift supervisor, to take priority, so that  
22      what they do sticks?

23                   MR. MASHIO: Currently, this Basic HSI  
24      system does not have any priority between the  
25      Operator Console and the Supervisor Console.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: Yes, and that's  
2 documented in there. The question that I came up  
3 was, these dynamics of, the last thing that I would  
4 want is having this large display panel suddenly  
5 flashing from trend information to some system, to  
6 something else, because then it could be really  
7 distracting to people.

8 MEMBER POWERS: Especially manually, or  
9 automatically.

10 CHAIRMAN STETKAR: Well, it doesn't come  
11 up automatically, somebody has to select it. But,  
12 but the question is, if I think I'm more important  
13 than you are and I want to see something and throw  
14 it up there, and you think you want to see something  
15 else, then you get these screens flashing on and off  
16 that could, indeed --

17 MEMBER POWERS: Well it appears that you  
18 get the screen flashing on and off, whether you take  
19 command, or not, from simple words.

20 (Simultaneous speaking)

21 MR. MASHIO: Yes, as long as I observed  
22 the operator coordination during the Phase 1 --

23 MEMBER POWERS: I thought automatically.

24 MR. MASHIO: -- testing. And --

25 MEMBER POWERS: Automatically.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 CHAIRMAN STETKAR: You're right, Dana.  
2 I didn't ever remember reading the -- what's the  
3 automatically displayed on the variable display?

4 MR. MASHIO: Oh. Okay, yes. This  
5 automatically, this feature is if a random  
6 initiation, such as a hostile alarm or further  
7 reactor trip, then this also sets our screen. For  
8 example then, if our reactor trip initiates, the  
9 reactor trip verification screen is popped up on the  
10 variable area. So this --

11

12 CHAIRMAN STETKAR: Automatically?

13 MR. MASHIO: Yes, automatically.

14 MEMBER SCHULTZ: Based upon the plant  
15 action, it will be connected to --

16 MR. MASHIO: The plant, based on the  
17 conditions of --

18 MEMBER SCHULTZ: -- it will be connected  
19 to an automatic display.

20 MR. MASHIO: -- significant transaction,  
21 like initiating, then the associated -- once the  
22 associated information displays, automatically will  
23 pop up on that variable area. But then, the operator  
24 can override any information data. And they --

25 CHAIRMAN STETKAR: I thought that that,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Kenji, I thought that that type of information  
2 appeared on the upper part of the right-hand fixed  
3 display panel. What, what additional, I mean, you  
4 can't see it here, but in the photograph, if you go  
5 back to Slide Number 30. Go back to Slide 30.

6 There you go. Now, you see the red stuff  
7 on the upper right-hand panel of the fixed display,  
8 I thought that that was, effectively, the first out  
9 indication with priorities of what came in, am I  
10 wrong?

11 MR. MASHIO: Yes. For example --

12 CHAIRMAN STETKAR: I mean, it doesn't  
13 show up on this, which is, yes, kind of up in the air  
14 where you're --

15 MR. MASHIO: Yes, this top area is, this  
16 is the facade around the indication area.

17 CHAIRMAN STETKAR: Okay.

18 MR. MASHIO: And this include our ECCS  
19 from the left, our ECCS, our reactor trip --

20 CHAIRMAN STETKAR: Yes.

21 MR. MASHIO: -- and turbine trip and --

22 CHAIRMAN STETKAR: Yes.

23 MR. MASHIO: -- general trip.

24 CHAIRMAN STETKAR: Yes. Yes, and I  
25 thought that that was all over along the top of the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 fixed displays.

2 MR. MASHIO: Yes.

3 CHAIRMAN STETKAR: So what comes up on  
4 the variable display automatically?

5 MR. MASHIO: Yes, when you have a trip  
6 initiate on the fixed area on the facade around.

7 CHAIRMAN STETKAR: Okay.

8 MR. MASHIO: Then, as I said, our  
9 overview information, in that case, our operator --  
10 reactor trip verification screen, such as a reactor  
11 trip breaker indication and an NIS indication, those  
12 are combined verification screens, which is installed  
13 in all the --

14 CHAIRMAN STETKAR: What does the OK  
15 monitor do for you, then?

16 MR. MASHIO: No, no, no. It's a specific  
17 dedicated screen overview.

18 CHAIRMAN STETKAR: Okay, I'll ask you,  
19 though, what does, I thought that the OK -- the  
20 so-called OK monitor, in the fixed display area, took  
21 care of all of that stuff.

22 That it looked at all of the stuff that  
23 was supposed to happen on a reactor trip, and you  
24 got, okay, reactor trip. Or, it looked at all of  
25 the stuff that's supposed to happen on a safeguard's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       actuation. You got OK safeguards actuation, or a  
2       Phase A containment isolation, I thought that that's  
3       the function that that part of the fixed display --

4               MR. MASHIO: Yes. That's what it -- but  
5       these OK monitors are checking the status, each  
6       status. For example, the reactor trip initiate every  
7       status to verify the reactor trip initiate, such as  
8       NIS monitoring reactor trip breakers and --

9               CHAIRMAN STETKAR: Okay, you just, I'll  
10       stop you right there.

11              MR. MASHIO: Okay.

12              CHAIRMAN STETKAR: You just said the word  
13       reactor trip breakers. Why do I need an automatic  
14       screen over in the variable display that shows me  
15       that the reactor trip breakers are open, if the OK  
16       monitor takes care of that?

17              MR. MASHIO: Yes. Yes, if our computer  
18       checking no good feature verified this one, its  
19       status is not working, then operators, ultimately,  
20       verify the cause of, cause of sequence. So this  
21       overview verification monitor helps fix the status,  
22       such as if a turbine breaker is noted open.

23              CHAIRMAN STETKAR: Kenji, it may help,  
24       from a computer systems designer, throwing a bunch  
25       of stuff up, flashing it in front of me, as an

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 operator, oftentimes distracts me, especially if I'm  
2 now challenged to, what, if I'm trained that the OK,  
3 monitor is taking care of that function for me,  
4 throwing up something in front, additional, in front  
5 of me is just more information that can distract me.

6 MEMBER BLEY: Did this come up in any of  
7 the testing?

8 MR. HALL: Yes. And --

9 (Simultaneous speaking)

10 MR. HALL: Yes, no. This happened  
11 throughout the testing, because we were failing  
12 things. And having the OK monitor do the checking  
13 of the various components and saying, okay, here NG,  
14 is a summary. It says, yes, everything is  
15 functioning, or one train is out of service, or the  
16 system is, but just a summary. And then the added  
17 information helping diagnose what the problem is,  
18 pops up on the variable side. So the variable side  
19 gives you the ability to drill down on what's causing  
20 the NG, for example. And during the test, it was  
21 quite helpful. I mean, this is, was not the  
22 confusion that we're --

23 MR. SPRENGEL: It wasn't.

24 MEMBER BLEY: And you didn't get a second  
25 one coming in that would flip this to another screen?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. HALL: No, no, no, no. Could that  
2 just be scenario selection? If I remembered all the  
3 detailed scenarios, you know, I would tell you, you  
4 get a sense that no, it was not an issue.

5 Because the scenarios we used were things  
6 like, again, small break, large break, steam  
7 generator tube rupture with, at least, one up to  
8 three to four compounding failures thrown in it. So  
9 the answer is, it was helpful, not confusing.

10 CHAIRMAN STETKAR: Okay. That's, seems  
11 the test would help. It's just the first, I don't  
12 recall seeing anything, this one Dana said,  
13 automatic. I was more concerned about the  
14 operator's, you know, conflicts among the operators,  
15 in terms of manual selection of who wants to see what  
16 up there.

17 I got comfortable, and I kind of liked  
18 the concept of the his OK monitor, because as an  
19 operator, I like to look at something quick and  
20 everything is green, fine, I don't need to worry  
21 about this stuff. If I need to worry about this  
22 stuff, I'll go worry about it, but maybe I have to  
23 worry about four or five different things. I'll have  
24 to think about that. Okay. That's the only  
25 automatic display that flashes up on the variable

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 display is this --

2 MR. MASHIO: Yes.

3 CHAIRMAN STETKAR: -- essentially a  
4 confirmatory status of the, whatever protection  
5 functions?

6 MR. MASHIO: Yes, as I said, when bypass  
7 initiates, then bypass of our permissive single  
8 initiates. Then this bypass permissive indication  
9 screen would metrically indicate on the variable  
10 area.

11 CHAIRMAN STETKAR: This is the status of  
12 the bypass --

13 MR. MASHIO: Variable --

14 CHAIRMAN STETKAR: -- also indicated on  
15 the left-hand side up here?

16 MR. MASHIO: Yes. Yes.

17 CHAIRMAN STETKAR: Okay. Just let me  
18 think.

19 MEMBER BLEY: I said, we'll need to think  
20 about that. I suspect on the manual side of this --

21 CHAIRMAN STETKAR: The manual --

22 MEMBER BLEY: -- it's no more of a  
23 coordination problem than we have in many other  
24 things that go on in a control room.

25 And the shift sup will have to just

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 takeover and --

2 CHAIRMAN STETKAR: And I kind of figure,  
3 you know, --

4 MEMBER BLEY: -- take control.

5 CHAIRMAN STETKAR: -- the fact of the  
6 matter is they're in there talking to one another,  
7 but I just want to make sure that there wasn't some  
8 sort of implicit priority, or things like that. The  
9 automatic stuff, it's just something new, report, at  
10 least, I didn't remember, if it's written down.

11 MEMBER BLEY: And we have seen something  
12 recently where there's multiple people controlling  
13 things and they can actually interfere with each  
14 other and they did have some prioritization to take  
15 care of that, but that was something altogether  
16 different. It's got our thinking going that way,  
17 though, a little bit.

18 CHAIRMAN STETKAR: Okay. Sorry.

19 MR. MASHIO: So let's continue on the  
20 next screen. The fixed display area provides the  
21 main plant parameter required for monitoring the  
22 plant status, during the normal operation enabling  
23 quick detection.

24 The main parameters required for  
25 monitoring plant status during our production and the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 parameters that may cause that reactor trip. And  
2 information required for verification reactor trip  
3 status information, which is associated to the  
4 reactor turbine and the generator immediately  
5 following. The engine -- the engineered safety  
6 feature component status on the process parameters  
7 indicating system performance.

8 Also this fixed screen indicates Type A,  
9 Type Alpha and the Bravo, parameter Reg. Guide 1.97.  
10 And also, alarm, all alarm. Some alarms, as grouped  
11 alarm, indicating that at the top of the screen. And  
12 the individual alarms and the associated alarms in  
13 the parameters are in the new graphic display.

14 And this safety system bypass inoperable  
15 status indication. This information is organized  
16 using the plant mix showing primary system,  
17 containment system, and toggling generator air  
18 quality system.

19 The next slide shows the left side fixed  
20 portion of LDP display. The --- in addition to  
21 measure pumps and parameter indication unique  
22 display, there are several special indication OK  
23 monitors, BISI Monitor, the system auto statistics  
24 emissions task monitor, Oak Ridge plant safety  
25 functions. Operator checks all the other function

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 and indicates inoperable status by each function.

2 The LDP presents us, and you can monitor  
3 the information, but always within our construct.  
4 And the OK monitor provide status of automatic checks  
5 on all applications result in RPS, and ESFAS. And  
6 the Critical Safety Function Monitor provide the  
7 status, or automatic checks for each critical safety  
8 function status.

9 And the BISI Monitor presents bypass or  
10 inoperable status for each safety function, as each  
11 are in each signal. LDP maintains same operator  
12 conventions in the O-VDU display design, therefore,  
13 minimizing operator confusion moving between HSIS.

14 The next slide shows the Operator Console  
15 configuration. The Operator Console consists of  
16 Operational VDUs, Alarm VDUs, Operating Procedure  
17 VDUs, Safety VDUs, and System Level Safety function  
18 initiation safeties.

19 CHAIRMAN STETKAR: Kenji, let's go back  
20 to that.

21 MR. MASHIO: Yes.

22 CHAIRMAN STETKAR: The Hardwired Switch  
23 Area, I know, I don't know the individual switches,  
24 but I know the intent of those switches, how are they  
25 actually implemented in the design? Are they simply

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 a manual input that bypasses the automatic signal  
2 comparison logic within the digital system, or do  
3 they go directly to the actuation interface for the  
4 various functions? In other words, how much do those  
5 hardwired switches bypass of the digital signal  
6 processing?

7 MR. MASHIO: This System Level Hardwired  
8 Switch is based on the safety requirement, they just  
9 wired to, as much as possible, to do that based on  
10 technology. So this hardwired switch is to the  
11 output of the digital LDP.

12 CHAIRMAN STETKAR: They are?

13 MR. MASHIO: Yes.

14 CHAIRMAN STETKAR: Okay.

15 MR. MASHIO: But this is HSI compilation,  
16 so this compilation how to integrating the I&N system  
17 described in Chapter 7.

18 CHAIRMAN STETKAR: Well yes, and that's  
19 why I went to Chapter 7 and I have these lines  
20 highlighted on this figure here. In particular, I  
21 see where manual reactor trip goes directly to the  
22 reactor trip breakers. But, the thing that's called  
23 manual ESF actuation seems to simply bypass the  
24 comparison logic in the reactor protection part of  
25 the PSMS, is that correct? So it still relies on a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 lot of the digital signal processing for safeguards  
2 actuation, is that correct?

3 MR. MASHIO: That's right.

4 CHAIRMAN STETKAR: Okay. Thank you. I  
5 wanted to make sure I understood that, because I had  
6 to go to Chapter 7, but Chapter 7 is just a big  
7 cartoon, so I wanted to make sure that I understood  
8 that. Thank you.

9 So my point is that for tripping the  
10 reactor, I can have reasonable assurance that it  
11 bypasses any digital faults for initiating other  
12 safeguards functions, it'll bypass some of the  
13 digital system, but not all of it.

14 Okay. Thank you.

15 MR. MASHIO: And so --

16 CHAIRMAN STETKAR: Recognizing that, for  
17 the record, we still have the diverse, the diverse  
18 panel over there.

19 MR. MASHIO: Okay, on the next slide, the  
20 VDU is the primary HSI for four functions, safety  
21 operation, integration monitoring and operation,  
22 automatic verification with company status and  
23 interactive screen because this ---- in the US-Basic  
24 HSIS, we use it providing four functions, which is  
25 installed at the operator console, supervisor console

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 and the system's technical advisor console. The  
2 following tables describes these functions.

3 Each display has associated navigation  
4 system designed to provide the operator with easy  
5 access to each display. The Navigation consider  
6 usability, minimizing potential human errors and  
7 contributing to human performance improvement.

8 The plant information and controls are  
9 organized in fluid system mimic graphics and  
10 modulation controllers are integrated with  
11 associated trend graphs. I'll bring up some images  
12 as an example, later, right?

13 And dedicated displays to integrate  
14 associated parameters and the controllers from  
15 different systems to support emergency operation  
16 and/or specific tasks are pre-designed and assigned  
17 as different groups in the top menu screen.

18 The top level system display uses content  
19 unique to separate content in this system from others  
20 and it uses lines to illustrate function dependencies  
21 between systems.

22 With only three levels of information,  
23 this display has a plant information hierarchy  
24 simplifying that task over organizing where in the  
25 network the current displays are illustrated and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       thereby minimizing confusing navigation, or  
2       information location.

3               The emergency display request area over  
4       the top navigation display provide our immediate  
5       access to safety status information that would  
6       particularly be needed during the implementation  
7       emergency procedures. Example could include plant  
8       trip status, safety injection by an inside item, SI  
9       sequence, and containment isolation status.

10              The plant-wide request area also support  
11      operator to set a dedicated display, which as I said  
12      to plant management implements, such as our  
13      environmental screen.

14              The top navigation display screen  
15      explained on the previous slide's screen typically  
16      used to access information, but it's important that  
17      by selecting the screen list menu, operator can  
18      display system grouping in alphabetic or numeric  
19      order.

20              The emergency information category  
21      including the current process marked red, blue is  
22      used to maximize our visibility of this grid. A  
23      function at the bottom is our display RO's operator  
24      to easily change between the two top level  
25      disparates.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           The next screens are second level  
2 screens. At the second level system that we've  
3 provided that containment system information and  
4 access to content. Later I'll move in between  
5 systems without returning to the Top Level Navigation  
6 Display supported by our functional bar at the right  
7 hand page of the display that mimic associated  
8 systems to be called up.

9           These displays consistently use our  
10 background with various bright colors representing  
11 the system unique communication. Active competence  
12 on the unique area, unique configured to look like  
13 convex shaped button, providing the operator with a  
14 simple, visible cue, or accessing the top level  
15 display network, which provides controls for  
16 associated components.

17           When the buttons touched or clicked on  
18 and the soft control becomes available, then your  
19 default control station is consistent, basically,  
20 like go outside and if the related information is  
21 hidden by pop-up window, the default pop-up station  
22 is ultimately set in the other corner of the screen.  
23 The operator can manually move the pop-up window in  
24 the unusual case that the information relevant to the  
25 operation may be hidden.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           Function toolbars are also available on  
2           the display, allowing the operator to move back and  
3           forth between the menu display, and the menu buttons  
4           for returning to the top navigation display. This  
5           functionality provide for simple and efficient  
6           movement both secondary and primary in the display  
7           interact.

8           CHAIRMAN STETKAR:     When was, don't  
9           change this. The so-called software cover on each  
10          controller, I understand it's -- no, no, no, no, go  
11          to the other.

12          Go to the right. Go to the right. See  
13          where the arrow is? Stop. Someplace, I don't know  
14          whether you touch the grey, or whether you touch the  
15          white, but you need to so-call open the software  
16          cover before you can actually operate the components,  
17          like an interlock. I get that. I understand that.  
18          I think it's a good feature.

19          Is that, anytime you pop-up a controller,  
20          whether it's from the operational VDU, or from a  
21          safety, or, is the software cover also functional  
22          from the safety VDUs?

23          Yes.     Okay, good.     Does the software  
24          cover automatically close when you navigate away from  
25          that --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 MR. MASHIO: Yes, the --

2 CHAIRMAN STETKAR: -- that pop-up --

3 MR. MASHIO: -- that's what --

4 CHAIRMAN STETKAR: It does?

5 MR. MASHIO: Yes. If our --

6 CHAIRMAN STETKAR: Okay.

7 MR. MASHIO: -- soft control --

8 CHAIRMAN STETKAR: So for example, I

9 touch the thing, I open the valve, and then I close

10 that display.

11 MR. MASHIO: Then --

12 CHAIRMAN STETKAR: The software cover

13 closes when the --

14 MR. MASHIO: Yes.

15 CHAIRMAN STETKAR: Okay. Good

16 that's -- thank you.

17 MR. MASHIO: Okay, so next screen is an

18 example of the modulation controller. The

19 controllers and the modules are safe providing

20 controller functions only available in fixed position

21 on controller's screen operator display on the

22 operation review. That displays a trend graph and

23 related parameter required to monitor that changing

24 trend.

25 And the next slide shows an example of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the dedicated display. And this screen is organized  
2 associated with the information on the controller  
3 screen for the specific orders. So this is an  
4 example of that reactor trip-dedicated screen,  
5 organizes front of plant status, such as reactor trip  
6 records, rod position and also NIS monitoring and  
7 also turbine status.

8 CHAIRMAN STETKAR: And this --

9 MR. MASHIO: And --

10 CHAIRMAN STETKAR: I don't want to  
11 interrupt this. Is that all you have to say about  
12 the operational VDUs?

13 MR. MASHIO: Yes.

14 CHAIRMAN STETKAR: Okay. We're going to  
15 break for lunch. But I have a couple of questions,  
16 quick questions, and you might want to answer them  
17 after lunch. Unfortunately, two of us have another  
18 meeting that we have to run to at 12:00 p.m., so we  
19 can't run over.

20 On the operational VDUs, there is  
21 something called a lock function, and I didn't quite  
22 understand how that works. It sounds like it's  
23 either a reset, or a block function, or some sort of  
24 safety actuation.

25 MR. MASHIO: Oh --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   CHAIRMAN STETKAR:       I got really  
2       confused, because I didn't know, it seems to talk  
3       about blocking, or inhibiting the operation of  
4       possible safety systems from this non-safety  
5       interlock and I don't know how it works, and I was  
6       curious about that. So you may want to, I mean, in  
7       particular, I could read you quotes, but they're from  
8       Section 4.5.3.1 and 4.6.3 of the Topical Report.

9                   Talks about block, or interrupt the  
10      automatic actuation signal for testing and  
11      maintenance, or for deliberate operator actions,  
12      during emergency conditions.

13                  That seems to tell me, from a  
14      non-safety-related operational VDU, an operator can  
15      jump in and stop safety injection, while it's being  
16      demanded, or something like that. And I hope I'm  
17      misinterpreting that, so if you could think about  
18      that.

19                  The other thing is that it talks about,  
20      under continuous controllers, it talks about a normal  
21      fast and slow mode of operation and it says that you  
22      can, I don't know whether it's shown on here, but  
23      that the I --

24                  (Simultaneous speaking)

25                  CHAIRMAN STETKAR: Yes. It's shown here

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 on the right-hand side. That the operator can select  
2 whether the operator wants a slow, or a fast, mode.  
3 And it said, well the reason for the slow mode is  
4 that, you know, the electronics can respond so  
5 quickly that, that maybe you don't want to have it  
6 do it that quickly.

7 My concern is, I don't know how slow is  
8 slow, and if the software decides that it wants to  
9 be in the slow mode, and I would really like it to  
10 respond in the normal or the fast mode, can it somehow  
11 prevent me from doing that? I didn't, for the life  
12 of me, understand why I need a slow mode, in effect.

13 Because it seemed to be, the whole  
14 discussion seemed to be related to response of little  
15 electrons, rather than real fluid systems and human  
16 beings.

17 And the thing that bothers me is that it  
18 said the slow mode is one-tenth of the speed. So if  
19 I want to, suddenly, if I want to increase flow and  
20 it's only letting me increase flow at a tenth of the  
21 rate that I'd really like to, because the software  
22 has somehow decided that it wants to do that, could  
23 that be a problem? So I'd like a little bit better  
24 information about what the benefit of having that  
25 slow mode is why do I need that? Okay? We'll just

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 leave that, you can pick it up after lunch. Anything  
2 else, quickly, from any of the, the operators, any  
3 of the members, whatever we are? If not, we will  
4 recess for lunch and reconvene at 1 o'clock.

5 (Whereupon, the foregoing matter went off  
6 the record at 12:00 p.m. and went back on the record  
7 at 1:10 p.m.)

8 CHAIRMAN STETKAR: We are back in  
9 session. And again I know that we threw you way off  
10 script this morning. In some sense, I apologize for  
11 that. In another sense, I think it was a really good  
12 discussion. I mean you may not feel that way, but it  
13 certainly was I think for us.

14 So unfortunately it's part of what we do  
15 in these Subcommittee meetings. And in the long run,  
16 I think it's helpful for all of us.

17 With that, I assume that you think you  
18 have a path forward for this afternoon. Let's see  
19 if we can embark on that path.

20 MR. SPRENGEL: We're back where we  
21 started. I want to first address some of the  
22 questions that came up and, depending your response,  
23 there may likely be some additional written response  
24 that will expand upon whatever discussion we have  
25 here.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 I will start -- I've got about five  
2 questions -- with the intent of the inventory list  
3 for the Topical Report. I think your basic  
4 understanding is correct. I'm not sure if you like  
5 it or not. But I think your basic understanding is  
6 correct that the inventory list in the Topical  
7 Report is not what we would consider the final  
8 inventory list for any plant. And the list  
9 that would -- I think the LDP comes up a lot, but it  
10 would really be for any of the HSI that the potential  
11 population would change. I think the main interest  
12 is the LDP.

13 CHAIRMAN STETKAR: The main interest  
14 only because I think that's the only place where  
15 there was a long list of very specific issues.

16 MR. SPRENGEL: The table.

17 CHAIRMAN STETKAR: The table, that  
18 table.

19 MR. SPRENGEL: So the intent with the  
20 Topical Report is for lack of a better word a sample.  
21 But it is really the starting point for the further  
22 use of the entire HFE program.

23 MEMBER BLEY: And as I understand it, you  
24 have updated it several times to be consistent with  
25 where that's headed.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. SPRENGEL: That is absolutely  
2 correct. So the one portion that clearly will have  
3 an impact for the US-APWR application will be any  
4 evolution not foreseen, but any potential evolution  
5 with the US-APWR plant design. That impact,  
6 obviously, the US-APWR application. And the similar  
7 would be said for any other application. They'd have  
8 to reevaluate what the inventory is.

9 CHAIRMAN STETKAR: And that, just in  
10 terms of process, reevaluation would be completed  
11 essentially post COL. Is that correct?

12 MR. SPRENGEL: That is correct. Would  
13 be completed, yes. The activity, you know, a lot of  
14 these are simplified and again we'll cover this again  
15 later this afternoon. Hopefully, not too much later.  
16 But we'll cover this in detail that they are somewhat  
17 parallel depending on the status of different  
18 activities. But it would not be completed until --

19 CHAIRMAN STETKAR: The only reason I  
20 bring that up is as you're fully aware the ACRS' role  
21 in this process for all practical purposes ends at  
22 the COL. So, for example, we don't have the  
23 opportunity, at least not easily anyway, to weigh in  
24 on technical issues that might be resolved post COL.

25 For example, if we saw a partial

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 inventory, which is exactly why I brought it up this  
2 morning, and had some fundamental technical issue  
3 with it, if we knew that that was just a state of  
4 flux, fine. We know that. If we knew that that  
5 partial inventory was in some sense cemented in place  
6 and could be supplemented, we could still comment at  
7 least before COL issuance on that portion that we  
8 knew was fixed which again is part of my wanting to  
9 understand what that table in the Topical Report how  
10 we should interpret that table.

11 MR. SPRENGEL: Given that clarification,  
12 the current status of that table in the Topical  
13 Report would reflect the current status of the  
14 US-APWR design as you have been given. If there was  
15 a technical -- Like you had questions on the two  
16 specific items, there are answers for those as well  
17 as others. But that's the real for right now.

18 CHAIRMAN STETKAR: But again in terms  
19 of -- I'm trying to keep my mind separated -- the  
20 Topical Report, comments on the population of that  
21 list in some sense are irrelevant because --

22 MR. SPRENGEL: The application.

23 CHAIRMAN STETKAR: -- from the purpose  
24 of the Topical Report, it's simply an example list  
25 that would be specialized for whatever application.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 MR. SPRENGEL: Correct.

2 CHAIRMAN STETKAR: Now in terms of how  
3 that Topical Report is used for the US-APWR  
4 application, what I'm hearing you is unless the APWR  
5 application at this point takes exception or  
6 supplements or changes that list, we can view it as  
7 at least a snapshot of the list currently for APWR.

8 MR. SPRENGEL: Correct.

9 CHAIRMAN STETKAR: Got it.

10 MR. SPRENGEL: Where do I want to go  
11 next? There was a question for the US-Basic HSI.  
12 Who would perform the roles of emergency director  
13 including various example activities? The answer  
14 from the US-Basic HSI perspective alone would  
15 consider that specific activity outside the scope of  
16 the US-Basic HSI and the Topical Report.

17 The program as a whole covers that. You  
18 know we got into some of the discussion of staffing  
19 and qualification and further activities. So the  
20 HIB program does encompass those type of activities.  
21 But the HSI design in terms of LDP and what kinds of  
22 displays are available does not get into those types  
23 of roles and activities.

24 CHAIRMAN STETKAR: Okay.

25 MR. SPRENGEL: BISI, there is the BISI

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       indication on the LDP from a safety-related display  
2       alone perspective, the question was would there be  
3       indication available on the SVDU. And the answer is  
4       kind of there is indication of bypass parameters on  
5       the multi-divisional display.

6               CHAIRMAN STETKAR: There is? Okay.

7               MR. SPRENGEL: It would indicate  
8       basically as a yellow alarm status. I don't think  
9       we've -- Have you shown this screen?

10              CHAIRMAN STETKAR: This is on a  
11       multi-divisional display.

12              MR. SPRENGEL: Correct. So this is an  
13       example of a red level alarm. So a bypassed  
14       parameter would indicate as a yellow alarm.

15              CHAIRMAN STETKAR: But that's a  
16       parameter if I have that particular sensor out.

17              MR. SPRENGEL: Correct.

18              CHAIRMAN STETKAR: It's not necessarily  
19       the channel bypass that I can implement.

20              MR. SPRENGEL: Correct.

21              CHAIRMAN STETKAR: Train, whatever you  
22       want to call it.

23              MR. SPRENGEL: Right. In terms of  
24       component functionality, there is train level  
25       indication on the hardwired switch area. There are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 four indications for the train level bypass.

2 CHAIRMAN STETKAR: The bypass  
3 isn't -- Ah, okay.

4 MR. SPRENGEL: I think it's these four  
5 little --

6 PARTICIPANT: The switch bypass.

7 MR. SPRENGEL: And that is indicated in  
8 the Topical Report. But it's a train level.

9 CHAIRMAN STETKAR: That is indicated in  
10 the Topical Report. I missed that.

11 MR. SPRENGEL: So same source of  
12 indication, but it's being compiled for the entire  
13 train.

14 CHAIRMAN STETKAR: But I mean that's at  
15 least -- See, that's the kind of information I was  
16 looking for is can the operator -- if the large  
17 display panel goes black on me and it goes black at  
18 t0 because of whatever the problem is, can the  
19 operators somewhere on the information they have  
20 available off to their left I guess it is quickly  
21 glance over and see that they don't have the okay  
22 status, they don't have all of that stuff. But if a  
23 train isn't running, can they quickly determine that  
24 it isn't running because it was in bypass? That  
25 channel was in bypass for some reason.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. SPRENGEL: Correct.

2 CHAIRMAN STETKAR: The answer to that is  
3 yes.

4 MR. SPRENGEL: Is yes with an indication  
5 on the hardwired switch area and then the procedural  
6 indication would be again seeing the performance  
7 using the safety they use including the  
8 multi-divisional safety VDU. But that would be over  
9 time after actuation.

10 CHAIRMAN STETKAR: Yes. See, here it's  
11 more difficult because you have to look at individual  
12 sensors and stuff like that. And you have to wait.

13 MR. SPRENGEL: And you have to wait for  
14 it.

15 CHAIRMAN STETKAR: You want something  
16 where the operators can just glance at something and  
17 say, "Okay. Train A, yes. I forgot Train A was in  
18 bypass. I have to deal now with Trains B, C and D  
19 all doing what they ought to do." Thanks.

20 MR. SPRENGEL: We're doing good. The  
21 next one was the OVDU lock function which was  
22 acknowledged I think primarily for a maintenance  
23 purpose. And the question was would it block an SI  
24 signal. Do we want to clarify.

25 CHAIRMAN STETKAR: Yes. Let me find

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 my -- You're speaking much faster than I can write.  
2 So give me like 30 seconds to copy my notes here  
3 because you're way ahead of me. And unfortunately  
4 you're answering the questions right. So I have to  
5 write these things.

6 (Laughter)

7 MR. SPRENGEL: So I should keep talking.

8 CHAIRMAN STETKAR: You can, but I'll  
9 force you to repeat yourself and that will just annoy  
10 both of us. Okay. Let me find my note then on it.  
11 The thing I stumbled over, Ryan, is that -- and I'll  
12 read the quote because I've got it oriented here.

13 In Section 4531, it says "Lock. This  
14 manual switch can block or interrupt the automatic  
15 actuation signal for testing and maintenance" -- got  
16 that -- "or for deliberate operator actions during  
17 emergency conditions. For soft controls of safety  
18 components, this function is enabled/disabled under  
19 permission from the Safety VDU. To avoid spurious  
20 blocking of safety signals from a single failure, the  
21 lock function is normally disabled for safety  
22 components or activating the lock disables the safety  
23 function at the division level. The bypass  
24 inoperable status indication is continuous displayed  
25 on the LDP."

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   So it's clear that part of the function  
2                   is for maintenance bypass and that indeed you get the  
3                   indications. But the thing that down in Section 4.6  
4                   .3, this thing that says "deliberate operator actions  
5                   during emergency conditions" and then later in 4.6.3,  
6                   it says "to manually initiate a maintenance bypass,  
7                   operating bypass lock of a component, or an RPS ESFAS  
8                   reset from the operational VDU, the bypass permission  
9                   from that train must be enabled. Bypass permission  
10                  is part of PSMS. There's one bypass permission for  
11                  each train. Administrative controls ensure that the  
12                  bypass permission for only one train is enabled at  
13                  any time. Therefore, an erroneous signal from an  
14                  operational VDU will affect only one safety train."

15                 This still seems to tell me that in the  
16                 heat of the battle and the reason I brought this up  
17                 the operator could manually, quickly intervene and  
18                 shut stuff off from the operational VDU despite the  
19                 fact that there might be a demand for it from the  
20                 safeguards. I hear these things about the operation  
21                 can do stuff during an emergency situation.

22                 And I hear things like administrative  
23                 controls. We'll make sure they only do this on a  
24                 single train. And I see alarms coming up. If I  
25                 decide to shut the stuff off, of course, I'll get the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 alarm. But maybe I shouldn't have shut it off. And  
2 that's the reason I brought it up because I don't  
3 really know what it's doing.

4 I understand part of it, the intent for  
5 maintenance. But the operational part of it made me  
6 pause.

7 MR. SPRENGEL: Okay. It's tricky.  
8 There's a couple questions I think in there.

9 CHAIRMAN STETKAR: Let me see if I can  
10 get the -- It might give you a chance to think a  
11 little bit. The fundamental question is if  
12 safeguards actuates automatically can the operator  
13 from the operational VDU intervene and shut the  
14 equipment off using this lock function, whatever that  
15 thing is.

16 MR. SPRENGEL: Well, they would have had  
17 to have done it before.

18 CHAIRMAN STETKAR: That's not the  
19 question that I asked it. You're answering  
20 perhaps -- I'm asking a yes or no question.

21 MR. SPRENGEL: For one train, yes. So  
22 the safety VDU provides the bypass permissive to the  
23 OVDU. And it's at a train level. So they can only  
24 provide that bypass permissive to one train. From  
25 the OVDU in terms of the lock function, you could

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       only use that lock function on one train.

2               CHAIRMAN STETKAR:  Let's see if I can go  
3       back.  Dr. Bley may have to help me here.  Scenario,  
4       I have a LOCA.  Safeguards actuates.  I'm an operator  
5       now and for some reason I believe it's in my best  
6       interest to shut off all injection.  Has it ever  
7       happened?  I think of once.

8               It's in my best interest to do that.  Can  
9       I go to the operational VDU and somehow enable this  
10      lock function for all four of the trains individually  
11      and do that without taking much extra active actions.  
12      Do you follow me?

13              MR. SPRENGEL:  That's okay.

14              CHAIRMAN STETKAR:  Can I basically  
15      override that safeguards signal from the operational  
16      VDU using this lock function?

17              MR. SPRENGEL:  My first concern is in  
18      this scenario you're overriding it after the signal  
19      has been sent.

20              CHAIRMAN STETKAR:  That's exactly my  
21      concern, yes.

22              MR. SPRENGEL:  Okay.

23              CHAIRMAN STETKAR:  I don't care about  
24      before the signal because you have to rely on  
25      administrative controls and alarms and so on after

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 the signal has actuated.

2 MR. SPRENGEL: You'd have to be very  
3 quick, number one.

4 CHAIRMAN STETKAR: No, no.

5 MR. SPRENGEL: To beat the signal.

6 CHAIRMAN STETKAR: No, no. I'm not  
7 beating the signal.

8 MEMBER BLEY: The signal is there.

9 CHAIRMAN STETKAR: The signal is in.  
10 According to the design criteria, the signal has to  
11 lock in.

12 MEMBER BLEY: Now can I override it?

13 CHAIRMAN STETKAR: But the pumps are all  
14 running and I suddenly decide that "Oh my God." I  
15 quickly want to shut these things off and I've got  
16 this lock function over here. And boom, boom, boom,  
17 they're all shut off.

18 MR. SPRENGEL: Okay. I'll follow up on  
19 that answer.

20 CHAIRMAN STETKAR: That's the concern.

21 MR. SPRENGEL: And but tied with that, I  
22 think we need to understand how it's used though  
23 because you would not be able to do that for all four  
24 trains at once. You would have to go to the safety  
25 VDU, enable the bypass permissive for one train,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 stop, lock the specific pump or whatever you're  
2 wanting to take action on and then go back to the  
3 safety VDU, take that bypass permissive off, put the  
4 other bypass permission on and go back to the OVDU.

5 CHAIRMAN STETKAR: I think what you're  
6 saying right now is what I'm looking for.

7 MR. SPRENGEL: It is a tortured path to  
8 do that with all four trains.

9 CHAIRMAN STETKAR: To do that, I do need  
10 to go to the safety VDU to actively enable that lock  
11 function.

12 MR. SPRENGEL: For A train.

13 CHAIRMAN STETKAR: For A train.

14 MR. SPRENGEL: Yes.

15 MR. WARD: This is Bill Ward. I'd like  
16 to add something to the discussion. This is actually  
17 in an RAI still injection 7 space how this lock and  
18 bypass works. So when you're getting into the actual  
19 functionality and what's designed for the  
20 functionality and what you can and can't do, that's  
21 still in a question in Chapter 7.

22 CHAIRMAN STETKAR: Okay.

23 MR. WARD: So the fact that the HSI may  
24 allow you to do something or not do something, that's  
25 part of the HSI design. But whether or not you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 really want to do that is still in the logic that's  
2 being discussed in Chapter 7.

3 CHAIRMAN STETKAR: Bill, part of the  
4 reason I ask these questions is that whether or not  
5 the human being wants to do it I want to see what  
6 types of safeguards are installed such that -- I'll  
7 use the technical term -- software going nuts can't  
8 somehow do it. But something out there in the  
9 non-safety related part of this system because of  
10 this function can't somehow shut stuff off if it  
11 decides to do it. Now I might be part of that system  
12 as an operator or the software might be part of that  
13 system. And the requirement of having an active --

14 MR. WARD: Bypass permissive.

15 CHAIRMAN STETKAR: -- function let's say  
16 over on the safety VDU before this thing can be enable  
17 on the non-safety VDU may satisfy that.

18 MEMBER BLEY: At least makes you stop and  
19 think again.

20 CHAIRMAN STETKAR: It makes the human  
21 stop and think and it leads me to believe that perhaps  
22 the software might not be able to do it by itself  
23 over there.

24 MEMBER BLEY: Just in the non-safety.

25 CHAIRMAN STETKAR: Just in the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 non-safety system because of some smoke getting into  
2 the panels or something.

3 MR. HALL: I remind you. It's more than  
4 the human stopping and thinking. The human gets out  
5 of his seated operating position, walks to a  
6 different part, does it and then comes back.

7 CHAIRMAN STETKAR: I'm sorry.

8 MR. HALL: It's not just stop and  
9 thinking. There's a time delay in there, too.

10 CHAIRMAN STETKAR: Bob, when I looked at  
11 the panel layout my arms are long enough to see the  
12 safety VDUs and the operational VDUs. I don't think  
13 I have to -- You'd better not tell me if I'm a single  
14 RO that I have to get up and walk the different  
15 panels.

16 MR. SPRENGEL: You do.

17 CHAIRMAN STETKAR: This display here as  
18 best as I can tell is equally within an arm span of  
19 the person, right?

20 MR. SPRENGEL: You would have to get up  
21 and physically move. This is an alarm VDU.

22 CHAIRMAN STETKAR: Yes.

23 MR. SPRENGEL: To move from this location  
24 to this location, you could if the chairs were on  
25 wheels or something slide.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: Yes.

2 MR. SPRENGEL: But you couldn't do one  
3 thing or one thing.

4 CHAIRMAN STETKAR: Yes. Getting up and  
5 walking different places.

6 MEMBER BLEY: It's not the corner or next  
7 door.

8 CHAIRMAN STETKAR: It's not over on the  
9 diverse actuation panel or it's not around the back  
10 of the boards or anything like that.

11 MR. SPRENGEL: So I don't want to -- I'm  
12 not going to claim victory on this discussion.

13 CHAIRMAN STETKAR: Check that. I mean  
14 you understand my concern.

15 MR. SPRENGEL: Yes.

16 CHAIRMAN STETKAR: The concern is that  
17 can I strictly enable that lock function, whatever  
18 it is, if you want to call block, inhibit block,  
19 strictly from the operational VDU without an active  
20 intervention from the safety VDU. Obviously, you  
21 have to be able to reset safeguards eventually and  
22 things like that.

23 MR. SPRENGEL: Right.

24 CHAIRMAN STETKAR: And again I'm the  
25 devil's advocate. I'm trying to read what's there

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 in a short text description and infer what might be  
2 there in terms of actual logic.

3 MR. SPRENGEL: I can confidently state  
4 that what we've discussed you will not be able to  
5 strictly enable the lock function without this  
6 repeated intervention of the safety VDU. The  
7 portions I want to follow up on and confirm before  
8 speaking is some of the use of the deliberate actions  
9 during emergency if we can provide any -- Or are we  
10 okay on that?

11 CHAIRMAN STETKAR: I can give you my  
12 personal feedback, but I'm only one of five of us  
13 here, six of us.

14 MR. SPRENGEL: Okay.

15 CHAIRMAN STETKAR: There always needs to  
16 be -- The operators always needs to be able to take  
17 control in a deliberate fashion. The operator always  
18 has to be able to whether you want to use the term  
19 reset, actively intervene. And we can't design  
20 against people who -- We can make them hesitate at  
21 best.

22 So having that interlock for me is okay.  
23 But I don't know whether any of the other people  
24 thought about it. I don't need any more information  
25 from what you told me. But I don't know if any of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the others do.

2 MEMBER BLEY: And there's no question  
3 about what you've told him.

4 MR. SPRENGEL: No question.

5 MEMBER BLEY: No question.

6 MR. SPRENGEL: Right.

7 MEMBER BLEY: And that's for sure.

8 MR. SPRENGEL: The only other area I want  
9 to follow up on which I think is good is let me get  
10 back on the lock function being put in place after  
11 the signal. I just want to follow up on that today.

12 CHAIRMAN STETKAR: That's the whole  
13 idea.

14 MR. SPRENGEL: I don't care about the  
15 answer, but I want to confirm what I understand first  
16 and then we'll come back to that.

17 CHAIRMAN STETKAR: Beforehand whether or  
18 not I can manually block or disable, inhibit all four  
19 channels is I can do that in any design. That's  
20 strictly administrative controls. One could wire in  
21 things. But most I'm not worrying about beforehand.  
22 Getting into a situation where I need safeguards  
23 actuation and all four trains are inhibited, I'm  
24 worried about active intervention after the fact.

25 MR. SPRENGEL: Okay. Understand. So

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 we'll leave that open a little bit longer today.

2 The last question was on slow mode and  
3 we might need some additional discussion and  
4 clarification. The short answer is that the  
5 application or the inclusion of slow mode was a  
6 result of using conventional controllers and copying  
7 the same functionality or potential functionality  
8 over. So it truly does as you said just allow a  
9 slower modulation of those I guess valves is the best  
10 example.

11 CHAIRMAN STETKAR: Valve is a good  
12 example or whatever.

13 MR. SPRENGEL: And my understanding  
14 would be that the selection of the speed would be a  
15 result of either operation decision or procedural  
16 control. The fast is as a good example in terms of  
17 how far something is moving and that's a little  
18 clearer to understand. The slow would be based on  
19 the operating condition and what is being controlled  
20 at the time.

21 CHAIRMAN STETKAR: The way it's  
22 presented is and it's another one of these things  
23 where there's a one paragraph short description. It  
24 says, "The normal and fast mode increase/decrease  
25 rates are comparable to that of conventional HSI

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 devices." So whatever. "To accommodate software  
2 operation-based fine tuning, the controller is  
3 provided with slow mode in addition to the above two  
4 modes offering one-tenth of the increase/decrease  
5 rate of normal mode. Fast and slow modes are  
6 selected by touching or clicking the fast and slow  
7 button respectively. The normal mode is selected by  
8 selecting neither of the fast mode nor the slow  
9 mode."

10 I don't for the life of me understand why  
11 I need slow mode. And that's basically why do I need  
12 that because if I'm not careful maybe I select it and  
13 I didn't realize I selected it. Or maybe that  
14 software selects it for me and I really want to open  
15 that valve fast and it won't let me because it knows  
16 it's got to be in slow mode.

17 MEMBER BLEY: I'd like to see a little  
18 more detail about how it works.

19 CHAIRMAN STETKAR: Yes.

20 MEMBER BLEY: I mean just the way it's  
21 presented in that short paragraph makes me even --

22 CHAIRMAN STETKAR: There's some other  
23 discussion.

24 MEMBER BLEY: If it's 10 times faster in  
25 normal mode than slow mode, how can slow mode be

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 replicating what a normal controller --

2 CHAIRMAN STETKAR: No, no. This says  
3 that the normal mode replicates the normal  
4 controller. I'll read you the quote.

5 MEMBER BLEY: Yes, but I was just reading  
6 as well. And if you go to slow mode or fast mode,  
7 it increases or decreases by a factor of ten over the  
8 normal mode.

9 CHAIRMAN STETKAR: Yes.

10 MEMBER BLEY: And is that the driving of  
11 the valve or is it the processing of deciding going  
12 through multiple steps? What exactly is slow mode  
13 controlling?

14 MR. SPRENGEL: It's  
15 controlling -- There's a cycle that's occurring over  
16 the time period of the valve being open in this case.  
17 So the example here --

18 MEMBER BLEY: And there's a fast and slow  
19 on every controller for every valve when you pop up  
20 the valve controller.

21 CHAIRMAN STETKAR: If it's a continuous  
22 control valve.

23 MEMBER BLEY: Yes.

24 CHAIRMAN STETKAR: That's my  
25 understanding.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           MR. SPRENGEL: And so my understanding  
2 of the process would be that the operator selects the  
3 speed at which the valve will be controlled based on  
4 preference or procedure depending on the circumstance  
5 or I guess it would be experience or procedure. And  
6 then the valve indicates using the control buttons  
7 what level that valve needs to open to.

8           And then again this is where the language  
9 comes into play. There's the cycle of information  
10 of controlling that valve opening and also then  
11 getting the feedback not only from the sensors on the  
12 valve but also the I&C system as well processing that  
13 information and feeding it back to the HSI.

14          CHAIRMAN STETKAR: Ryan, if anything in  
15 a nuclear power plant is so sensitive to the  
16 milliseconds at which that information is processed,  
17 you have a big problem. I read all of that stuff  
18 and I'm thinking signal processing time in terms of  
19 finally knowing that the valve is only 37.86235  
20 percent opened versus about 40 percent.

21          MEMBER BLEY: Let me change the question  
22 a little. It could be that in operation in Japan or  
23 in testing either in Japan or in the U.S. you found  
24 some things. The operator were to control it and  
25 the normal mode he was hanging around too long to get

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 to get to where he wanted to do. And the fast mode  
2 looked like it would be very helpful.

3 Or in the normal mode it was real hard  
4 to set it precisely to the setpoint you wanted. So  
5 you go to slow mode to zero in on the setting.

6 I have the same question you asked  
7 earlier about the software lock. You go in here. I  
8 run it in normal mode until I get close. I put it  
9 in slow mode. I put it exactly where I want it. And  
10 now I go to do something else. This resets to normal  
11 or does it stay locked into slow or fast?

12 MR. MASHIO: It's going to reset. And  
13 so if our -- As a -- Also this slow mode resets.

14 MEMBER BLEY: It resets.

15 MR. MACHIO: Yes.

16 MEMBER BLEY: I guess I can see it on a  
17 valve with a lot of turns to get it opened you might  
18 want to go to fast mode to get there. And then as  
19 you approach the normal setting, you go back.

20 What did operators find? Why did we end  
21 up with this and how do operators really use it? And  
22 in the testing you did for the U.S. one, did people  
23 use it? Was it something that evolved out of  
24 operations in Japan? How did we get to it and how  
25 do people use it?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. HALL: The fast and slow came out of  
2 the testing program.

3 MEMBER BLEY: Over here.

4 MR. HALL: Yes. The original one had  
5 normal and we found going to the fast speed that  
6 there was a long time delay of the operator pushing  
7 the button, waiting to see the thing move. So we  
8 added the fast movement because of that, because of  
9 the --

10 MEMBER BLEY: Because it was driving the  
11 operators kind of nuts.

12 MR. HALL: Exactly.

13 MEMBER BLEY: Sorry.

14 MR. HALL: So we can up with a criteria  
15 where the operator should not take more than X while  
16 concentrating on this and the fast mode came up. The  
17 slow mode was also added because of one or two  
18 scenarios. I don't remember much more than that for  
19 justifying the slow speed.

20 MEMBER BLEY: Was it added to just a few  
21 things or to everything?

22 CHAIRMAN STETKAR: It's on everything.

23 MR. HALL: This is basically a standard  
24 template.

25 MEMBER BLEY: Yes. It's for everything.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 But it came up on a few. That's kind of what I  
2 guessed it would have happened. But the fast mode  
3 was really to get the guy back looking at the whole  
4 plant and not sitting there with his hand on the  
5 switch to --

6 MR. HALL: Remember what we wanted to do  
7 was make sure the operator doesn't dwell on  
8 nonproductive things. And we found that the normal  
9 mode time was wasted and not needed since the machine  
10 is going up to a target anyhow.

11 MEMBER BLEY: Now the other piece of what  
12 John asked about, this makes sense to me. As an  
13 operator, I could see that.

14 MR. HALL: But I can't give you more  
15 details on that.

16 MEMBER BLEY: Especially on some kinds  
17 of valves and the like. But you also talked about  
18 software flipping in a normal mode or fast mode or  
19 slow mode. Is that right?

20 CHAIRMAN STETKAR: I'm not so much  
21 concerned about fast. I'm concerned about slow.

22 MR. HALL: Fast can get you in trouble,  
23 too.

24 CHAIRMAN STETKAR: Fast can also get me  
25 in trouble. Remember this is confused control

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 function. These are not --

2 MEMBER BLEY: You have to have your hand  
3 on the switch.

4 CHAIRMAN STETKAR: They're not bi-mobile  
5 valves.

6 MEMBER BLEY: Right.

7 CHAIRMAN STETKAR: They're continuous  
8 control valves.

9 MEMBER BLEY: I remember that. But I  
10 can hold it on the switch and jam it onto the seat.  
11 It's going to overshoot. Depends on how much control  
12 fanciness they put on here.

13 CHAIRMAN STETKAR: The whole way these  
14 things are you get speed. You get a setpoint.

15 MR. SPRENGEL: There might be a  
16 misunderstanding in the use of the controller. After  
17 the activation speed is set in terms of how fast the  
18 valve is opened or closed --

19 MEMBER BLEY: Can I talk to you right  
20 there before you get to the after? I did that with  
21 my finger or does the software ever do that? How  
22 does it get set? Only by the operator deciding to  
23 push fast or slow?

24 MR. SPRENGEL: Yes. Only the operator.

25 MEMBER BLEY: Somewhere I heard.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           MR. SPRENGEL: The example of taking  
2 control, changing the valve position, then closing  
3 and coming back whenever you reactivate that control  
4 or that component, it would come back in normal mode.

5           MEMBER BLEY: In normal mode, yes. So  
6 nothing besides me ever puts it in fast or slow.  
7 That makes me more comfortable if I'm hearing that.  
8 And then the second half you're going to tell me that  
9 you put it to a setting and then it drives itself  
10 there. And that's alright. I misspoke.

11          MR. SPRENGEL: Okay.

12                   (Laughter)

13          CHAIRMAN STETKAR: And the concern was  
14 that in a normal mode you could quickly put the  
15 setting in there and the operators were  
16 concerned -- let's think about the fast part -- that  
17 they were not seeing the response fast enough because  
18 they wanted to go play with something else faster.

19          MR. SPRENGEL: Right.

20          MEMBER BLEY: Or the evaluators thought  
21 they were not focusing on the rest of the plant and  
22 just staring at this thing.

23          MR. HALL: I think I interpret both  
24 comments as the same that the feeling was both from  
25 the operator point of view as well as the observers

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1       that too much time was being taken on this. Given  
2       the kind of controller we wanted them to move on. So  
3       we added the fast speed.

4               CHAIRMAN STETKAR: But why do we have the  
5       slow speed then? I get normal and fast. I really  
6       understand that. But why do we have slow?

7               `       (Off record comments)

8               `       MR. SPRENGEL: We're going to provide a  
9       written response.

10              CHAIRMAN STETKAR: Okay.

11              `       MR. SPRENGEL: Ultimately I understand  
12       your confusion with the words you've been provided.  
13       And we'll provide a better explanation to expand upon  
14       the need for slow speed in terms of the control aspect  
15       in the system.

16              CHAIRMAN STETKAR: Again from an  
17       operational -- we been talking here -- perspective,  
18       I get the notion of normal and fast. I understand  
19       why it's there. I can see benefits to me as an  
20       operator to be able to quickly set and get something  
21       going here and have confidence that indeed it's going  
22       in the direction that I wanted it to go so I can go  
23       focus on something else. So the normal and fast I  
24       get.

25              In particular, I'm really interested in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       why you need the slow primarily because if I can do  
2       it as a human being the software can do it to me.  
3       And if I think something is operating fast and walk  
4       away from it, I might be surprised that it indeed was  
5       only going slow if it has that possibility.

6               MR. SPRENGEL: So you have concerns with  
7       the potential problem with the feature existing. So  
8       you want to understand why it's even there at all.

9               CHAIRMAN STETKAR: Exactly. Why  
10       would -- I think I understand why the fast mode was  
11       put in there as opposed to normal, not so much the  
12       slow mode.

13              MR. SPRENGEL: Okay. Got it.  
14              We are going to go slide -- I think it's  
15       43, the Alarm System.

16              MR. MASHIO: So the alarm system  
17       dedicated alarm VDU organizes and manages all alarms,  
18       presenting the alarm list by chronological order, by  
19       functional grouping and the providing alarm  
20       acknowledge and reset functions. Alarm status is  
21       also integrated in graphical P&ID contents in O-VDU  
22       screens. All alarms are indicated in either LDP  
23       dynamic display areas or grouped alarm tiles in LDP.  
24       Alarm presentation has dynamic prioritized color  
25       coordination, red, yellow, green.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           The alarm screen present one development  
2           of the information and contain connectivity to the  
3           operating procedure and the operation we use. It  
4           will use functional grouping of primary system in  
5           containment, primary system outside of containment,  
6           secondary systems and electrical system. And then  
7           within each of these categories, it uses  
8           characterization sequence to display around.

9           Alarm groups. Alarm caution status and  
10          alarm clear are segregated on the individual pages  
11          providing simple prioritization of the information  
12          to the operator. Operator on yellow, green, white  
13          and light gray background and white background  
14          provide contrast to easily read the information.

15          And the prioritized alarm system is  
16          provided to avoid information overload and  
17          facilitates the plant status indicated  
18          identification. The alarm function comprise of many  
19          simultaneous alarms and displays them on the alarm  
20          videos and on the LDP with alarm coordination  
21          identifying three priority levels.

22          The priority of the individual alarms has  
23          changed automatically depending on the importance of  
24          additional alarms. So that when important alarms  
25          are activated the overall plant status is easily

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 organized.

2 CHAIRMAN STETKAR: Can I stop you right  
3 here?

4 MR. MASHIO: Okay.

5 CHAIRMAN STETKAR: Was this alarm system  
6 as it's described functional during the operator  
7 tests?

8 MR. HALL: Yes.

9 CHAIRMAN STETKAR: It was. Okay. As I  
10 read through this -- I want to see if I understand  
11 it -- the dynamic prioritization system constantly  
12 updates the three levels of priority of the alarms  
13 depending on what's happening. For example, if I  
14 have tank level going down, if it's normal level, I  
15 have no alarm. If it gets to let's say low I have  
16 maybe a priority three alarm. If I get to low-low,  
17 I'll get a priority two alarm. If I get a  
18 low-low-low level, I'll get priority one alarm. And  
19 those things will constantly update as the level  
20 drops down.

21 It also says that the operators are  
22 instructed to keep the things from stopping flashing.  
23 They have to go in and acknowledge actively all  
24 priority one and priority two alarms on a page by  
25 page basis. Is that correct?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. MASHIO: That's correct.

2 CHAIRMAN STETKAR: Okay. This is  
3 supposed to reduce operator overload. Does it  
4 increase operator overload where I suddenly start to  
5 see as my level starts going down stuff starts to  
6 priority, level two things flash. Okay, I  
7 acknowledge those. I go over here and wait a  
8 minute. Priority one, it's suddenly now a priority  
9 one alarm. I have to go acknowledge that. And maybe  
10 it's on the third page that I have to get to. That's  
11 why I was asking whether it was actually there in one  
12 of these time sensitive dynamic scenarios. I'm not  
13 talking about starting up the plant, but something  
14 where things --

15 MR. HALL: The answer is yes. And we  
16 did not see those problems.

17 CHAIRMAN STETKAR: You did not see those  
18 problems.

19 MR. HALL: No.

20 CHAIRMAN STETKAR: Did they just ignore  
21 them? I mean we've burned up a turbine at Unit 2 at  
22 the Zion Nuclear Power Plant because our computer  
23 system gave us so many alarms that the operators just  
24 got used to ignoring them. Sometimes they were  
25 worthy of attention.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 But you didn't see any problems with it.  
2 And you really tested it under situations where  
3 levels and stuff were changing rapidly such that the  
4 priorities were -- You know you were going from three  
5 to two to -- from zero to three to two to one.

6 MR. HALL: Yes.

7 CHAIRMAN STETKAR: Okay. I can work  
8 with it. I get it for slow transients. You know  
9 it's a really good idea to keep people focused on  
10 what's important.

11 MEMBER BLEY: Yes, I guess I'd have to  
12 see it, too. I was worried about that. And I'd seen  
13 other plants when they'd first gone to alarm displays  
14 like this that list them all in one place instead of  
15 up on tiles where you can do some kind of pattern  
16 recognition where people had a lot of trouble with  
17 that.

18 MR. HALL: But I remind you that it's  
19 simply not just the list. The list is there, but  
20 the alarms are displayed on --

21 MEMBER BLEY: But you've got to deal with  
22 the list. You've got to shut the darn thing off  
23 because it's drawing your attention.

24 MR. HALL: That's true.

25 MEMBER BLEY: Then it didn't cause much

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 trouble. That kind of surprises me. I don't know  
2 how many you get, but you could get several hundred  
3 I would think.

4 CHAIRMAN STETKAR: It's limited to the  
5 number that will come up on a single page.

6 MEMBER BLEY: Yes, but there are a lot  
7 of them on there.

8 CHAIRMAN STETKAR: But there are several  
9 nested pages. I mean to get everything you might  
10 have four pages of priority two alarms, right? In  
11 principle, you could.

12 MEMBER BLEY: Well, what kind of numbers  
13 do you see?

14 CHAIRMAN STETKAR: I don't know. I  
15 actually don't know.

16 MR. HALL: I don't have an answer to  
17 that. I don't remember.

18 CHAIRMAN STETKAR: As I understand it,  
19 you have to acknowledge it. You do it on a page by  
20 page basis. So if the first page is displayed, you  
21 acknowledge it. And there might be priority two  
22 alarms perhaps that are down on the second page. You  
23 pull up the second page. You have to acknowledge  
24 those.

25 MEMBER BLEY: Right. And I'm thinking

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 with four or five people in the control room somebody  
2 is doing that. And with two people in the control  
3 room this could drive me off the wall.

4 CHAIRMAN STETKAR: Or you just ignore  
5 it.

6 MEMBER BLEY: I don't know what it sounds  
7 like. Sometimes ignoring it leads to confusion, too.

8 CHAIRMAN STETKAR: But do you  
9 think -- This is one of these things where I know  
10 your answer is going to be yes. But it's one of  
11 those things where I would have really tried to  
12 challenge the operators to see if during a rapidly  
13 evolving scenario involving pressures, temperatures,  
14 flows, levels and things like that they indeed  
15 responded. But their attention was not diverted to  
16 simply paging through this thing and acknowledging  
17 alarms because they were constantly coming in versus  
18 paying attention to the bigger picture. Again, if I  
19 only have one person to do this, it's a problem.

20 MEMBER BLEY: And I was thinking of a  
21 thing like we've seen in some simulators a loss of  
22 instrument AC or something which brings in all kind  
23 of alarms, low priority and high priority.  
24 Everything comes in as soon as you re-energize it.

25 I'm just surprised that it's not

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1       problematic. In your first set of tests when you  
2       did write up a pretty thorough report, was there any  
3       significant discussion of the alarm VDUs and how  
4       people dealt with them?

5               MR. HALL: Let me try to answer your  
6       concerns. But I'll do it quickly. So dig deep earth  
7       needed. When we were looking at the scenarios in  
8       the first series of tests there was an early version  
9       of the prioritization scheme applied to all the  
10      alarms. And there was a significant amount of alarms  
11      still coming in.

12             The second series of tests had a more  
13      dynamic and a more robust screening going on or  
14      filtering of the alarms or I should say  
15      prioritization of the alarms is right. And those  
16      tests were very successful.

17             The data we collected on it included  
18      literally time on the alarms, measured time, how much  
19      time was spent here versus elsewhere. Measured  
20      situation awareness of the operator, figuring out did  
21      he know that there was an alarm going on in here and  
22      did he recognize it.

23             And then took feedback in the form of  
24      structured questionnaires from the operators. And  
25      this was a set of questions about each area of the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 HSI, but the alarms were one of them. And there were  
2 no significant problems that were addressed.

3 And you keep kind of circling around the  
4 levels of scenarios. They were very complex. Some  
5 of them very, very fast from a human point of view.  
6 Some of them very, very slow because that could be  
7 very challenging, too.

8 And we superimposed over the objection  
9 of a lot of the I&C engineers as I said additional  
10 failures up to in some cases three or four  
11 independent failures on top of standard types of  
12 scenarios. So these were very, very complex  
13 scenarios that we were running.

14 MEMBER BLEY: Thank you.

15 MR. MASHIO: The next slide shows how  
16 alarm indication LDP and some examples of the  
17 indication in LDP. Additionally, in the present  
18 paragraph and when the alarm is -- the parameter  
19 exceeds the setpoint, then the alarm indicator with  
20 alarm color code. This example is showed.

21 And the group alarm indicates on the  
22 upper side of the area. The example shows  
23 engineering feature function actuation with yellow  
24 color code. The bravo charging pump indicator with  
25 the title of bravo as well as component's presented

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 alarm information. And the clear alarm on VCT  
2 indicates with white color code. OK monitor  
3 indicates with green color code when plant computer  
4 checks the component status as everything working  
5 correctly.

6 Computer also checks critical safety  
7 function and indicates alarm as normal condition on  
8 PI. That means primary system integrated, for  
9 example. And we introduced a gray-form concept  
10 feature which means all information indicates gray  
11 in normal condition and indicates outstanding color  
12 code when abnormal status is initiated.

13 MEMBER BLEY: I'm going to interrupt you  
14 again just because my mind is still spinning on what  
15 we talked about thinking about it. When you watch  
16 the operators use this and when they made their  
17 comments, did they really use the alarm VDU very  
18 much? Or did they more focus on these kind of  
19 displays which are more historically like they've  
20 looked at and run the plant from that and just  
21 acknowledge those darn things and get them out of the  
22 way?

23 MR. HALL: My conclusion would be this  
24 was the primary directing force which it's supposed  
25 to be. That's what it's there for. And the alarm

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 VDUs were used as a secondary source. The list in  
2 other words was used as a secondary source.

3 MEMBER BLEY: If I wanted to dig a little  
4 deeper, I'd go over there which makes me wonder why  
5 you might not just have a single acknowledgment for  
6 all the screens. But that's a separate thing,  
7 especially if it wasn't causing problems.

8 MR. MASHIO: The next slide shows an  
9 example of the parameter diagram. This is a steam  
10 generator indication with alarm low-low. And  
11 general setpoint low alarm on steam generator  
12 regulator. The low-low on the alarm display or low  
13 alarm degrees are downgraded to low alarm with green  
14 highlights when low-low level alarm initiated with  
15 highest gravity color code that is red.

16 CHAIRMAN STETKAR: Has this display  
17 template changed from what's documented in the  
18 Topical Report? I had a real question about this  
19 and the problem is your picture here doesn't show the  
20 question I had.

21 There's a figure 4.9-4 in the Topical  
22 Report itself that got me thinking about things. And  
23 this picture that we see in front of us is different  
24 from that. But the picture in 4.9-4 doesn't have  
25 the little arrows off to the side which helps me.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: I have a question about the  
2 arrows actually.

3 CHAIRMAN STETKAR: Okay. But let's just  
4 in 4.9-4 -- we all don't have it in front of us  
5 here -- there's an example that shows a low level in  
6 steam generator C that comes up with a red on the C  
7 with an (L) and it shows a different deviation in  
8 steam generator B which is shown as a red with a plus  
9 sign next to it.

10 But the meaning of that plus sign is that  
11 there is a positive deviation low level. Every time  
12 I have looked at this thing now three times reading  
13 this report every time I look at the plus sign it  
14 tells me the level is high. That there's a level  
15 deviation high and it's the description in the text  
16 and the note on this thing that says no, it's a  
17 positive level deviation low below the setpoint which  
18 to me really can confuse me.

19 The arrows may help me, but in a Topical  
20 Report they don't have the arrows. If I see a plus  
21 with an arrow pointing down maybe that reminds me  
22 that the plus doesn't mean plus. It means  
23 something --

24 MEMBER BLEY: And you see the numbers.

25 CHAIRMAN STETKAR: And I see the numbers.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 See without the arrow if I just see the numbers I can  
2 glance away.

3 MEMBER BLEY: No, I had the same reaction  
4 when I looked at it. I wondered if the U.S.  
5 operators in the tests if those plus signs bother  
6 them or if they even saw them. Did they get those  
7 displays?

8 MR. HALL: The early displays, the phase  
9 1A displays, didn't have plus signs or arrows. It  
10 was just the digital displays.

11 CHAIRMAN STETKAR: Just the numbers.

12 MR. HALL: Just the numbers.

13 CHAIRMAN STETKAR: Okay.

14 MEMBER BLEY: But it lit up red if it was  
15 alarming.

16 MR. HALL: Yes, it had the alarm.

17 MEMBER BLEY: But you had to read the  
18 numbers.

19 CHAIRMAN STETKAR: You had to read it was  
20 20 and 30.

21 MR. HALL: And if you know anything about  
22 humans and digital systems, that's a no-no. And  
23 those are the exact comments we got back from the  
24 operators was "I can't tell" especially when  
25 procedures said is it increasing or decreasing and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 they were looking at flutter. And the time was  
2 consumed as to what's really going on to meet that.

3 MEMBER BLEY: Yes.

4 MR. HALL: Given the kind of display the  
5 LDP is, this gray board concept, putting graphs on  
6 it and stuff like that confuses it. It just gets it  
7 away from sparse density to highly dense. And that's  
8 not what we wanted to do.

9 So the arrows were a way of giving those  
10 trends. You didn't have to consume a lot of time  
11 when all you wanted to know was it going up, down or  
12 was it stable. And there are normalizing algorithms  
13 behind the arrows based on the parameter it's  
14 measuring as to what is simply flutter versus a trend  
15 occurring.

16 MEMBER BLEY: And with the arrows, are  
17 they just straight across, angled up, angled down or  
18 do they get taller?

19 MR. HALL: Just three.

20 MEMBER BLEY: Just three positions.

21 MR. HALL: Up, middle down. It's not  
22 graduated. Is it increasing, decreasing or is it  
23 consistent?

24 MEMBER BLEY: That's good. But you see  
25 that. And are the plus signs still in there for this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 positive deviation thing which is beyond most  
2 operators thinking about I&C system honestly?

3 MR. HALL: I can't answer that question.  
4 I don't know.

5 MR. MASHIO: Yes, we still have a plus  
6 and minus compared with the setpoint.

7 MEMBER BLEY: I mean in truth to me from  
8 my past experience that might be helpful to the I&C  
9 maintenance guy. But the operators probably will  
10 have --

11 CHAIRMAN STETKAR: But if you look at  
12 this figure here, I mean just the figure in the report  
13 that we're reviewing, it says "Deviation (-) means  
14 level is greater than the setpoint. Deviation (+)  
15 means level is less than the setpoint."

16 I'm sorry. To me that is just backwards.  
17 Now the arrows -- help me out. But it tells me I'll  
18 probably ignore those +s and -s. I sure hope so.  
19 Or get really confused.

20 MEMBER BLEY: And that didn't cause any  
21 confusion, the + and - stuff, even after you did  
22 the -- Were the arrows there when you did the second  
23 round of testing?

24 MR. HALL: Yes. The pluses were not.

25 MEMBER BLEY: They went away.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 CHAIRMAN STETKAR: Oh, wait a minute.  
2 Kenji said they're in.

3 MR. HALL: The second set of tests, this  
4 is what the test looked like.

5 MEMBER BLEY: This one, okay. What's  
6 the now? Is it both arrows and plus and minuses?  
7 Or is it just what you did in the second set of tests  
8 which I hope?

9 MR. HALL: I don't have an answer to  
10 that.

11 CHAIRMAN STETKAR: Again, this is low  
12 level. So it's not a plus or minus thing.

13 MR. HALL: Remember, this is -- the  
14 arrows are communicating --

15 (Simultaneous speaking)

16 MEMBER BLEY: I'm not asking about the  
17 one up here. I'm asking about the pluses and minuses  
18 and when they are appropriate.

19 CHAIRMAN STETKAR: We heard from Kenji  
20 that they're in there. We heard from Bob that  
21 they're not.

22 MEMBER BLEY: Well, that they weren't on  
23 the second round of tests is what Bob said.

24 CHAIRMAN STETKAR: On the other hand,  
25 the second round of tests is supposed to be getting

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       what we're reviewing.

2                   MEMBER BLEY:       Okay.       There is a  
3       discrepancy there which perhaps they'll clean up.

4                   MR. HALL:   I was talking to Kenji and the  
5       basic HSI -- please make sure I'm saying it right,  
6       Kenji, includes the arrows as you see on the screen  
7       plus or minus as it describes in the document,  
8       correct?

9                   MR. MASHIO:   So again the basic design  
10      features are HSI.   But the actual I&C setpoint of  
11      the division alarm before the low-low alarm initiate.  
12      So you have a divisional alarm, plus or minus alarm.  
13      Then we have a low alarm setpoint.   And we have a  
14      low alarm.   So we have three setpoints in this  
15      simulation.

16                   But in the final phase one test, we need  
17      this point arrow helps to explain this parameter  
18      trend.   So operator recognizes this alarm going down  
19      or increased.

20                   MEMBER BLEY:   If I kind of get it, if  
21      it's low, it will have a single valve and if it's  
22      low-low it will have a double valve.   I'm guessing.

23                   MR. MASHIO:   Yes, that's correct.

24                   MEMBER BLEY:   That is correct.

25                   MR. MASHIO:   It means a low-low.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: And if it's just beginning  
2 to deviate you'll get the thing in parenthesis that  
3 will either be a plus or a minus.

4 MR. MASHIO: That's correct.

5 MEMBER BLEY: And, boy, I would run that  
6 by your operators again because I agree with John.  
7 I think it's just backwards to what they think it  
8 meant.

9 CHAIRMAN STETKAR: I understand the need  
10 for an operator to get an early indication that level  
11 is starting to deviate. In general, most people  
12 think that plus means it's going up and minus means  
13 it's going down whether that's pressure or  
14 temperature or flow or level or whatever. And at  
15 least what I can read in front of me here is just  
16 contrary to the way normal people think.

17 And that's just basic human factors  
18 engineering. I mean if you read stuff that you ought  
19 not to have level decreasing in an upwards fashion  
20 on a gauge, ought not to have things getting faster  
21 by going leftwards. I mean that's paint, label and  
22 tape, but human factors engineering.

23 And what's in the report doesn't talk  
24 about the arrows. The arrows at least help me  
25 personally a little bit.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. SPRENGEL: Let's take a little time  
2 and maybe revisit it. But for now we'll go ahead  
3 and continue on.

4 CHAIRMAN STETKAR: Okay.

5 MR. MASHIO: These couple explain safety  
6 VDU feature. The safety VDU must only be used when  
7 OVDU fails. The safety VDUs provide monitoring and  
8 component level controls for safety functions. And  
9 the safety VDUs are designed to satisfy class 1E  
10 requirements.

11 They are divided into two groups. First  
12 is the two multi-divisional safety VDUs and the four  
13 selectable train-based safety VDUs. The orientation  
14 and retrieval features of the safety VDU network are  
15 similar to the OVDU network, but there is  
16 significantly less information being managed. That  
17 is used with paper procedures only.

18 The next slide shows selectable  
19 train-based screen that third level of the  
20 information menu. And this screen contains the three  
21 level information hierarchy. The top level display  
22 is the organized system and the components present  
23 in the hierarchy order.

24 The second level, the next slide, the  
25 display are components associated with systems

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 selected on the top level display, one page down  
2 display, 20 components in our order. The screen  
3 shows the example that operators select A-charge  
4 pump. Self-control alpha-charging pump will show up  
5 on the side of whatever display. The next slide.

6 The third level of the information  
7 hierarchy contains components of controls. These  
8 are grouped by system work by tasks. It is  
9 structured the same as the operation based level, but  
10 only contains safety related controls. Similar to  
11 the operation we use, we use contrast between light  
12 and dark color to maximize visibility of displayed  
13 group at both the first and second information  
14 levels.

15 The third level of safety controls uses  
16 black background with light color for controls  
17 associated with the information. The function is  
18 what's in the right-hand navigation toolbar. The  
19 information is operation of VDU output and the  
20 component control from a safety VDU toolbar.

21 CHAIRMAN STETKAR: Two questions. Why  
22 don't the safety VDUs or that part of the console  
23 contain flow mimics which the operators are used to  
24 using 99 plus several nines after that percent of the  
25 time?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. MASHIO: That is because as the  
2 safety software application requirement. This  
3 software application for safety should be simplified.  
4 So that's why we limited this graphics not using the  
5 graphics P&ID that we have used

6 CHAIRMAN STETKAR: All right. I'll have  
7 to think about that. Something I did think about.  
8 The scenarios that you ran, were they run for a  
9 two-train plant or a four-train plant?

10 MR. MASHIO: Actually, the testing is  
11 conducted for a current plant. So we have a whole  
12 VDU for a safety VDU.

13 CHAIRMAN STETKAR: Did the simulator  
14 have two trains or four trains?

15 MR. MASHIO: This simulation is from  
16 Japanese PWR. They have four loops.

17 CHAIRMAN STETKAR: Four loops?

18 MR. MASHIO: Four loops.

19 CHAIRMAN STETKAR: The number of safety  
20 trains, two or four?

21 MR. MASHIO: I'm sorry. I don't know  
22 anything about that trains.

23 CHAIRMAN STETKAR: I'll tell you why I'm  
24 asking. US-APWR has four safety trains. I got it.  
25 I understand that. Charging pump A is off train A.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Charging pump B (boy) is off Train D (dog). And  
2 there are other anomalies, but that's a good one.

3 If I have a flow mimic in front of me and  
4 I want to get this pump running, I go push that pump.  
5 I don't care what freakin' train it's off. If I have  
6 to now go and remember that I want to get B running  
7 so I have to go to safety VDU D (dog) and pull up  
8 three screens and finally get to this thing and get  
9 it running, that to me is really confusing. It's  
10 confusing to me.

11 If you ran your validation on a two-train  
12 plant and had something jimmied up with four trains  
13 of safety divisions because you can get signals out  
14 there to do things automatically, that doesn't test  
15 my ability to use the safety VDUs in a real four-train  
16 plant design that may have a symmetries or things  
17 like this B is off D. It has cross connect systems  
18 where I have like component cooling there's a whole  
19 bunch of A valves that are off different divisions  
20 forcing me to remember which the heck of these things  
21 I need to go to to then go down three levels and  
22 select the right valve.

23 MEMBER BLEY: Which seems to defeat the  
24 valve of an electronic system.

25 CHAIRMAN STETKAR: Yes. So have we now

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       invoked the need for simplicity to the extent that  
2       we've made it so simple that people are going to get  
3       in trouble with it because they're not really used  
4       to doing this and they're forced to remember some  
5       things that are not necessarily intuitive in the heat  
6       of battle?

7                   MEMBER BLEY:     I was going to ask  
8       something, but I guess there's no way to do it.  If  
9       you could see a schematic of the whole system and  
10      say, "I want that one" and it told you which place  
11      to go, that would help.  But you've got to go there  
12      to find it which makes it hard.  And if that didn't  
13      make sense, forget it.

14                  CHAIRMAN STETKAR:  No, I understand what  
15      you said.  I understand what you're saying that if  
16      you had a schematic in front of you that said I want  
17      to start that pump and it reminds you, although it's  
18      given a pump name A, all of this stuff is just off  
19      of text names of things.

20                  MEMBER BLEY:     Right.

21                  CHAIRMAN STETKAR:     And you have to  
22      remember the pump.  You need to go to the CVDU to  
23      start pump A, yeah, that might help.

24                  MEMBER BLEY:     But most of them I've seen  
25      you point to the schematic and you could start the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 pump right there.

2 CHAIRMAN STETKAR: But that's what the  
3 operators are used to doing.

4 MEMBER BLEY: Yes.

5 CHAIRMAN STETKAR: And in some sense I  
6 suspect when you're on the schematic you don't care  
7 particularly that that pump on the bottom of the  
8 screen happens to be powered from bus C or something  
9 like that.

10 MEMBER BLEY: No, that's what you said  
11 earlier.

12 CHAIRMAN STETKAR: It's just you want to  
13 get that running because the one on the top of the  
14 screen is out of service or whatever.

15 MEMBER BLEY: Yes.

16 CHAIRMAN STETKAR: And you don't run into  
17 those problems on a two and only two-train plant  
18 because I've never seen a two-train plant that  
19 labeled the B train E or F or A. And that's why I  
20 was curious when you ran your tests. If it was run  
21 only on a two-train plant you don't run into this  
22 problem.

23 MR. SPRENGEL: In a moment we plan to  
24 present the other orientation or use of the SVDU. On  
25 the right side of the screen, there are different

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       ways to ask it. One of the ways is a task control  
2       menu. And with that, the intent would be to have  
3       that task control menu on all four trains and to  
4       follow the steps so that you have access to the  
5       controls on those different trains with the process  
6       going on.

7                   CHAIRMAN STETKAR: But let's get through  
8       that because for the life of me I couldn't understand  
9       what the task control menu was doing. So that may  
10      help.

11                  MR. SPRENGEL: Right. This section will  
12      be related to the question that was asked. We'll  
13      get to that portion and revisit the question.

14                  MR. MASHIO: Let's continue. This  
15      displays monitoring site. And this display is an  
16      example of the safety monitoring navigation screen.  
17      The system category and request scheme of safety  
18      parameters are the same way as component control  
19      navigation screen. The top are safety monitoring  
20      and control navigation menu. It can be switched by  
21      touching the function menu on the right side.

22                  And the next slide shows an example of  
23      the safety monitoring indication screen on the  
24      containment system. The green color code is used  
25      for fixed characters such as indication name and type

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 number. The variable characters are indicated as a  
2 white color code with that indication as actual  
3 display. When parameter exceeds the setpoint, the  
4 parameter barrier time around indications with  
5 intuitive square character box appears.

6 There are two modes of operation,  
7 train-based mode and task-based mode. In  
8 train-based mode, safety function control and  
9 monitoring are arranged by system and provide  
10 separator for each train.

11 In the task-based mode, monitoring and  
12 controls are still provided with a separator for each  
13 train. However, monitoring and control functions  
14 are grouped so that a single screen supports  
15 pre-defined set tasks needed to execute emergency  
16 operating procedures.

17 This mode reduces the navigation task  
18 burden as well as we reach our A switches are located  
19 for train. This mode reduced. So this display is  
20 an example of the task-based mode. This is when the  
21 operator touches E-0, then as I said, then as a safety  
22 control and the parameters are aligned along with  
23 operating procedure steps.

24 The slide shows an example of E-0 step  
25 28. In the step 28 the E-0 operator is required to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 control emergency feedwater flow using the EFW  
2 control panel. So the Alpha EFW flow control alarms  
3 and associated parameter. In this case, EFW and ECG  
4 level are located in the step 28 row. The operator  
5 selects the bar and monitors the parameter in  
6 accordance with the procedure steps.

7 CHAIRMAN STETKAR: Kenji, if I can make  
8 sure I understand so far what has gone into this.  
9 The task-based control menu if you go back to your  
10 previous slide 34, 54, whatever number it is, that  
11 one, it seems to me the same as I was understanding  
12 the computer-based procedure menu. If I popped up  
13 E-0, it would then give me the steps. I could go  
14 over and do it. Is this essentially a surrogate for  
15 that?

16 I mean this doesn't do anything  
17 automatically, right. It just knows that in what  
18 you're telling me here is that it knows that, an E-0  
19 part of that, I have to make sure that I have  
20 auxiliary feedwater control. It's not actually -- I  
21 still have to go next it manually down three levels  
22 to get to that valve, right?

23 MR. SPRENGEL: Okay. First, a reminder,  
24 using the safety VDU you're using paper-based  
25 procedures. Just a reminder.

CHAIRMAN STETKAR: Yes, you're right.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       Okay.  Never mind.

2               MR. SPRENGEL:  So we're done.

3               CHAIRMAN STETKAR:  Never mind.  I'm  
4       sorry.

5               MR. SPRENGEL:  Now the other thing I do  
6       want to address, drilling down through the  
7       task-control menu, this next menu, selecting in this  
8       case A-EFW control valve would then pull up the  
9       controller for that valve.

10              CHAIRMAN STETKAR:  Yes, I mean that's  
11       what he's showing.

12              MR. SPRENGEL:  So there is no further  
13       navigation.

14              CHAIRMAN STETKAR:  There isn't when you  
15       say pass control.  It's a selected set of tasks to  
16       achieve the functions in that base procedure.

17              MR. SPRENGEL:  Tied to the procedure,  
18       yes.

19              CHAIRMAN STETKAR:  Tied to the  
20       procedure.  Okay, got it.  And this is train by  
21       train.

22              MR. SPRENGEL:  Train by train.

23              CHAIRMAN STETKAR:  Okay.  Got it.  Now I  
24       understand.  Wait.  Back up.  I understand now the  
25       intent of the task.  Honestly, it didn't come across

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 to me reading it. But I understand what that's  
2 doing.

3 How does this solve my problem of making  
4 sure that I remember charging pump boy is powered  
5 from division D (dog) so that if I now only have my  
6 safety VDUs available and I want to start charging  
7 flow I can remember that because you said this was  
8 going to help me understand that.

9 MR. MASHIO: I understand your question.  
10 Operator selects the same step on each train. So we  
11 have a Whole VDU safety train. In this case,  
12 operator selects this task-based screen of 28 steps  
13 on in each train. Operator knows which switches are  
14 located on each pitch arm review. Whole VDU shows  
15 all of controls inventory required in the 28 steps.

16 The EOP steps are required to identify  
17 which train switches are operated. So based on the  
18 E-0 step, operator selects which group for switches  
19 can control.

20 CHAIRMAN STETKAR: Let me ask you. Are  
21 the task control menus strictly limited to the  
22 emergency operating procedures? I mean I see buttons  
23 on this picture here that are related to the  
24 emergency operating procedures. Is it only the  
25 emergency operating procedures?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. MASHIO: Yes, that's correct.

2 CHAIRMAN STETKAR: Only the emergency  
3 operating procedures.

4 MEMBER BLEY: A function restoration  
5 guide on here. I don't know if there is one.

6 CHAIRMAN STETKAR: I don't know.

7 MR. MASHIO: EOP and also SAMG are in the  
8 accident management operating.

9 CHAIRMAN STETKAR: I'd really like to  
10 figure out how the heck this thing works because if  
11 I'm responding to a tube rupture it kind of makes a  
12 difference what's going on, which loop it's in. And  
13 I see a concept that boom I hit row seven, column six  
14 on all four of my safety VDUs. And four screens pop  
15 up and I see wait a minute. Over here on screen  
16 three I need to work this valve and on screen number  
17 one I need to work this other valve.

18 MR. SPRENGEL: In all this discussion,  
19 the missing part though is the EOP guiding the  
20 actions. So the SVDU is providing information, not  
21 the farthest right, but the right column of  
22 information as well as providing control access.  
23 When you have all four trains up aligned in terms of  
24 the step that you're on, you're really following the  
25 EOP procedure.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   And the procedure is telling you what to  
2                   do. The VDU is just providing you ready access to  
3                   that. So the EOP is actually telling you where to  
4                   go to take action. The SVDU is just pulling those  
5                   potential areas into the particular row for that  
6                   step.

7                   MEMBER BLEY: On the one you took us to,  
8                   if you went down a step on these and you get down to  
9                   auxiliary feedwater control valve. But by following  
10                  the procedure you'd go to all the trains of aux  
11                  feedwater one at a time and make sure they're all  
12                  aligned properly. Is that it?

13                 MR. SPRENGEL: Based on procedure, yes.  
14                 Right.

15                 MEMBER REMPE: Earlier today, didn't one  
16                 of you mention that the difference between the  
17                 Japanese response and the U.S. response and the fact  
18                 that the procedure isn't always just followed  
19                 immediately in Japan. Is this something you added  
20                 for the American version or was this already there?  
21                 I heard from you saying that you just did this.

22                 MR. HALL: No, this was one of the  
23                 additions after the first series of tests.

24                 MEMBER REMPE: Okay. Thanks.

25                 MR. HALL: For that reason.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1           MR. SPRENGEL:   Right.   And what was  
2   brought up before, multiple jumping and back and  
3   forth in detail and then, right, this proves the  
4   access to those components and the control of them  
5   as part of your steps instead of having to navigate  
6   through the three levels. But having to continually  
7   navigate to those, it provides the information as  
8   well as the control readily available to the  
9   operator.

10           CHAIRMAN STETKAR: I'll come back to when  
11   you actually ran people through the simulator did  
12   they use this? I'm assuming in the second because  
13   you said this came out of the first.

14           MR. HALL: 1a didn't have it.

15           CHAIRMAN STETKAR: They didn't?

16           MR. HALL: 1a.

17           CHAIRMAN STETKAR: Yes, 1a. That's  
18   right.

19           MR. HALL: 1a didn't have it.

20           CHAIRMAN STETKAR: So 1b had it.

21           MR. HALL: 1b had it and performance was  
22   substantially enhanced because these follow the EOPs.

23           CHAIRMAN STETKAR: But did they only need  
24   to do this on two of two trains because that's all  
25   they needed to deal with? Did they need to deal with

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 four trains of equipment?

2 MR. HALL: We had it set up so that it  
3 looked like four trains, but it was being driven  
4 by -- It was limited because it was driven by a  
5 two-train model. So the answer is they had to take  
6 action on the four screens, not two screens.

7 CHAIRMAN STETKAR: They had to take  
8 action on the four screens. Okay.

9 MEMBER BLEY: But two of them were for  
10 just observing them and two of them were driving the  
11 show, driving the simulator. It's hard looking at  
12 pages in the report or sheets of emails and trying  
13 to imagine how people are doing that. Wish you had  
14 a movie.

15 MR. HALL: We actually do.

16 MEMBER BLEY: With you?

17 (Laughter)

18 MR. SPRENGEL: We'll get back to you on  
19 that.

20 CHAIRMAN STETKAR: Thanks.

21 MR. MASHIO: Next slide, the  
22 multi-divisional safety VDU screen. These screens  
23 are dedicated for monitoring of post-accident  
24 monitoring variables and the parameter supporting  
25 credit manual operator actions. All parameters are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 displayed as spatially dedicated and continuously  
2 visible as the SDCV and include alarm color coding.  
3 These we use and their design features minimize any  
4 navigation needs to monitor safety parameter and  
5 improve station awareness of total plant status  
6 particularly during loss of safety-related.

7 The next display gives an example of the  
8 multi-divisional safety VDU screen. The upper side  
9 alarm features the present color-coded safety  
10 parameters displayed with red color code. Also  
11 specific parameter features alarm setpoint are also  
12 indicated as red color code. That's all for safety  
13 VDU.

14 And the next couple of slides explains  
15 computer-based procedure system. The operating  
16 procedure VDU displays procedures that are structured  
17 in accordance and compliant with the textual images  
18 from the hard copy procedure. This provides a task  
19 sequence of which operator is review. It also  
20 retains the latest guide-formatting design to enhance  
21 the usability of procedure.

22 The procedures are presented in a  
23 standardized format with the title and a specific  
24 procedure index in the left column display, allowing  
25 the operator to move to the desired section of the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 procedure.

2 The function bar is available at the  
3 bottom of the page to allow interface with O-VDU  
4 where the control functions are initiated. As an  
5 alternative, by selecting hyper-link on the operating  
6 procedures, VDU, the related O-VDU display are  
7 automatically displayed.

8 The related switches or controller is not  
9 requested directly on the operating procedure VDU to  
10 avoid the operator's omission of the relevant  
11 information confirmation.

12 The procedure menu and the bookmarking  
13 controls are also provided. Arrows are simple that  
14 there is movement into the controls and/or the  
15 information needed to implement the procedures. A  
16 back-up of CBP system is the paper-based procedure.

17 The next slide shows an example of  
18 the -- I'm sorry. Continues the explanation of the  
19 CBP features. The alarm VDU supports similar lateral  
20 movement by using a function key to bring up alarm  
21 response procedures on the operating procedure VDU.  
22 In case of emergency such as a plant trip, the  
23 operators can request the emergency procedure for a  
24 reactor trip or ECCS operation by touching the  
25 first-out alarm on the alarm VDU.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   Distinctive accident procedures such as  
2           LOCA, steam generator are requested from CBP menu  
3           screen after the operators identifies the accident  
4           condition.

5                   CHAIRMAN STETKAR:   Kenji, if I need to  
6           be in two or three procedures simultaneously, how do  
7           I do that with this display?   Do I have to toggle  
8           back and forth between multiple windows?

9                   MR. MASHIO:       Yes.   On this kind, we  
10          have bookmarking function.   So we track the previous  
11          procedures which is different at different  
12          procedures.   So we can back up by using the scroll  
13          function.   Bookmarking scroll function, it locates  
14          at this screen.

15                  MR. SPRENGEL:   As well as the bookmark  
16          tab.   But to directly answer your question, yes.   You  
17          would have to -- Multiple procedures would not be  
18          displayed simultaneously.

19                  CHAIRMAN STETKAR:   Okay.   I asked about  
20          that because people have gotten into trouble needing  
21          to go back and forth among more than one procedure.  
22          And in the Topical Report, it says the CBP system  
23          allows the operator to easily move from one procedure  
24          to another at any time through the use of multiple  
25          operating procedure VDUs and multiple procedure

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 windows within each VDU. As I understand it, it's  
2 multiple procedure windows within the VDU.

3 MR. SPRENGEL: Yes, except for the  
4 ability to utilize the linking function out of the  
5 procedure which we haven't touched on.

6 CHAIRMAN STETKAR: The linking function  
7 out of the procedure.

8 MEMBER BLEY: You mean a branch point in  
9 the procedure where it branches to the next procedure  
10 in line.

11 MR. SPRENGEL: Right. So in a way you  
12 are utilizing the multiple VDUs. But the operating  
13 VDUs, those are still maintaining their original  
14 function. But you're able to connect to specific  
15 systems from the operating procedure VDU.

16 CHAIRMAN STETKAR: That I understand.  
17 But what I'm talking about is I have a fire going  
18 on and I've lost offsite power and I have a leak out  
19 of the system. So it's not a good day in the electric  
20 factory, but I have procedures for all of those  
21 things. And I need to figure out how to coordinate  
22 my way through all of those procedures at the same  
23 time. That's not part of this linking function  
24 you're talking about because they're not, at the  
25 point I've gotten you into, linked to one another.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: And they're progressing  
2 simultaneously.

3 CHAIRMAN STETKAR: Yeah. The plant is  
4 doing what it's doing.

5 MEMBER BLEY: And the fire.

6 CHAIRMAN STETKAR: And the fire, yeah,  
7 as part of the plant.

8 MR. SPRENGEL: Which section were you  
9 reading from?

10 CHAIRMAN STETKAR: That quote is 4.8,  
11 General Review Criteria. But it's -- I don't want  
12 to dwell on that particular sentence although I  
13 quoted it. It does mention multiple operating  
14 procedure VDUs and I know that a single operator  
15 doesn't have that. The bigger concern is if the  
16 operators do get into a situation where they need to  
17 be in two or more procedures in parallel to cope with  
18 what's going on in the plant. It's my understanding  
19 that they need to basically toggle back and forth  
20 between those procedures on this display.

21 MR. SPRENGEL: To try not and confuse  
22 matters, US-APWR application has some improvements  
23 in those specific areas for the US-APWR application.

24 CHAIRMAN STETKAR: Thanks. That will  
25 help later.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. SPRENGEL: Right.

2 CHAIRMAN STETKAR: But right now.

3 MR. SPRENGEL: For now the functionality  
4 to address your concern is the bookmarking feature.

5 CHAIRMAN STETKAR: Okay.

6 MR. SPRENGEL: And the allowance -- the  
7 arrow control being controlled within -- It's like a  
8 back.

9 CHAIRMAN STETKAR: Yes.

10 MR. SPRENGEL: As well as the upper level  
11 arrows are within that PDF document kind of idea. So  
12 that's the feature to address what you've identified.

13 MEMBER BLEY: In the current plant, we  
14 can put the primary system guide following the EOP,  
15 E-0, whatever. And if we've got a fire going on,  
16 take the plant guy, hand him the fire procedure and  
17 he gets on the phone with the fire team. And he's  
18 walking through the fire procedure. Can our second  
19 board operator, if you have one, pull up the fire  
20 procedure and walk through that with somebody while  
21 the other guy is in the EOP?

22 CHAIRMAN STETKAR: You've  
23 established -- let me make sure before you answer  
24 that -- the fact that there are two people who have  
25 reactor operator qualifications somewhere in the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 building.

2 MEMBER BLEY: The vicinity, yeah.

3 CHAIRMAN STETKAR: Will people buy -- Can  
4 people buy one of these things that has one and only  
5 one reactor operator console complement of displays?  
6 In other words, only one reactor operator procedure?

7 MR. SPRENGEL: No.

8 CHAIRMAN STETKAR: It's always going to  
9 have two.

10 MR. SPRENGEL: There will always be the  
11 two RO stations.

12 CHAIRMAN STETKAR: That is really  
13 important.

14 MEMBER BLEY: It gets you through part  
15 of the thing.

16 CHAIRMAN STETKAR: Thank you. The  
17 problem is if I read this it says it can configured  
18 for the maximum number of people. But nowhere does  
19 it say will always have that full complement of  
20 stuff. Honestly, for the purpose of the Topical  
21 Report, one of my big concerns is how many screens.

22 Even if it's only one reactor operator,  
23 does that person have available for them to pull up  
24 stuff like trend information, inactions along single  
25 procedures and systems and interactions among

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 multiple procedures that I might be dealing with  
2 parallel? That's difficult for me to as a single  
3 person doing all of that stuff. But you have the  
4 other bodies someplace out there.

5 But the US basic -- I want to get this  
6 on the record -- HSI design will always come with the  
7 hardware that's available for both reactor operators.  
8 Is that true?

9 MR. SPRENGEL: Yes.

10 CHAIRMAN STETKAR: Thank you. It wasn't  
11 clear to me. I was assuming that you could buy one  
12 of these things with simply on this picture the  
13 safety VDUs, the hardwired stuff and the single set  
14 of VDUs for one RO.

15 MEMBER BLEY: While we're on -- Go ahead.

16 CHAIRMAN STETKAR: No.

17 MEMBER BLEY: While we're on this kind  
18 of specific thing, when we were up at the site many  
19 years ago and as you guys were talking today,  
20 everything is touch screen. Yet in the Topical  
21 Report it says touch screen or mouse click. Do you  
22 offer either one or have you decided it's got to be  
23 touch screen?

24 MR. MASHIO: Basically decided either  
25 technology are available.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   MEMBER BLEY:   Okay.   So if I buy one, I  
2   can put either thing on it or either thing on each  
3   station if I want to.

4                   MR.   SPRENGEL:       Depending   on   the  
5   application of the rest of the HFE program.

6                   MEMBER BLEY:   Okay.

7                   MR.   SPRENGEL:       There   was   a   buried  
8   question in there and I think the basic question was  
9   could there be different procedures on different  
10   operating procedure VDUs and the answer is yes.

11                   MEMBER BLEY:   That's where we started.

12                   CHAIRMAN STETKAR:   No and that's good.

13                   MR. SPRENGEL:   I wanted to make sure we  
14   got an answer.

15                   CHAIRMAN STETKAR:   I've been operating  
16   under the notion misguided admittedly that indeed  
17   what we're being asked to review could in fact be  
18   purchased by a customer in a configuration that had  
19   only one RO set of screens.   And that the other guy  
20   is available to kind of help out.   But they both then  
21   would be dealing with a complement of the thing on  
22   this that says a set of VDUs for RO-1.

23                   MR. SPRENGEL:   That understanding is  
24   incorrect.

25                   CHAIRMAN STETKAR:   And that helps me a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       heck of a lot with a lot of things, the procedures  
2       being only one of them. Thank you. That's good.  
3       And I'm glad we have that on the record.

4               MR. SPRENGEL: Okay. I think we've kind  
5       of already addressed the CPV screen, operating  
6       procedure VDU and some of the uses of it.

7               MEMBER BLEY: I had a question because  
8       I'm mixing up things I've seen in different places  
9       with different people and I don't see anything in the  
10      written document here. But on your procedure  
11      screens, are there any operator aids built into it  
12      such as something that tracks the two, made two of  
13      the three conditions and you got one more condition  
14      to do before you take the next step? Is there  
15      anything like that? Or is it just like the paper  
16      procedure like it looks like on this screen?

17              MR. SPRENGEL: Well, I think the answer  
18      from the Topical Report perspective is different than  
19      US-APWR.

20              MEMBER BLEY: Okay.

21              MR. SPRENGEL: So I think there has been  
22      some additional improvements in terms of the US-APWR  
23      application of this HSI where there would be those  
24      additional tools to help log or track. I don't know  
25      how best to phrase it. But, yes, there would be.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: Not in basic, but maybe in  
2 the plant.

3 MR. SPRENGEL: Correct.

4 MEMBER BLEY: Thank you.

5 MR. SPRENGEL: Now we transition with  
6 the possible --

7 CHAIRMAN STETKAR: Before we take a break  
8 which we all need, let me do some difficult things  
9 because I need feedback from folks. My sense is that  
10 we're not going to have enough time today to get  
11 through both the Topical Report and Chapter 18 of the  
12 DCD. That's only my sense.

13 We also have the staff that needs to  
14 come. And I don't know how much discussion we're  
15 going to have with them.

16 If that's the case, I certainly want us  
17 to get through the Topical Report because that's the  
18 key element of everything here. If we're all  
19 convinced that we can get through both the Topical  
20 Report and the DCD by a reasonable time being no  
21 later than -- Let me ask our reporter. Do you have  
22 any time constraints?

23 (Off record comment)

24 Okay. I actually am a human being.

25 MEMBER BLEY: Tell me one element.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 (Laughter)

2 CHAIRMAN STETKAR: If we can get through  
3 it by about 6:30 p.m. or so, I'm willing to try to  
4 tackle that. But I don't want us to get rushed at  
5 the 11th hour. So before we take a break -- and it's  
6 a good time to take a break -- I'd like the staff and  
7 MHI to sort of concur, discuss and see whether we can  
8 get through everything.

9 If we can get through everything, then  
10 it's probably okay for you to continue where you are.  
11 If we can't, I'm going to have the staff come up and  
12 talk about their review of the Topical Report.

13 MR. SPRENGEL: Okay.

14 CHAIRMAN STETKAR: Okay.

15 MR. SPRENGEL: We have already covered a  
16 significant amount of the Chapter 18 portion because  
17 we of course applied the US-Basic HSIS.

18 CHAIRMAN STETKAR: Yes, you have.

19 MR. SPRENGEL: There is a small number  
20 of slides left which again a portion of those we have  
21 not only covered in general but specifically covered.  
22 And my understanding of the staff's presentation is  
23 finding no issues with our design as part of their  
24 review. I don't specific the presentation portion  
25 would be lengthy, but I'll let Paul address it maybe.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 I don't think we have much time and we  
2 can definitely condense it, too, outside questions,  
3 yes.

4 CHAIRMAN STETKAR: Let's just leave it  
5 there. But again you thought you were going to be  
6 done with this by noontime, you know, the stuff that  
7 we've gotten to right now.

8 MEMBER BLEY: Would it make sense to go  
9 ahead and have the staff come up and do the Topical  
10 and see where we are.

11 MR. MASHIO: They have only eight slides.

12 MEMBER BLEY: Slides don't make the  
13 difference.

14 CHAIRMAN STETKAR: Slides don't make the  
15 difference. Rather than doing this on the record in  
16 real time, let's take a break and let people discuss  
17 offline what the path forward is. I just want to  
18 make sure that we don't get to the end of the day  
19 where we're shortchanging something because we're  
20 being too rushed. That's all.

21 So let's take a break until 3:10 p.m.  
22 please. We're recessed until then.

23 (Whereupon, the above-entitled matter  
24 went off the record at 2:56 p.m. and resumed at 3:13  
25 p.m.)

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: We are back in session  
2 and to index people, we're going to hear from the  
3 staff on their review of the Topical Report, I hope.

4 Bill, Paul, I don't know who's going to  
5 kick it off.

6 MR. PIERINGER: This is Paul Pieringer,  
7 I'm the Technical Reviewer for Human Factors and I'll  
8 be presenting the review of the Topical Report.

9 The first slide tells you the main  
10 contributors.

11 Next slide?

12 And the next slide -- Just by way of  
13 overview, I'll focus on the Topical Report here, the  
14 first bullet.

15 The primary regulatory guidance we  
16 exercised was NUREG-0700.

17 And, the next slide talks about the  
18 Topical Report specifically.

19 It's the most detailed design that we've  
20 received. Because, as you know, most of the  
21 submittals have been deferred designs using the DAC  
22 concept. So, it took us some amount of time to  
23 figure out how to review actual design and what to  
24 review it against.

25 0700 was what we came up with as relevant

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 and I divided into two parts. First, was the design  
2 process and when I looked at the design process, if  
3 you'll remember from the SER, it talks about the  
4 operating experience review, the testing program and  
5 the Japanese design precursor development.

6 My take on the Japanese precursor was  
7 that it used a NUREG-type strategy in developing the  
8 Japanese design and we asked for documentation of the  
9 process that was used. That documentation hadn't  
10 been translated and basically ended up not being  
11 available to us.

12 So, I used what you saw in the Appendices  
13 from 09019 as my background.

14 But, did give credit for the fact that  
15 operators and simulators were used to exercise the  
16 design.

17 I then looked at the testing program and  
18 was -- in particular attention to the -- just the use  
19 of the simulator and my take on that was that the two  
20 simulator sessions that have been describe, Phase 1A  
21 and Phase 1B were thorough. They didn't have the  
22 documentation that we would expect for an ISV, but I  
23 wasn't expecting that and I'll tell you that in a  
24 minute.

25 Now, I have seen the results of the Phase

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 1-Bravo testing.

2 CHAIRMAN STETKAR: You have?

3 MR. PIERINGER: I have.

4 CHAIRMAN STETKAR: Was that submitted or  
5 you have just seen it?

6 MR. PIERINGER: Well, the best I can  
7 reconstruct without going back through the  
8 documentation that was submitted under what we called  
9 MUAP-08014 which was the document that was withdrawn.

10 And, the pertinent information that was  
11 in there was supposed to have been moved to 09019,  
12 Attachment Charlie.

13 Now, I was -- I checked that and I thought  
14 that everything that was needed was there. I did  
15 not identify that the descriptions of the second test  
16 was missing.

17 But, and so, it -- I'm not absolutely  
18 sure that I saw that testing description in that  
19 document or whether through the various other  
20 discussions and demonstrations of the simulator and  
21 RAIs, I perhaps collected it a different way.

22 CHAIRMAN STETKAR: 09019 Rev 5 which is  
23 the most recent Rev which is --

24 MR. PIERINGER: I'd have to look.

25 CHAIRMAN STETKAR: And that's just

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the -- but that's now called the Human Factors  
2 Engineering Program Management Plan which is simply  
3 the Plan. It's a 2014 document.

4 MR. PIERINGER: Well, it's the program.

5 CHAIRMAN STETKAR: I didn't look at the  
6 previous -- I have it here -- in the previous Rev.  
7 And I bet it might be in 09019 Rev 2, but you don't  
8 refer to that in the SER. You refer to the later  
9 2014 version.

10 And, I didn't look here for it because I  
11 ignored this Rev because it wasn't referred to by  
12 anything.

13 MR. PIERINGER: Right. So, we've got to  
14 find out where that information -- where it was  
15 submitted and provide some better documentation.  
16 Because it was part of the essential argument that I  
17 was trying to put forward on the relevancy of the  
18 Japanese design as a starting point.

19 And then, this was the testing that  
20 translated that to the US-Basic design.

21 And then, the third leg on the stool, if  
22 you will, was the use of operating experience to  
23 update that Japanese design for current operating  
24 practice. Well, for operating experience up to the  
25 US-Basic design and then when you get into the ECD,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       there's another operating experience implementation  
2       plan that updated it to the USA PWR.

3               CHAIRMAN STETKAR:       That's in there.  
4       That's where it is.

5               MR. PIERINGER:       So, I use those three  
6       elements, the operating experience review, the  
7       simulator exercise with scenarios in an ISV-type  
8       setting and then the initial Jap development of the  
9       Japanese design via their program as the fundamental  
10      bases for this.

11              I then -- so that established my starting  
12      position.

13              The next point was that I wanted to make  
14      sure that the HFE design met the criteria in 0700.

15              Now, I had seen their style guide which  
16      they use generically for their designs and I knew  
17      that their style guide is consistent with 0700, but  
18      I was particularly concerned about whether the actual  
19      design as you view it on the simulator and in these  
20      slides actually implemented 0700, and by consequence,  
21      their style guide.

22              So, I chose not to do a restrictive  
23      sampling. I had to do some sampling, but the  
24      technique was to take all the major 0700 sections  
25      basically I read through every acceptance criteria

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 in those sections and came to an understanding of  
2 both the detail and the larger concept within that  
3 section. And then, I went back into the design, the  
4 Topical Report specifically, and I evaluated it and  
5 reached the conclusion as to whether it met these  
6 criteria or didn't meet these criteria.

7 And, my general conclusion was that it  
8 did meet the 0700 criteria.

9 Now, there are a couple of specific  
10 points I want to address.

11 The description of the design in 07007  
12 is just a description of the design. It's the  
13 control room layout and it's the physical  
14 characteristics of the HSIs.

15 The inventory, no matter how thoroughly  
16 it's described in 07007 I snot credited in that  
17 safety evaluation report.

18 In fact, there as a lot of RAIs back and  
19 forth asking for an explanation of whether these were  
20 real indication to be provided or not and the  
21 response, to my memory was, no, these are example.  
22 And, what we're telling is these are the functions  
23 that are displayed.

24 So, for example, you have safety  
25 functions across the top of screen 3 or 2 -- 2 or

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       3 -- well, we're not at the stage of the US-Basic HSI  
2       design, I'm not concerned with what specific safety  
3       functions are being used. That's something that's  
4       done in the COL review or in the operating plant  
5       review, depending on how this platform is used.

6               The same with the inventory. Reg Guide  
7       1.97 parameters Type A and B are a function that has  
8       to be provided because they require specially  
9       dedicated continuously visible indication. BISI has  
10      to be up there because it's a function that was  
11      described in this.

12             And so, the concept was that these are  
13      the functions that the large display panel is going  
14      to contain. The inventory will be developed in the  
15      subsequent licensing submittals. And, to ensure  
16      that happens, we added an action item that you'll see  
17      on page 35 of the SER that says the Applicant that  
18      uses this platform must provide a statement of how  
19      the inventory is going to be developed.

20             And, the inventory is defined  
21      specifically as the controls, displays and alarms  
22      that are going to be wedded with this platform.

23             So, I wanted to make sure that there's  
24      no misunderstanding here. If we wrote it wrong, we  
25      need to fix it. But, the inventory is not -- that's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 described is only by example and is not credited in  
2 the SER.

3 Now, having heard the discussion, there's  
4 a problem with the SER, I think. And, I missed one  
5 action item and that action item is any time you  
6 change your inventory, you need to do, in my opinion,  
7 an integrated system validation test to demonstrate  
8 that the inventory is satisfactory.

9 And, not only that, but positions on that  
10 large display screen can change. We are not looking  
11 at the positions as described in these -- in the  
12 displays that you've seen as being the licensed  
13 positions.

14 And so, those positions, depending on  
15 what inventory is identified, may need to change.

16 And so, that's one element of why you  
17 need an ISV.

18 The second element is that those -- the  
19 ISV-type testing that they did was not controlled.  
20 It didn't have the test plan that an ISV, an  
21 Integrated System Validation, as described by  
22 NUREG-0711 contains.

23 And so, it's my fundamental belief that  
24 the most important thing you and do to certify an HFE  
25 design is to demonstrate that it's effective in an

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Integrated System Validation setting. And, I would  
2 never write an SER that didn't require that as a  
3 final step in validating that the design works. And,  
4 unfortunately, I wrote an SER that did that and so,  
5 that needs to -- I need to go back and fix that.

6 CHAIRMAN STETKAR: For the Topical  
7 Report?

8 MR. PIERINGER: For the Topical Report.

9 CHAIRMAN STETKAR: Okay.

10 MR. PIERINGER: And, that's part of why  
11 I got confused is when I was working on Topical, I  
12 was thinking that, you know, the DCD followed  
13 naturally from that and I knew the DCD had an ISV.

14 CHAIRMAN STETKAR: And, honestly, Paul,  
15 that's why I've been militantly today trying to draw  
16 that line between the two because it's too easy to  
17 muddle the two.

18 MR. PIERINGER: Right. And, no matter  
19 how much Integrated System Validation type testing  
20 or a similar testing you did during the design phase,  
21 you can never do enough and I don't think you could  
22 ever control it enough to take total credit for that  
23 to basically certify the performance of your HFE  
24 design because HFE designs are too subjective for  
25 that.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1           They don't conform to a code like a  
2       mechanical system would. So, you can't predict  
3       performance that accurately. So, instead, you run  
4       the Integrated System Validation and you had a large  
5       number of tough scenarios with a variety of manning  
6       levels and all the rest that you read about in  
7       NUREG-0700 and you try and demonstrate it.

8           Now, I will tell you, I think we need  
9       some more work on what constitutes a good Integrated  
10      System Validation because I think, now that we've  
11      seen one, we realize there's some challenges to an  
12      Integrated System Validation that we didn't  
13      appreciate before.

14           MEMBER BLEY: Let me ask you a question,  
15      though. I agree with what you've said. On the other  
16      hand, what's your opinion of what you saw that they  
17      had done as a development tool for this moving the  
18      design from a Japanese design to a U.S. design?

19           MR. PIERINGER: Well, my take on their  
20      process, once I understood it, because I had the same  
21      problem you were with the Phase 1A, B and the multiple  
22      testing points.

23           But, once I got into those details, I  
24      thought it was the best program I've seen. And,  
25      actually, I think it's the model for a Phased

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Integrated System Validation program. And, that's  
2 what I mean when I say we have work to do on the ISV  
3 is the type testing they did to get from Japanese to  
4 1-Bravo needs to be part of the regulatory -- well,  
5 I don't know if it needs to be regulated, but  
6 definitely it needs to be part of the -- an industry  
7 standard that says this is how you develop an HFE  
8 design.

9 Because when you get to that final ISV,  
10 there's too many variables to control if you haven't  
11 done some ISV type testing previously.

12 And, with the unnamed predecessor who has  
13 done an ISV, that's what we're finding, they just had  
14 too many variables, too many problems they didn't  
15 know about and now it's placed a situation where you  
16 really have to ask the question, do we need another  
17 ISV?

18 Whereas, the MHI strategy gives me a high  
19 degree of confidence when they get to that final ISV,  
20 they will actually be testing a finalized design.

21 Now, in terms of specific controls and  
22 displays, I found them conforming to 0700. And,  
23 you've asked questions that have identified potential  
24 human factors issues that I didn't identify. 0700  
25 didn't bring them to my attention nor did my

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 experience.

2 And so, I didn't find --

3 MEMBER BLEY: When you asked about the  
4 slow-fast switch that says yes, that's a question  
5 that doesn't come up from the NUREG-0700 criteria,  
6 at least as best I could go through them and apply  
7 it.

8 But my position on that is that with an  
9 HFE design, I think there is the more you evaluate  
10 and the more you test it, the more you can find. I  
11 thought that this met some -- the minimum regulatory  
12 requirement for being applied as a basis for either  
13 a control room update in an operating plant or a new  
14 application in a COL type application, with the  
15 knowledge that, one, they're going to provide a  
16 description of how inventory is going to be developed  
17 and they're going to -- which means you have to do a  
18 task analysis. And they're going to do an Integrated  
19 System Validation.

20 So, those two contingencies are tightly  
21 woven into the logic for saying that this is an  
22 acceptable platform.

23 I think I just covered the next -- the  
24 Full Scope Simulator was used effectively in the  
25 design process. That's what I just spoke to.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           If we put guidance into place that talked  
2    about a phased ISV, we'd probably ask for more  
3    documentation of like scenario types.

4           But, from an -- just in the industry  
5    meetings we have, there's -- an ISV is very expensive  
6    to do it right. And so, if we over regulate all  
7    these interim ISV type testing, then you get into  
8    this balance of what do you do because it's the right  
9    thing to do and how do you make it cost effective?

10          And so, we're, at least in my opinion,  
11    we don't want to over-specify what needs to take  
12    place in these interim tests. But, we do need to  
13    makes sure that everyone is focused on doing a final  
14    test that meets the testing criteria from the 0711.

15          CHAIRMAN STETKAR: And, Paul, you know,  
16    again, it's a subcommittee meeting, so I only speak  
17    as an individual.

18          I fully agree with that. I think that  
19    what MHI has done, I perhaps would have been a bit  
20    more aggressive, for example, at trying to test  
21    elements of the system that could challenge the  
22    operators to have a little bit better confidence.

23          But, in terms of a regulatory  
24    perspective, trying to codify what should be done in  
25    a stage process, I think that -- and I honestly think

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       that would be very counterproductive.

2               I agree with you fully, at the end, you  
3       have to have some type of formal documented, well  
4       thought out ISV because that's the only way that you  
5       can essentially demonstrate to yourself and to  
6       regulators that you've achieved what you thought you  
7       were achieving, you know, all along.

8               But, trying to provide too much guidance  
9       for the -- I worry that trying to conform to that  
10      guidance at an intermediate stage would become an end  
11      to itself rather than the process that they used to  
12      actually challenge the design.

13              So, I don't know how to do that. I mean  
14      what they've done is right, as I said, I personally  
15      would have been a little more aggressive at trying  
16      to challenge the system but --

17              MR. PIERINGER: There were two areas I  
18      wanted to bring up and we're addressing them as part  
19      of the DCD, but I'm concerned that they may reflect  
20      back into the topical report and but we --

21              It's an interface between I&C and HFE.  
22      And the first is that they propose control of safety  
23      related equipment through the operational VDUs. And  
24      that challenges the independence as its currently  
25      applied in the Chapter 7 arena.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: Right.

2 MR. PIERINGER: And, we're trying to make  
3 a judgment as to whether the HFE improvements offset  
4 the reduction in independence. And, right now, we  
5 have not reached a conclusion. And a big driver in  
6 that is I don't understand all of the I&C challenges  
7 to independence.

8 And so, it's hard for me to make a  
9 recommendation on how that balances. Where the  
10 control operational VDU is warranted at the expense  
11 of the loss of independence. But, that's one we're  
12 working through with RAIs right now.

13 CHAIRMAN STETKAR: And, I guess I have  
14 to be careful about commenting, but I -- some of the  
15 questions that I was raising touch on that but not  
16 in the design criteria sense. Because I just want  
17 to make sure that nothing can -- I don't -- quite  
18 honestly, I'd really like to have the safety VDUs be  
19 able to draw -- pull up a mimic diagram. That would  
20 be great for the operators. But, you know, they're  
21 constrained.

22 The problem is, can, you know, what can  
23 happen out on the non-safety related stuff that can  
24 make things go funny on the safety area?

25 And the answer is, I don't know, but

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1        simply drawing a black solid block wall that say,  
2        okay, because we can't think of anything, you can't  
3        have it is probably counterproductive.

4                MR. PIERINGER:    Well, and that's the  
5        exact question we're trying to answer.

6                CHAIRMAN STETKAR:    Well, the question is  
7        then, how during the review process do you actively  
8        challenge, within the context of this design, those  
9        issues?    That's not an easy answer.    I mean that's  
10       not an easy question.

11               MR. PIERINGER:    But that is the question  
12       we're trying to answer between I&C and HFE is what  
13       impact can it have.

14               And, part of the issue is different staff  
15       have different opinions on that.    Some put more  
16       weight on independence and some put more weight on  
17       versatility and --

18               CHAIRMAN STETKAR:    Sure.

19               MR. PIERINGER:    -- just efficiencies.

20               CHAIRMAN STETKAR:    But, I'd hate for us  
21       to ever melt a plant in this country because we made  
22       something so independent and so simple that the  
23       operators couldn't use it when they were really in  
24       dire straits.    I'll just say that on the record.

25               So, this adherence to black brick walls

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       because that's the most expedient way to satisfy  
2       somebody's interpretation of some criterion doesn't  
3       necessarily make the world better or make it easier  
4       for the operators.

5               MR. PIERINGER:       Now I've got your  
6       perspective.

7               CHAIRMAN STETKAR:   And, again, that's  
8       just -- the good thing is we're a subcommittee here,  
9       so --

10              MR. PIERINGER:   The second point I wanted  
11       to make, and this -- and I'm not sure I caught all  
12       the discussion, but the BISI function, I'm sorry, the  
13       block function that you were discussing, to the best  
14       of -- we've had some internal discussions and there's  
15       an RAI outstanding but it's to my understanding right  
16       now, correct me if I'm wrong, but this block function  
17       that we're discussing does not interface with the  
18       BISI function.

19              And so, when you go to override, you  
20       don't get notification via BISI that you used this  
21       override.

22              Now, that may be wrong, but there's a  
23       question that's outstanding to try and resolve that.  
24       Because I don't understand how an override could not,  
25       by regulation, could not input to that generic alarm

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 on your large display panel.

2 CHAIRMAN STETKAR: And, in my state of  
3 knowledge, is from what I heard -- I couldn't figure  
4 it out which is why I asked the question.

5 From I thought I heard was that to do  
6 something over on the operational VDU to -- they use  
7 the term block, they use the term inhibit, they use  
8 the term of block, I'll use the term to make it not  
9 work. I needed to enable that function from a safety  
10 VDU and then go to the operational VDU and push on  
11 something that says make it not work.

12 MR. PIERINGER: But you --

13 CHAIRMAN STETKAR: And, when I did that,  
14 I would then get an indication that I had made it not  
15 work.

16 MR. PIERINGER: But, you were asking a  
17 question about post-actuation override.

18 CHAIRMAN STETKAR: And, that's part of  
19 it.

20 MR. PIERINGER: I'm asking the question  
21 about pre-surveillance support --

22 CHAIRMAN STETKAR: The alarm --

23 MR. PIERINGER: -- when you override  
24 the --

25 CHAIRMAN STETKAR: But the alarm

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 function shouldn't make a difference in my mind.

2 MR. PIERINGER: -- alarm function.

3 CHAIRMAN STETKAR: In the pre-action  
4 function, if I want to go in and I want to take Train  
5 A out of service, it's my understanding -- this is  
6 my understanding as a result of today -- that I go  
7 to the safety VDU for Train A. I enable -- take  
8 Train A out of service and I go over to -- I can on  
9 the operational VDU and block Pump A. Maybe it's  
10 only safety injection Pump A, maybe it's not the  
11 whole train. And I will get some sort of alarm up  
12 telling me that I've done that and that alarm will  
13 stay there as long as it's not operable.

14 Now, that's the pre. My understanding  
15 now in the post-world -- so I've got a LOCA going on  
16 and the operator, for some reason, wants to shut off  
17 Pump A that has been actuated, that the operator  
18 would have to go to the safety VDU, enable the block  
19 or lock or whatever it's called and then go to the  
20 operational VDU and stop it. And I'd get the alarm  
21 but, okay, I know I wanted to stop it in that case.

22 MR. PIERINGER: But I understand --

23 CHAIRMAN STETKAR: But that's state of  
24 mind.

25 MR. PIERINGER: -- the post-actuation.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 I'm just not certain of the pre-actuation alarm yet.

2 CHAIRMAN STETKAR: Okay.

3 MR. PIERINGER: I'm sure you get an alarm  
4 somewhere, but I'm like regulatory --

5 CHAIRMAN STETKAR: You don't know  
6 whether it's regulatory on the BISI?

7 MR. PIERINGER: The regulation says BISI  
8 needs enunciate -- overrides block functions of  
9 safety actuations. And so, it may be acceptable to  
10 have other alarms, but you'd have to make the case  
11 that those were as good or better than having in the  
12 BISI alarm.

13 So, I just want to make sure we're clear  
14 from a regulatory standpoint. And, I just mention  
15 it here because it's an outstanding interface with  
16 I&C.

17 CHAIRMAN STETKAR: Because, I mean quite  
18 honestly, the reason I ask about the BISI, the  
19 ability for the operator to understand what was  
20 bypassed and inoperable strictly from the safety VDU  
21 complement of displays was precisely for those types  
22 of concerns.

23 MR. PIERINGER: Okay.

24 CHAIRMAN STETKAR: You know, I would hope  
25 that the operators would get used to glancing very

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 quickly at some geographic area of their displays.  
2 If the non-safety stuff is available, it's on the  
3 large display panel in some geographic area up there,  
4 being able to quickly glance at it and, by pattern  
5 recognition or anything else, understand what's up  
6 and what's not up.

7 And, similarly, if that all goes away,  
8 if they only have safety stuff available by some  
9 other geographic pattern recognition, understand  
10 whether something's available or not.

11 And, I think we're saying the same thing,  
12 that if I have a safety train somehow, totally or  
13 partially disabled and it doesn't show up in that  
14 geographic area, that's a problem.

15 MR. PIERINGER: Yes.

16 CHAIRMAN STETKAR: Whether I do it pre  
17 or post, I mean I don't care about the timing of it.

18 MR. PIERINGER: The same --

19 CHAIRMAN STETKAR: Okay.

20 MR. PIERINGER: The same frame of --

21 CHAIRMAN STETKAR: And, you're not sure  
22 whether it will show up?

23 MR. PIERINGER: I just don't know yet.

24 CHAIRMAN STETKAR: Okay.

25 MR. PIERINGER: Right.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           I did want to speak to alarms and alarm  
2 navigation. And, I understood it a little bit  
3 different than the way it was characterized earlier.  
4 Because, when I did the audit of the Style Guide, we  
5 went through a lot of the learnings that had occurred  
6 during the testing and one of the learnings was,  
7 there were way too many alarms and operators were  
8 getting confused by the number of alarms.

9           And, when I said well, what are  
10 you -- and, at the point it was volunteered to me,  
11 and this is our action plan for addressing that.  
12 And, the action plan was to go back in and look at  
13 the alarm logic that's being used to drive the  
14 prioritization and also the mode dependencies and  
15 accident dependencies.

16           So, you literally strip out those alarms  
17 that don't tell the operator anything meaningful and  
18 the condition that it's in.

19           I found that where they were, and this  
20 is kind of an interim stage in the development, there  
21 were too many challenges. But, this was by their  
22 own characterization. And, when I followed up on  
23 that later to get more feedback on how they managed  
24 it, they had done a considerable amount of logic  
25 identification.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   Now, I will tell you that that doesn't  
2                   make it okay. It just gives -- it just tells me that  
3                   they're on the right track. What tells me it's okay  
4                   is the integrated system validation when the operator  
5                   has --

6                   CHAIRMAN STETKAR:   And, that's what I  
7                   was going to ask you, Paul. Because both aspects of  
8                   what you've been discussing bothered me as I read  
9                   through this, both the issue that I raised in terms  
10                  of three or four levels of priority of alarms  
11                  flashing as you drop level and raise pressure and  
12                  change levels or flows or whatever.

13                 And the operating being faced with a  
14                 continually evolving set of priorities of things that  
15                 pop up and he needs to go check them and acknowledge  
16                 them, which could divert his attention, to a  
17                 prioritization logic that is now so smart that it  
18                 knows precisely what the operator needs to know and  
19                 only what the operator needs to know and tells him  
20                 that information until he flies the plane into the  
21                 ground because he doesn't realize that he's losing  
22                 altitude because his pitot tube is blocked.

23                 Where during the -- now, I understand  
24                 from the Topical Report perspective that to have they  
25                 functionality to develop that type of -- a type of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 prioritization logic that will achieve some sort of  
2 balance between those two extremes is something that,  
3 perhaps, all needs -- that statement or that  
4 functionality perhaps is all that needs to be  
5 established the fact that it's there for approval of  
6 the Topical Report for this thing.

7 When and where, though, does that actual  
8 logic get tested? From what I hear you saying is it  
9 gets tested and you wait until the final ISV. Is  
10 that --

11 MR. PIERINGER: That's the only place  
12 that I have confidence that there is enough  
13 complexity to put the system under a test.

14 CHAIRMAN STETKAR: I mean, in some sense,  
15 it's like there could be an example, you know, in the  
16 Topical Report submittal like that -- what I'm  
17 learning to understand now like that example table  
18 of the parameters for the HSI inventory, it's a nice  
19 example, but I don't necessarily accept that as  
20 anything --

21 MR. PIERINGER: Right.

22 CHAIRMAN STETKAR: -- right now.

23 MR. PIERINGER: How far are they on this  
24 scale of alarm --

25 CHAIRMAN STETKAR: But, I mean that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 strikes me as a very, very fundamental and  
2 potentially really, really important part of the  
3 design process. Not hardware necessarily, but  
4 certainly integrated hardware/software operator --

5 MR. PIERINGER: It definitely is because  
6 in the ISV that's been done, it's not a hundred  
7 alarms, it's some scenarios had a thousand to two  
8 thousand alarms. And they were prioritized, but even  
9 with the prioritization, you were getting so many  
10 alarms that the operators either got lost trying to  
11 address them all and/or they stopped looking at --

12 CHAIRMAN STETKAR: In the Phase 1A or  
13 Phase 1B?

14 MR. PIERINGER: No, this was in the other  
15 real ISV that was done by somebody else.

16 CHAIRMAN STETKAR: Oh, oh, somebody  
17 else, okay. Okay, never mind. Okay.

18 MR. PIERINGER: Right. But, that's kind  
19 of the benchmark.

20 CHAIRMAN STETKAR: But, I mean that's  
21 symptomatic of these digital systems. You can have  
22 an alarm that, you know, a tenth of inch increment  
23 on level.

24 MR. PIERINGER: But, the difference  
25 being is that in this ISV that has been done, that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 feature of the design had never been tested before.  
2 They didn't know how many alarms they were going to  
3 get.

4 CHAIRMAN STETKAR: On the other --

5 MR. PIERINGER: On the other on.

6 CHAIRMAN STETKAR: Other one? Okay.

7 MR. PIERINGER: On the testing that MHI  
8 has done, they've done repetitive testing. They  
9 don't know the alarms for every scenario, but they've  
10 got a good feel for the number of alarms on complex  
11 scenarios.

12 So, when we look at the ISV, it will be  
13 with great attention to the diversity of the  
14 scenarios that they choose and with great attention  
15 to the number of alarms that are generated and  
16 whether -- and what categories are.

17 Because, not only did we see a high  
18 number of alarms generated, we saw alarms that were  
19 generated and needed priority one attention and  
20 didn't get it --

21 CHAIRMAN STETKAR: Oh, sure.

22 MR. PIERINGER: -- because they were --

23 CHAIRMAN STETKAR: Sure, sure.

24 MR. PIERINGER: And so, you get the  
25 inverse there, right? You get too many and then you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 get I didn't have the ones I needed.

2 So, I don't know any way to analyze that  
3 other than run scenario after scenario. And, that's  
4 why I credit their design program with the use of  
5 the, you know, with the integration of the simulator  
6 as being quite robust because they're testing alarm  
7 response on a very -- not -- well, I was going to say  
8 very frequent, but at least a more frequent basis  
9 than many of the others in the industry are doing  
10 that.

11 CHAIRMAN STETKAR: Provided that that  
12 testing program, as I said earlier, in my opinion, I  
13 would have kind of designed the ones that they did a  
14 little bit differently from a timing complexity  
15 perspective.

16 This is also timing complexity, but  
17 perhaps --

18 MR. PIERINGER: It's different.

19 CHAIRMAN STETKAR: -- different -- a  
20 little different to sort of challenge those things  
21 in particular to try to -- essentially to try to make  
22 the operators fail and see what threshold do you  
23 achieve that.

24 MR. PIERINGER: Well, actually, to that  
25 point, most -- the people who are testing are trying

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 to test until failure right now. So they -- and  
2 that's why you hear about these scenarios that  
3 go -- are beyond design basis even with multiple  
4 failures imbedded within the scenarios is, they're  
5 trying to do that and it does put a little bit of a  
6 twist from a regulatory perspective and we're trying  
7 to make sure it works and they're trying to drive it  
8 to failure.

9 And, that's where you get back to you  
10 point as the regulator can't over-regulate in this  
11 kind of testing that's going on.

12 But, nonetheless, that scenario  
13 testing -- the simulator testing to me is so  
14 fundamental that, you know, just from my personal  
15 perspective is like how can you approve a design with  
16 any credibility that doesn't have imbedded simulator  
17 testing? I'm that far to the -- in support of the  
18 simulator testing now.

19 But, right now, our --

20 CHAIRMAN STETKAR: Be careful, you're on  
21 the record.

22 MR. PIERINGER: Yes. But, right now,  
23 our program only calls for an Integrated System  
24 Validation Test at the end. So, that's the position,  
25 the regulatory position and we're actively

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 encouraging the use of the phased validation.

2 And so, we've had discussions with like,  
3 for example, NuScale who's still developing their  
4 program and I think they're looking carefully at how  
5 they can do similar simulator tests.

6 Those are the --

7 CHAIRMAN STETKAR: Hope you brought your  
8 walking shoes?

9 MR. PIERINGER: Pardon me?

10 CHAIRMAN STETKAR: I said, I hope you  
11 brought your walking shoes.

12 MR. PIERINGER: I did get it moved back  
13 15 minutes.

14 CHAIRMAN STETKAR: But, you are still  
15 under a clock here, so -- okay.

16 MR. PIERINGER: So, those are the  
17 comments that I had, the comments that I heard that  
18 I wanted to particularly comment on. And so, I think  
19 now would be -- I'll field any questions that you  
20 have.

21 CHAIRMAN STETKAR: I did, just for the  
22 record, I have not read it. Indeed, Part 3 of  
23 Revision 2 of MUAP-09019-P purports to document the  
24 Phase 1B testing.

25 MR. PIERINGER: Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   CHAIRMAN STETKAR: Program and results,  
2                   at least I -- and it's several pages. I didn't read  
3                   that version of that report because it didn't seem  
4                   to be used anywhere and in the version that's  
5                   referred to in the staff's review of DCD Chapter 18,  
6                   all of that information has been stripped out. It's  
7                   strictly the programmatic elements of what would be  
8                   done in the future.

9                   MEMBER BLEY: Now that you've said  
10                  that --

11                  CHAIRMAN STETKAR: I said that  
12                  purposefully to give you an in.

13                  MEMBER BLEY: -- it sounds as if, to  
14                  me, if we'd seen that, that would have led us to some  
15                  of the same questions, but at least we'd have known  
16                  it was there.

17                  I suspect a few pages isn't quite what  
18                  we're looking for, if we can get more to really  
19                  understand that process.

20                  MR. SPRENGEL: We agree. Yes, so we'll  
21                  continue to maintain our action to provide additional  
22                  detail in appropriate form as a result of this  
23                  meeting.

24                  CHAIRMAN STETKAR: That's all you have  
25                  on the Topical Report, right?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. PIERINGER: Yes, sir.

2 CHAIRMAN STETKAR: So, let's --

3 MR. PIERINGER: I mean I weave that in  
4 to the DCD discussion in terms how they interface,  
5 but that's --

6 CHAIRMAN STETKAR: So, essentially,  
7 we're at the end of our discussion on the Topical  
8 Report.

9 So any Members have any comments or  
10 further questions in the context of the Topical  
11 Report, everything that we've heard?

12 If not, then you all know how much  
13 material you have. I know how much I have. I think  
14 we can probably get through a shot at the DCD.

15 Paul, I don't like to do this in reverse,  
16 but if you think you can get through your stuff in  
17 about the time you have left, it would be really  
18 useful to have you physically here.

19 MR. PIERINGER: Let me give a chance.

20 CHAIRMAN STETKAR: So, why don't you try  
21 that?

22 MR. PIERINGER: Because actually, the  
23 way we set this up is that NHI was going to talk  
24 about the design, physical design. They've  
25 submitted implementation plans and I'm on Slide 5

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       now.     And those implementation plans have been  
2       reviewed and I'll just tell you, they meet all of the  
3       NUREG-0711 criteria as you would expect.

4               But, to get there, let me just comment  
5       that the design certification has very little  
6       information in it.   It really is intended to point  
7       to the implementation plan and what we do is we make  
8       sure that the implementation plan is sufficiently  
9       described, that it is included by reference so that  
10      legally it takes the status of the design  
11      certification.

12             The -- all the implementation plans were  
13      rewritten in the beginning of 2014.   And, I'll just  
14      be blunt and say the previous implementation plans  
15      were not of sufficient quality and we spent a lot of  
16      time to try and raise that quality to meet the  
17      quantification we needed under the deferred design  
18      concept and could not meet that and we issued a letter  
19      and said the quality is not sufficient.   Here are  
20      the problems, you need to work on the implementation  
21      plans.

22             They were rewritten.   We got brand new  
23      implementation plans almost basically from scratch  
24      on some of them.   That's why you see some results in  
25      some of the early versions.   But, those are partial

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 results. We could draw no conclusion from partial  
2 results.

3 CHAIRMAN STETKAR: You know, I --

4 MR. PIERINGER: One, because --

5 CHAIRMAN STETKAR: But, you couldn't  
6 from a regulatory perspective, but it sure as heck  
7 helped me understand what they had done, what they  
8 had found, what information they were using. And  
9 now, officially, we've lost, we the ACRS has  
10 officially lost that because we don't --

11 MR. PIERINGER: And, that's not --

12 CHAIRMAN STETKAR: -- those things are  
13 not referred to anywhere anymore.

14 MR. PIERINGER: And, that's not a problem  
15 with what MHI did. And it's not a problem with how  
16 the reviewers are working under the regulatory  
17 guidance. It's a problem with the fact that we've  
18 got DAC in place and DAC is -- and now, I do have to  
19 be careful about what I'm going to say -- DAC is  
20 making every feature of a DCD review much, much more  
21 complex and it's making the implementation of the DCD  
22 from a COL perspective much more complex.

23 So, for example, you need a referenced  
24 plant simulator to train operators on. You don't  
25 have a referenced plant simulator until you have a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 design built into the simulator and you don't have a  
2 design until you've finished all elements of the HFE.

3 So, if you defer HFE design, in  
4 particular, the ISV doesn't get done until late, you  
5 have no simulator to train operators on until that's  
6 done. And, that's the condition in some other areas.

7 CHAIRMAN STETKAR: But see, Paul, it  
8 strikes me as -- and I don't know who's doing it, so  
9 I won't point fingers at individuals, but it seems  
10 like people are adopting an absolutely all or  
11 absolutely nothing approach. To say that it's okay,  
12 I have to have absolutely all and, otherwise, I can't  
13 say anything so, therefore, I have absolutely  
14 nothing. All I have is a program.

15 MR. PIERINGER: But, we made a step jump  
16 because before you never would have seen the material  
17 that's in this Topical Report. That design would  
18 not have been provided.

19 CHAIRMAN STETKAR: Yes, but, for  
20 example, I had operating experience that they cited  
21 that I don't see anymore. I have interim results  
22 that may be partial of things that they had done that  
23 I don't see anymore because somebody has decided that  
24 everything was necessary so, therefore, I have  
25 nothing.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. PIERINGER: I understand and --

2 CHAIRMAN STETKAR: And that, to me, is --

3 MR. PIERINGER: So, we need to change the  
4 process so that if it's your intent to look at  
5 results -- let me start over.

6 It's our intent to look at results  
7 because we think 52.47 says the design has to be  
8 sufficiently complete to support construction,  
9 inspection and procurement. Well, it's very hard to  
10 do that unless you have detailed specifications that  
11 describe your design.

12 So, our intent is to say you cannot use  
13 DAC unless you can provide a positive statement of  
14 how SECY 92-053 applies. It basically says that  
15 technology is moving so quickly that you can't  
16 produce a design that would not be obsolete by the  
17 time you went to construct it.

18 CHAIRMAN STETKAR: Yes, but see, these  
19 guys are the first guys you've approached that they  
20 really do have a design. And, you can't deal with  
21 that.

22 MR. PIERINGER: Yes, and --

23 CHAIRMAN STETKAR: That's the problem.

24 MR. PIERINGER: But it was a year and a  
25 half for us to figure out that they were giving us a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 design. Right?

2 CHAIRMAN STETKAR: Pretty obvious to me  
3 the first time I picked it up. It looked like a real  
4 design.

5 MR. PIERINGER: It sure did, but it was  
6 a paradigm the reviewers were in. We compare  
7 everything to 0711 and so, when they gave us a design  
8 we said, wait a minute, what do we do with this? It  
9 doesn't say anything on 0711 about this. So, it took  
10 us a while to figure out that, hey, you know what  
11 does apply? NUREG-0700.

12 So, once we broke the paradigm down, it's  
13 like you're saying, it became very transparent about  
14 how to do the evaluations and what we should be doing.  
15 But, a paradigm is a paradigm. So, I mean that's --

16 So, what we're finding now, though, is  
17 that we're spending a tremendous amount of time  
18 trying to quantify the process being used to make  
19 sure that it's going to end up in a design that's  
20 safe that we're always the -- we're the lagging  
21 chapter in any DCD review, even to almost behind  
22 seismic and some of the other complex.

23 MEMBER BLEY: I suspect we're going to  
24 end up saying something about this, but if you guys  
25 can think this through a little bit more before a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 full committee meeting, then and have something -- a  
2 position that you might want to go further than  
3 you've gone today. We would appreciate that.

4 MR. PIERINGER: Okay.

5 MEMBER BLEY: But, we're probably going  
6 to say something close to the last thing we said on  
7 DAC in recent years.

8 MR. PIERINGER: That will be good.

9 You know, from my perspective, it's just  
10 not working well. So, I'll just leave it at that.

11 CHAIRMAN STETKAR: It's certainly in  
12 this case and I'll -- I know you have to go, but I  
13 want to get this on the record.

14 I was reading the original set of  
15 technical reports that are referred to in Rev 4 of  
16 Chapter 18 of the DCD.

17 MR. PIERINGER: Okay, yes, Rev 4.

18 CHAIRMAN STETKAR: Those technical  
19 reports not, you know. They're also referred to in  
20 Rev 5 of the Topical Report but not in Rev 6.

21 I was reading through those things and I  
22 said, gee, this is great. I understand we have a  
23 real design. It's not finished, final because I  
24 don't have parameter -- maybe I don't have a full  
25 parameter set. Maybe I don't have, you know, values

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 for level alarms and stuff like that. But, I can  
2 actually look at something. It's the first one I've  
3 had to look at.

4 And, indeed, I have some interim  
5 information on which I can develop some confidence.  
6 I know what people have done. I know what they  
7 haven't done. I know some basis for decisions that  
8 were made. Maybe I can raise questions about some  
9 of that, but I also recognize that that will be  
10 implemented going forward.

11 And, now that all of that information  
12 that made me feel really well has been removed from  
13 the process. I've essentially taken a step backwards  
14 in my mind from where this process was, where their  
15 approval process was because somebody wants to make  
16 it process oriented and not make a conclusion until  
17 everything is perfectly finished, which is after we  
18 get involved, as ACRS, which is in alignment, first  
19 of all. And it seems very unnecessary.

20 MEMBER BLEY: No, I think that's on the  
21 record.

22 The other thing is if staff is moving  
23 toward a position such as you indicated before, that  
24 at least in the future, you've got to really defend  
25 that it's moving too fast. That's absolutely

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 consistent with the policy on DAC and that would make  
2 me very happy.

3 MR. PIERINGER: I mean, the problem --

4 MEMBER BLEY: But, I think we've got to  
5 let you go.

6 MR. PIERINGER: The problem as I see it  
7 is, in 2008 when we reviewed it, we started ESBWR and  
8 AP1000 was pretty much done, but had a lot of DAC  
9 imbedded in it.

10 But, when we started ESBWR we should have  
11 enforced SECY-92-053. And, I think if we had done  
12 that, we would have ended up with a results-based  
13 submittal and then everybody who's filed subsequently  
14 would have filed with that model.

15 Unfortunately, we allowed at least three  
16 more applications to come in following the same 0711  
17 model which set a precedent which, to be honest, we  
18 didn't realize existed until we got the MHI submittal  
19 and it had design in it and then we started  
20 questioning, well, if they can do it, why can't  
21 others do it. And, that was the --

22 You know, so the paradigm of 0711 driving  
23 HFE into process space was broken when MHI submitted  
24 these. But, I tell you, it was -- I mean I was  
25 probably the most vocal advocate of this is an

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 unacceptable submittal that MHI is providing because  
2 it doesn't follow 0711.

3 And now --

4 MEMBER BLEY: Which was put in place to  
5 enable DAC. So, go ahead.

6 MR. PIERINGER: So, it's -- there's a lot  
7 of internal I guess I'd call it old perspective that  
8 got carried forward that we had to unlearn.

9 CHAIRMAN STETKAR: Paul, in the interest  
10 of time, I really, you know, I think we've got stuff  
11 on the record related to DAC, related to kind of our  
12 concerns, I know that you did want to mention things  
13 about the ITAAC, your second bullet here and Slide  
14 Number 6, so before you run --

15 MR. PIERINGER: So, the Generic ITAAC  
16 process was implemented to identify, to streamline  
17 and simplify ITAAC so that people could actually  
18 implement them consistently and effectively.

19 And so, besides that spelling error in  
20 the first sentence, our perspective was that really  
21 there were two essential elements. The first is you  
22 have to do a V&V and the V&V has to be done in  
23 accordance with a detailed implementation plan,  
24 testing plan, and that the NRC's going to inspect the  
25 results of that ISV against that implementation plan.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   And, our feeling is, is that that ISV  
2                   actually tests all the precursor elements of the 0711  
3                   process to a sufficient degree. It doesn't hit some  
4                   as hard as others. Like OER, sometimes you wouldn't  
5                   be able to tell from the ISV whether it got every  
6                   element of the OER review, but we still get a result  
7                   summary report. And if we chose to or think there's  
8                   reason to, we could look more thoroughly at any  
9                   individual element.

10                  So, because the ISV is really the measure  
11                  of effectiveness, we wanted to focus the ITAAC on  
12                  that.

13                  Now, the other thing we do is we don't  
14                  wait for the ISV to be completed and then inspect the  
15                  results. We actually inspect the performance of the  
16                  ISV.

17                  So, for the ISV that was performed, we  
18                  had a series of five inspections over, I don't know,  
19                  three or four months I guess because we looked at the  
20                  pre-ISV preps. We looked at three or four  
21                  inspections of the actual ISV performance. We will  
22                  go up in December and look at the post-ISV analysis  
23                  work and then we'll go up subsequent to that and look  
24                  at the HED closeouts. And that's directed by our  
25                  inspection plan.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1                   Now, if you read about these inspections,  
2                   they would be Westinghouse inspections. You may see  
3                   the word audit in there because this is done as a  
4                   vendor inspection, vendor audit, but the work is  
5                   actually done under an inspection.

6                   And then, the last ITAAC is just the  
7                   classic, once you construct the control room, you  
8                   inspect it against the criteria that you validated  
9                   in the ISV.

10                  CHAIRMAN STETKAR: As part of those  
11                  inspections or audits or whatever you want to call  
12                  the of the ISV process, to me, a key element is indeed  
13                  the selection of the scenario set that will be used  
14                  in that whole process and how well it does things  
15                  that I've been talking about earlier, challenges  
16                  elements of the design that are new or conceptually  
17                  different whether it's logical prioritization of  
18                  alarms or whether it's a physical layout of displays  
19                  of the ability to navigate or things like that.

20                  Is that part of the staff's inspection  
21                  or do you simply inspect that indeed they've selected  
22                  scenarios?

23                  MR. PIERINGER: It's neither one.

24                  CHAIRMAN STETKAR: Okay.

25                  MR. PIERINGER: We don't -- first of all,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 we make sure that the scenarios represent the scope  
2 required in 0711.

3 Now, some of that scope would include new  
4 technology, specialized systems, but the -- like we  
5 didn't explicitly go after alarm response and alarm  
6 support. It evidenced itself as part of the  
7 scenarios.

8 What we did make sure of is that the  
9 scenarios were complex enough that it would drive a,  
10 you know, high degree of interaction between the  
11 operator and the HSIs. And we weren't worried about  
12 operators failing because we didn't intend to test  
13 those. We really wanted to see HSIs failing so we  
14 could analyze whether there was a way to improve  
15 that.

16 So, a lot of our pass/fail criteria are  
17 pretty high levels at the thermodynamic requirements  
18 have been -- have you damaged the core is a classic  
19 one.

20 And, we allowed most of the criteria we  
21 inspected against were against the performance  
22 criteria which were geared at how can we make it  
23 better?

24 So, our best friends in the ISV are the  
25 operators because they don't tolerate things that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 don't help them. And so --

2 CHAIRMAN STETKAR: That's true. I mean  
3 that's easy to say, but on the other hand, if they're  
4 put into a situation, they don't get to select the  
5 scenarios by and large.

6 MR. PIERINGER: Right.

7 CHAIRMAN STETKAR: Right? They don't  
8 get to look at it and say, hey, please put me through  
9 the ringer on this particular set of things because  
10 I don't think it's going to work very well.

11 MR. PIERINGER: Right.

12 CHAIRMAN STETKAR: The people designing  
13 the ISV program do that, but, in many cases, those  
14 people may just be following guidance and yes, I have  
15 to have one of these. I have to have one of these  
16 over here, I have to have one of these over here so  
17 I have the right complement of things so that the  
18 inspectors can come in and say do you have one of  
19 these and yes, you do.

20 MR. PIERINGER: Just my opinion, but I  
21 think we're probably more closer to the we have to  
22 have one of these and one of these and one of these  
23 than we are of specifically formulating the worst  
24 case scenarios to test a certain feature of the  
25 design. I don't think we've matured to that point,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 but I'm just speaking of the scenarios I observed  
2 during ISV testing and the scenarios as they were  
3 written.

4 I will tell you, though, that every  
5 scenario I've seen exercised is extremely challenging  
6 beyond what you'd test an operator to. It's just as  
7 you're alluding to, John, does it focus on a specific  
8 challenge area that you perhaps think exists or maybe  
9 does exist? We're not that sophisticated in  
10 identifying those from a regulatory perspective and  
11 I don't think that -- MHI may have a different  
12 opinion, but I didn't see that in the development of  
13 the ISV that's been completed. It was more of the  
14 way you described it.

15 CHAIRMAN STETKAR: Okay.

16 Do you have anything more?

17 MR. PIERINGER: No, sir. In fact, I've  
18 covered a lot of the other points on the next slide  
19 in the discussions we've had.

20 The implementation plans I thought were  
21 very good once it was understood what needs to be in  
22 an implementation plan.

23 We talked about prompting alarms and  
24 alarm logic, detailed process discussion in the  
25 phased validation process. Those were the three

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 elements that I thought MHI brought new perspective  
2 and I would say energy to the design for the APWR  
3 that we hadn't seen in previous designs.

4 So, we found some weak areas but my take  
5 on it is just from having reviewed a number -- all  
6 the other -- all the previous design certifications,  
7 they had a much more disciplined approach or maybe  
8 they just described it better once we got the good  
9 descriptions.

10 And, the other thing I would say is they  
11 didn't keep their implementation plans to the  
12 regulatory minimum. So, you'll see the regulatory  
13 objectives listed in their criteria, but then you'll  
14 see they added some that they thought were needed and  
15 necessary.

16 And, from a reviewer standpoint, it's all  
17 the difference in the world. It's like, okay,  
18 they're not just trying -- you know that if they  
19 missed something it's not because they're trying to  
20 minimize the work they're doing, they just missed it  
21 because they've already embellished and built on the  
22 regulatory minimum.

23 So, that's really what I mean by detailed  
24 process descriptions there.

25 CHAIRMAN STETKAR: And, you did note that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 in the SER.

2 MR. PIERINGER: I would think, yes.

3 CHAIRMAN STETKAR: You did.

4 MR. PIERINGER: Good. And, that's all I  
5 have.

6 CHAIRMAN STETKAR: Thank you.

7 MR. PIERINGER: Sure.

8 CHAIRMAN STETKAR: Do any of the Members  
9 have any questions or comments for the staff?

10 If not, Paul, I'm really sorry. I hope  
11 you don't have to walk too much, scurry off. Thanks  
12 very much for accommodating us.

13 MEMBER REMPE: May we could -- if you're  
14 leaving to say thank you also. I thought your  
15 insights were very helpful.

16 MEMBER SCHULTZ: Yes, I agree, Paul.  
17 You've brought a lot forward and it should be very  
18 meaningful for not only the review but also the  
19 process issues that we need to address. Thank you.

20 CHAIRMAN STETKAR: Okay. And, Bill will  
21 fill you in later on what you need to do in the next  
22 week.

23 We'll have MHI come up and do whatever  
24 you need to do for Chapter 18. Pick up where we left  
25 off and continue from there.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Ryan, while you're getting set, I noticed  
2 the first screen up here is not particularly where  
3 we left off, whether you're doing that  
4 intentionally -- never mind. Thank you.

5 One of the things I'd like you to do if  
6 not - and I haven't skimmed through your slides yet  
7 and I know that this is now very much oriented toward  
8 implementation plans and programs, but if there are  
9 elements of the design that have been enhanced in  
10 particular for the US-APWR application, I think would  
11 be compared to what we spent most of today -- all of  
12 today so far talking about, we'd be particularly  
13 interested to hear about that, in addition to your  
14 plans.

15 MR. SPRENGEL: Okay.

16 CHAIRMAN STETKAR: Okay?

17 MR. SPRENGEL: For logistics, what is  
18 our plan? We have some restrictions on our staff at  
19 some point, so what is the meeting logistics?

20 CHAIRMAN STETKAR: I don't want to run  
21 any later than about 6:30.

22 MR. HALL: I'm going to have to leave  
23 here latest 6:00.

24 CHAIRMAN STETKAR: Okay. Well, you  
25 know, we have --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. HALL: Only because of a flight.

2 CHAIRMAN STETKAR: No, that's fine.

3 We've got an hour and three-quarters. I am not clear  
4 that there's all that much to go through, but let's  
5 see if we can do it.

6 MR. SPRENGEL: Well, are you going to  
7 start the presentation?

8 MR. HALL: I was going to.

9 MR. SPRENGEL: Okay. I have a few  
10 follow-up items.

11 MR. HALL: Go ahead.

12 MR. SPRENGEL: Okay.

13 CHAIRMAN STETKAR: Good to see you all  
14 again. If you have -- Ryan, if you have follow-up --

15 MR. SPRENGEL: Or we can put them at the  
16 end.

17 CHAIRMAN STETKAR: -- put them at the end  
18 because I really would like to not press Bob too much  
19 on his time. So, let's see if we can get through  
20 the straight line stuff and then do follow-up at the  
21 end.

22 MR. SPRENGEL: Okay.

23 CHAIRMAN STETKAR: And, even if we don't  
24 get to that, we can always communicate that some  
25 other way.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 MR. SPRENGEL: Not a problem.

2 CHAIRMAN STETKAR: Okay?

3 MR. HALL: Okay, what we're going to do  
4 now is shift focus a bit. We're going to shift to  
5 the DCD and we're going to start talking about  
6 process rather than design.

7 Just want the NRC's discussion just said  
8 is maybe not the most important thing. The design  
9 was one of the critical paths.

10 The key is that the process we're going  
11 to talk about has been really fine-tuned to address  
12 the review criteria within 0711, and that's what Paul  
13 was talking about as well.

14 However, it's been applied throughout the  
15 basic HSI design as well as being applied and will  
16 be applied to the US-APWR.

17 So, we're going to start going through  
18 process now. Some of these are the documents where,  
19 you know, some of the details were stripped out, the  
20 results, and what we agreed to with discussions with  
21 the staff a few days ago is my slides do not go  
22 through each and every process.

23 I don't have slides on task analysis, how  
24 we're doing it or whatever. So, if you have  
25 questions will address that in an open forum.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           What we're going to do is just talk about  
2           the HFE program management plan. That's the first  
3           overarching plan that all the other implementation  
4           plans fall into. It's the management scheme for the  
5           human factors program. It summarizes the human  
6           factors program.

7           And, what I'll do since we've talked  
8           somewhat about a number of these slides already is  
9           I'm going to quickly jump through them so you stop  
10          me when I say I think we've covered this if you need  
11          more information and I'll try to, based on the  
12          questions, elaborate a little bit more than I was  
13          planning to on some of the things that has and will  
14          be done. Make sense?

15          So, there's a little bit of a change from  
16          where I was headed. So, let's go to the first one.

17          Okay. We talked about that we did, in  
18          fact, do the basic design and are working on the  
19          US-APWR design and all the implementation plans,  
20          NUREG-0711, Rev 2. The process meets that.

21          What we've intended to do is to basically  
22          take Rev 2 and where we saw it needs in the process  
23          to expand it, we've added additional parts to Rev 2.  
24          So now, Paul was talking about specifics and  
25          methodology we did such as goals and objectives, but

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 we've also gone beyond what the 0711 Rev 2 requires  
2 because we felt it was needed.

3 So, I'm going to touch on those. I think  
4 it might be in the next slide.

5 So, the next two bullets on this are kind  
6 of just generic statements so I'm going to slip to  
7 the next slide.

8 You've seen this before. It's been  
9 presented to you up in the very beginning. These  
10 are the elements of 0711 so there is a technical  
11 report on each of them.

12 The first one is the PMP, the rest of  
13 them are the implementation plans.

14 0711 calls the PMP, the Project  
15 Management Plan Implementation Plan 2, but you get  
16 tongue tied with so many plans in a sentence.

17 So, this is the HFE program. We talked  
18 about -- I'm going to jump now to operating  
19 procedures and training. Right here, then we wrote  
20 that out because it's important to note that early  
21 on, we had implementation plans for both of them.

22 During the maturing of the thinking on  
23 this and discussions with the NRC on RAIs, they were  
24 then withdrawn and bounced over to the review of  
25 Chapter 13.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   However, by withdrawing them, that does  
2                   not mean the human factors program does not address  
3                   training and procedures.

4                   And, the way we've addressed it is within  
5                   the other implementation plans, when information  
6                   comes out of the plan as a result, we talk about the  
7                   process by which it gets to the training development  
8                   people when it needs to and how it gets to the  
9                   procedural development people and how the human  
10                  factors people then review it and make sure those  
11                  findings from these various pieces of the program  
12                  were addressed in the final procedures and final  
13                  training.

14                  So, when we look at this, remember that  
15                  the review process isn't here.     There aren't  
16                  documents in Chapter 18 related to this, but within  
17                  the documents we do point to how human factors brings  
18                  its information in the robustness of the analysis  
19                  into that process and then how it reviews it at the  
20                  back end.

21                  The next thing I'll mention on this, and  
22                  this is some of the expansion I think I'm doing that  
23                  I wasn't planning on doing, is the OER, we said has  
24                  been done once during the basic analysis.   It was  
25                  done prior to that within the Japanese analysis.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           It will be done again and is being done  
2           again during the US-APWR analysis and that's because  
3           it's constantly changing and this process is  
4           occurring over years and we want to make sure we get  
5           the most current information into the process. And,  
6           it was answered earlier today that that information  
7           is nuclear as well as non-nuclear. And the reason  
8           we brought non-nuclear to the table is we don't in  
9           this industry have a lot of highly automated digital  
10          systems experience, but other industries do.

11           So, we've searched databases and brought  
12          that information in where we looked -- that where it  
13          looked like it was applicable.

14           I'm going to jump down --

15           MEMBER BLEY: Before you jump down.

16           MR. HALL: Okay, I'm sorry.

17           MEMBER BLEY: What I wanted to tack on  
18          was just to draw the tie back to the basic HSIS. As  
19          you progress through the evolution of the HFE  
20          elements and move toward fully developing the  
21          procedures and all of that sort of stuff.

22           Will you be bringing the simulator that's  
23          up at Cranberry into the US-APWR realm and is that  
24          going to be the base place where you do all this  
25          testing or is that going to happen somewhere else

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 with some other?

2 MR. HALL: I don't know the answer to  
3 that.

4 MR. MASHIO: So, Cranberry, just  
5 basically was tested in Cranberry -- it was  
6 Pittsburgh but --

7 It depends on the whether application  
8 of -- if we have a Comanche Peak, proceed. So, this,  
9 based on this, this is tied with actual data. So,  
10 if Comanche Peak in progress, at least to construct  
11 the use there. This is the Comanche Peak area.

12 So this kind --

13 MR. SPRENGEL: The basic answer is there  
14 is no current plan --

15 MR. MASHIO: There's no current plan.

16 MR. SPRENGEL: -- for how we would  
17 proceed. So, there are intentions based on --

18 (Simultaneous speaking)

19 MR. SPRENGEL: Correct. Right. As we  
20 noted at the beginning, the US-APWR design review is  
21 in a slower pace and the Luminant Comanche Peak site  
22 has suspended their COL application.

23 So, right now, there's no clear path to  
24 anything. The intent, obviously, would be to  
25 continue to refine and iterate, I think Paul

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 mentioned some of that activity. But, the intention  
2 would be to continue to refine and implement and  
3 iterate and continue to develop over time rather than  
4 waiting until the end.

5 CHAIRMAN STETKAR: Let me ask a couple  
6 of questions here because you mentioned operating  
7 experience, so let me -- I want to make sure that by  
8 the time all of this stuff comes to the ACRS full  
9 committee that we had a coherent set of information.

10 So, now, I'm going to start talking about  
11 US-APWR DCD Chapter 18, in particular, and in the  
12 current version of the US-APWR Chapter 18 DCD, it  
13 makes reference to operating experience. And,  
14 indeed, it makes reference to a technical report that  
15 apparently doesn't exist anymore, but, you know, I  
16 read it.

17 And it says, well, we took credit for all  
18 of this Japanese operating experience. And I looked  
19 at all of that Japanese operating experience and  
20 there were ten events in there that dated from 1978  
21 to 1993 which strikes me as being perhaps somehow  
22 relevant to digital system, but maybe not so much.

23 So, I'm curious when you say going  
24 forward you're going to include operating experience,  
25 it -- I don't know what you're going to do there.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   Now, from the staff's perspective, and  
2                   because of the timing this afternoon, I'll just beat  
3                   them up here. In the SER on operating experience,  
4                   there's a quote that says the staff performed a  
5                   complete element level of review as described in  
6                   NUREG-0711 in Section 18.0.4 of this report in  
7                   operating experience. Hard for me to now understand  
8                   how you performed a complete element review of that  
9                   operating experience where, (a) it's incomplete and  
10                  will be completed in the future.

11                  So, now I don't understand how I  
12                  interpret the staff's conclusion that the operating  
13                  experience is perfectly acceptable for the design  
14                  certification because it can't be because we just  
15                  heard it's incomplete.

16                  So, now I don't know how the SER lines  
17                  up with the thing that the SER is even supposed to  
18                  be reviewing which is not the thing that is submitted  
19                  in Rev 4 of the DCD.

20                  Can you -- I don't know, somebody help  
21                  me here?

22                  MR. WARD: Yes, I was going to say that  
23                  the review is on the plan, not necessarily on all the  
24                  details. So --

25                  CHAIRMAN STETKAR: I'm sorry, if it was

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 on the plan, it would be an implementation plan level  
2 of review. It would not be a complete element level  
3 of review. There were only a couple of parts where  
4 you said you did a complete level of review,  
5 operating experience being one of those.

6 MR. WARD: Okay, I will get back --

7 CHAIRMAN STETKAR: The other ones are  
8 carefully couched in the phrase that we did an  
9 implementation plan level IP level of review and you  
10 conclude that the plan looks like it's okay going  
11 forward.

12 But, in this one in particular, you did  
13 the complete review. And it's documented as such  
14 and it's acceptable.

15 MR. WARD: There may be a question as to  
16 how much was acceptable, whether or not the amount  
17 of OE that was provided was considered acceptable  
18 or -- but we'll have to take it back.

19 CHAIRMAN STETKAR: I didn't see any  
20 dangling things there saying it didn't seem  
21 completed. The staff was pretty happy with it. I  
22 don't have the quote from it, but there were two  
23 items and I don't want to belabor it here.

24 One was operating experience it  
25 was -- where it was one other element of the HFE

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 program that was characterized as a complete element  
2 review. And, obviously, that can't be complete  
3 either because none of it's complete yet. It was  
4 almost there, but we backed away from that.

5 So, by the time it comes to the ACRS full  
6 committee, it would be nice to have the SER, even  
7 though the current SER purports to be timely and  
8 consistent with the 2014 level of documentation, it's  
9 not clear that it is either.

10 I'm done.

11 MR. HALL: Okay. Let me then continue  
12 and what I wanted to mention is the FRA and FA and  
13 the task analysis two limitation documents are very  
14 extensive process oriented implementation plans.

15 The approaches we're using start from  
16 scratch. It doesn't start from a predecessor plant  
17 that doesn't make the assumption that the FRA/FA was  
18 done with the Japanese plan. It starts from ground  
19 zero.

20 And, both of those methodologies and both  
21 of those IPs are quite extensive. And, what we chose  
22 to do was to, in those documents, include directions  
23 to the people that were going to use the tables.

24 These tables, if you looked at it, are,  
25 you know, multi-pages long almost and we wanted to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 put enough information in it for our own use, but  
2 also for the review as to understand how this  
3 methodology would be applied and how, in fact, you  
4 would fill out the tables, make the numerical  
5 estimate, do the averaging, et cetera, et cetera.

6 So, those two documents are  
7 implementation plans, but they do, in fact, go to  
8 more detail because we wanted to make sure that we  
9 documented how we propose to use the tabular-type of  
10 analysis.

11 Another interesting thing in what we did  
12 is the HRA. Rev 2 of 0711 asks for the process to  
13 make account for important or risk-important human  
14 actions from Chapter 19, basically.

15 And, we decided that, yes, we would do  
16 that. In fact, we're extracting, have extracted the  
17 important, risk-important human action as a critical  
18 sequences, et cetera, et cetera from the PRA, from  
19 the HRA.

20 But, we also decided that there are other  
21 parts of the design process that are important when  
22 you're talking about important human action, not  
23 risk-important human actions necessarily.

24 So, the HRA IP and the process that'll  
25 be used by Mitsubishi looks at risk-important as well

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 as deterministically-important human actions.

2 So, the human actions that come out of  
3 that element and feed into the rest of the analysis  
4 come from Chapter 19, Chapter 15 and Chapter 7. So,  
5 another example of where we felt we needed to go  
6 further than what the guidance is in Rev 2 of 0711.

7 And that's what it should -- and that's  
8 the discussion in the IP. I believe the IP still  
9 says HRA, but when you read the text, you'll see that  
10 the deterministic has been added to that.

11 CHAIRMAN STETKAR: And, I did it and it's  
12 very clear in there.

13 MR. HALL: Okay.

14 CHAIRMAN STETKAR: And the reasons for  
15 it --

16 MR. HALL: Okay.

17 CHAIRMAN STETKAR: -- being rolled in  
18 there is very clear.

19 Just to make sure, that element of the  
20 human factors engineering is not yet complete, is it?

21 MR. HALL: That's correct.

22 CHAIRMAN STETKAR: You're an excellent  
23 straight man.

24 The other element of the SER that  
25 received a complete element review was the human

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 reliability analysis. And I will quote here because  
2 I have the quote.

3 The staff concludes that the important  
4 HAs are appropriately identified and integrated into  
5 the HFE design process. Human error mechanisms are  
6 adequately addressed in the HFE design and provides  
7 reasonable assurance -- reasonable assurance -- that  
8 the likelihood of personnel error is minimized and  
9 that errors are detected and recovered from.

10 The staff concludes that the HRA  
11 considerations with respect to HFE have been  
12 adequately addressed and that the requirements in 10  
13 CFR 50.34(f) and 10 CFR 52.47 related to this  
14 technical area are satisfied.

15 Interesting. This is the SER that's done  
16 to the 2014 Implementation Plan that hasn't done  
17 anything yet. But the staff is satisfied that what  
18 was done was complete and I have adequate assurance  
19 that operators are not going to make any errors with  
20 this design.

21 So, I'd strongly suggest that the staff  
22 go back and look at the SER and see what conclusions  
23 you can draw about these areas where a complete level  
24 of review of something is done when that something  
25 doesn't exist.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. WARD: Understood.

2 MEMBER BLEY: I'd go back to what Bob was  
3 talking about and make two comments.

4 The first one is, the HRA can't be real  
5 good at this point because we haven't got the other  
6 things to support it like the procedures and the  
7 operators and the simulator, which is a good reason  
8 to look more broadly.

9 The language, we found them  
10 deterministically leaves me wanting a little bit. I  
11 don't know what the heck that means. I hope that  
12 means that you've thought about things that might not  
13 have been reflected in the HRA and expanded your  
14 thinking. And that isn't quite deterministic but  
15 it's a search kind of idea.

16 MR. HALL: It is a -- it's a soul  
17 searching. You're right about the HRA, but remember,  
18 all of these, and that's one of the strengths but  
19 also confusing parts of this process go around.

20 I mean if you're looking at the HRA or  
21 important human actions, or OER was another question,  
22 you've got to decide when you snap the camera because  
23 it's that ongoing process.

24 And, the HRA -- I'm sorry --

25 MEMBER BLEY: I was actually

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       complementing you on what you've done, but just  
2       fussing about that one word.

3               MR. HALL:    Oh, thank you, thank you,  
4       thank you.

5               CHAIRMAN STETKAR:   Part of this --

6               MR. HALL:    I won't answer a question that  
7       was not asked.

8               CHAIRMAN STETKAR:   -- though is, the HRA  
9       and the PRA are not -- right now, they are what they  
10      are.  I'll just leave it at that.

11              The PRA has not done a seismic risk  
12      assessment.  It's done a very simplified assessment  
13      of low power and shut down modes.  It has not  
14      factored in what may be plant and site-specific types  
15      of design features, for example, ultimate heat sink  
16      cooling water systems, interfaces with electric power  
17      supply, flooding mitigation, external flooding  
18      mitigation and so forth.

19              The list of important human actions that  
20      are derived from a Capability Category 1 PRA that's  
21      done largely for internal events during full power  
22      operation may morph very significantly if you did a  
23      full scope PRA as is required before you load fuel,  
24      accounting for all of the contributors.

25              So -- and you might discover something

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 in the human system interface design that you didn't  
2 think about for all of those operator actions that  
3 are now much less important than the things that  
4 popped up.

5 So, this, again, reinforces the notion  
6 of the fact that it is an evolving, you don't want  
7 to use the term iterative of evolving process, but  
8 you don't know what that inventory of important human  
9 actions is even from the risk assessment until you  
10 really have a risk assessment and you don't have one  
11 yet.

12 MR. HALL: It should also be noted  
13 that --

14 CHAIRMAN STETKAR: You have something  
15 called a risk assessment right now, I don't want to  
16 imply --

17 MR. SPRENGEL: We understand your  
18 concerns.

19 CHAIRMAN STETKAR: You don't have the  
20 risk assessment that is required sometime between COL  
21 and fuel of --

22 MR. SPRENGEL: Yes.

23 MR. HALL: And, part of this process, and  
24 I'm talking about the overall human factors process,  
25 is to attempt to take -- let me back up a minute.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 Paul talked about some of the limitations  
2 of 0711 and, having been one of the authors of the  
3 original 0711, I think it's only justice that I'm now  
4 trying to figure out how to meet 0711. I think  
5 that's critical. The old what comes around or  
6 whatever.

7 CHAIRMAN STETKAR: Your children will  
8 come back to haunt you.

9 MR. HALL: What we tried to weave into  
10 this is 0711, because it's an engineer's view of  
11 this, makes all these separate little categories when  
12 really this is an integrated process.

13 The difference between an FRA, FA and a  
14 TA, you've got to kind of draw a line. It kind of  
15 flows from one to the other.

16 So, and what you have to do to meet 0711,  
17 is you've got to pull them apart which is really not  
18 the best thing to do, but we've attempted in the IPs  
19 to make it so that we clearly defined how these  
20 various elements communicate.

21 And, in the important human actions, or  
22 what's called HRA, part of that is to confirm what  
23 is included in Chapter 19, included in Chapter 15 and  
24 Chapter 7.

25 And, what I mean by that is, the output

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 of the TA, for example, are going to be lots of  
2 detail, not only on inventory, but on operator-type  
3 events for the types of scenarios we just said might  
4 be missing in the current PRA.

5 The process is that the HFE program then  
6 is going to feed that forward into the PRA team to  
7 start looking at some of these things that come out  
8 of the analysis of task analysis, for example.

9 So, this truly is iterated into the  
10 overall process and we've attempted in the PMP to  
11 build in the management rules that enforce this  
12 interlocking of the various elements and this design  
13 process into the rest of the design process, you  
14 know, the I&C, the systems design, et cetera.

15 What I wanted to do now is jump quickly  
16 down to V&V and, again, just to go into a little bit  
17 more detail based on the interest of the committee  
18 and say that I mentioned earlier that the testing as  
19 it's described in the implementation plan grew out  
20 of what we did for that Phase 1A, Phase 1B testing.

21 So, it was a lessons learned and, as Paul  
22 described, those tests, especially the first one, a  
23 little bit less the second one, weren't quite as  
24 controlled as an integrated system validation is  
25 because we weren't claiming they were.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   This V&V standard, the IP now, attempts  
2                   to put those controls in place that allow us to get  
3                   to this completion of the ITAAC that Paul was talking  
4                   about.

5                   Within the V&V we also, although the  
6                   NUREG-0711 does not request or require the idea of  
7                   what scenarios will look like, we've learned very  
8                   quickly from the tests we ran that the tires of this  
9                   car, the rubber meets the road piece of the V&V  
10                  program of the ISV, is really buried into the  
11                  scenarios.     What's there, what data are you  
12                  collecting?   What is the detail?   Who's doing what?  
13                  What should you be looking for as observers, et  
14                  cetera?

15                  So, we included, although it's not asked  
16                  for by the NUREG, we included three example scenarios  
17                  in the back just to give you a sense of the level of  
18                  detail of what we would have in these.

19                  This is not one-page long.   It's quite  
20                  extensive just to, again, give you the flavor of when  
21                  all these other things in the V&V implementation plan  
22                  are done, this is what they end up looking like.

23                  And, in that, it clearly identifies  
24                  events that were deemed to be significant for this  
25                  design that come out of OE.   It clearly identifies

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 events that have come out of the important human  
2 actions.

3 And, there is a table in the document,  
4 in the IP, that shows all the various selection  
5 criteria that are used to go into the scenarios and  
6 the testing and almost a check list for the people  
7 developing the scenarios as to whether or not OERs  
8 were, in fact, looked at down the line.

9 So, there is the attempt to capture this  
10 stuff in scenarios imbedded in the ISV. And, in  
11 fact, identify where we feel, or the team that does  
12 this, the various important actions or actions coming  
13 out of OE are, in fact, being tested within the  
14 scenarios.

15 It may not be perfect, but we are trying  
16 to make it so it's trackable and we don't miss  
17 anything.

18 Referring to missing anything, and again,  
19 I'm taking more time in this, but I'm going to go  
20 very quick on the other slides, each of these  
21 documents has an appendix. I don't remember the  
22 appendix number. But, I'm sorry, it's actually a  
23 section of the document which I think it's called a  
24 compliance matrix.

25 What we did as we were developing these,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       because, again, 0711 is very explicit with the  
2       criteria one has to meet, we used the check list to  
3       make sure that we had everything addressed and  
4       addressed adequately when we did the independent  
5       reviews of each of these IPs.

6               That check list was part of the process  
7       or the methodology we used to build the IP, turned  
8       out to be of, we felt, enough importance to clarify  
9       what was in the document that they're now included  
10      in each of the IPs.

11             So, if you looked at that original list  
12      that Ryan pointed out of the outline of each of these,  
13      you'll see a section, I think it's called compliance  
14      matrix, and that's basically what that is. That was  
15      our internal tool to make sure we didn't miss  
16      something that, in fact, we put in there to help to  
17      review the documents that we put forth.

18             Okay, so that being said about the  
19      individual elements, I'm going to move on to the next  
20      one and it'll go a little bit more into the management  
21      plan.

22             We put this up -- yes, we put this up  
23      earlier so you've seen it. We kind of talked around  
24      it a lot. I think you understand what happened, so  
25      I'm going to talk to it a little bit about where the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 HFE program fit and where it fits as we move forward.

2 But, I'm going to do it fairly quickly,  
3 so, again, if you have more questions, drill me down  
4 harder, please.

5 The program's been developed. The  
6 program has been applied to the basic HSI. The  
7 program is and will be applied to the US-APWR and the  
8 program is applied to the US-APWR with a basic  
9 assumption, we start with the design from the basic  
10 HSI. So, that's the starting point of this design  
11 and we're going to change it as we finish up all  
12 these analyses.

13 And, the reason was we did not want to  
14 wait until the end to have a design to look at and  
15 then apply all this stuff to.

16 During the design of the basic HSI, we  
17 talked, I believe, enough about the Japanese design  
18 input to it. The table -- an early version of  
19 tabletop task analysis was done to go into the  
20 testing program.

21 OER was done to go into -- the early  
22 version of OER was done to go into the testing  
23 program.

24 We did, in fact, look at the early and  
25 risk important human actions. They are by no means

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 completed. And that's how we developed this center  
2 box which talks about the operator assessment.

3 Those are the tests and those are  
4 the -- those are the tests that were conducted in the  
5 first series of tests we ran, that 1A testing scheme.

6 As I said earlier, everything that has  
7 been done and will be done will result in an HED  
8 which is another example of going beyond what 0711  
9 says because, to change how you report data on these  
10 tests and on these analyses, we felt didn't make much  
11 sense later in the game so we wanted to develop the  
12 database early and track it through the design.

13 Those HEDs were, in fact, processed.  
14 They were processed as described in the documents you  
15 have. That second large box is the second series of  
16 tests that were done. That's the Phase 1B testing  
17 which then rolled out to the basis HSI.

18 Now, that's what we talked about this  
19 morning. Those tests were done as close to the early  
20 versions of the V&V, for example, as possible. Those  
21 tests not only included dynamic testing, it included  
22 verification. I said we did early because the task  
23 analyses were not done at that time.

24 We did early, with operators, tabletop  
25 walkthroughs of the simulator looking at what a task

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 would look like. And, I'm by no means saying it's  
2 reported as final results. And, in fact, did the  
3 task level evaluation of what would be needed by an  
4 operator, the kinds of data that needed, showed up  
5 either on LDPs or on the screens.

6 And, we took the Style Guide that we had  
7 and used the style guide to, again, evaluate that the  
8 screens we had, the displays we had, met the Style  
9 Guide.

10 I must admit we did it to about 25 percent  
11 of the screens but when you look at the number of  
12 screens that was a large number we did. So this  
13 testing we talked earlier about was -- we talked  
14 about the dynamic testing, the testing using  
15 operators and a simulator, we also sat down and  
16 looked at colors and made sure they met color charts,  
17 looked at sized of text and that kind of stuff on a  
18 sampling basis.

19 So, that's what went into the basic HSI  
20 and, again, what helped us write the V&V  
21 implementation plan.

22 Now, we're in that green element on the  
23 bottom and the human factors program fits in that  
24 center box. The OER, the FRA, FA and, by the way,  
25 the OER, FRA, FA and TA are started. The OER is I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 believe significantly done. I think the thing that's  
2 left is the documenting of the report but we'd have  
3 to check on that.

4 So, that work has started. That's where  
5 it fits in that bottom process. I may add, like with  
6 all flow charts, we make a lot of simplifications so  
7 that we don't have a spider diagram up here. So,  
8 please, there are feedbacks and loops and, you know,  
9 lots of lines are missing from this just to show more  
10 of a linear type process.

11 That then ends up, especially at the task  
12 analysis, with this HSI inventory that's missing from  
13 the basic that we talked about. Remember, the task  
14 analysis is where we identify whatever's been  
15 assigned to the human. Can the human do it? Is  
16 there enough time for them to do it? Are they under  
17 too much load to do it? And if they do it, what do  
18 they need to do it? What are the displays and what  
19 are the control systems they need to perform those  
20 things?

21 I may add that that task analysis again,  
22 feeds back to the system designers, if you understand  
23 the way a large plant is designed, through the HED  
24 process. If a system is being designed and we find  
25 instrumentation is being proposed that's not used

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 from the task analysis or instrumentation is not  
2 being proposed for a system, the task analysis says  
3 is needed, well HEDs are written and then there's a  
4 compliance-type review to see how the system design  
5 might be changed.

6 That, between the US-APWR inventory and  
7 any site specific changes that might be needed and  
8 this would, again, require a COL applicant to the  
9 table, moves forward and becomes what we would call  
10 the final HSI US-APWR HSI.

11 It's that final design that then goes  
12 into the V&V and the ITAAC -- and the ITAACs of the  
13 V&V and the design implementation as described in  
14 those two implementation reports.

15 Now, across the board on these, we are  
16 living to the 0711 requirements that we're supplying  
17 the implementation plans for review and when the work  
18 is done will, in fact, submit to the docket the result  
19 summary reports. Those are the two pieces of  
20 information that 0711 require.

21 So, each of these elements, with the  
22 exception of the management plan will, in fact, have  
23 a results report submitted when the work is  
24 completed.

25 CHAIRMAN STETKAR: And, just for my

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 curiosity, when in process will that be done? Will  
2 it be done prior to certification of the design?  
3 Will it be done prior to issuance of the COL? Or  
4 will it be done prior to fuel load?

5 MR. SPRENGEL: Prior to fuel load.

6 CHAIRMAN STETKAR: Thank you.

7 MR. HALL: Okay, now, we had a lot of  
8 discussion on this earlier and, hopefully, I didn't  
9 confuse anything, but that's kind of what it looks  
10 like.

11 Okay, I said the program plan, the  
12 management plan, attempts to put forth how we're  
13 going to run this thing? How is Mitsubishi going to  
14 run this thing? And will the human factors program  
15 have enough clout to get anything changed in the  
16 plan?

17 And, I've got to admit, historically, one  
18 reason why we at Brookhaven moved forward on the  
19 early 0711 was really to drive having human factors  
20 looked at seriously and really considered in an  
21 overall design. That's my little sidebar statement.

22 MEMBER BLEY: We had John O'Hara in here  
23 a few years ago telling us the history.

24 MR. HALL: Okay, that's fine. Yes, John  
25 used to work for me.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 So, that's what it's all about.

2 So, we wanted to make sure in the plan  
3 that we could demonstrate how this team functioned,  
4 how it was organized because there's multiple company  
5 organizations, if a Mitsubishi organizations are fit  
6 together, and what the roles and responsibilities.

7 And, if I was to rewrite this view graph  
8 today, I would put comma and authority of the team  
9 is because the document clearly talks about who  
10 within this team has the ability when the design is  
11 maturing to, and I'm going to use the term, stop work  
12 on the design, or hold the design because the human  
13 factors input hasn't showed up in the design, hasn't  
14 been looked at seriously, has been ignored, whatever.

15 So, there's the ability of this team at  
16 the management level that has the ability to direct  
17 this design to consider human factors. Okay?

18 So, I think that's an important issue  
19 here.

20 It also, I mentioned HEDs, and therefore,  
21 we wanted to make sure at this level that we got the  
22 HED processed, the database and all this other stuff,  
23 what's contained in an HED, how it's evaluated, who  
24 evaluates it, documented.

25 So the PMP also has a relatively lengthy

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 section on what this data looks like, how is it  
2 tracked, who initiates it? More importantly, how is  
3 it , in fact, closed to say that, yes, we made a  
4 change or no, we don't need to make a change because?

5 It then addresses, I'm just going down  
6 the list, the technical program. And what I mean by  
7 that, all the IPs. But it gives a brief kind of  
8 summary of all the IPs in it and then the combined  
9 license type information.

10 This activity is, I said, broken down to  
11 the implementation plan and, by the way, ReSR is  
12 because when -- that's our Results Summary Report.  
13 In the industry, that's referred to as RSR, but that  
14 conflicts with the Remote Shutdown Room in the  
15 acronyms of the Mitsubishi design. So, we stuck the  
16 little e in there. So, that's the Results Summary  
17 Report.

18 And, basically, the document, each of the  
19 IPs in it has a detailed description of what will be  
20 contained in the Results Summary Report. Because we  
21 wanted to make sure that when we were all done and  
22 submitted the Results Summary Report that it didn't  
23 contain less information that's needed to give the  
24 staff an understanding of what, in fact, had been  
25 done.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           An example would be, each IP describes  
2           the team that will do it generically. There will be  
3           human factors expertise. There will be operational  
4           expertise. There will be an I&C engineer.

5           And then, it describes what does human  
6           factors expertise mean? What degree? How many  
7           years' experience? Et cetera, et cetera.

8           The Results Summary Report goes further  
9           as an example that it's -- we're planning in it to  
10          not only say the types of people, but by definition  
11          describe the individuals by name and their little  
12          resume bead or how they meet the criteria.

13          You've seen these assumptions and  
14          constraints before, so I was going to go quick past  
15          them very, very quickly.

16          So, as you're reading, I'm going to slide  
17          to the next one and then we'll come back if there are  
18          questions.

19          This is the assumption of minimum  
20          staffing. The SRO and RO, we talked about that.

21          We also talked about the other SRO, RO  
22          and in the US-APWR, there's this floating SRO. So,  
23          I'm not going to go over that.

24          But, those are assumptions going into the  
25          design.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: I'm sorry, I'm sorry.

2 Let me --

3 MR. HALL: Please stop me.

4 CHAIRMAN STETKAR: Yes, I'm going to stop  
5 you because, finally, I want to talk about real  
6 things.

7 MR. HALL: Ouch.

8 CHAIRMAN STETKAR: We are now talking  
9 about US-APWR.

10 MR. HALL: Yes.

11 CHAIRMAN STETKAR: And US --

12 MR. HALL: This is --

13 CHAIRMAN STETKAR: It's -- let me finish  
14 here.

15 In the Design Certification Chapter 18,  
16 it's my understanding that the complement will be an  
17 RO and an SRO continuously in the control room.  
18 Another RO and another SRO somewhere in the plant.  
19 And a third SRO available that can be shared among  
20 multiple units that will -- can fulfill the STA  
21 function or, among the three SORs, you've got an STA,  
22 an emergency director and an actual operations  
23 director.

24 Is that correct for the US-APWR certified  
25 design? That's a yes or a no question.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   Because what you have up on the screen  
2           there that says US-APWR HFE assumptions and  
3           constraints is not my understanding of the US-APWR.  
4           It is my understanding of the thing we talked about  
5           90 percent of the time today which is the Generic  
6           Topical Report.

7                   And, I want to make sure that I'm real  
8           clear on this because now we're talking about the  
9           US-APWR. So, if I need to go back, Ryan's looking  
10          at me like I --

11                   MR. SPRENGEL: Well, I just want to  
12          understand the alternative. I don't understand -- is  
13          this your new understanding or your previous  
14          understanding or --

15                   CHAIRMAN STETKAR: No, no, no from  
16          reading through DCD Chapter 18 because I want to make  
17          sure that this is clear because what Bob said is  
18          inconsistent on this slide.

19                   And my understanding of the certified  
20          design that the certified design complement from  
21          US-APWR will be one SRO continuously in the control  
22          room -- eventually it will die -- one RO continuously  
23          in the control room another somewhere in the plant  
24          assigned to that unit. Another RO somewhere in the  
25          plant assigned to that unit and now, a third position

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 in the plant with, and this is a quote, SRO or STA  
2 qualifications. This person is intended to assume  
3 the main control room SRO or STA function during  
4 plant upsets but need not be in the main control  
5 continuously. This person can be shared among  
6 multiple units.

7 So, for the certification going forward,  
8 is that the minimum staffing?

9 MEMBER BLEY: And that's, by the way,  
10 consistent with something Bob told us earlier today.

11 CHAIRMAN STETKAR: That is what he told  
12 us earlier, but we were mixing earlier versus later  
13 and now we're later. So, I just want to make sure  
14 it's --

15 MEMBER BLEY: And he was talking about  
16 later at the time he said it.

17 MR. SPRENGEL: Yes, we can confirm that  
18 for US-APWR.

19 CHAIRMAN STETKAR: And, the intent is  
20 that this third -- this additional body can be shared  
21 among multiple units so that if I have a two unit  
22 site, I can have four SROs plus an additional body  
23 who might have an SRO license or might be STA  
24 qualified but I need five of those types of folks,  
25 not six.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. SPRENGEL: At a minimum, that's  
2 correct.

3 CHAIRMAN STETKAR: On site? Okay.

4 MEMBER BLEY: I mean, this slide is  
5 correct as it's written. It's in the control room --

6 MR. HALL: Yes, this is --

7 MEMBER BLEY: -- but it doesn't have  
8 those other people on it --

9 MR. HALL: That's right, it doesn't.

10 MEMBER BLEY: -- who are not necessarily  
11 inside the control room.

12 MR. HALL: And that's why I verbalized  
13 it.

14 CHAIRMAN STETKAR: Okay, okay.

15 MR. HALL: So, again, the design  
16 constraint is for the minimum staffing. So, we're  
17 working on the HFE, but in the control room, these  
18 two people exist and we can run the plant with it.

19 And this is my last slide. As I said, I  
20 had no plans on really going into all the IPs. But,  
21 I did a little bit earlier.

22 And, the applicable facilities are,  
23 obviously, main control room. The HFE program  
24 reflects the remote shut down room which basically  
25 another main control room, it's basically the same

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 interface. The tech support center and limited  
2 applications to local control stations and the EOF  
3 and the limitations are described in the  
4 documentation.

5 MEMBER BLEY: Now, I think we have good  
6 understanding on this but I want to add one little  
7 glitch to it to make sure you folks agree and that  
8 the staff eventually we get them to agree.

9 If, in fact, a customer should build two  
10 of these, number one, it doesn't look like there's a  
11 revision to have a shared control room, so there  
12 would be separate control rooms.

13 And, number two, this fifth guy is shared  
14 among them such that if you have a multi-unit event  
15 caused by a loss of offsite power or a major  
16 earthquake or something of that nature, we won't have  
17 enough STAs to go around so we'd have one in every  
18 plant.

19 CHAIRMAN STETKAR: We don't have enough  
20 bodies to go around to fulfill --

21 MEMBER BLEY: All those functions in  
22 every unit.

23 CHAIRMAN STETKAR: -- each unit --

24 MEMBER BLEY: And every unit.

25 CHAIRMAN STETKAR: -- an operational

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 control, an emergency director and an STA in each  
2 unit.

3 MEMBER BLEY: Yes. Sorry, that's more  
4 precise, yes.

5 MR. HALL: From an analysis point of  
6 view, remember, those first slides that brought us  
7 into these design constraints, these were constraints  
8 or assumptions going into the human factors program.

9 If the human factors program moves  
10 forward and says things within those constraints  
11 aren't doable, more automation is needed, less  
12 automation is needed, different layout is needed,  
13 then, in fact, this process I described of reviewing  
14 the compliance of the design as it stands gets  
15 reviewed and proposed to be changed.

16 MEMBER BLEY: Yes, but I think what we're  
17 hearing is it's likely to go forward on the basis of  
18 thinking about a single unit.

19 CHAIRMAN STETKAR: And the  
20 staff -- remember, the staff has approved -- has  
21 written an SER that's approved this. The staff --

22 MEMBER BLEY: Oh, that's right.

23 CHAIRMAN STETKAR: -- has written an SER  
24 that has approved the concept of a shared -- if I  
25 have a site that looks like Palo Verde with three

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 units, I have to have one body who runs back and  
2 forth among the three units because that's all I need  
3 to have. And the staff has written an SER that  
4 approves that concept.

5 MEMBER SCHULTZ: But, you've got --

6 CHAIRMAN STETKAR: At the stage of their  
7 review.

8 MEMBER SCHULTZ: - you've got two units,  
9 two control rooms, four chairs in each control room  
10 and one other SRO. That's nine. Nine operators and  
11 SRO you'll have. I just hope we're counting  
12 consistently.

13 CHAIRMAN STETKAR: In each unit, you will  
14 have two ROs, you will have two SROs, period. So,  
15 between them that's eight bodies.

16 MR. HALL: Right.

17 CHAIRMAN STETKAR: ROs are -- and one  
18 more. And, if I had ten units, I would have 40  
19 bodies plus one more. I mean by extrapolation.

20 Clean up stuff, I don't know what the  
21 plan, but we need to talk a little bit about the plan  
22 going forward by the time we finish here.

23 But, as I was reading through at least  
24 the version of DCD Chapter 18 that we have, there are  
25 several references in there that go back to the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 standard Japanese-Basic human system interface  
2 design compared to the US-APWR HSIS.

3 And because of my prior confusion on the  
4 US-Basic design, I highlighted, for example, it says  
5 one of the differences is arrangement of the main  
6 control room operator console to accommodate the  
7 change from one to two reactor operation stations.

8 Now, what I learned earlier today is that  
9 two reactor operator stations, I think I was told,  
10 is a fundamental feature of the US-Basic design,  
11 correct?

12 MR. HALL: That's correct.

13 CHAIRMAN STETKAR: Okay. And there are  
14 a few places in at least Rev 4 of the DCD that draws  
15 the distinction between what's being proposed for the  
16 US-APWR system but distinguishes it from the  
17 so-called Japanese-Basic. And it strikes me that it  
18 ought to be distinguishing it from the US-Basic and  
19 it might not be a difference anymore. Follow me?

20 And, I didn't -- I don't know if I caught  
21 all of those but it's something that if you're  
22 submitting Rev 5 of the DCD Chapter 18 --

23 MR. SPRENGEL: Yes, we'll say that the  
24 significant changes to the implementation plans and  
25 the PMP that were mentioned, there was also

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 coordinating significant changes to the design  
2 certification.

3 CHAIRMAN STETKAR: Yes, so a lot of the  
4 verbiage is going to change?

5 MR. SPRENGEL: Right.

6 CHAIRMAN STETKAR: Okay, okay.

7 MR. SPRENGEL: Which it has, again,  
8 submitted as on the docket.

9 CHAIRMAN STETKAR: It has already?

10 MR. SPRENGEL: Yes.

11 CHAIRMAN STETKAR: Rev 5?

12 MR. SPRENGEL: No, the --

13 CHAIRMAN STETKAR: Oh, I'm --

14 MR. SPRENGEL: The changes have been  
15 submitted.

16 CHAIRMAN STETKAR: Right.

17 MR. SPRENGEL: Right.

18 CHAIRMAN STETKAR: By the process you  
19 described?

20 MR. SPRENGEL: Right. So, we have  
21 officially submitted those changes. We have not  
22 officially published a new DCD revision.

23 CHAIRMAN STETKAR: Yes, okay. Okay.

24 A couple of things that I did come across  
25 here, and I'll skip the standard Japanese stuff,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       there's something called -- and this, again,  
2       it's -- maybe I just misunderstood it, it's cast in  
3       the contrast with the standard Japanese-Basic design,  
4       but it says, addition of automatic data checking to  
5       computer-based procedure system, it's noted that this  
6       is a US-APWR-specific change from the computer-based  
7       system of the US-Basic HSIS described in reference  
8       whatever.

9               Automated data checking has been added  
10       to specifically reduce human performance errors when  
11       executing procedures.

12              So, what is -- I mean we didn't -- this,  
13       to me, says it's something different from what we  
14       talked about this morning. So, what is that?

15              MR. HALL: Okay. What we found when we  
16       were inputting data into the computer-based procedure  
17       system that there started to become concerns that was  
18       the data, in fact, correct or not? Was it updated?  
19       Was the data correctly displayed in it?

20              So, now, the US-APWR has a process of  
21       confirming that the data that's imported into the CDP  
22       is correct.

23              And, what I mean by that is the CBP, for  
24       US-APWR will say check that the pressure is greater  
25       than X and it will have imbedded in it what the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 pressure is now being measured at.

2 CHAIRMAN STETKAR: In where? I mean I  
3 understand if I pull up on the operational VDU that  
4 I know what pressure is --

5 MR. HALL: It'll be imbedded in these  
6 computer-based procedure systems.

7 CHAIRMAN STETKAR: That's a much  
8 different construct from what I understood -- much  
9 different construct.

10 MR. HALL: And the -- can I go further?

11 CHAIRMAN STETKAR: Isn't it? Because,  
12 as I understood it, the computer-based  
13 procedure -- as I understood, maybe I was wrong -- for  
14 the generic design, for the Topical Report, you'd  
15 bring up procedure sections. It's essentially a  
16 replicate of the paper-based procedures. You push  
17 on a procedure task that opens up a screen or over  
18 on your operational VDU with the stuff that you need  
19 to operate in there.

20 It didn't have this interaction of --

21 MR. HALL: No, it didn't in the basic.  
22 And, again, we're now venturing into this design  
23 process as we're moving forward.

24 On the new CBP, it has the ability when  
25 it asks the operator to check a number, rather than

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       having the operators look around either the LDP or  
2       go into the displays on his side to basically have  
3       that value that says check this pressure. The  
4       pressure value's sitting next to it on the CBP, on  
5       the computer so you don't have to look for it.

6               And, again, design process now, so this  
7       is not completed design, please. I'm --

8               CHAIRMAN STETKAR: No, no, no, but it's  
9       functionally different from what I understood the --

10              MR. HALL: It's an enhancement of what  
11       was there and it's one of these, you know, when you  
12       run tests there are certain changes you can make that  
13       are quick and there are certain changes like this one  
14       that take a lot of design effort to do it. It  
15       requires -- starting to entertain larger  
16       computer-based procedure screens, multiple  
17       procedures on it. But, these are -- this is that  
18       process.

19              And, when the US-APWR is done, it will  
20       be in that document. So, you know, I'm venturing  
21       into soft areas now.

22              MEMBER BLEY: When we say in that  
23       document, we mean? I know it'll be in the computer,  
24       but when you just said when it's all done it'll be  
25       in that document?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. HALL: Oh, no, I'm sorry.

2 MEMBER BLEY: What document?

3 MR. HALL: What did I mean?

4 MEMBER BLEY: Maybe you didn't mean to

5 say what you said?

6 MR. HALL: No, I didn't. I'm sorry, no.

7 MEMBER BLEY: What did you mean to say?

8 It'll be in the computer?

9 MR. HALL: In the computer, yes. I'm

10 sorry.

11 MEMBER BLEY: So, it'll be on the screen

12 so that'll all be one integrated --

13 MR. HALL: But, please, the last few

14 things I said are design process.

15 MEMBER BLEY: Now, this process will go

16 on after you get --

17 MR. SPRENGEL: After certification.

18 MEMBER BLEY: After certifications?

19 MR. SPRENGEL: Correct.

20 MEMBER BLEY: So --

21 MR. SPRENGEL: Following --

22 MEMBER BLEY: You can't --

23 MR. SPRENGEL: -- the implementation.

24 MEMBER BLEY: You can't keep Chapter 18

25 up to date with the design process, period, until you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 get done sometime later?

2 MR. SPRENGEL: We keep in alignment with  
3 Chapter 18, yes. So, that's why he's kind of  
4 alluding to the specific implementation of it and why  
5 there's not necessarily a graphic or anything because  
6 the actual implementation is much more involved and  
7 much more detailed.

8 And that will definitely take some time  
9 and any other improvements that may be found, you  
10 know, could be implemented over time as well in  
11 accordance with what's been given in Chapter 18.

12 MEMBER BLEY: The plans that are in 18 --

13 MR. SPRENGEL: Right.

14 MEMBER BLEY: -- essentially? Okay.

15 CHAIRMAN STETKAR: Tell me about GOMS.  
16 In -- that didn't even get a rise from anybody, it's  
17 getting late.

18 In the task analysis methodology, there  
19 is reference made to the use of the Goals Operators  
20 Methods and Selection Rules, GOMS, theory of  
21 cognitive skills involved in human computer tasks.

22 And, somehow that process is used in the  
23 task analysis to determine that, indeed, everything  
24 is fine.

25 And, as best I read through all of that,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 and there are things like it says, well, I breakdown  
2 all of these tasks into I need to look at a display  
3 and that takes me 50 to 200 milliseconds, so I can  
4 use 200 milliseconds of that and I have to do that  
5 seven times so, I have to assign 1,400 milliseconds  
6 for those things and I'm okay. And I --

7 This strikes me as something I've never  
8 heard about. It's from something that was published  
9 in 1983 and it strikes me as it would be nice in  
10 terms of thinking about human beings as calibrating  
11 instruments with tolerances and taking an upper bound  
12 on the uncertainty of a tolerance, but it's not clear  
13 how it, to me, how that supports a task analysis.

14 So, could you explain how all of that  
15 supports a task analysis? And, I couldn't, for the  
16 life of me, figure out how it's actually being  
17 used -- going to be used.

18 MR. HALL: Okay. I'm going to have  
19 difficulty giving you the level of data you want  
20 because of my preparation at this time. But, I can  
21 say the following, that the operational sequence  
22 diagrams and the GOMS fit together.

23 CHAIRMAN STETKAR: Yes, they do.

24 MR. HALL: Both of those are standard  
25 approaches in the human factors industry.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   CHAIRMAN STETKAR:       I'm sorry, I  
2 understand operational sequence diagrams, I guess I'm  
3 not a standard human factors guy because I don't know  
4 about this counting up milliseconds.

5                   MR. HALL: Okay, let me finish then.

6                   CHAIRMAN STETKAR: Okay.

7                   MR. HALL: GOMS was used originally in  
8 the military and it was used for human computer-type  
9 activities. It was not used for going out and  
10 calibrating necessarily a valve or something like  
11 that. But, it was an attempt to get a handle -- the  
12 original concept was of, not ours, but the original  
13 developers of it, an attempt to get a handle on how  
14 does one develop the time it takes to see an  
15 indication, process it, determine an action and take  
16 an action?

17                  CHAIRMAN STETKAR: I get a push a button,  
18 eat a banana-type response. I'm talking about a  
19 complex task analysis in evolving scenario.

20                  MR. HALL: That's correct.

21                  CHAIRMAN STETKAR: All right.

22                  MR. HALL: But, that complex task  
23 analysis is broken down to very, very, very simple  
24 steps such as how long does it take to determine that  
25 I have this kind of event going on in the plant?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   And, if you look at the chart, that table  
2                   in the task analysis is how it does it.

3                   The GOMS associated with the diagrams is  
4                   the starting point for the SMEs to then determine  
5                   timing of an event. And then, later on in the task  
6                   analysis, that timing, because we're trying to work  
7                   out workloads, and later on in the task analysis,  
8                   basically, situational factors or multiplication  
9                   factors are added to the amount of time that's needed  
10                  so we can compare the time we feel is going to be  
11                  required to do something versus the time the plant  
12                  has to take that action. And that lets us work out  
13                  the workload.

14                  So, it's this cascading set of tools to  
15                  come up is this is a high workload, medium, low  
16                  workload situation?

17                  And, then we have rules in the task  
18                  analysis that say depending on whether it's high,  
19                  medium or low should this be relegated to automation?  
20                  Should it stay as a human activity? Et cetera.

21                  And, that's the process.

22                  CHAIRMAN STETKAR: You do, and it's  
23                  almost impossible to get -- you do have those rules  
24                  and I can't find them right here and it's kind of  
25                  irrelevant of what the actual numbers are.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 But, to me, it's impossible to get a  
2 medium workload because there's only a very, very,  
3 very narrow window of a couple of numerical  
4 increments to get medium. So, you either determine  
5 that manual is fine or you need to automate it.

6 And, there's a bias toward automation and  
7 I just don't know what this is doing for me because  
8 I'm counting up, I think, milliseconds under things  
9 and inferring that a task is simple because this  
10 thing tells me I can do it in 2,780 milliseconds and  
11 I have two hours to do it because all I need to do  
12 is push a button and eat a banana 17 times.

13 I don't know how this relates to actual  
14 task analysis in the context of a scenario is what  
15 I'm really confused about. And, maybe it all works  
16 out okay, but I'm just a bit worried because the task  
17 analysis is a really important part of the process.

18 MR. HALL: I can't answer better than I  
19 just did.

20 CHAIRMAN STETKAR: I don't know, maybe  
21 the staff -- is the staff -- we're kind of thin on  
22 staff people, but is the staff familiar with the  
23 process? I mean have you had experience? Have you  
24 audited task analyses that have actually been done  
25 this way and come out with reasonable conclusions?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 MR. WARD: I'm not aware of any. But,  
2 I've personally have not been involved in that.

3 CHAIRMAN STETKAR: Okay. Well, maybe we  
4 need to think about it a little bit.

5 MEMBER POWERS: Well, it is used in the  
6 military applications.

7 CHAIRMAN STETKAR: Is it used in military  
8 applications for complex evolving scenarios or is it  
9 more of a, I hate to use the term, push a button, eat  
10 a banana or the gunner, you know, giving some  
11 indication how long do I have before I press the  
12 trigger.

13 MEMBER POWERS: You're asking me about  
14 combat situations, I don't know. But I do know in a  
15 nuclear weapons position --

16 CHAIRMAN STETKAR: Okay.

17 MEMBER POWERS: -- about activities  
18 there. And now, our experience base in people trying  
19 to take away nuclear weapons from us and use them in  
20 a purloined basis is substantially thinner than our  
21 database on severe accidents.

22 So, you ask me how good are the estimates  
23 and I struggle to do that very much. They do run  
24 red head exercises and things like that with it and  
25 it is used as an input into how to refine responses.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       What the manpower that you need to up standoff design  
2       basis threats and whatnot.

3               CHAIRMAN STETKAR:   Okay.

4               MEMBER POWERS:   And, the quality of those  
5       things, I mean a lot of that is in the eyes of the  
6       beholder, if you're looking.   I mean, as with all  
7       human activities, looking for three decimal point  
8       accuracy, you're just not going to get it.

9               CHAIRMAN STETKAR:   Well, the thing  
10       that -- I mean I read through it, I'm not at all  
11       familiar with the methodology, had never heard of it  
12       and I didn't have enough time to go do a lot of  
13       self-education.

14               But, there's an example that's worked out  
15       in one of the documents that I read that says, well,  
16       here's a task analysis for reactor operators to  
17       confirm safety injection, reactor trip and turbine  
18       trip.   Okay?   Typical, you know, kind of things.

19               You go through the process and he gets  
20       nine of number one type things, 18 of number two type  
21       things, one of number three type things and you add  
22       them all up and it's 2,230 milliseconds or 2.23  
23       seconds to do that.

24               Okay, under what conditions?   What kind  
25       of scenario?   Two point two-three seconds is kind of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 fast given the fact that I was sitting there and  
2 nothing is happened in the last 30 years of my life  
3 and suddenly something happens, I guess maybe none  
4 of you have been in that situation.

5 So, I'm curious about what value-added  
6 this apparently quite complex and numerically precise  
7 2,230 milliseconds gets me in terms of a real task  
8 analysis kind of challenging how much time in a  
9 scenario is required to accomplish these tasks?

10 MEMBER BLEY: But, your concerns --

11 CHAIRMAN STETKAR: The diagrams help me  
12 because they help me understand the combinations of  
13 identification cognitive response manipulation type  
14 things. How many of those types of things do I need  
15 to do in a series in parallel action.

16 So, laying out those diagrams is -- seems  
17 to be a really useful function. But then, parsing  
18 it down into nine things of a hundred milliseconds a  
19 piece --

20 MEMBER BLEY: But, where were the  
21 examples? I didn't see them.

22 CHAIRMAN STETKAR: Okay, yes, you had to  
23 ask. So, I'll dredge it up.

24 They are in -- they happen to be in  
25 MUAP-07007-P, Revision 5. The previous revision of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the Topical Report. They're in Section 5 point --

2 MEMBER BLEY: That's good enough.

3 CHAIRMAN STETKAR: I can find it  
4 here -- Section -- but a section that has been removed  
5 because it was part of the human factors engineering  
6 part of that formal report, Section 5.4.3.2 or  
7 something like that. It's in Section 5.10 basically.

8 MEMBER BLEY: I didn't see that. I've  
9 seen sometime in the past, you know, the way it's  
10 talked about in Chapter 18 is just in terms of the  
11 GOMS operators selection which kind of you see  
12 they're laying out in basic things in the task  
13 analysis but --

14 CHAIRMAN STETKAR: And the --

15 MEMBER BLEY: -- if they're claiming  
16 that kind of accuracy --

17 CHAIRMAN STETKAR: The current version  
18 of the task analysis --

19 MEMBER BLEY: I don't know what this  
20 example was that's in one of your previous documents.

21 CHAIRMAN STETKAR: The current version  
22 of the task analysis implementation program does not  
23 have those examples. It just says we're going to  
24 use -- I checked it to see, oh, are they still going  
25 to use this GOMS approach or not and it says, yes,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 we are and just gives you a reference to the original  
2 1983 research that's done. And it's extracted this  
3 numerical example that was useful to me earlier.

4 MR. HALL: In the task analysis, GOMS is  
5 a starting point and your concerns about stress  
6 levels, other things going on, competing activities  
7 the operator may have are all very, very well taken  
8 and are not handled by GOMS.

9 CHAIRMAN STETKAR: Okay.

10 MR. HALL: GOMS is a starting point and  
11 there are rating factors and adjustment factors that  
12 scale those numbers, usually in the upward direction,  
13 to come up with the final times of time required to  
14 take action, not time available, but time required.

15 So, that's why the matrices are  
16 relatively complex when you get into -- continue?

17 CHAIRMAN STETKAR: Yes.

18 MR. HALL: When you get into the waiting  
19 factors, we start introducing expert opinion because  
20 these are, I think we talk about three operators that  
21 are licensed operators with experience that have to  
22 start saying, is this highly complex, is this highly  
23 challenging and they scale the values of timing in  
24 the upward direction to account for things like that.

25 CHAIRMAN STETKAR: But, I think, Bob, a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 little bit of what I'm concerned about is it does  
2 sound to me like a very, very (a) complex process  
3 that, (b) derives numerically very precise values  
4 that are then examined and weighted and scaled and  
5 things.

6 And, I think the concern is by implying  
7 that this is a very precise process and giving people  
8 weights and criteria that if something comes up  
9 with -- in two values then it might be manual or it  
10 might be automatic. Or, if it's outside one is  
11 manual, one is automatic implies a heck of a lot of  
12 precision and a heck of a lot work and I'm concerned  
13 about maybe missing something that a less numerically  
14 focused add, multiply, divide, count, count, count  
15 process might actually capture better.

16 MR. HALL: I don't believe the documents  
17 attempt to imply that this is a highly accurate down  
18 to X decimal point activity.

19 CHAIRMAN STETKAR: Okay.

20 MR. HALL: So, I think that might be a  
21 misunderstanding or misinterpretation of the  
22 methodology.

23 The methodology does bring to the table  
24 in what we attempt to do a very, very structured way  
25 expert opinion, people that have been there and done

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       it to be able to evaluate what the important tasks  
2       are and how human handle those tasks. That's all I  
3       can say.

4               CHAIRMAN STETKAR: Okay, okay, thanks.

5               Bear with me now because I have finally  
6       gotten to the point where I can't find anything  
7       anymore, so I need to --

8               And, there's a statement in here, again,  
9       under task analysis, and this in the implementation  
10      plan document for task analysis that says staffing.  
11      If the task is executable within the defined minimum  
12      operator staffing for plant operating modes and for  
13      stabilization after abnormal conditions, with the  
14      exception of conditions that lead to severe  
15      accidents, and within the assumed maximum operating  
16      staffing for shutdown modes, stabilization for beyond  
17      design basis conditions and to achieve stabilization  
18      for conditions that lead to severe accident record  
19      acceptable and document the basis for this  
20      conclusion.

21              Why, I get the minimum operating staff,  
22      I have no problems with that for plant operating  
23      modes and abnormal conditions. Why do I, when I'm  
24      doing this evaluation, get to assume that I have the  
25      maximum number of people available when I'm in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 shutdown modes or beyond design basis conditions or  
2 conditions that are progressing to the severe  
3 accident? Like, why do I get to -- in fact, I'm  
4 instructed to do that?

5 MR. HALL: The maximum number is talking  
6 about for modes 3 through 6, I guess go beyond the  
7 minimum assumptions coming in of one RO and one SRO.

8 The staffing analysis, that's one of the  
9 implementation plans, has an incoming assumption of  
10 what -- how many people will be available in the  
11 control room during those other activities, not modes  
12 1 and 2.

13 When that's referring to the maximum  
14 number, it's talking about the values coming out of  
15 the staffing analysis that are above the operating  
16 crew of one and one, one SRO, one RO.

17 CHAIRMAN STETKAR: Okay, those words are  
18 on the record, I don't understand what you said. So,  
19 let's try this again.

20 During power operation, I understand that  
21 the minimum staffing is one RO and one SRO in the  
22 control room with another RO and another SRO floating  
23 around there some place.

24 During shutdown, there will also be a  
25 staffing analysis and, in many plants, that staffing

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 analysis justifies fewer bodies in the control room.

2 But, you're saying I can credit the  
3 maximum number of bodies that I can find for this  
4 analysis. Why is that? I mean the analogy would be  
5 why can't I credit you like 12 people or something  
6 like that during power operation because I can count  
7 up the maximum number of people that might be around  
8 during power operations?

9 I don't get why I get to credit the  
10 maximum number of bodies simply because I'm in  
11 shutdown modes or stabilization for beyond design  
12 basis conditions.

13 For example, if I have a beyond design  
14 basis earthquake during power operation, if I have a  
15 design basis earthquake, I have to do the analysis  
16 for one and one. But, if I have a beyond design  
17 basis earthquake, I can credit a whole bunch of other  
18 people for being there. I don't get it.

19 MR. SPRENGEL: We'll follow up on that  
20 question.

21 CHAIRMAN STETKAR: Okay, thanks.

22 And these are things that I kind of ask  
23 you to highlight between what I understood for the  
24 standard stuff and what I can read referenced in  
25 US-APWR.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Under, and this is in the DCD under the  
2 HSI change process, it says configuration of operator  
3 managed trend displays and operator managed alarms.  
4 Operators can configure new trend displays, and I  
5 know that, that's a really good feature, and new  
6 alarms that are not pre-configured in the HSI design.

7 Is that -- because I had not heard about  
8 operators configure -- what is the operator  
9 configured alarm function and is that a US-APWR  
10 something specific or is that the Topical Report  
11 US-Basic function?

12 Because I hadn't heard about it until I  
13 came to here that the operators could configure  
14 alarms. Like I want an alarm when it's time to go  
15 to dinner or something like that. I mean, you know,  
16 being --

17 But --

18 MR. SPRENGEL: We'll follow up on that  
19 question.

20 CHAIRMAN STETKAR: Follow up?

21 The only reason I bring this up is if the  
22 validation process is supposed to test the adequacy  
23 of the HSI inventory and part of that is the alarms  
24 and part of that is the prioritization function. And  
25 then, we're giving the operator the ability to go in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 and muddle with all of that stuff, it's not at all  
2 clear to me that the operator muddling, if they can  
3 do that, might somehow perturb all of those really,  
4 really sophisticated algorithms that are doing all  
5 of that smart things to take me down from a thousand  
6 alarms to the key 25 or so that I need to be careful  
7 about.

8 MS. SPRENGEL: So, the impact to the  
9 priority logic?

10 CHAIRMAN STETKAR: That's the primary  
11 thing that I'm concerned about is, if the operators  
12 are given the ability to establish new alarms and,  
13 in principle, to set their priorities, does that  
14 somehow perturb all of that built in logic that the  
15 operators probably are not intimately familiar with  
16 in terms of how the algorithms set those priorities.

17 MR. SPRENGEL: Okay. And, one of your  
18 questions, that's definitely part of the US-APWR  
19 scope.

20 CHAIRMAN STETKAR: It's the only place I  
21 could find it was in DCD Section 18.7.3.3 under the  
22 change process. And that is US-APWR. I found no  
23 mention of it in the Topical Report whatsoever.

24 MR. WARD: There is a statement in that  
25 paragraph, the operator configured HSI does not

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 change any pre-configured HSI.

2 CHAIRMAN STETKAR: It does not change  
3 any pre-configured HSI. I don't know -- you're  
4 right. But I don't know what that means.

5 So, if the operator says, well, I think  
6 because of the plant status these days, I think an  
7 alarm on whatever ought to be really important, so  
8 I'm going to now establish -- I need an alarm on  
9 what -- I don't have an alarm on whatever. Or, I  
10 need to somehow change a priority on the whatever  
11 alarm. I don't know what it says its meaning that  
12 it doesn't change any per-configured HSI.

13 MR. SPRENGEL: We can check on that. I  
14 think this is limited to the trend displays. So, if  
15 you have a trend display --

16 CHAIRMAN STETKAR: Trend displays, I  
17 have no problem at all.

18 MR. SPRENGEL: And I think it's a setting  
19 like an alarm here if you're watching a trend, not  
20 an overall, it's only in that aspect.

21 CHAIRMAN STETKAR: I don't know. I mean  
22 I looked at this, obviously, in the context of the  
23 alarm VDU and the prioritization that's gone on with  
24 all of those alarms.

25 I have no problem at all with trend, you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 know, I'd really like the ability for the operators  
2 to configure their own different trend displays and  
3 set what they wanted to.

4 MR. SPRENGEL: I think that was the  
5 intent.

6 CHAIRMAN STETKAR: Okay.

7 MR. SPRENGEL: And then, it would go away  
8 when you got rid of the trend display. But, we'll  
9 check.

10 CHAIRMAN STETKAR: Okay.

11 MR. SPRENGEL: In the most recent  
12 submitted DCD rooted in the information material, not  
13 actual --

14 CHAIRMAN STETKAR: Whatever it is, yes.

15 MR. SPRENGEL: -- it does not have that  
16 feature.

17 CHAIRMAN STETKAR: It does -- thank you.  
18 I would not have asked the question with  
19 new -- whatever that new thing is. Thanks, thanks.

20 Trend -- it does still have the trend  
21 display configuration, though, right?

22 MR. SPRENGEL: We'll follow up on that  
23 information.

24 CHAIRMAN STETKAR: Well, I mean if -- I  
25 sure hope --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. SPRENGEL: I'll follow up on the  
2 whole package of discussion that we're -- let's keep  
3 capturing.

4 CHAIRMAN STETKAR: Okay, okay.

5 And I think I only have one more. No, I  
6 don't have any more. I'm not going to belabor that,  
7 I'm done.

8 And, serious, I mean I have a lot of  
9 picky things here, but they were answered pretty  
10 much.

11 Do you folks have anything more? You  
12 want to follow up --

13 MR. SPRENGEL: I will risk bringing, I  
14 think, two items up.

15 CHAIRMAN STETKAR: Okay.

16 MR. SPRENGEL: Well, the first one, it's  
17 an answer, it's a response and I think it is how it  
18 is.

19 I just want to revisit, I think your  
20 understanding is correct in terms of the plus/minus  
21 alarm indication. So, there is new logic as a say a  
22 level is dropping, you know, as it reaches a set  
23 point and then a margin -- the deviation --

24 CHAIRMAN STETKAR: Well, I mean it'd  
25 typically be called a deviation --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. SPRENGEL: Right.

2 CHAIRMAN STETKAR: -- on the set.

3 MR. SPRENGEL: And so, with that  
4 deviation, you're either on the positive side of the  
5 set point or the negative side of the set point.

6 CHAIRMAN STETKAR: Yes.

7 MR. SPRENGEL: So, as the level is  
8 dropping, you would first hit the positive side of  
9 that deviation and then you would fall below the set  
10 point and you'd be in the minus portion of the  
11 deviation. And, if it continues to drop, obviously,  
12 now we have trend indication.

13 CHAIRMAN STETKAR: Yes.

14 MR. SPRENGEL: Continues to drop, you'd  
15 hit your low level and then your low, low level.

16 CHAIRMAN STETKAR: The L would pop up and  
17 then the LL would pop up.

18 MR. SPRENGEL: So, although I  
19 understand, you know, the negative/positive implying  
20 rising, lowering, there is logic in terms of the  
21 progression and why a plus and a minus is there. And  
22 I guess the best answer would be that the operators  
23 would also become familiar with those symbols.

24 And now, there's the added feature of the  
25 trend indication on to I think clarify the package

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 of information.

2 CHAIRMAN STETKAR: The trend indication  
3 helps me a lot. But, the way it helps me is that  
4 sitting here at a table having this discussion with  
5 a static thing with arrows on it, I can say, yes,  
6 that's going to help me.

7 And, basically, I'm going to ignore  
8 anything that's plus and minus because that's  
9 confusing to me and I'll look at arrows.

10 Not clear to me when things are actually  
11 changing and I've got four steam generators with a  
12 couple levels swinging up and down and a couple of  
13 levels going down and I need to make decisions about  
14 what I need to do with main or emergency feed water  
15 or things like that.

16 MR. SPRENGEL: Right. And it's fair --

17 CHAIRMAN STETKAR: Then, I might get  
18 tricked.

19 MR. SPRENGEL: Right, but in that  
20 circumstance, I think the focus is, again, on the  
21 alarm and the trend, you know, and whatever other  
22 information is going on --

23 MEMBER BLEY: I'd throw --

24 MR. SPRENGEL: -- and not necessarily  
25 the detail of the plus and the minus specifically.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 MEMBER BLEY: I'd throw in something just  
2 for you to think about because it's easy to sit here  
3 and say, well, the detail of the plus and minus, I'll  
4 throw that away. But when --

5 MR. SPRENGEL: Oh, no, no, no, don't  
6 throw it away.

7 MEMBER BLEY: When we're tossed into a  
8 situation where we're responding, funny things tend  
9 to happen and I'm recalling just as an anecdote, a  
10 case where in a plant I was involved in and a major  
11 change in the design and in some of the instruments --

12 Somebody's phone is going off.

13 CHAIRMAN STETKAR: Who has their phone  
14 on the table?

15 MEMBER BLEY: Major change which led to  
16 major changes in procedures and our very -- the  
17 problem occurred afterwards with our very best  
18 operators, the ones who really knew the plant.

19 And, what would happen because I was then  
20 standing watch as an oversight place where you can  
21 see all the different things going on in different  
22 places. When you'd have an emergency, despite a  
23 year's worth of training on all the new procedures  
24 in the simulator, everything where we knew how this  
25 stuff worked, something would go wrong and you'd

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 watch the guy and the new ones had no trouble.

2 The guys that were deeply trained and  
3 really knew it beforehand, somehow their brain would  
4 flip back to the old plan and you'd watch a minute  
5 and you'd call up and you'd say, hey, Dave, why'd you  
6 do that? And he'd tell you and you'd say, you're  
7 operating the old plant. And he'd say, oh my God.

8 So, these things get in your head and  
9 they don't go away very easily. So, just think about  
10 it.

11 MR. SPRENGEL: Okay. I think it's fair  
12 and usable feedback.

13 CHAIRMAN STETKAR: Yes. There have  
14 been -- I mean there have been studies done that  
15 people say that, you know, going clockwise gets more  
16 because everybody is trained that a clock, the  
17 numbers get bigger this way, so you don't, for  
18 example, make clockwise things get less.

19 That, as I said, if you're, you know,  
20 this is obvious that you don't make -- invert a level  
21 gauge so that the thing goes up as the level goes  
22 down. And people are used to seeing plus as meaning  
23 bigger and minus is meaning smaller. And they're  
24 not used to thinking about changes in a trend of a  
25 deviation getting lesser or bigger in the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 direction --

2 MR. SPRENGEL: But, it's not a change in  
3 the trend, it's within the upper portion of the set  
4 point.

5 CHAIRMAN STETKAR: Yes. And --

6 MR. SPRENGEL: So, within the deviation  
7 of the measurement, so it's not a trend at all.

8 CHAIRMAN STETKAR: But, it's reversed  
9 because if you look at the way it's laid out, it says  
10 that if level is deviating low, your example is  
11 actually wrong.

12 MR. SPRENGEL: If the level is within the  
13 lower deviation --

14 CHAIRMAN STETKAR: If level -- I have a  
15 set point.

16 MR. SPRENGEL: Right.

17 CHAIRMAN STETKAR: And if level is above  
18 that set point, I'm fine.

19 MR. SPRENGEL: Plus.

20 CHAIRMAN STETKAR: And, no, it's not  
21 plus.

22 MR. SPRENGEL: That's what I'm  
23 explaining, it is --

24 CHAIRMAN STETKAR: It's minus there.  
25 It's minus there. Level -- actual level is greater

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       than the set point gives you a minus, actual level  
2       is less than the set point gives you a plus.

3               MR. SPRENGEL:   Okay.

4               CHAIRMAN STETKAR:   At least according to  
5       the --

6               MEMBER BLEY:   The notes on that, yes.

7               CHAIRMAN STETKAR:   -- the notes on that  
8       display.

9               MR. SPRENGEL:   Okay.   For the example in  
10      the --

11              CHAIRMAN STETKAR:   In the DCD.

12              MR. SPRENGEL:   -- in the report?   Okay.

13              CHAIRMAN STETKAR:   In the report.

14              MR. SPRENGEL:   Okay.   The other --

15              CHAIRMAN STETKAR:   I don't know whether  
16      it's the DCD or the -- it's the Topical --

17              MR. SPRENGEL:   Right.   I think it's --

18              CHAIRMAN STETKAR:   It's the Topical  
19      Report.

20              MR. SPRENGEL:   I think it's, yes, the  
21      Topical, correct.

22              CHAIRMAN STETKAR:   Because it has those  
23      examples.

24              MR. SPRENGEL:   Lock.

25              CHAIRMAN STETKAR:   Lock?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. SPRENGEL: And there's a question  
2 of -- we've gone through the tortured path of the  
3 operator taking those actions and that it forces  
4 thought on -- we have confirmation that lock will  
5 override and stop the pump.

6 CHAIRMAN STETKAR: Okay, good. It --

7 MR. SPRENGEL: Because it would have  
8 priority over like the ECCS signal --

9 CHAIRMAN STETKAR: Yes.

10 MR. SPRENGEL: - to protect operators  
11 or --

12 CHAIRMAN STETKAR: But, you do also, just  
13 for the record here, you do also -- do you also have  
14 confirmation that to enable that function on the  
15 operational VDU, the operator must actively enable  
16 it from the safety VDU?

17 MR. SPRENGEL: Absolutely, yes.

18 CHAIRMAN STETKAR: Okay.

19 MR. SPRENGEL: Yes.

20 CHAIRMAN STETKAR: I just -- I wanted to  
21 make sure we had that on the record.

22 MR. SPRENGEL: Okay. The other thing  
23 I'd like to do, not necessarily enjoyable, but I do  
24 want to review what I have captured, just so that  
25 we're clear, in terms of actions that we have taken.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           We will plan -- we will work with the  
2       staff, of course, on this in terms of revising the  
3       Topical Report or other documentation to be clear  
4       about the Phase IB testing that was done.

5           Understanding that there is some  
6       information out there which may or may not be  
7       adequate, that will be reviewed and supplemented as  
8       an active submittal.

9           We will also update the Topical Report  
10      with the information as discussed today about the SRO  
11      and STA VDU to bring the images and the description  
12      of the Topical Report into alignment with what was  
13      discussed today.

14          We will provide information on a  
15      more -- we'll provide information on the reason  
16      behind the slow mode control.

17          We will provide information -- we'll need  
18      to work with the staff and continue, I think,  
19      discussion on the discussion about the block override  
20      BISI, the outstanding RAI on the I&C side. So,  
21      that's not --

22           CHAIRMAN STETKAR:    Yes, I understand  
23      there's an RAI on that.

24           MR.   SPRENGEL:       That's an ongoing  
25      discussion.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   CHAIRMAN STETKAR:     Yes, that's not  
2 particularly focused on that part of it.

3                   MR. SPRENGEL:   And then just this final  
4 portion, we will provide information on the reason  
5 behind differences in evaluating against the minimum  
6 staffing versus maximum for the different operating  
7 modes in the task analysis.

8                   And then, also, we will follow up and  
9 confirm in relation to the HSI change process in  
10 terms of the operators configuring new alarms. It  
11 appears that has been removed. We'll follow up on  
12 that in more detail.

13                   And then, also, the confirmation of  
14 operators being able to configure trend information.

15                   CHAIRMAN STETKAR:   Yes, because that  
16 part of the process, I thought was pretty cool and I  
17 really like that because operators tend to like to  
18 see how fast and the directions things are going.  
19 And so, I hope that hasn't been somehow sort of lost.

20                   MR. SPRENGEL:   And that --

21                   CHAIRMAN STETKAR:   And, there may be  
22 other things as you go through the transcript, but I  
23 think you've probably captured --

24                   MR. SPRENGEL:   I'm pretty confident in  
25 capturing this.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: Yes, you are. I  
2 think everything else was resolved, clearly.

3 Now, before we -- we have a couple of  
4 things to do here and I'll do them on the record and  
5 then we'll go off the record and discuss a little bit  
6 more of logistics.

7 First thing that I need to do is ask if  
8 there is -- we need to get the -- I don't know if  
9 there's anyone on the bridgeline, but we need to at  
10 least find out whether there is, Girija, if you can  
11 do that.

12 Is there anyone in the room who has any  
13 comments that you'd like to make? If you want to,  
14 come up and do so now.

15 We'll see if there's indeed anyone out  
16 there on the bridgeline who might have weathered all  
17 of this and would like to say anything. Is it open,  
18 Girija?

19 If there's anyone on the bridgeline, can  
20 you do me just a favor, if you're out there, just say  
21 hello or something so that we confirm that the line  
22 is open?

23 Okay, it sounds like the line is open, I  
24 hear rumbling. So, if there's anyone out there who  
25 would like to make a comment, please identify

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1       yourself and do so.

2                   Okay, hearing none, we'll presume that  
3       no one wants to.

4                   What I'll do, this is a little bit of a  
5       departure, but only because of the order that we did  
6       things.

7                   Bill, do you have anything to say from  
8       the staff because we beat you up a little bit here  
9       and didn't give you a chance to come back up and  
10      defend yourself? So, is there anything else you'd  
11      like to supply on this?

12                  MR. WARD: No, I think Paul acknowledged  
13      that there were some things he'd like to change in  
14      the SER and we'll just look at what we've heard today  
15      and see what we might change.

16                  CHAIRMAN   STETKAR:        Okay.        Is  
17      there -- now, as we typically do, we'll go around the  
18      table and see if any of the Member have any final  
19      comments you'd like to make and I'll start with the  
20      unusually quiet but every esteemed Dr. Powers.  
21      Steve?

22                  MEMBER    SCHULTZ:        I    thought    the  
23      discussion was excellent today and really did  
24      appreciate the presentations as well as the dialogue  
25      that we have had. So, I think a lot was accomplished

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 with all of the effort that has gone before the  
2 meeting and also in the meeting today. Thank you  
3 very much.

4 CHAIRMAN STETKAR: Joy?

5 MEMBER REMPE: I don't have any  
6 additional comments, but I also appreciated the  
7 presentations.

8 CHAIRMAN STETKAR: Thank you.  
9 Ron?

10 MEMBER BALLINGER: Yes, this was the  
11 first time I've read anything like this. I'm a  
12 metallurgist, so and I --

13 CHAIRMAN STETKAR: Hence the quote on  
14 bending metal. You will never live this down.

15 MEMBER BLEY: But it had to be there.

16 MEMBER BALLINGER: Actually, my name is  
17 Roland.

18 But, I found it remarkable. I mean I was  
19 up until 1:30 in the morning reading this stuff and  
20 everything. It's the first time I have had exposure  
21 to this. And so, in spite of the fact that it'll  
22 probably take me the next 25 years to live down the  
23 metal part, I found it a fantastic experience. It  
24 was a great presentation.

25 I have been present at some of the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 earlier ones from MHI which I did not find so  
2 interesting, but actually I didn't find them so good,  
3 but this was great. So, thank you very much.

4 CHAIRMAN STETKAR: Dr. Bley?

5 MEMBER BLEY: I had a lot of things that  
6 I learned today that I probably couldn't have learned  
7 any other way. No further comments, though, thank  
8 you. It was good day.

9 CHAIRMAN STETKAR: And, in summary, this  
10 has been probably a really painful day for the folks  
11 up front here.

12 I think, I'll act with Dennis, I think  
13 that, for me, it was really, really useful. I  
14 did -- I learned technical things that I certainly,  
15 obviously, did not understand from all of the stuff  
16 that I read, regardless of, you know, whining about  
17 the vintage of different documents and things like  
18 that, I think it was really useful.

19 And, it certainly helps me to understand  
20 the design and how it evolved to where it is right  
21 now. So, I know it was painful, but I thank you  
22 very, very much for putting up with our questions and  
23 comments, and, in fact, being, you know, really,  
24 really open and honest and answering this stuff for  
25 us.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   After we close, I'd like to get together  
2           with Ryan and Bill and figure out, you know, a path  
3           forward in terms of schedule and process and things  
4           like that, but we don't need to do that on the record.

5                   So, if there is nothing else,  
6           miraculously, before 6:00, we are adjourned.

7                   (Whereupon, the above-entitled matter  
8           went off the record at 5:55 p.m.)

9  
10  
11  
12  
13  
14

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



# **Presentation to ACRS Subcommittee Chapter 18 & HFE Topical Report**

August 20, 2015

Mitsubishi Heavy Industries, Ltd.

## Lead Presenters

Ryan Sprengel, MNES

Kenji Mashio, MHI

Robert E. Hall, MHI/RTS

## Technical Experts

Takae Yamashita, MHI

Katsuhisa Takaura, MHI (over bridgeline)

Takayuki Mori, MHI (over bridgeline)

- 1. Structure of the submittals**
- 2. US-Basic HSI**
- 3. US-APWR HFE Program Management Plan**

# 1. Structure of the submittals



## DCD

#	No.	Rev.	Document Title	Issue Date	Submittal Date	MHI Ref.
1	-	4	DCD	Aug. 2013	Sep. 10, 2013	UAP-HF-13212
2	-	0	DCD Revision 4 Update Tracking Report	-	Mar. 14, 2014	UAP-HF-14025
3	-	-	DCD Markup - DCD Tier 1 Section 2.9 Markup - DCD Tier 2 Chapter 1 Markup - DCD Tier 2 Chapter 18 Markup	-	Jun. 4, 2014	UAP-HF-14042

## Topical Reports and Technical Reports (1/2)

#	No.	Rev.	Document Title	Issue Date	Submittal Date	MHI Ref.
4	MUAP-07007	6	Human-System Interface System Description	May 2014	Jun. 4, 2014	UAP-HF-14042
5	MUAP-09019	5	Human Factors Engineering Program Management Plan	Aug. 2014	Aug. 22, 2014	UAP-HF-14047
6	MUAP-13005	1	Operating Experience Review Implementation Plan	May 2014	Jun. 4, 2014	UAP-HF-14042
7	MUAP-13007	1	Functional Requirements Analysis and Function Allocation Implementation Plan	May 2014	Jun. 4, 2014	UAP-HF-14042

## Topical Reports and Technical Reports (2/2)

#	No.	Rev.	Document Title	Issue Date	Submittal Date	MHI Ref.
8	MUAP-13009	1	Task Analysis Implementation Plan	May 2014	Jun. 4, 2014	UAP-HF-14042
9	MUAP-10008	4	Staffing and Qualifications Implementation Plan	May 2014	Jun. 4, 2014	UAP-HF-14042
10	MUAP-13014	1	Human Reliability Analysis Implementation Plan	May 2014	Jun. 4, 2014	UAP-HF-14042
11	MUAP-10009	4	Human-System Interface Design Implementation Plan	May 2014	Jun. 4, 2014	UAP-HF-14042
12	MUAP-10012	4	Human Factors Verification and Validation Implementation Plan	May 2014	Jun. 4, 2014	UAP-HF-14042
13	MUAP-10013	4	Design Implementation Implementation Plan	May 2014	Jun. 4, 2014	UAP-HF-14042

## MHI Internal Documents

#	No.	Rev.	Document Title	Issue Date	Submittal Date	MHI Ref.
14	JEJC-1763-1001	2	HSI Design Style Guide	May 2008	-	
15	7DS-UAP-20140002	0	Operating Experience Review Results	Aug 2014	-	

## Topical Report

Human-System Interface System Description,  
MUAP-07007, Revision 6, May 2014

## Purpose/Key issues

- Document and obtain an approval of the US-Basic Human-System Interface (HSI) System (HSIS), incorporating HEDs identified through testing performed with U.S. licensed operators
- Introduced US-Basic HSI simulator
- Formed the foundation of the HFE Implementation Plans (IPs)

### Technical Reports

The US-APWR HFE submittals prior to design certification cover the HFE program management plan (PMP) and 8 HFE element IPs;

- HFE Program Management Plan
- Operating Experience Review (OER)
- Functional Requirements Analysis and Function Allocation (FRA/FA)
- Task Analysis (TA)
- Staffing and Qualifications (S&Q)
- Human Reliability Analysis (HRA)
- HSI Design (HD)
- Verification and Validation (V&V)
- Design Implementation (DI)

- The PMP and IPs address specific HFE activities and provide detailed methodologies for addressing review criteria
- The PMP and IPs each follow the same outline as defined below;

Section 1: Purpose

Section 2: Scope

Section 3: Methodology Overview

Section 4: Methodology

Section 5: Implementation Team

Section 6: Results Summary Report Content

Section 7: NUREG-0711 Compliance Evaluation

Section 8: References

- HFE activities related to procedure development and training program development are addressed by programs discussed in Chapter 13, Conduct of Operations

### **COL Items**

- COL Applicants address the HFE requirements associated with Human Performance Monitoring

### For audit

Following supporting documents were not docketed but audited by NRC staff;

- HSI Design Style Guide
- OER Results

Results summary reports will be submitted following the completion of each HFE activity;

- OER (The Basic HSIS OER completed)
- FRA/FA
- TA
- S&Q
- HD
- V&V
- DI



ITAAC, DCD Tier 1 Section 2.9 Table 2.9-1 (UAP-HF-14042)


Design Commitment	Inspections, Tests, Analyses	Acceptance Criteria
1. The Control Room design incorporates human factors engineering principles that minimize the potential for operator error.	1. An Integrated System Validation (ISV) test will be performed in accordance with the Human Factors Verification and Validation implementation Plan.	1. All pass/fail criteria associated with each test scenario are passed either on initial performance of the scenarios or following remediation of failures.
2. The as-built Control Room Human-System Interface is consistent with the final validated design specifications.	2. An inspection of the as-built Control Room Human-System Interfaces will be performed.	2. The as-built Control Room Human-System Interface conforms to the validated design with no configuration deviations.

# 1.5 Summary of Document Structure

## US-Basic HSI Plant Specific Design Application

### Licensing Phase

### Design Phase



## 2. US-Basic HSI

### Documentation of US-Basic HSI features and functions

- Submitted as a topical report, MUAP-07007

### The document structure:

- Concept of Operation
- Control room layout
- Display overview and display navigation
- Operational VDU display
- Safety VDU
- Alarms

- Computer-based procedures
- Large Display Panel
- Automatic Checking of Actuations
- Diverse HSI Panel
- History of Development of Japanese PWR Main Control Room by Mitsubishi and Japanese PWR Power Utilities (Appendix A)
- HFE V&V Experience in Japan (Appendix B)
- US-Basic HSIS Evaluation Program (Appendix C)

### Background

- MHI used the foundational elements of the Japanese-Basic HSIS as a starting point to create the US-Basic HSIS, applying combinations of design review, redesign, and design validation through a phased implementation
- Appendix A contains information about the Japanese-Basic HSIS & development history
  - Developed Japanese-Basic HSIS with Japanese utilities from 1987 to 2003 with guidance from NUREG-0711 and NUREG-0700
  - Japanese operators were involved in conducting V&V
  - Introduced Japanese HSIS to Japanese latest plant design and MCR modernization
  - No performance issues identified

- The Japanese HSIS, as applied in the U.S., is comprised of;
  - The Basic HSIS
  - The HSI Inventory (i.e., controls, displays, alarms) which will be developed as a part of the plant-specific analysis phase of the HFE design program
  
- The HSI Inventory is developed as part of the US-APWR DC in accordance with the US-APWR HFE program

Phase 1 (Topical Report scope)

Translated the Japanese-Basic HSIS to the US-Basic HSIS

Phase 2

Develop an application specific (e.g. US-APWR) inventory, which will be combined with the US-Basic HSIS to yield an application specific design

Phase 3

Confirm the site-specific assumptions of Phase 2 and/or make minor site specific changes to finalize the application design



### Phase 1

Translated the Japanese-Basic HSIS to the US-Basic HSIS

#### Phase 1a

- Addressed language, engineering units, anthropometric changes to the consoles for American body types
- Adopted the US-style step-by-step operating procedures
- Made improvements identified from completing the OER program element from NUREG-0711 which included U.S. nuclear plants and additional, generic, digital HSI technology experience

#### Phase 1b

- Resolved deficiencies from Phase 1a, validated design changes, and updated Section 4 of the topical report (Revision 2) to reflect these changes

## 2.6 The US-Basic HSIS test

- In Phase 1a and 1b, the tests were implemented using the
  - US-Basic HSIS simulator
  - Static portable HSIS analysis tool
- U.S. licensed operators participated in dynamic testing: 8 crews (22 persons in total (Phase 1a)) and 5 crews (10 persons (Phase 1b))
- Went through seven scenarios that included normal and emergency events under normal as well as degraded HSI conditions
- Phase 1a results identified difference between Japan and U.S. operation style and identified design improvements documented via HEDs
- An expert panel (HFE, I&C, plant operations, US-APWR systems engineers) was organized to resolve HEDs
- Phase 1b tested design changes

- OE Sources include;
  - NUREG/CR-6400, “HFE Insights For Advanced Reactors Based Upon Operating Experience,”
  - INPO database
  - Japan Nuclear Technologies Institute (JANTI) Nuclear Information Archives (NUCIA) database
  - Issues obtained from non-nuclear industries (similar HSIS technologies) in U.S. and Japan
- Findings were evaluated and included in the US-Basic HSIS

- The concept of operation is addressed in Section 4.1
- The US-Basic HSIS addresses the following subjects:
  - Crew composition
  - Roles and responsibilities
  - Personnel interaction with plant automation
  - Use of control room resources by crewmembers
  - Methods used to ensure good coordination of crewmember activities, including non-licensed operators, technicians, and maintenance personnel

#### ➤ Operating crew composition


- The normal MCR staffing consists of one RO and one SRO
- The normal MCR staff is supplemented by one additional SRO and one additional RO that will be at the plant to accommodate unexpected conditions
- While the HSIS is designed to support the minimum MCR staffing described above, the space and layout of the MCR are designed to accommodate the foreseen maximum number of operating and temporary staff

The S&Q IP handles further staffing levels for the US-APWR

## 2.8 US-Basic HSI Design Features

### 2.8.1 Concept of Operation (3/6)

#### MCR personnel allocation



- The computer-based HSIS provides operational visual display units (VDUs) as the fundamental interface. The operator monitors plant status and initiates actions from a VDU by touching or clicking on the appropriate sections of the screen
- The operators workload is significantly reduced by providing relevant process control information in integrated displays on the VDUs and utilizing a compact console that minimizes required operator movement
- The HSIS also provides operational support functions that utilize the computer to consolidate large amounts of data into meaningful displays
- Section 4.1 identifies further specific interfaces and responsibilities between the crew and the HSIS

- Control Room Crew coordination with the HSIS
  - Control Room Crew coordination with the HSIS is described in each HSI design feature
  - The Large Display Panel (LDP) provides Spatially Dedicated Continuously Visible (SDCV) information to the operation personnel to enhance situation awareness
    - Helps operators maintain continuous awareness of overall plant status and critical status changes
    - The secondary purpose is to help the operations staff coordination and communication by providing a common visualization of plant information
  - The Operator Console provides all monitoring and control functions which are available in the MCR so that ROs can perform all operation tasks using the Operator Console from a seated position



## 2.8 US-Basic HSI Design Features

### 2.8.1 Concept of Operation (6/6)

- The Supervisor Console, located behind the RO, provides the same display set as those on the Operator Console, without control functions
- The STA console provides the same display set as those on the Operator Console, without control functions as well
- Each console has paging phones and internal phones to communicate with local staff
- Maintenance console, which is a temporary console (disconnected from the digital data communication bus during normal plant operation) used to support an additional operator in the MCR for tests during plant shutdown conditions and periodic inspections
- Tagging feature on the O-VDU and physical tag for local component are also addressed to support maintenance activities between MCR crew and maintenance staff

## 2.8 US-Basic HSI Design Features

### 2.8.2 The US-Basic HSIS Overview


## US-Basic HSI prototype simulator



- LDP provides plant overview information and alarms to enhance MCR staff awareness of the plant status (i.e., presents spatially-dedicated continuously visible (SDCV) critical safety and power production functions with supporting component status and parameters and is the apex of entire HSI information hierarchy)
- LDP provides computer aided operator's support information;
  - i) OK monitors (computer checking relevant component status at Reactor Trip, ECCS, CV isolation, etc.,)
  - ii) Critical safety function status
  - iii) Bypass or inoperable status indication (BISI) along with safety signals (e.g., Reactor Trip, ECCS, CV isolation)

Additional detailed information is displayed in the O-VDU screens

Large Display Screen Panel  
(100 inches × 4)




LDP screen display features;

- Four 100-inch diagonal screens
- Three screens are fixed
- One screen is variable and the information displayed can be changed manually or automatically

# 2.8 US-Basic HSI Design Features

## 2.8.3 Large Display Panel (3/4)

### LDP screen display features (fixed screens)





## 2.8 US-Basic HSI Design Features

### 2.8.3 Large Display Panel (4/4)


#### Left panel

#### System Auto Status Monitor

#### Partial Trip Monitor

#### Critical Safety Function Monitor


#### Plant Safety Feature Actuation Signals



#### OK Monitor BISI Monitor

## 2.8 US-Basic HSI Design Features

### 2.8.4 Operator Console Layout




VDU application	Main purpose
operational VDU	To execute all of the plant control and monitoring functions, including control of the safety systems.
safety VDU	To execute the safety-related control and monitoring functions as a backup for the Operational VDU. It can control operation signals from the Operational VDU.
alarm VDU	To acknowledge and display individual alarms using prioritization color codes. Alarm VDU also provides the alarm confirmation/non-confirmation information to the operator.
operating procedure VDU	To provide computer-based operation procedure displays near the operational VDU and the alarm VDU in order to facilitate and simplify the performance of operation procedure.



- Navigation considers usability, human errors and human performance improvement
- Plant information and controls are organized in fluid system mimic graphics and modulation controllers are integrated with associated trend graphs
- Dedicated displays to integrate associated parameters and controllers from different systems to support emergency operations and/or specific tasks are pre-designed and assigned as different groups in the top menu screen

### Top Menu (System-based)



System  
Display  
Request  
Area

Plant-Wide  
Request Area

Emergency  
Display  
Request Area

### Top Menu (Screen List Menu)

**SCREEN LIST MENU**

Group List				Screen Number	Screen Name
All Group	AC	AN	AS	AC-1	BRG COOLING WATER SYSTEM
BD	BS	CC	CH	AN-1	PRIMARY ANNUNCIATOR
CP	CS	CW	CX	AN-2	SECONDARY&ELECTRIC ANNUNCIATOR
DV	EM	FW	GD	AN-3	COMPUTER ALARM
GE	GS	HE	IA	AN-6	PERMISSIVE&BYPASS LIGHT
IG	JW	MO	MS	AS-1	AUX STEAM SYSTEM
RC	RF	RH	RM	BD-1	SGBD SYSTEM
RS	SF	SI	SS	BS-1	H1 PRESSURE STEAM EXTRACTION MASTER CONTROL
SW	TB	TG	TM	CC-1	CCWS (SURGE TANK PUMP)
VS	WD	WT		CC-2	CCWS (A+B HEADER)
TGL1	TGL2	TGL2S	TGL3	CC-3	CCWS (C HEADER)
TGL4	TGLG1	TGLG2	DT	CH-1	CHILLED WATER SYSTEM
BGL1	BGL2	BGLG1	BGLG2	CP-1	C/V SPRAY SYSTEM
DO	XY	MUL		CP-2	C/V MONITOR TREND
				CS-1	CVCS (CHARGING/LTDN)

-10 Page

-1 Page

+1 Page

+10 Page

Mimic Menu

LDP (Left)

LDP (Center)

LDP (Right)

Link to LDP (Variable)

VDU01

VDU03 (BD-1)

VDU05

VDU02

VDU04


VDU06

▲

▼

## 2.8 US-Basic HSI Design Features


### 2.8.6 Operational VDU Screen and Navigation (4/7)



## 2.8 US-Basic HSI Design Features


### 2.8.6 Operational VDU Screen and Navigation (5/7)

#### Control station “pop-up”



# 2.8 US-Basic HSI Design Features

## 2.8.6 Operational VDU Screen and Navigation



### Dedicated Display

EM-1

PLANT TRIP STATUS

04 / 03 / 2009    Gen PWR 99.9 %

23 : 24 : 55    Rx PWR 98.2 %

First Out Alarm

(SI)

(Reactor Trip)

(Turbine Trip)

(Generator Trip)

Reactor	Status
<input type="checkbox"/> Reactor Trip Breaker Open	CLOSE
<input type="checkbox"/> Rod Position Bottom	DRAW

Turbine	Status
<input type="checkbox"/> Emerg Shutoff Oil P Lo	NOR
<input type="checkbox"/> MSV	All Close
<input type="checkbox"/> GV	All Close
<input type="checkbox"/> RSV	All Close
<input type="checkbox"/> ICV	All Close

Generator	Status
<input type="checkbox"/> Field Circuit Breaker Open	CLOSE
<input type="checkbox"/> GLBS	— CLOSE
<input type="checkbox"/> Main Breaker	— CLOSE

NIS

Pwr Rng (%)	98.2	98.2	98.2	98.2
IR (A)	$3.0 \times 10^{-04}$		$3.0 \times 10^{-04}$	
Src Rng (cps)	—		—	

TB Spray Vlv

OK

TB Drain Vlv

OK

Extraction Related Vlv

OK

MSR Related Vlv

OK

Non-Safeguard Bus Auxiliary Trans Breaker

Safeguard Bus Emergency Trans Breaker

CLOSE

CLOSE

PLANT TRIP STATUS (EM-1)

ESF SUMMARY (EM-7)

ACCIDENT DISCRIM IND (EM-9)

◀

▶

## Alarm System

- A dedicated alarm VDU organizes and manages all alarms, presenting the alarm list by chronological order, by functional grouping, and providing alarm acknowledge and reset functions
- Alarm status is also integrated in graphical P&ID contents in O-VDU screens
- All alarms are indicated in either LDP dynamic display areas or grouped alarm tiles in LDP
- Alarm presentation has dynamic prioritized color coordination  
Red – Yellow - Green



## 2.8.7 Alarm System (2/4)

## Alarm title area

- “Primary (1)”: Primary systems besides (2)
- “Primary (2)”: Reactor/NSSS systems
- “Secondary”: Turbine system
- “Electrical”: Electrical and transmission system


## Alarm message display area

## Alarm acknowledgement/reset and screen request buttons area

[illegible]

## LDP Display

All plant alarms appear in either group alarm tiles or individual parameter titles




- Normal = “Gray Board”
- Icons/tiles typically represent multiple conditions and therefore they display highest priority with re-flash for new alarms

### Alarm Display on the LDP

Dynamic display area

	<b>NR Level</b>		Parameter type
	A	33.3 →	
Parameter status ←	<b>B LL</b>	20.0 ↘	Parameter value and trend arrow
	C	33.3 →	
	D	34.0 ↗	

First Out



#### Safety VDU Features

- The safety VDUs provide monitoring and component level control for safety functions
- The safety VDUs are designed to satisfy class 1E requirements
- They are divided into two groups:
  - Two multidivisional safety VDUs
  - Four selectable train-based safety VDUs
- The orientation and retrieval features of the safety VDU network are similar to the O-VDU network but there is significantly less information being managed
- Used with paper procedures only

## 2.8 US-Basic HSI Design Features

### 2.8.8 Safety VDU (2/11)

#### Selectable Train-based Screen (Top level operation menu)

Train A Operation Screen Menu					PMT	DCT
SA-20 ACC Tank	SA-21 Block	SA-22 CSS/RHS	SA-23 CVS	SA-24 EFS	Monitoring Menu	
SA-25 EWS	SA-26 FSS	SA-27 FWS	SA-28 IAS	SA-29 ICTS	Operation Menu	
SA-30 MCRVS	SA-31 MSS	SA-32 NCS	SA-33 NCS Surge Tank	SA-34 NIS	Task Control Menu	
SA-35 Przr	SA-36 RMS	SA-37 RPS Bypass/Reset 1/2	SA-38 RPS Bypass/Reset 2/2	SA-39 RPS Trip/Reset 1/2	▲ ▼	
SA-40 RPS Trip/Reset 2/2	SA-41 RWS	SA-42 SGS/PSS	SA-43 SIS	SA-44 System Level Act/Reset 1/2	Back	
SA-45 System Level Act/Reset 2/2	SA-46 Test	SA-47 VAS	SA-48 VCS	SA-49 VRS 1/2	Erase Screen	
SA-50 VRS 2/2	SA-51 VWS	SA-52 WDS Other System			N-Enable /Disable	

## 2.8 US-Basic HSI Design Features


### 2.8.8 Safety VDU (3/11)

#### Selectable Train-based Screen (The second level layer)

SA-24 CVS

				PMT	DCT
1st Chg Pump Suct Alternate Sply Vlv (A) CVSLCV031D	1st Letdown Line Isolation Valve CVSLCV361	1st VCT Outlet Isolation Valve CVSLCV031B	1st VCT Inlet Primary Water Sply Ln Isol Vlv CVSFCV128	Monitoring Menu	
2nd Letdown Line Isolation Valve CVSLCV362	2nd Seal Water Return Line Cntmt Isol Vlv CVSMOV204	A-Chg Pump CVSMPP001A	A-Chg Pump Oil Pump CVSMPP004A	Operation Menu	
A-Ltdn Orif Isolation Valve CVSAOV001A	A-Seal Inj Ln Containment Isolation Valve CVSMOV178A	A-Seal Water Return Ln 1st Isol Vlv CVSAOV192A	B-Ltdn Orif Isolation Valve CVSAOV001B	Task Control Menu	
B-Seal Inj Ln Containment Isolation Valve CVSMOV178B	B-Seal Water Return Ln 1st Isol Vlv CVSAOV192B	Charging Line Containment Isolation Valve CVSMOV152	C-Ltdn Orif Isolation Valve CVSAOV001C	▲ ▼	
C-Seal Water Return Ln 2nd Isol Vlv CVSAOV196C	D-Seal Water Return Ln 2nd Isol Vlv CVSAOV196D	Letdown Line Cntmt Inside Isolation Valve CVSAOV005		Back	
				Erase Screen	
				N-Enable /Disable	

## Selectable Train-based Screen (Soft control Screen)



## 2.8 US-Basic HSI Design Features

### 2.8.8 Safety VDU (5/11)

## Selectable Train-based Screen (Top level monitoring menu)





## 2.8 US-Basic HSI Design Features

### 2.8.8 Safety VDU (6/11)

## Selectable Train-based Screen (The second layer)

SA-1 CV				PMT	DCT
<b>Containment HRAM (R-91A) (R/h)</b>  RMSR091A    xxx1E+7 ■ XX × 10    1E+0	<b>Containment HRAM (R-91B) (R/h)</b>  RMSR091B    xxx1E+7 ■ XX × 10    1E+0	<b>CV Press (NR) (psi)</b>  CSSP010        80 ■ XX            -7	<b>CV Temp (*F)</b>  CSST020        430 ■ XX            0	Monitoring Menu	
				Operation Menu	
				Task Control Menu	
				▲ ▼	
				Back	
				Erase Screen	
				N-Enable /Disable	

## Selectable Task-based Screen







Per  
operating  
procedure

## 2.8 US-Basic HSI Design Features


### 2.8.8 Safety VDU (8/11)

Operating  
Procedure  
Step  
Number

SA-61.1		E-0 Reactor Trip				PMT	DCT
28	A-EFW Flow Control Valve EFSMOV017A 				SG NR Level (%) 44.0 EFW Flow (gpm) 0.0	Monitoring Menu	
30	SI Reset EFSA061SW1 RST					Operation Menu	
31	CV ISOL Phase A Reset EFSA063SW1 RST	CV ISOL Phase B Reset EFSA066SW1 RST				 	
32	UV Reset Undef RST					Back	
33	IA CV ISOL Valve IASMOV002 					Erase Screen	
						N-Enable /Disable	

## 2.8 US-Basic HSI Design Features

### 2.8.8 Safety VDU (9/11)



#### **Multidivisional Safety VDU screen;**


- Spatially dedicated, continuous visible (SDCV) screen on two redundant multidivisional safety VDUs
- Alarms and parameters for Credited Manual Actions and CSF monitoring
- Alarm color coding
- This information is especially useful in case of loss of the O-VDUs

## 2.8 US-Basic HSI Design Features

### 2.8.8 Safety VDU (11/11)

### Multi-divisional Safety VDU (SDCV Screen)

CR Ins Limit	PMWS	Przr Level	HS MSL Rad	CV Rad	VCT Level	CHG Flow	PMT	DCT
LO	HIGH	LO	HIGH	HIGH	LO	HIGH		
WR NIS (cps)	N-33		5.1E-11	N-34		5.1E-11		Monitoring Menu
IR SU Rate (dpm)	N-35		-5.7E-02	N-36		-5.7E-02		Operation Menu
Przr Level (%)		0.0						Task Control Menu
RCS Thot (°F)	A	255.7	B	255.7	C	255.7	D	
RCS Tcold (°F)	A	536.0	B	536.0	C	536.0	D	
RCS Pressure (psi)		18.7						
Core Ex Temp (°F)	trnA		255.7	trnD		255.7		
Subcooling (°F)	trnA		0.0	trnD		0.0		
Rx Vessel Level	trnA		VESSEL FULL	trnD		VESSEL FULL		
SG Level (NR) (%)	A	0.0	B	0.0	C	0.0	D	
SG Level (WR) (%)	A	68.0	B	68.6	C	68.1	D	
MSL Pressure (psi)	A	945.2	B	944.0	C	944.9	D	
EFW Flow (gpm)	A	224.8	B	226.0	C	225.1	D	
EFW Pit Level (%)	A   trnA	70.9	trnD	70.9	B   trnA	0.0	trnD	0.0
RWSP Level (%)	NR   trnA	95.0	trnD	95.0	WR   trnA	95.0	trnD	95.0
CS/RHR Pmp	trnA	START	trnB	START	trnC	START	trnD	START
CV Pressure (psi)		18.726						
CV Rad (mR/h)		1.87E+01						
CV Isol. (Ph A)	trnA	OK				trnD		NG
CV Isol. (Ph B)	trnA	—	trnB	—	trnC	—	trnD	—
CV Isol. (Purge)	trnA	NG				trnD		NG



#### CBP Features

- The operating procedure VDU displays procedures that are structured in accordance and compliant with the textual images from the hardcopy procedure
- Procedures are presented in a standardized format with the title and a specific procedure index in a left column display, allowing the operator to move to the desired section of a procedure
- The function bar is available at the bottom of the page to allow interface with the O-VDU. Alternatively, by selecting hyper-links on the operating procedures VDU, the related O-VDU display is automatically displayed
- The procedure menu and bookmarking controls are also provided
- Back-up of CBP system is the paper-based procedures

#### CBP Features

- The alarm VDU supports similar lateral movement by using a function key to bring up alarm response procedures on the operating procedures VDU
- In case of emergency, the operators can request the emergency procedure for a reactor trip or ECCS operation by touching the first-out alarm on the alarm VDU
- Distinctive accident procedures (e.g., LOCA, SGTR) are requested from the CBP menu screen after the operator identifies the accident condition



# 2.8 US-Basic HSI Design Features

## 2.8.9 Computer-Based Procedure System (3/3)

### CBP Screen

Options ▾ ×

Emergency Operating Procedures:

- [E-0 Reactor Trip or Safety Injection](#)
- [E-1 Loss of Reactor or Secondary Coolant](#)
- [E-2 Steam Generator Tube Rupture](#)
- [ES-0.1 Reactor Trip Response](#)
- [ES-1.3 Transfer to Cold Leg Recirculation](#)

Number: E-0 Title: REACTOR TRIP OR SAFETY INJECTION Revision: Phase 1b V&V Testing

STEP	Action	Check	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
11	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Verify Containment Spray not required: (CP-2) a. Containment pressure HAS REMAINED LESS THAN 28 psig.	a. Verify Containment Isolation / Spray Signals (OK monitor)  1) Φ B Signal • GREEN OK light lit IF Φ B signal is not actuated, then manually actuate C/V Spray. (SLCSP) IF YELLOW NG light LIT, Go to step 12. Manually close valves on (EM-4) to ensure isolation in both trains as time permits. IF RED NG light LIT, align components on (EM-4) to establish one train of Φ B isolation. Continue efforts to establish both trains as time permits.  2) CS Signal • GREEN OK light lit IF CS signal is not actuated,

8.27 x 11.69 in

7 of 15

1 Display 2 Display 3 Display Menu Alarm Menu Attach Bookmark Clear Bookmark Clear All Bookmarks

### **3. US-APWR HFE Program Management Plan**

- ✓ The US-APWR HFE program implementation is in accordance with NUREG-0711, Revision 2, “Human Factors Engineering Program Review Model,” issued February 2004.
- ✓ The HFE program assures that the HSI reflects modern human factors principles and satisfies the applicable regulatory requirements.
- ✓ The resulting HSI supports safe, efficient and reliable operator performance, test, maintenance and surveillance tasks

### 3. US-APWR HFE PMP (2/7)


✓ The following HFE elements (as defined in NUREG-0711, Revision 2) are covered by the US-APWR HFE Program:

- HFE PMP
- OER
- FRA/FA
- TA
- S&Q
- HRA
- HD
- Operating Procedure Development\*
- Training Program Development\*
- V&V
- DI
- HPM\*\*

\* Procedure Development and Training program development will be reviewed in Chapter 13, Conduct of operation

\*\* COL applicants will develop HPM program

### 3. US-APWR HFE PMP (3/7)



- ✓ The scope of the HFE PMP includes:
  - HFE design team and organization, roles and responsibilities
  - HFE process and procedures
  - HFE issues tracking (HED process)
  - HFE technical program
  - Combined license (COL) information
  
- ✓ For HFE activities completed within the scope of the US-APWR design, the program element methodology is described within an implementation plan (IP) and the element is documented in a results summary report (ReSR) as per the IP.

#### ➤ **Assumptions and Constraints Identification**

- ✓ The US-APWR HSIS is based on application of the US-Basic HSIS, which establishes the generic monitoring, alarm, control, and computerized procedure technologies to be employed in the MCR for all plant systems.
- ✓ The generic HSI technologies of the US-Basic HSIS are combined with the specific HSI inventory needed for the US-APWR plant design to create the US-APWR HSIS.
- ✓ The development process for a US-APWR site-specific HSIS confirms or changes the HSI inventory to reflect a site-specific plant.

#### ➤ **Assumptions and Constraints Identification (Cont.)**

- ✓ A fundamental design assumption and constraint of the US-Basic HSIS that also applies to the US-APWR HSIS is that the plant can be operated with minimum operation staff, one RO and one SRO in the MCR during postulated plant operating modes.




#### ➤ **Applicable Plant Facilities**

- ✓ MCR
- ✓ Remote shutdown room (RSR)
- ✓ Technical support center (TSC)
- ✓ Local control stations\* (LCSs)
- ✓ Emergency operations facilities\* (EOFs)

\* Portion of stations or facilities

AL	administrative workload	ECSS	emergency core cooling system
AOO	anticipated operational occurrences	FA	function allocation
AOP	alarm operating procedure	FL	critical function workload
BISI	bypassed and inoperable status indication	FRA	functional requirements analysis
CBP	computer-based operating procedure	FWS	main feedwater system
CSF	critical safety function	GOP	general operating procedure
CCF	common cause failure	HED	human engineering discrepancy
COL	combined license	HF	human factors
CV	containment vessel	HFE	human factors engineering
D3	defense-in-depth and diversity	HPM	human performance monitoring
D3CA	defense-in-depth and diversity coping analysis	HRA	human reliability analysis
DC	design certification	HD	human-system interface design
DCA	design change analysis	HSI	human-system interface
DHP	diverse human-system interface panel	HSIS	human-system interface system
DI	design implementation	I&C	instrumentation and control
DIHA	deterministically important human action	IHA	important human action
EFW	emergency feedwater	IP	implementation plan
EOF	emergency operations facility	ISV	integrated system validation
EOP	emergency operating procedure	LCS	local control station
		LDP	large display panel
		MCR	main control room

MHI	Mitsubishi Heavy Industries, Ltd.	RO	reactor operator
MNES	Mitsubishi Nuclear Energy Systems, Inc.	ReSR	results summary report
MS	main steam	RSR	remote shutdown room
NASA	National Aeronautics and Space Administration	RT	reactor trip
NI	nuclear island	S&Q	staffing and qualifications
NOP	normal operating procedure	SDCV	spatially dedicated, continuously visible
NSSS	nuclear steam supply system	SG	steam generator
OCS	operational conditions sampling	SME	subject-matter expert
OER	operating experience review	SRO	senior reactor operator
O-VDU	operational-visual display unit	SRP	Standard Review Plan
PA	postulated accident	STA	shift technical advisor
PAM	post-accident monitoring	TA	task analysis
P&ID	piping and instrumentation diagram	TAA	transient and accident analyses
PCMS	plant control and monitoring system	TI	turbine island
PMP	program management plan	TLX	Task Load Index
PRA	probabilistic risk assessment	TSC	technical support center
QA	quality assurance	US-APWR	U.S. advanced pressurized-water reactor
RCS	reactor coolant system	V&V	verification and validation
RIHA	risk-important human action	VDU	visual display unit



Our Technologies, Your Tomorrow

A thick red horizontal line with a slight upward curve at the right end, acting as a decorative underline for the text above.



# **Mitsubishi APWR Design Certification Review**

---

## **SER Chapter 18 Human Factors Engineering Program**

Presentation to the ACRS Subcommittee  
August 20, 2015



# Chapter 18 Review Team

## Technical Staff

- **Paul Pieringer**, Technical Reviewer, COLP/DCIP
- **Jacqwan Walker**, Technical Reviewer, COLP/DCIP

## Project Manager

- **Bill Ward**, Project Manager, NWE2/DNRL

# Overview

- The HFE design described in the Topical Report conforms to NUREG-0700
- DCD Scope conforms to NUREG-0711, revision 2; implementation plans are complete and level of detail is sufficient to assess implementation effectiveness
- One confirmatory item to verify DCD, chapter 18 is updated to reflect latest revisions in the implementation plans
- Final design results are provided for the following HFE elements: HFE Program Management, Operating Experience, Human Reliability Analysis

# Topical Report Comments

- The US-Basic Human-System Interface (HSI) System is the most detailed design description we have reviewed.
- Through an audit and review of the HFE design descriptions, the “hardware” design was verified to conform to NUREG-0700.
- Full scope simulator was used effectively in the design process

## Issue:

- Control of safety related equipment through the Operational VDUs vice the Safety VDUs



# Design Certification Comments

- Reviewed to ensure the appropriate Implementation Plan was included by reference and there were no inconsistencies with the Implementation Plan.

## Issue:

- DAC introduces complexity.

## Significant changes in regulatory strategy:

- Two ITAAC verses an ITAAC for every element submitted at the Implementation Plan level

# ITAAC

Design Commitment	Inspections, Tests, Analyses	Acceptance Criteria
<ol style="list-style-type: none"> <li>1. Thee Control Room design incorporates human factors engineering principles that minimize the potential for operator error.</li> <li>2. The as-built Control Room Human-System Interface is consistent with the final validated design specification.</li> </ol>	<ol style="list-style-type: none"> <li>1. An integrated system validation (ISV) test will be performed in accordance with the Human Factors verification and validation Implementation Plan.</li> <li>2. An inspection of the as-built Control Room Human-System Interfaces will be performed.</li> </ol>	<ol style="list-style-type: none"> <li>1. All pass/fail criteria associated with each test scenario are passed either on initial performance of the scenarios or following remediation of failures.</li> <li>2. The as-built Control Room Human-System Interface conforms to the validated design with no configuration deviations.</li> </ol>

# Implementation Plan comments

- NUREG-0711, revision 3, addresses “Important Human Actions” which adds credited manual actions to risk important human actions. MHI chose to expand their scope to “Important Human Actions.”
- Procedure and training elements are addressed in Chapter 13 to avoid duplication of work.
- Prompting alarms, alarm logic
- Detailed process descriptions
- Phased validation process

# Conclusions

- The topical report describes an acceptable main control room and HSI configuration. It is an acceptable generic platform on which to add specific HFE design requirements identified through the implementation plans contained in Chapter 18 of the APWR DCD.
- DCD Chapter 18 and the associated ITAAC provide reasonable assurance that acceptable HFE practices will be incorporated into APWR design.

## Backup – Nureg-0711 information

<b>Planning and Analysis</b>	<b>Design</b>	<b>Verification and Validation</b>	<b>Implementation and Operation</b>
HFE Program Management			
Operating Experience Review	HSI Design		Design Implementation
Functional Requirements Analysis and Function Allocation	Procedure Development	Human Factors Verification and Validation	
Task Analysis	Training Program Development		Human Performance Monitoring
Staffing and Qualifications			
HRA			

# Backup – Program Management

- ✓ The scope of the HFE program management plan includes:
  - HFE design team and organization: roles and responsibilities
  - HFE process and procedures
  - HFE issues tracking (HED process)
  - HFE technical program
  - Combined license (COL) information

# Backup – Program Management

## ➤ **Assumptions and Constraints Identification**

- ✓ A fundamental design assumption and constraint of the US-Basic HSIS that also applies to the US-APWR HSIS is that the plant can be operated with minimum operation staff, one reactor operator (RO) and one senior reactor operator (SRO) in the MCR during postulated plant operating modes.
- ✓ The US-APWR HSI System (HSIS) is based on application of the US-Basic HSIS, which establishes the generic monitoring, alarm, control, and computerized procedure technologies to be employed in the main control room (MCR) for all plant systems.

# Backup – Program Management

## ➤ **Applicable Plant Facilities**

- ✓ MCR
- ✓ Remote shutdown room (RSR)
- ✓ Technical support center (TSC)
- ✓ Local control stations (LCSs)
- ✓ Emergency operations facilities (EOFs)



# Backup – Program Management

## ➤ **HFE Team and Organization**

- ✓ The HFE team's areas of responsibility with respect to the HFE program (including scheduling of activities and milestones)
- ✓ HFE team is positioned within the design organization so there is reasonable assurance it will have authority to accomplish its areas of responsibility and to identify problems in the implementation of the overall plant design
- ✓ Design team composition and expertise is described

# Backup – Program Management

## ➤ **HFE Issues Tracking**

- ✓ HFE issues and concerns that are not immediately resolved are entered in the HFE issues tracking system.
- ✓ These issues are referred to as Human Engineering Discrepancies (HED). The HFE design team members are responsible for issue logging, tracking, resolution, and resolution acceptance.
- ✓ The HFE issues tracking system is integrated with the existing tracking system used for the US-APWR design effort as a whole.

# Backup – Operating Experience

## Sources

- ✓ Nuclear and non-nuclear sources of OE information to be evaluated.
  - Predecessor/related plants and systems
  - Recognized industry HFE issues from NUREG/CR-6400
  - Similar technology (i.e. Touch screens operation) issues corrected from the other industries
- ✓ Issues identified through interviews conducted with plant operators during the development of the US-Basic HSIS.

## Analysis

- ✓ Evaluate to determine whether the issue is applicable to the US-APWR, and resolved by the US-Basic HSIS or by the US-APWR (plant design, HSI inventory, or HFE process).


# Backup – Functional Requirements Analysis

## Specification of functional requirements

- ✓ Development of success paths for each mode and condition includes: Identification of sub-functions, systems, components and actions
- ✓ Conditions indicating high-level function is needed
- ✓ Parameter indicating the high-level function is available, operating, achieving purpose, and can or should be terminated
- ✓ Ensure Success Paths for Postulated accidents and anticipated operational occurrences

Performed by subject matter experts

# Backup – Functional Requirements Analysis



## Backup – Functional Allocation

- ✓ FA is a systematic method of allocating the success path actions identified in the FRA. These success path actions are allocated to machine (automated), human (manual), or shared (combination of machine and human) controls
- ✓ FA identifies the following characteristics which are obtained from IEC 60964 and 61839, and uses them to discern actions best suited for machine or human:
  - Load
  - Time Available
  - Rate
  - Complexity of Action Logic
  - Decision Types and Complexity

## Backup – FRA/FA

- ✓ After the initial FRA and FA, the SMEs perform the following review:
  - IHAs are reviewed to ensure that success paths exist to address events associated with these actions and that they are appropriately allocated to the operator.
  - OER issues, related to high-level functions or success paths are identified and then reviewed to ensure FA adequately addresses the OER issue (i.e., verify that allocation expectation from OER matches the FA results to avoid similar issues)
- ✓ Compare the FRA/FA allocations with allocations extracted from design document, then generate HEDs if mismatches are found.
- ✓ Resolve, reevaluate and verify FRA/FA

# Backup – Task Analysis

## Task Selection:

- ✓ Tasks which are needed to execute operating procedures (normal, abnormal, emergency, and alarm response) are gone through by a basic task analysis.
- ✓ Additional tasks, from surveillance, test, inspection, and maintenance procedures conducted by operations personnel, are also identified by plant operation SMEs who review and understand the US-APWR design and US-APWR OER report (i.e., IHAs, and tasks causing negative consequence, and plant transient)



# Backup – Task Analysis

## Basic Task Analysis:

### ✓ Task Narrative specifies:

Overview, IHA, Actions, HSI Inventory, Staff, Time Constraints, Procedures, Decision making, Communications, Support, Situation, Workplace Factors and Hazards, Plant Condition, Critical Functions, Precursor Human Actions, HEDs

### ✓ HSI Inventory:

Process Indications: Measured Parameter, Range, Units, Resolution, Refresh/Update Rate, Display Characteristics, Trend, Automated Calculations, Alarms

Controlled Components: Equipment, Control Function, Indications, Alarms, Interlocks/Blocks/Overrides

# Backup – Task Analysis

## Task Evaluation:

- Time Constraint – Record the operational time constraint

A detailed TA is conducted for all tasks with operational time constraints

- OER – Identify a similar task identified in the OER

A detailed TA is conducted for tasks with unresolved OER concerns

- FRA/FA – Identified task, associates to “success path” in the FRA/FA;

A detailed TA is conducted for tasks with allocation concerns

- IHA –Record the IHA; A detailed TA is conducted for IHAs

- Precursor Human Actions – A detailed TA is conducted for tasks that include human actions that, if performed incorrectly potentially have negative consequences (such as precursors to plant transients)

- Task Burden – Identify “questionable” tasks which may cause task burden based on SME’s judgment. A detailed TA is conducted for all “questionable” task burden results

- Staffing – Identify “questionable” tasks which may be regarded as difficult to be execute with minimum or maximum operator staffing

# Backup – Task Analysis

## Task Evaluation:

- Communication –A detailed TA is conducted for tasks requiring communication with personnel outside the control room for plant operating modes
- Local Actions –Identify task involves local actions in areas with accessibility limits (e.g., hazardous areas, potential concerns for personnel safety, special security restricted areas, accessible only with special equipment)
- Support Actions – Identify support tasks undertaken by operators during maintenance, tests, inspections, and surveillances, which may cause task burden.
- New or Unique Actions – Identify tasks, are unique (not consistent with predecessor plants)
- HED – Identify HEDs, should be evaluated in the TA for their resolution

# Backup – Task Analysis

## Detailed Task Analysis:

- A detailed TA uses a time analysis to confirm the acceptability of the operator actions, workload, and HSI inventory evaluated in the basic TA or to identify HEDs that must be resolved to achieve acceptable results.
- Analyze in detail operator action times constructed with OSDs (Operation Sequence Diagrams) and assessments of additional duration required for decision making, communications, workplace factors and hazards, task support requirements, and situational and performance-shaping factors.
- These factors are used to determine the timeline for operators to perform the task.
- Task difficulty, complexity, frequency, and accuracy are used to adjust the time line for stress induced mental workload

# Backup – Task Analysis

## Backup – Staffing and Quals

- ✓ The S&Q employs two distinct methods for determining the personnel staffing and qualifications
  - The first method applies to the operating crew
  - The second method applies to non-operations personnel that directly support plant safety

**Step1** Establish a staffing baseline (i.e., initial staffing level):

- a. For the operating crew this baseline is established based on inputs from the previous HFE program elements (i.e., design constraint in PMP, OER, FRA/FA, TA, HRA, US-APWR basic design concept)
- b. For non-operations positions this baseline is extracted from a predecessor plant

**Step2** Evaluate the baseline to establish the final US-APWR S&Q

# Backup – Staffing and Quals

## Step 1 - Initial staffing baseline settlement

- ✓ For operations personnel, the staffing baseline reflects the minimum operating crew design constraint for plant operating modes, and the output of TA for plant shutdown modes. The operating crew staffing baseline also reflects the resolution of staffing related HEDs from development of the US-Basic HSIS and from the US-APWR OER, FRA/FA, HRA and TA. These initial baselines for staffing levels comply with 10 CFR 50.54.
- ✓ For non-operations personnel, the staffing baseline reflects the staffing levels of predecessor four-loop PWR plants for non-operations positions.
- ✓ The qualifications requirements for the US-APWR staff are consistent with current U.S. four loop PWR plants and are reflected in personnel job titles.

# Backup – Staffing and Quals

## Step 2 - Evaluation

- ✓ The S&Q for the plant operating crew is conducted by plant operations SMEs, with support from HFE SMEs and SMEs on the design of the US-APWR technology and systems.
- ✓ The S&Q team evaluates the staffing baseline through an aggregate overall job assessment that compares this US-APWR operating crew baseline to the operating staff at predecessor U.S. four-loop PWR plants.  
Specifically,
  - The S&Q implementation team reexamines the scenarios selected from the previous program elements within the context of GOPs, NOPs, AOPs, and EOPs.
  - The evaluation is conducted using tabletop walkthroughs of the appropriate sections of the procedures for the identified scenarios.



# Backup – Staffing and Quals

## Step 2 - Evaluation (Cont.)

The SMEs assess the design differences in the plant and the design differences in the HSI, compared to the predecessor, to ensure they are sufficient to facilitate the staffing reduction reflected in the baseline, as compared to the operator staffing for the same scenario in the predecessor plant

## Backup – Human Reliability Analysis

- ✓ The HRA establishes the process for identification and treatment of IHAs in the HFE program.
- ✓ IHAs comprise the:
  - Risk-important human actions (RIHAs) contained in the PRA; from Chapter 19, Probabilistic Risk Assessment and Severe Accident Evaluation
  - Deterministically important human actions (DIHAs) from;
    - Transient and accident analysis (TAA) described in Chapter 15, Transient and Accident Analyses
    - Defense-in-depth and diversity coping analysis (D3CA) described in Chapter 7, Instrumentation and Controls

# Backup – Human Reliability Analysis

Treatment of IHAs in the other HFE programs:

## ✓ OER

The OER confirms that the PRA has adequately considered operating experience documented in the OER in establishing the potential for human performance errors.

## ✓ FRA/FA

FRA/FA verifies that the IHAs identified in HRA are appropriately allocated.

## ✓ TA

TA confirms the assumptions about HFE characteristics used in the PRA to determine HEPs and the assumptions used in the TAA and D3CA to conclude that operators can execute DIHAs within the time available.

# Backup – Human Reliability Analysis

## Treatment of IHAs in the other HFE programs (CONT):

### ✓ S&Q

The staffing defined by TA is used as the operating crew baseline for further evaluation in the S&Q program element. the S&Q implementation team reexamines IHAs as they are aggregated in abnormal and emergency operating procedures.

### ✓ HSI Design (HD)

The HD ensures that the assumptions about HSI characteristics for all IHAs are implemented in the HD (e.g., control availability from the MCR, prompting alarms to reduce time required for HAs).

### ✓ Operating Procedure

Plant design specifications include basic operation sequences and/or guidance, which comply with task performance requirements for IHAs as plant design assumptions. The operating procedures are developed to meet the operation sequences and guidance in the plant design specifications.

### ✓ Training Program

Training materials and the training program include guidance and special annotations for IHAs, which are verified by the training program developers.

# Backup – Human Reliability Analysis

## Treatment of IHAs in the other HFE programs (CONT):

### ✓ V&V

The adequacy of the HD in supporting operator performance for IHAs is confirmed in the integrated system validation (ISV) process. The scenarios addressed in the ISV address the IHAs, dominant sequences, systems, and events.

### ✓ Design Implementation (DI)

One objective of DI is to demonstrate systematically that the HD that is implemented (i.e., the as-built design) accurately reflects the design that has been verified and validated in the V&V program element. This includes the HSI employed for IHAs.

# Backup – HSI System Design

## **HSI development process**

- ✓ The development of the US-APWR HSIS starts with the evaluation of design inputs, including personnel task requirements, system requirements, and regulatory requirements, that lead to a concept of operations, HSI functional requirements specification, and, ultimately, to an HSI design concept.
- ✓ This process has culminated in the US-Basic HSIS and was documented in the Topical Report
- ✓ The US-APWR HSI design focuses on creating the specific HSI inventory that encompass the alarms, indications, controls, and procedures needed to operate the US-APWR. This development process uses the HSI inventory requirements defined by the US-APWR plant system designs and by input of analysis of personnel task requirements, as extracted from predecessor HFE elements (i.e., OER, FRA/FA, TA, S&Q and HRA)

## Backup – HSI System Design

### **HSI Detailed Design and Integration**

The HSI detailed design and integration is performed based on the following:

- Any changes to the US-Basic HSIS that may result from US-Basic HSI HED resolutions (including OER)
- The output of US-APWR FRA/FA, TA, HRA, and S&Q, including resolution of any HEDs pertinent to the US-Basic HSIS and US-APWR HSI inventory

### **HSI Test & Evaluations (T&Es)**

- ✓ Performance test for the basic HSIS has been performed.
- ✓ Additional performance test integrating HSI inventories are to be performed for the complex elements of HSI inventory.

# Backup – Verification and Validation

## ➤ Operational conditions sampling (OCS)

### (1) Sampling dimensions

- Plant conditions
- Personnel tasks
- Range of situational factors known to challenge human performance
- HSI features

### (2) Identification of scenarios

## ➤ Design verification

### (1) HSI Inventory and Characterization

### (2) HSI task support verification

### (3) HFE design verification



# Backup – Verification and Validation

## ➤ Integrated system validation (ISV)

- (1) Test objectives
- (2) Validation test beds
- (3) Plant personnel
- (4) Scenario definition
- (5) Performance measurement
- (6) Test design
- (7) Data analysis and interpretation
- (8) Validation conclusions

## ➤ HED resolution

- The V&V methodology is based on lessons learned from the V&V program conducted during the HSI design phase

# Backup – Verification and Validation

## ➤ Design verification

### (1) HSI Inventory and Characterization

- A unique identification code number or name
- Associated plant system and subsystem
- Associated personnel functions/sub-functions
- Type of HSI component
  - Computer-based controls (e.g., touch screen, keyboard)
  - Hard-wired controls (e.g., J-handle control, push button, automatic controller)
  - Computer-based displays (e.g., text, digital value, analog representation)
  - Hard-wired displays (e.g., dial, gauge)
- Display characteristics and functionality (e.g., plant variables/parameters, units of measure, accuracy, precision of display, dynamic response, display format (bar chart, trend plot, trend arrow, digital value))
- Control characteristics and functionality (e.g., continuous versus discrete settings, number and type of control modes, accuracy, precision, dynamic response, control format (touch screen, keyboard, hard switches))
- User–system interaction and dialogue types (e.g., navigation aids, menus)
- Location in data management system (e.g., screen identification number)
- Physical location in the HSI (e.g., panel identification number)

# Backup – Verification and Validation

## (2) HSI task support verification

- *Criteria identification:*

*Criteria extracted from the TA result,*

- Task requirements identified by the TA

- *General methodology:*

- Conducts a detailed comparison of the personnel task requirements identified by the TA with the available alarms, displays, information sources, and control capabilities in the HSI inventory; the use of a procedure is one way to control bias and assure consistency in the individual reviews
- Assessment of the CBP system design (e.g., display design, display content, navigation links, and recordkeeping) and the procedures completeness; a checklist method is used in this task support verification.
- The checklist is developed by extracting the HSI inventory and characteristics from the TA
- A documented list of each team members findings that is used to develop a team consensus

# Backup – Verification and Validation

## (3) HFE Design Verification

The HFE design verification is conducted to confirm that the characteristics of the US-APWR HSIS and US-APWR local HSIs conform to HFE guidelines as presented in the HSI Design Style Guide.

In order to simplify the application of the guidelines and results reporting, the guidelines are applied to the HSI based on level of feature;

- *Global features*

Features that relate to configurational and environmental aspects of the HSI

- *Standard features*

Features that are generically designated for plant wide application by the US-APWR HSI Design Style Guide and are applied across the controls and displays

- *Detailed features*

Features that are aspects of a specific HSI are not addressed by the US-APWR HSI Design Style Guide and must reference either NUREG-0700 or industry-accepted guidance

# Backup – Verification and Validation

## ➤ Design validation

### (4) Integrated System Validation (1/4)

- ✓ The ISV is the process by which an integrated system design (i.e., hardware, software, and personnel elements) is evaluated using performance-based tests to determine whether it acceptably supports safe operation of the plant.
- ✓ The ISV is considered complete when the HSI has achieved the acceptance criteria for each validation scenario by and the data analysis from the ISV, including an evaluation of the extent of the HEDs, is completed. If the HSI does not successfully achieve the pass/fail criteria with all three crews, based on the initial assumption of a minimum of three crews as stated above an HED is generated, the HED resolution is implemented, and that scenario is repeated with an additional crew.

# Backup – Verification and Validation

## **(4) Integrated System Validation (2/4)**

- ✓ The ISV also results in the identification of performance improvements. HEDs are also generated for performance improvements, but these are clearly distinguished from HEDs related to pass/fail criteria. HEDs for performance improvements can be resolved after the ISV is completed but before any site-specific as-built implementation is evaluated in DI.
  
- ✓ The ISV applies specific tools:
  - PC Tool
  - Dynamic Simulator
  - Mockups

Note: HSI design elements that can not be tested using the tools are identified and tested on the as built plant

# Backup – Verification and Validation

## (4) Integrated System Validation (3/4)

### ✓ **Validation Conclusions (Section 4.3.8)**

(1) Document the statistical and logical bases for determining that the performance of the integrated system is acceptable.

(2) Document that the limitations of the ISV are considered in terms of identifying their possible effects on validation conclusions and that the impact on DI is considered, including the following:

- Aspects of the tests that were not well controlled
- Potential differences between the test situation and actual operations, such as absence of productivity–safety conflicts
- Differences between the ISV design and the as-built US-APWR
- Potential differences, based on the V&V results, between the validated design and the as-built plant
- Effects of bias and remaining uncontrolled bias that have been identified during the testing
- Unforeseen events that occurred during the V&V that affect the results

## Backup – Verification and Validation

### **(4) Integrated System Validation (4/4)**

#### **Human Engineering Discrepancy Resolution (Section 4.3.9)**

The HED\* process has four steps:

- (1) Discrepancy identification and problem statement
- (2) Discrepancy evaluation
- (3) Discrepancy resolution
- (4) Discrepancy closure

\* The HED process was applied throughout the US-Basic HSI design test program to track findings and their resolutions



## Backup – Design Implementation

- ✓ The DI demonstrates that the design that is implemented (i.e., the “as-built” design) accurately reflects the design that has been verified and validated in the V&V.
- ✓ The DI identifies and evaluates aspects of the design that were not addressed in the V&V.
- ✓ The DI employs four distinct methods to evaluate the implementation of the HSI and confirm conformance to the verified and validated design:
  - Configuration control
  - As-built HSI design conformance review
  - Plant walkdowns
  - Design change analysis (DCA)