

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8008260482 DOC. DATE: 80/08/15 NOTARIZED: NO DOCKET # 05000270
 FACIL: 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co.
 AUTH. NAME: PARKER, W.O. AUTHOR AFFILIATION: Duke Power Co.
 RECIP. NAME: DENTON, H.R. RECIPIENT AFFILIATION: Office of Nuclear Reactor Regulation, Director
 REID, R.W. Operating Reactors Branch 4

SUBJECT: Forwards "Reactor Containment Bldg Integrated Leak Rate Test," per Tech Spec 6.6 & 10CFR50 App J. Test results indicate leak rate within acceptance criteria.

DISTRIBUTION CODE: A017S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1+42
 TITLE: Containment Leak Rate Testing - Appendix J

NOTES: M Cunningham: all amends to FSAR & changes to Tech Specs. 05000270

ACTION:	RECIPIENT ID CODE/NAME		COPIES		RECIPIENT ID CODE/NAME		COPIES	
			LTR	ENCL			LTR	ENCL
	REID, R.	04	7	7				
INTERNAL:	A/D CORE & CS11		1	0	CONT SYS BR 09		1	1
	D/DIR, HUM FAC10		1	0	I&E 06		2	2
	NRC PDR 02		1	1	OELD 13		1	1
	OR ASSESS BR 07		1	1	PROC/TST REV 08		1	1
	<u>REG FILE</u>	01	1					
EXTERNAL:	ACRS	12	16	16	LPDR 03		1	1
	NSIC	05	1	1				

AUG 28 1980



DUKE POWER COMPANY

POWER BUILDING

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242

WILLIAM O. PARKER, JR.
VICE PRESIDENT
STEAM PRODUCTION

TELEPHONE: AREA 704
373-4083

August 15, 1980

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555


Attention: Mr. R. W. Reid, Chief
Operating Reactors Branch No. 4

Re: Oconee Unit 2
50-270

Dear Mr. Denton:

Pursuant to Oconee Nuclear Station Technical Specification 6.6.3(f) and 10CFR 50, Appendix J, Section v.2, please find attached 15 copies of the Reactor Containment Building Integrated Leak Rate Test Report for Oconee Unit 2. The test results indicated a leak rate well within the acceptance criteria specified in Oconee Nuclear Station Technical Specification 4.4.1.1.2(b).

Very truly yours,


William O. Parker, Jr.

JLJ:vr
Attachments

cc: Mr. James P. O'Reilly

AP 17
5.11

8008260 482