

**Simulator JPM  
S1**

---

**Facility:** Davis-Besse **Task No.:** 001-021-01-0100

**Task Title:** Transfer Control Rod Group 7 from the Auxiliary Power Supply

**K/A Reference:** (001) A2.11 4.4/4.7 **Job Performance Measure No.:** S1 (NEW)

**Examinee:** \_\_\_\_\_

**NRC Examiner:** \_\_\_\_\_ **Date:** \_\_\_\_\_

**Method of testing:**

Simulated Performance \_\_\_\_ Actual Performance X

Classroom \_\_\_\_ Simulator X Plant \_\_\_\_

***Read to the examinee:***

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

**Initial Conditions:**

The plant conditions are specified in the Initial Conditions and Initiating Cues.

**Task Standard:**

Transfer Group 7 Rods to the Normal Power Supply, return ICS to Auto and trip Reactor

**Required Materials:**

DB-OP-06402, R25, Limits & Precautions and Section 4.2, Transferring Control Rod(s) from the Auxiliary Power Supply

**General References:**

None

**Initiating Cue:**

The plant conditions are specified in the Initial Conditions and Initiating Cues.

**Time Critical Task:**

No

**Alternate Path:**

Yes

**Validation Time:**

15 minutes

**SIMULATOR INSTRUCTIONS****TASK DESCRIPTION:**

Transfer Group 7 Control Rods from the Auxiliary Power Supply to the Normal Power Supply, identify undesired rod motion and trip the reactor

**INITIAL CONDITION:**

Plant stable at 50% power

Group 7 Control Rods on the Auxiliary Power Supply per DB-OP-06405 Section 4.1

Rod Control Panel in MANUAL

ICS REACTOR DEMAND Station in HAND

**ADDITIONAL SETUP/DEVIATION FROM INITIAL CONDITION:**

Misalign SUPPLY PHASES between the NORMAL and AUX Power Supplies

Fail Rod Stop Button:

A06A1A25S501-1 to OFF

**MALFUNCTIONS/FAILURE TO INSERT:**

Continuous rod insertion when Reactor Demand is placed in Auto:

L502U

**EXAMINER COPY****INITIAL CONDITIONS:**

Plant is stable at 50% Power  
Group 7 Rods are on the Auxiliary Power Supply for I&C troubleshooting  
Rod Control Panel in MANUAL  
ICS REACTOR DEMAND Station in HAND

**INITIATING CUES:**

I&C troubleshooting is complete

The Unit Supervisor directs you to transfer Group 7 Rods to the Normal Power Supply per DB-OP-06402, Section 4.2, Transferring Control Rod(s) from the Auxiliary Power Supply, and return the Rod Control Panel, ICS REACTOR DEMAND Station and the Unit Load Demand (ULD) station to Auto

**(Provide examinee a copy of DB-OP-06402, Section 4.2)**

**CANDIDATE COPY****INITIAL CONDITIONS:**

Plant is stable at 50% Power  
Group 7 Rods are on the Auxiliary Power Supply for I&C troubleshooting  
Rod Control Panel in MANUAL  
ICS REACTOR DEMAND Station in HAND

**INITIATING CUES:**

I&C troubleshooting is complete

The Unit Supervisor directs you to transfer Group 7 Rods to the Normal Power Supply per DB-OP-06402, Section 4.2, Transferring Control Rod(s) from the Auxiliary Power Supply, and return the Rod Control Panel, ICS REACTOR DEMAND Station and the Unit Load Demand (ULD) station to Auto

**PERFORMANCE INFORMATION**

NOTE: Critical steps denoted with a "C". Failure to meet any one of these standards for this item constitutes failure. Sequence is NOT critical unless denoted in the "Comments".

START TIME: _____
-------------------

1. PERFORMANCE STEP: Verify Rod Control Panel in MANUAL

STANDARD: Observe Rod Control Panel MANUAL light ON, AUTO light OFF

CUE: **None**

\_\_\_\_\_  
SAT UNSAT

2. PERFORMANCE STEP: Verify ICS REACTOR DEMAND Station in HAND

STANDARD: Observe ICS REACTOR DEMAND Station HAND light ON, AUTO light OFF

CUE: **None**

\_\_\_\_\_  
SAT UNSAT

3. PERFORMANCE STEP: Verify Rod Control Panel in SEQ BYPASS

STANDARD: Rod Control Panel SEQ BYPASS light ON

CUE: **None**

\_\_\_\_\_  
SAT UNSAT

4. PERFORMANCE STEP: Select Group 7 using GROUP SELECT switch  
.....**C**.....

STANDARD: Turn GROUP SELECT switch to group 7

Comment: Evaluator will provide Independent Verification

CUE: **None**

\_\_\_\_\_  
SAT UNSAT

- 
5. PERFORMANCE STEP: Select ALL using the SINGLE SELECT switch  
.....**C**.....

STANDARD: Turn SINGLE SELECT switch to ALL

Comment: Evaluator will provide Independent Verification

CUE: **None**

---

SAT UNSAT

- 
6. PERFORMANCE STEP: Press and release AUX  
.....**C**.....

STANDARD: Press and release AUX pushbutton. Observe AUX light ON

CUE: **None**

---

SAT UNSAT

- 
7. PERFORMANCE STEP: Press and release JOG SPEED  
.....**C**.....

STANDARD: Press and release JOG SPEED pushbutton. Observe JOG SPEED light ON

CUE: **None**

---

SAT UNSAT

- 
8. PERFORMANCE STEP: Check SUPPLY PHASES lights are ON

STANDARD: Observe SUPPLY PHASES lights are ON

CUE: **None**

---

SAT UNSAT

- 
9. PERFORMANCE STEP: Line up SUPPLY PHASES  
.....**C**.....

STANDARD: Position Rod Control T-Handle to the Insert position until SUPPLY PHASE lights are lined up across from each other

CUE: **None**

---

SAT UNSAT

10. PERFORMANCE STEP: Verify SYNC CONFIRM

STANDARD: Observe SYNC CONFIRM light is ON

CUE: **None**

---

SAT UNSAT

---

11. PERFORMANCE STEP: Press and release CLAMP

.....**C**.....

STANDARD: Press and release CLAMP pushbutton. Observe CLAMP light ON

CUE: **None**

---

SAT UNSAT

---

12. PERFORMANCE STEP: Transfer Group to Normal Power Supply

.....**C**.....

STANDARD: Press and release MANUAL XFR button. Observe MANUAL XFR light

CUE: **None**

---

SAT UNSAT

---

13. PERFORMANCE STEP: Verify Group transferred to Normal Power Supply

STANDARD: Observe PI Panel CONTROL-ON lights for Group 7 rods OFF

CUE: **None**

---

SAT UNSAT

---

14. PERFORMANCE STEP: Release Clamp

.....**C**.....

STANDARD: Press and release CLAMP REL button. Observe CLAMP light OFF

CUE: **None**

---

SAT UNSAT

---

15. PERFORMANCE STEP: Select RUN SPEED

.....**C**.....

STANDARD: Press and release RUN SPEED. Observe RUN light ON, JOG light OFF

CUE: **None**

---

SAT UNSAT

---



---

16. PERFORMANCE STEP: Select GROUP  
.....**C**.....

STANDARD: Press and release GROUP. Observe GROUP light ON

CUE: **None**

---

SAT UNSAT

---

17. PERFORMANCE STEP: Select XFR RESET  
.....**C**.....

STANDARD: Press and release XFR RESET. Observe XFR RESET light ON.

CUE: **None**

---

SAT UNSAT

---

18. PERFORMANCE STEP: Verify Group 7 controlling

STANDARD: Observe PI panel CONTROL-ON lights for the group 7 ON

CUE: **None**

---

SAT UNSAT

---

19. PERFORMANCE STEP: Select OFF using SINGLE SELECT switch

STANDARD: Turn SINGLE SELECT switch to OFF

CUE: **None**

---

SAT UNSAT

---

20. PERFORMANCE STEP: Select OFF using GROUP SELECT switch

STANDARD: Turn GROUP SELECT switch to OFF

CUE: **None**

---

SAT UNSAT

---

21. PERFORMANCE STEP: Select SEQ control for Regulating Rods  
.....**C**.....

STANDARD: Press and release SEQ. Observe SEQ light ON

CUE: **Sequence operation of the Rod Control Panel is directed by the Shift Manager**

---

SAT UNSAT

22. PERFORMANCE STEP: Transfer rod control to AUTO  
.....**C**.....

STANDARD: Press and release AUTO on the Rod Control Panel. Observe AUTO light ON and MANUAL light OFF

CUE: **None**

SAT UNSAT

**NOTE:**

**Alternate Path Starts here. When the ICS REACTOR DEMAND Station is placed in AUTO, control rods will receive a continuous IN command. The Candidate will implement the immediate actions of DB-OP-02516, CRD Malfunctions for Undesired Control Rod Motion. The ROD STOP button will be depressed and the rods will continue inserting requiring the Reactor to be tripped.**

23. PERFORMANCE STEP: Transfer ICS Reactor Demand Station to Auto  
.....**C**.....

STANDARD: Press and release AUTO on the ICS REACTOR DEMAND Station. Observe AUTO red light ON and HAND white light OFF

CUE: **None**

SAT UNSAT

24. PERFORMANCE STEP: Identify Undesired rod motion depress ROD STOP

STANDARD: Press and hold ROD STOP button and recognize rods continue inserting

COMMENT: May first attempt to stop rod motion by returning Reactor Demand Station to manual which will not stop rod motion

CUE: **None**

SAT UNSAT

25. PERFORMANCE STEP: Identify Undesired rod motion and trip Reactor  
.....**C**.....

STANDARD: Press Reactor trip button and observe rods insert

CUE: **None**

SAT UNSAT

TERMINATING CUES: This JPM is complete (Terminated by the examiner)

END TIME

**Verification of Completion**

**Job Performance Measure No.** \_\_\_\_\_

**Examinee's Name:** \_\_\_\_\_

**Examiner's Name:** \_\_\_\_\_

**Date Performed:** \_\_\_\_\_

**Facility Evaluator:** \_\_\_\_\_

**Number of Attempts:** \_\_\_\_\_

**Time to Complete:** \_\_\_\_\_

**Question Documentation:**

**Question:** \_\_\_\_\_  
\_\_\_\_\_

**Response:** \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**Result:** Satisfactory/Unsatisfactory

**Examiner's signature and date:** \_\_\_\_\_

**Simulator JPM  
S2**

---

**Facility:** Davis-Besse **Task No:** 004-044-04-0100**Task Title:** Recover from Letdown Isolation on High Temperature**K/A Reference:** (004) A4.06 3.6/3.1 **Job Performance Measure No:** S2 (JPM 017)**Examinee:** \_\_\_\_\_**NRC Examiner:** \_\_\_\_\_ **Date:** \_\_\_\_\_**Method of testing:**Simulated Performance \_\_\_\_ Actual Performance XClassroom \_\_\_\_ Simulator X Plant \_\_\_\_***Read to the examinee:***

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

**Initial Conditions:**

The plant conditions are specified in the Initial Conditions and Initiating Cues.

**Task Standard:**

Restore Letdown through Purification Demineralizer 1

**Required Materials:**

DB-OP-02523, Component Cooling Water System Malfunctions, Attachment 7

**General References:**

None

**Initiating Cue:**

The plant conditions are specified in the Initial Conditions and Initiating Cues.

**Time Critical Task:**

No

**Alternate Path:**

No

**Validation Time:**

10 Minutes

**SIMULATOR INSTRUCTIONS****TASK DESCRIPTION:**

Recover from Letdown Isolation on High Temperature

**INITIAL CONDITION:**

FPSS

**ADDITIONAL SETUP/DEVIATION FROM INITIAL CONDITION:**

Purification Demineralizer 1 in service  
MU 10A open  
MU 10B closed  
MU 1903 closed

**MALFUNCTIONS/FAILURE TO INSERT:**

Close CC 97, CCW Isolation Valve to Letdown Cooler 2  
**IRF KAD3 0.0**

After Letdown isolates on high temperature then reopen CC 97  
**IRF KAD3 0.8**

**ACTION/CUES:**

- |    |         |  |
|----|---------|--|
| 2. | ACTION: | Open MU 104, Purification Demin Bypass<br><b>IRF BM00 1.0</b>  |
|    | CUE:    | MU 104 is open   |
| 6. | ACTION: | Close MU 104, Purification Demin Bypass<br><b>IRF BM00 0.0</b> |
|    | CUE:    | MU 104 is closed   |

**EXAMINER COPY****INITIAL CONDITIONS:**

The Plant is in Mode 1

Purification Demineralizer 1 is in service

**INITIATING CUES:**

Letdown has isolated on high temperature due to a loss of CCW to Containment

The cause has been determined and corrected

The Unit Supervisor directs you to restore Letdown through Purification Demineralizer 1 using Attachment 7 of DB-OP-02523, CCW Malfunctions

**(Provide the examinee a copy of Attachment 7 of DB-OP-02523)**

**CANDIDATE COPY****INITIAL CONDITIONS:**

The Plant is in Mode 1

Purification Demineralizer 1 is in service

**INITIATING CUES:**

Letdown has isolated on high temperature due to a loss of CCW to Containment

The cause has been determined and corrected

The Unit Supervisor directs you to restore Letdown through Purification Demineralizer 1 using Attachment 7 of DB-OP-02523, CCW Malfunctions



**PERFORMANCE INFORMATION**

NOTE: Critical steps denoted with a "C". Failure to meet any one of these standards for this item constitutes failure. Sequence is NOT critical unless denoted in the "Comments".

START TIME: _____
-------------------

**PERFORMANCE INFORMATION**

NOTE: Critical steps denoted with a "C". Failure to meet any one of standards for this item constitutes failure. Sequence is NOT required unless denoted in the "Comments".

START TIME: _____
-------------------

1. PERFORMANCE STEP: Direct plant operator to open MU 104, PURIFICATION DEMINERALIZER BYPASS

STANDARD: Communicate with an Equipment Operator

COMMENT: Step 1 shall be completed prior to step 3

CUE: **MU 104 is open (given by examiner – no action required)**

\_\_\_\_\_  
SAT UNSAT

2. PERFORMANCE STEP: Isolate Purification Demineralizer 1  
.....**C**.....

STANDARD: Push close pushbutton on HIS MU10A, MIXED BED 1 LETDOWN INLET, using HISMU10A. Observe GREEN light ON. RED light off

CUE: **None**

\_\_\_\_\_  
SAT UNSAT

3. PERFORMANCE STEP: Manually override the high temperature trip signals  
.....**C**.....

STANDARD: Simultaneously depress and hold in the OPEN position:

- MU2B, LETDOWN COOLERS INLET ISOLATION, using HISMU2B – Observe RED light ON, GREEN OFF  
AND
- MU1A, RC LETDOWN COOLER 1 INLET ISOLATION, using HISMU1A – Observe RED light ON, GREEN OFF  
AND
- MU1B, RC LETDOWN COOLER 2 INLET ISOLATION, using ISMU1B – Observe RED light ON, GREEN OFF

until Annunciator 2-3-A LETDOWN TEMP HI clears AND TIMU8 is less than 125°F and then release

COMMENT: **The critical part of this step is that all three valves can remain open after releasing their respective control switches**

CUE: **None**

---

SAT UNSAT

4. PERFORMANCE STEP: Restore MU System to normal valve lineup  
.....**C**.....

STANDARD: Push OPEN pushbutton on HIS MU10A, MIXED BED 1 LETDOWN INLET, using HISMU10A. Observe RED light ON. GREEN light off

CUE: **None**

---

SAT UNSAT

5. PERFORMANCE STEP: Restore MU System to normal valve lineup

STANDARD: Contact EO to close MU 104, Purification Demin Bypass Valve

CUE: **MU 104 is closed (given by examiner – no action required)**

---

SAT UNSAT

TERMINATING CUES: This JPM is complete. (Terminated by the Examiner)

---

END TIME

**Verification of Completion**

**Job Performance Measure No.** \_\_\_\_\_

**Examinee's Name:** \_\_\_\_\_

**Examiner's Name:** \_\_\_\_\_

**Date Performed:** \_\_\_\_\_

**Facility Evaluator:** \_\_\_\_\_

**Number of Attempts:** \_\_\_\_\_

**Time to Complete:** \_\_\_\_\_

**Question Documentation:**

**Question:** \_\_\_\_\_  
\_\_\_\_\_

**Response:** \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**Result:** Satisfactory/Unsatisfactory

**Examiner's signature and date:** \_\_\_\_\_

**Simulator JPM  
S3**

---

Facility: Davis-Besse Task No: 005-012-04-0100

Task Title: Start Decay Heat Removal Pump 1 following a loss of DHR

K/A Reference: (005) A2.04 2.9/2.9 Job Performance Measure No: S3 (NEW)

Examinee: \_\_\_\_\_

NRC Examiner: \_\_\_\_\_ Date: \_\_\_\_\_

**Method of testing:**

Simulated Performance \_\_\_\_ Actual Performance X

Classroom \_\_\_\_ Simulator X Plant \_\_\_\_

***Read to the examinee:***

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

**Initial Conditions:**

The plant conditions are specified in the Initial Conditions and Initiating Cues.

**Task Standard:**

Place Decay Heat Pump 1 in service. Recognize DH14B, DH Cooler 1 Outlet valve failure and throttle downstream motor operated valve DH1B.

**Required Materials:**

DB-OP-02527, Rev. 18 Attachment 1  
3-2-H LP INJ 1 FLOW HI from DB-OP-02003

**General References:**

None

**Initiating Cue:**

The plant conditions are specified in the Initial Conditions and Initiating Cues.

**Time Critical Task:**

No

**Alternate Path:**

Yes

**Validation Time:**

20 minutes

**SIMULATOR INSTRUCTIONS****TASK DESCRIPTION:**

Start Decay Heat Pump 1, following a loss of running Decay Heat Pump 2

**INITIAL CONDITION:**

Mode 5

DH Loop 1 in STBY DH Mode per DB-OP-06012, DH and LPI Operating Procedure, Section 3.5

DH Pump 2 was in service per DB-OP-06012, DH and LPI Operating Procedure, Section 3.8  
(DH Loop 2 STBY DH Mode Section 3.6 completed prior to placing in service)

DH11 and DH12 open with control power removed

CC1467 closed

CCW non-essential header is being supplied from CCW Loop 1

Decay Heat Pump 2 tripped

**ADDITIONAL SETUP/DEVIATION FROM INITIAL CONDITION:**

Isolate CCW loads or throttle CC172, DH Cooler Outlet as required to maintain Loop 1 CCW flow less than 7800 gpm when CC1467 is opened per ATT 1 Step 6.3

Ensure Annunciator 3-2-H LP INJ 1 FLOW HI will come in when DH14B fails open, it has a variable setpoint (3750 gpm per DB-OP-06904)

Hang information tags indicating open on DH1517 and DH1518

**MALFUNCTIONS/FAILURE TO INSERT:**

When DH Pump 1 is started, DH Cooler 1 outlet valve, DH14B, will fail open

**EXAMINER COPY****INITIAL CONDITIONS:**

Mode 5

Decay Heat Pump 2 breaker AD112 tripped due to a 50/51 Instantaneous Overcurrent

**INITIATING CUES:**

The Command SRO directs you to perform Attachment 1, Starting Decay Heat Pump 1 of DB-OP-02527, Loss of Decay Heat Removal

There were NO signs of cavitation on either DH Pump

**(Provide examinee a copy of DB-OP-02527 Attachment 1)**

**CANDIDATE COPY****INITIAL CONDITIONS:**

Mode 5, RCS Filled

Decay Heat Pump 2 breaker AD112 tripped due to a 50/51 Instantaneous Overcurrent

**INITIATING CUES:**

The Command SRO directs you to perform Attachment 1, Starting Decay Heat Pump 1 of DB-OP-02527, Loss of Decay Heat Removal

There were NO signs of cavitation on either DH Pump



**PERFORMANCE INFORMATION**

NOTE: Critical steps denoted with a "C". Failure to meet any one of these standards for this item constitutes failure. Sequence is NOT critical unless denoted in the "Comments".

START TIME: _____
-------------------

1. PERFORMANCE STEP: Verify closed DH14B, DH CLR 1 OUTLET

STANDARD: Press AUTO for DH14B using HIS DH14B. Rotate knob to Close DH14B using HIC DH14B. Observe GREEN light ON, RED light OFF

COMMENT: DH14B will already be closed per standby lineup

CUE: **If asked, Instrument Air is in a normal lineup**

\_\_\_\_\_  
SAT UNSAT

2. PERFORMANCE STEP: Verify closed DH13B DH CLR 1 BYPASS

STANDARD: Press AUTO for DH13B using HIS DH13B. Rotate knob to Close DH13B using HIC DH13B. Observe GREEN light ON, RED light OFF

COMMENT: DH13B will already be closed per standby lineup

CUE: **None**

\_\_\_\_\_  
SAT UNSAT

**NOTE: Decision step here to vent pump based on cavitation. The initial cue states no evidence of cavitation on either pump so venting should be marked N/A**

3. PERFORMANCE STEP: Verify DH1517 is open

STANDARD: Verify DH1517 DH PUMP 1 SUCTION, is open using HIS 1517 per Operations Information Tag providing valve position

CUE: **None**

\_\_\_\_\_  
SAT UNSAT

4. PERFORMANCE STEP: Verify DH Drop Line valves are open using HIS DH11  
And HIS DH12

STANDARD: Verify DH Drop Line valves are open using HIS DH11  
And HIS DH12

CUE: **None**

\_\_\_\_\_  
SAT UNSAT

5. PERFORMANCE STEP: Verify Decay Heat Train 1 CCW/SW cooling is available  
.....**C**.....

STANDARD: Observes CCW Pump 1 in service. Amps indicated. RED light ON  
Open CC1467 using HIS1467. RED light ON, GREEN light OFF  
Observes SWP 1 in service. Amps indicated. RED light ON

COMMENT: Opening CC1467 is the only Critical portion of this step

CUE: **If asked, CC172 has been throttled to maintain CCW flow <7800 gpm**  
**If asked, DH Pump 1 will NOT be placed on DH/LPI Injection line 2**

SAT UNSAT

6. PERFORMANCE STEP: Verify DH1B is open

STANDARD: Observes HIS DH1B RED light ON, GREEN light OFF

CUE: **None**

SAT UNSAT

**NOTE:**

**Alternate Path Starts here. When Decay Heat Pump 1 is started, DH14B will fail open. Annunciator 3-2-H LP INJ 1 FLOW HI will alarm. Alarm procedure DB-OP-02003 will be referred to and will direct throttling of DH1B to 3000 gpm.**

7. PERFORMANCE STEP: Start Decay Heat Pump 1  
.....**C**.....

STANDARD: Rotate HIS DH6B to start. Observe Decay Heat Pump 1 amps increase.  
Observe RED light ON, GREEN light OFF. Release HIS DH6B.

CUE: **None**

SAT UNSAT

8. PERFORMANCE STEP: Respond to Annunciator 3-2-H, LP INJ 1 FLOW HI

STANDARD: Refer to DB-OP-02003, Annunciator 3-2-H LP INJ 1 FLOW HI  
Recognize DH14B has failed open

COMMENT: Annunciator 3-1-H LP INJ 1 FLOW LO should have been expected.

CUE: **If asked, EO reports DH14B can NOT be operated manually,  
indicates full open locally, no other issues noted  
If asked, hi flow set point is 3750 GPM (DB-OP-02003, 3-2-H, note 3.1)  
When identified – hand candidate 3-2-H LP INJ 1 FLOW HI alarm pages**

---

SAT UNSAT

---

9. PERFORMANCE STEP: Throttle flow with DH1B  
.....**C**.....

STANDARD: Press HISDH1B-2 ON to turn on DH1B control power.

Press close to throttle DH1B using HIS DH1B to stabilize RCS Temperature  
and monitor pump parameters

COMMENT: May initially throttle to 3000 GPM IAW Alarm procedure

CUE: **If asked for desired flow rate, ask for recommendation**

---

SAT UNSAT

---

TERMINATING CUES: This JPM is complete (Terminated by the examiner)

---

END TIME

**Verification of Completion**

**Job Performance Measure No.** \_\_\_\_\_

**Examinee's Name:** \_\_\_\_\_

**Examiner's Name:** \_\_\_\_\_

**Date Performed:** \_\_\_\_\_

**Facility Evaluator:** \_\_\_\_\_

**Number of Attempts:** \_\_\_\_\_

**Time to Complete:** \_\_\_\_\_

**Question Documentation:**

**Question:** \_\_\_\_\_  
\_\_\_\_\_

**Response:** \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**Result:** Satisfactory/Unsatisfactory

**Examiner's signature and date:** \_\_\_\_\_

**Simulator JPM  
S4**

---

**Facility:** Davis-Besse **Task No.:** 039-011-04-0100

**Task Title:** Actions for a Steam Leak on the Gland Steam Header

**K/A Reference:** (055) 051 AA2.02 3.9/4.1 **Job Performance Measure No.:** S4 (JPM 020)

**Examinee:** \_\_\_\_\_

**NRC Examiner:** \_\_\_\_\_ **Date:** \_\_\_\_\_

**Method of testing:**

Simulated Performance \_\_\_\_ Actual Performance X

Classroom \_\_\_\_ Simulator X Plant \_\_\_\_

***Read to the examinee:***

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

**Initial Conditions:**

The plant conditions are specified in the Initial Conditions and Initiating Cues

**Task Standard:**

Isolate steam leak in the Gland Steam Header and Trip the Reactor

**Required Materials:**

DB-OP-02525, Steam Leaks, Attachment 4 Step 9.0

**General References:**

None

**Initiating Cue:**

The plant conditions are specified in the Initial Conditions and Initiating Cues.

**Time Critical Task:**

No

**Alternate Path:**

Yes

**Validation Time:**

5 Minutes

**SIMULATOR INSTRUCTIONS****TASK DESCRIPTION:**

Perform actions for a steam leak on the Gland Steam Header

**INITIAL CONDITION:**

Place the simulator in a Mode 3 configuration with RCS pressure at 2155 psig and RCS temperature at 532 °F with Control Rod Safety groups 1-4 withdrawn

**ADDITIONAL SETUP/DEVIATION FROM INITIAL CONDITION:**

None

**MALFUNCTIONS/FAILURE TO INSERT:**

1. On Simulator page HP & LP TURBINE DRAINS & SEAL SYSTEM – TD1 fail open GS 1932 and GS 1931 to simulate a steam leak on GS.
2. Place simulator in run for 5 seconds then **freeze the simulation** until Examinee and Examiner are ready to start JPM
3. Take simulator to run after Examiner has read the initiating cue.

**EXAMINER COPY****INITIAL CONDITIONS:**

Plant is in Mode 3 with a plant startup in progress

The Reactor Coolant System is at normal operating pressure and temperature.

All systems are in a normal lineup.

**INITIATING CUES:**

An Equipment Operator reports a steam leak on the Gland Steam Header.

The Unit Supervisor directs you to perform step 9.0 of Attachment 4 of DB-OP-02525, Steam Leaks.

**(Provide the examinee a copy of Step 9.0 of DB-OP-02525, Attachment 4)**



**CANDIDATE COPY****INITIAL CONDITIONS:**

Plant is in Mode 3 with a plant startup in progress

The Reactor Coolant System is at normal operating pressure and temperature.

All systems are in a normal lineup.

**INITIATING CUES:**

An Equipment Operator reports a steam leak on the Gland Steam Header.

The Unit Supervisor directs you to perform step 9.0 of Attachment 4 of DB-OP-02525, Steam Leaks.

**PERFORMANCE INFORMATION**

NOTE: Critical steps denoted with a "C". Failure to meet any one of these standards for this item constitutes failure. Sequence is NOT critical unless denoted in the "Comments".

START TIME: _____
-------------------

- 
1. PERFORMANCE STEP: Verify GS 2384, Main Steam System Isolation is closed

STANDARD: Check GREEN light ON, RED light OFF on HIS 2384

CUE: **None.**

\_\_\_\_\_  
SAT UNSAT

- 
2. PERFORMANCE STEP: Close GS 2380, Aux Steam Isolation

**C**

STANDARD: Depress CLOSE on HIS 2380. GREEN light ON, RED light OFF.

CUE: **None.**

\_\_\_\_\_  
SAT UNSAT

- 
3. PERFORMANCE STEP: Verify GS 2385, Steam Supply Bypass Valve is closed

STANDARD: Check GREEN light ON, RED light OFF on HIS 2385

CUE: **None.**

\_\_\_\_\_  
SAT UNSAT

- 
4. PERFORMANCE STEP: Check for steam leak isolation

STANDARD: Contact Equipment Operator

CUE: **Leak has been isolated**

\_\_\_\_\_  
SAT UNSAT

- 
5. PERFORMANCE STEP: Identify that Turbine Sealing Steam is lost

STANDARD: Check 0 psig on PI 2340, Gland Steam Header Pressure and rising condenser pressure PR530 and PR541

CUE: **None.**

\_\_\_\_\_  
SAT UNSAT

6. PERFORMANCE STEP: Trip the reactor  
    **C**

STANDARD: Press either Reactor Trip pushbutton; Rods insert and power decreasing

CUE: **None.**

---

SAT  UNSAT

7. PERFORMANCE STEP: Initiate & Isolate SFRCS  
    **C**

STANDARD: Press both SFRCS Initiate & Isolate pushbuttons.

CUE: **None.**

---

SAT  UNSAT

TERMINATING CUES: This JPM is complete (Terminated by the examiner)

---

END TIME

**Verification of Completion**

**Job Performance Measure No.** \_\_\_\_\_

**Examinee's Name:** \_\_\_\_\_

**Examiner's Name:** \_\_\_\_\_

**Date Performed:** \_\_\_\_\_

**Facility Evaluator:** \_\_\_\_\_

**Number of Attempts:** \_\_\_\_\_

**Time to Complete:** \_\_\_\_\_

**Question Documentation:**

**Question:** \_\_\_\_\_  
\_\_\_\_\_

**Response:** \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**Result: Satisfactory/Unsatisfactory**

**Examiner's signature and date:** \_\_\_\_\_

**Simulator JPM  
S5**

Facility: Davis-Besse Task No: 026-002-05-0100Task Title: Initiate Containment SprayK/A Reference: (026) A2.03 4.1/4.4 Job Performance Measure No: S5 (NEW)

Examinee: \_\_\_\_\_

NRC Examiner: \_\_\_\_\_ Date: \_\_\_\_\_

**Method of testing:**Simulated Performance \_\_\_\_ Actual Performance XClassroom \_\_\_\_ Simulator X Plant \_\_\_\_***Read to the examinee:***

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

**Initial Conditions:**

The plant conditions are specified in the Initial Conditions and Initiating Cues.

**Task Standard:**

Start both Containment Spray Pumps and open their respective discharge valves  
Stop CTMT Spray pump and close its discharge valve when leak develops

**Required Materials:**

DB-OP-06013 Section 5.2 and 5.3  
DB-OP-02003, 3-4-J to be given when located

**General References:**

Db-OP-02000

**Initiating Cue:**

The plant conditions are specified in the Initial Conditions and Initiating Cues.

**Time Critical Task:**

No

**Alternate Path:**

Yes

**Validation Time:**

15 Minutes

**SIMULATOR INSTRUCTIONS****TASK DESCRIPTION:**

Start both Containment Spray Pumps and open their respective discharge valves

**INITIAL CONDITION:**

A LOCA has occurred. Containment pressure has exceeded the SFAS Level 4 setpoint and containment spray pumps have not started.

**ADDITIONAL SETUP/DEVIATION FROM INITIAL CONDITION:**

Insert malfunction that inhibits start of both containment spray pumps and opening of CS discharge valves. Both containment spray pump discharge valves, (CS1530 and CS1531) are closed.

**MALFUNCTIONS/FAILURE TO INSERT:**

Insert pipe rupture in Train 2 Containment Spray Header when Containment Spray Pump 2 is started

**EXAMINER COPY****INITIAL CONDITIONS:**

A LOCA has occurred. Containment pressure has exceeded the SFAS Level 4 setpoint and containment spray pumps have not started

**INITIATING CUES:**

The Unit Supervisor has directed you to manually start Containment Spray pumps 1 and 2 and spray containment in accordance with DB-OP-06013, Section 5.2 and 5.3

**(Provide examinee a copy of DB-OP-06013, Section 5.2 and 5.3)**

**(NOT PROVIDED AT THIS TIME - DB-OP-02003, 3-4-J. Provided during Alternate Path)**



**CANDIDATE COPY****INITIAL CONDITIONS:**

A LOCA has occurred. Containment pressure has exceeded the SFAS Level 4 setpoint and containment spray pumps have not started

**INITIATING CUES:**

The Unit Supervisor has directed you to manually start Containment Spray pumps 1 and 2 and spray containment in accordance with DB-OP-06013, Section 5.2 and 5.3

**PERFORMANCE INFORMATION**

NOTE: Critical steps denoted with a "C". Failure to meet any one of these standards for this item constitutes failure. Sequence is NOT critical unless denoted in the "Comments".

START TIME: _____
-------------------

**Note: Spray pumps can be started in either sequence. If CTMT Spray Pump 2 is selected to be started first, go to step 5 and return following step 13.**

1. PERFORMANCE STEP: Verify DH7B, BWST ISOLATION VALVE, is OPEN

STANDARD: Observes DH7B RED light ON, GREEN light OFF

CUE: **None**

\_\_\_\_\_  
SAT UNSAT

2. PERFORMANCE STEP: OPEN CS1530, CTMT SPRAY DISCH  
.....**C**.....

STANDARD: Presses OPEN on HIS 1530. Observes RED light ON, GREEN light OFF

CUE: **None**

\_\_\_\_\_  
SAT UNSAT

3. PERFORMANCE STEP: Start CTMT SPRAY PUMP 1  
.....**C**.....

STANDARD: Rotates HIS 1533 to Start and releases. Observes amp increase, RED light ON and GREEN light OFF.

CUE: **None**

\_\_\_\_\_  
SAT UNSAT

4. PERFORMANCE STEP: Verify flow indicated on FI1547, CS PUMP 1 DISCH FLOW

STANDARD: Observe flow indication between 1100 GPM and 1900 GPM. Acknowledge Alarms 3-1-J, CS PMP 1 DISCH FLOW LO, and 3-3-J CS PMP 1 DISCH FLOW HI. Observe alarm annunciators extinguish.

CUE: **None**

\_\_\_\_\_  
SAT UNSAT

**Note: If CTMT Spray Pump 2 was started first. JPM is complete.**

5. PERFORMANCE STEP: Verify DH7A, BWST ISOLATION VALVE, is OPEN  
STANDARD: At SFAS panel verifies that DH7A GREEN light OFF and RED light ON  
CUE: **None**

---

SAT UNSAT

---

6. PERFORMANCE STEP: OPEN CS1531, CTMT SPRAY DISCH  
.....**C**.....  
STANDARD: Presses OPEN on HIS 1531. Observes RED light ON, GREEN light OFF  
CUE: **None**

---

SAT UNSAT

---

7. PERFORMANCE STEP: Start CTMT SPRAY PUMP 2  
.....**C**.....  
STANDARD: Rotates HIS 1532 to Start and releases. Observes amp increase, RED light ON and GREEN light OFF  
CUE: **None**

---

SAT UNSAT

---

8. PERFORMANCE STEP: Verify flow indicated on FI1535, CS PUMP 2 DISCH FLOW  
STANDARD: Observe flow above 1900 GPM. Acknowledge Alarms 3-2-J, CS PMP 2 DISCH FLOW LO, and 3-4-J CS PMP 2 DISCH FLOW HI. Observe alarm 3-2-J extinguishes and 3-4-J CS PMP 2 DISCH FLOW HI remains in alarm (light ON).  
CUE: **None**

---

SAT UNSAT

---

**NOTE:**

**Alternate Path Starts here. When the CTMT Spray Pump 2 is started a leak will develop in Train 2 CTMT Spray Header. Alarm 3-4-J will sound and Alarm Panel 3 Procedure DB-OP-02003 will direct stopping CTMT Spray Pump 2 and closing CS1531.**

---

9. PERFORMANCE STEP: Respond to Alarm 3-4-J, CS PMP 2 DISCH FLOW HI  
STANDARD: Locate Alarm Panel 3 Procedure DB-OP-02003 for alarm 3-4-J  
CUE: **None**

---

SAT UNSAT

---

10. PERFORMANCE STEP: Check for flow rate high at FI 1535 located on Panel C5716

STANDARD: Observe flow above 1900 GPM alarm setpoint

CUE: **None**

SAT UNSAT

11. PERFORMANCE STEP: Check the Containment Spray Header 2 outside Containment for a piping break or leak

STANDARD: Contact Equipment Operator to look for leaks

CUE: **Equipment Operator reports “water is spraying from the CTMT Spray line just upstream of CS 1531, CTMT Spray Discharge Valve.”**

SAT UNSAT

12. PERFORMANCE STEP: Stop CTMT Spray Pump 2

.....**C**.....

STANDARD: Turn HIS 1532 to Stop and release. Observe amps decrease with GREEN light ON and RED light OFF

COMMENT: May press block push button but SFAS is failed for this pump

CUE: **None**

SAT UNSAT

13. PERFORMANCE STEP: Close CS 1530, CTMT Spray Discharge Valve

.....**C**.....

STANDARD: Press Close on HIS 1530. Observe GREEN light ON and RED light OFF

COMMENT: May press block push button but SFAS is failed for this pump

CUE: **None**

SAT UNSAT

**NOTE: If CTMT Spray Pump 2 was started first, return to step 1 for placing CTMT Spray Pump 1 in service.**

TERMINATING CUES: This JPM is complete (Terminated by the examiner)

END TIME

**Verification of Completion**

**Job Performance Measure No.** \_\_\_\_\_

**Examinee's Name:** \_\_\_\_\_

**Examiner's Name:** \_\_\_\_\_

**Date Performed:** \_\_\_\_\_

**Facility Evaluator:** \_\_\_\_\_

**Number of Attempts:** \_\_\_\_\_

**Time to Complete:** \_\_\_\_\_

**Question Documentation:**

**Question:** \_\_\_\_\_  
\_\_\_\_\_

**Response:** \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**Result:** Satisfactory/Unsatisfactory

**Examiner's signature and date:** \_\_\_\_\_

**Simulator JPM  
S6**

Facility: Davis-Besse Task No: 062-005-01-0100Task Title: Transfer Essential 4160 Kv Bus C1 only to AlternateK/A Reference: (062) A4.01 3.3/3.1 Job Performance Measure No: S6 (JPM 084)

Examinee: \_\_\_\_\_

NRC Examiner: \_\_\_\_\_ Date: \_\_\_\_\_

**Method of testing:**Simulated Performance \_\_\_\_ Actual Performance XClassroom \_\_\_\_ Simulator X Plant \_\_\_\_***Read to the examinee:***

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

**Initial Conditions:**

The plant conditions are specified in the Initial Conditions and Initiating Cues.

**Task Standard:**

Transfer C1 bus only to Alternate and back to Normal

**Required Materials:**

DB-OP-06315 Sections 3.27 and 3.28 with prerequisites completed

**General References:**

None

**Initiating Cue:**

The plant conditions are specified in the Initial Conditions and Initiating Cues.

**Time Critical Task:**

No

**Alternate Path:**

No

**Validation Time:**

9 Minutes

**SIMULATOR INSTRUCTIONS**

**TASK DESCRIPTION:**

Transfer C1 only to Alternate (BD Transformer) and back to Normal (Bus C2)

**INITIAL CONDITION:**

Mode 1  
Normal system lineup

**ADDITIONAL SETUP/DEVIATION FROM INITIAL CONDITION:**

None

**MALFUNCTIONS/FAILURE TO INSERT:**

None



**EXAMINER COPY****INITIAL CONDITIONS:**

The Plant is in Mode 1

All systems are in a normal lineup

**INITIATING CUES:**

The Unit Supervisor directs you to perform a live transfer of Bus C1 ONLY from the normal to the alternate power supply, using Section 3.27 of DB-OP-06315, 4160 V Switching Procedure.

**(Provide examinee Section 3.27 of DB-OP-06315, 4160 V Switching Procedure with prerequisites completed)**

**(Section 3.28 is NOT to be provided at this time but will be directed to be provided later)**

**CANDIDATE COPY****INITIAL CONDITIONS:**

The Plant is in Mode 1

All systems are in a normal lineup

**INITIATING CUES:**

The Unit Supervisor directs you to perform a live transfer of Bus C1 ONLY from the normal to the alternate power supply, using Section 3.27 of DB-OP-06315, 4160 V Switching Procedure.

**PERFORMANCE INFORMATION**

NOTE: Critical steps denoted with a "C". Failure to meet any one of these standards for this item constitutes failure. Sequence is NOT critical unless denoted in the "Comments".

START TIME: _____
-------------------

1. PERFORMANCE STEP: Notifies Shift Manager to refer to Tech Specs

STANDARD: Notifies Shift Manager to refer to Tech Specs

CUE: **The Shift Manager is referring to Tech Specs**

\_\_\_\_\_  
SAT UNSAT

2. PERFORMANCE STEP: Close ABDC1, BUS TIE XFMR BD and hold  
.....**C**.....

STANDARD: Positions HIS 6220, ABDC1 to CLOSE and holds in the close position.  
Observes breaker ABDC1 RED light ON, GREEN light OFF

CUE: **None**

\_\_\_\_\_  
SAT UNSAT

3. PERFORMANCE STEP: Open AC110, BUS TIE FROM C2 BUS  
.....**C**.....

STANDARD: Positions HIS 6223, AC 110 to OFF and releases. Observes GREEN light  
ON, RED light OFF

CUE: **None**

\_\_\_\_\_  
SAT UNSAT

4. PERFORMANCE STEP: Release HIS 6220, ABDC1

STANDARD: Release HIS 6220

CUE: **The Unit Supervisor directs you to return bus C1 to the normal power supply using Section 3.28 of DB-OP-06315, 4160V Switching Procedure (Provide Section 3.28 of DB-OP-06315, prerequisites complete).**

\_\_\_\_\_  
SAT UNSAT

5. PERFORMANCE STEP: Close AC110, BUS TIE FROM C2 BUS  
.....**C**.....

STANDARD: Turn HIS 6223, AC110 to CLOSE. Observe RED light ON, GREEN light OFF

CUE: **None**

---

SAT UNSAT

---

6. PERFORMANCE STEP: Open ABDC1, BUS TIE XFMR BD  
.....**C**.....

STANDARD: Turn HIS 6220, ABDC1 to OFF. Observe GREEN light ON, RED light OFF

CUE: **None**

---

SAT UNSAT

---

TERMINATING CUES: This JPM is complete (Terminated by the examiner)

---

END TIME

**Verification of Completion**

**Job Performance Measure No.** \_\_\_\_\_

**Examinee's Name:** \_\_\_\_\_

**Examiner's Name:** \_\_\_\_\_

**Date Performed:** \_\_\_\_\_

**Facility Evaluator:** \_\_\_\_\_

**Number of Attempts:** \_\_\_\_\_

**Time to Complete:** \_\_\_\_\_

**Question Documentation:**

**Question:** \_\_\_\_\_  
\_\_\_\_\_

**Response:** \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**Result:** Satisfactory/Unsatisfactory

**Examiner's signature and date:** \_\_\_\_\_

**Simulator JPM  
S7**

---

**Facility:** Davis-Besse **Task No.:** 016-001-01-0100

**Task Title:** Exchange RC flow Inputs to RPS Channel 2

**K/A Reference:** (016) A4.01 2.9/2.8 **Job Performance Measure No.:** S7 (JPM 048)

**Examinee:** \_\_\_\_\_

**NRC Examiner:** \_\_\_\_\_ **Date:** \_\_\_\_\_

**Method of testing:**

Simulated Performance \_\_\_\_ Actual Performance X

Classroom \_\_\_\_ Simulator X Plant \_\_\_\_

***Read to the examinee:***

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

**Initial Conditions:**

The plant conditions are specified in the Initial Conditions and Initiating Cues.

**Task Standard:**

Transfer RC Flow Inputs for the Computer and NNI from RPS Channel 1 to RPS Channel 2

**Required Materials:**

DB-OP-06403, Reactor Protection System (RPS) and Nuclear Instrumentation System (NI)  
Operating Procedure, Section 4.3

DB-OP-06407, Non-Nuclear Instrumentation System Operating Procedure, Section 4.2

**General References:**

None

**Initiating Cue:**

The plant conditions are specified in the Initial Conditions and Initiating Cues.

**Time Critical Task:**

No

**Alternate Path:**

No

**Validation Time:**

20 Minutes

**SIMULATOR INSTRUCTIONS**

**TASK DESCRIPTION:**

Exchange RC Flow Inputs to the Computer and NNI from RPS channel 1 to RPS Channel 2

**INITIAL CONDITION:**

4 RCPs in operation

**ADDITIONAL SETUP/DEVIATION FROM INITIAL CONDITION:**

NNI Flow Inputs selected to RPS Channel 1

**MALFUNCTIONS/FAILURE TO INSERT:**

None



**EXAMINER COPY****INITIAL CONDITIONS:**

Maintenance is planned for RPS Channel 1 RCS flow instrumentation

The RC Flow inputs are selected from RPS Channel 1

**INITIATING CUES:**

The Unit Supervisor directs you to exchange RC flow inputs (Computer and NNI) to RPS Channel 2 in accordance with section 4.3 of DB-OP-06403, RPS and NI Operating Procedure

**(Provide the examinee a copy of section 4.3 of DB-OP-06403)**

**CANDIDATE COPY****INITIAL CONDITIONS:**

Maintenance is planned for RPS Channel 1 RCS flow instrumentation

The RC Flow inputs are selected from RPS Channel 1

**INITIATING CUES:**

The Unit Supervisor directs you to exchange RC flow inputs (Computer and NNI) to RPS Channel 2 in accordance with section 4.3 of DB-OP-06403, RPS and NI Operating Procedure

**PERFORMANCE INFORMATION**

NOTE: Critical steps denoted with a "C". Failure to meet any one of these standards for this item constitutes failure. Sequence is NOT critical unless denoted in the "Comments".

START TIME: _____
-------------------

- 
1. PERFORMANCE STEP: Locate correct procedure step

STANDARD: Mark step 4.3.1 N/A. Begin with step 4.3.2 in DB-OP-06403

CUE: **None**

\_\_\_\_\_  
SAT UNSAT

- 
2. PERFORMANCE STEP: Remove cap on Selection Panel for the alternate RC flow  $\Delta p$   
.....**C**..... COMPUTER receptacle

STANDARD: Locate the selection panel in RPS Channel 2 and rotate the cap counterclockwise to remove the cap

CUE: **None**

\_\_\_\_\_  
SAT UNSAT

- 
3. PERFORMANCE STEP: Disconnect the amphenol connector from RC flow  $\Delta p$  computer  
.....**C**..... Sub-assembly and reconnect to alternate RC flow  $\Delta p$  receptacle

STANDARD: Unscrew the amphenol connector from RPS Channel 1 input and screw in to RPS Channel 2 RC flow  $\Delta p$  input

CUE: **None**

\_\_\_\_\_  
SAT UNSAT

- 
4. PERFORMANCE STEP: Cap the open receptacle

STANDARD: Replace cap on the open receptacle

CUE: **None**

\_\_\_\_\_  
SAT UNSAT

- 
5. PERFORMANCE STEP: Administratively document the amphenol exchange in Unit Log

STANDARD: Document RPS Channel 2 supplying NNI in the procedure and inform Control Room to enter in Unit Log

CUE: **Another Operator will make the entry in the Unit Log**

---

SAT UNSAT

---

6. PERFORMANCE STEP: Remove the Tave SASS Instrument string from automatic  
STANDARD: Refer to section 4.2 of DB-OP-06407, Non-Nuclear Instrumentation System  
Operating Procedure

CUE: **Provide the examinee a copy of section 4.2 of DB-OP-06407**

---

SAT UNSAT

---

7. PERFORMANCE STEP: Select the instrument string to be tested  
.....**C**.....

STANDARD: Take the test selector switch for Loop 2 Tave and Loop 1 Tave to the "A" or  
"B" position AND hold

CUE: **There is no suspected problem with the instrument string**

---

SAT UNSAT

---

8. PERFORMANCE STEP: Release the test selector switch  
.....**C**.....

STANDARD: Test selector switch released after the Yellow MISMCH light is LIT

CUE: **None**

---

SAT UNSAT

---

9. PERFORMANCE STEP: Verify green AUTO light is OFF for instrument pair in test

STANDARD: Check that the Green AUTO light is OFF

CUE: **None**

---

SAT UNSAT

---

10. PERFORMANCE STEP: Remove the cap on the Selection Panel for the alternate RC  
.....**C**..... flow  $\Delta p$  NNI receptacle

STANDARD: Rotate the cap counterclockwise to remove the cap

CUE: **None**

---

SAT UNSAT

---

11. PERFORMANCE STEP: Disconnect amphenol receptacle for RC flow and reconnect  
.....**C**..... to alternate RC flow NNI  $\Delta$ p receptacle

STANDARD: Unscrew amphenol connector from RPS Channel 1 input and screw in to  
RPS Channel 2 RC flow  $\Delta$ p NNI

CUE: **None**

SAT UNSAT

---

12. PERFORMANCE STEP: Cap the open receptacle

STANDARD: Replace cap on the open receptacle

CUE: **None**

SAT UNSAT

---

13. PERFORMANCE STEP: Administratively document the amphenol exchange in Unit Log

STANDARD: Document RPS Channel 2 supplying NNI in the procedure and inform Control  
Room to enter in Unit Log

CUE: **Another Operator will make the entry in the Unit Log**

SAT UNSAT

---

TERMINATING CUES: This JPM is complete (Terminated by the examiner)

END TIME

**Verification of Completion**

**Job Performance Measure No.** \_\_\_\_\_

**Examinee's Name:** \_\_\_\_\_

**Examiner's Name:** \_\_\_\_\_

**Date Performed:** \_\_\_\_\_

**Facility Evaluator:** \_\_\_\_\_

**Number of Attempts:** \_\_\_\_\_

**Time to Complete:** \_\_\_\_\_

**Question Documentation:**

**Question:** \_\_\_\_\_  
\_\_\_\_\_

**Response:** \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**Result:** Satisfactory/Unsatisfactory

**Examiner's signature and date:** \_\_\_\_\_

**Simulator JPM  
S8**

---

Facility: Davis-Besse Task No: 029-003-01-0100

Task Title: Purge Containment in Mode 5

K/A Reference: (016) A2.03 2.7/3.1 Job Performance Measure No: S8 (JPM 162)

Examinee: \_\_\_\_\_

NRC Examiner: \_\_\_\_\_ Date: \_\_\_\_\_

**Method of testing:**

Simulated Performance \_\_\_\_ Actual Performance X

Classroom \_\_\_\_ Simulator X Plant \_\_\_\_

***Read to the examinee:***

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

**Initial Conditions:**

The plant conditions are specified in the Initial Conditions and Initiating Cues.

**Task Standard:**

Place Containment Purge in service on Containment

**Required Materials:**

DB-OP-06503, Containment Purge System (entire procedure), with Section 3.1 prerequisites completed

**General References:**

None

**Initiating Cue:**

The plant conditions are specified in the Initial Conditions and Initiating Cues.

**Time Critical Task:**

No

**Alternate Path:**

Yes

**Validation Time:**

12 Minutes



**SIMULATOR INSTRUCTIONS****TASK DESCRIPTION:**

Place Containment Purge in service on Containment

**INITIAL CONDITION:**

Mode 5

**ADDITIONAL SETUP/DEVIATION FROM INITIAL CONDITION:**

Turn off CTMT Purge Supply and Exhaust Fans  
Close dampers CV 5004, 5016, 5009 and 5021  
Install fuses in SFAS cabinets  
Verify dampers CV 5005, 5006, 5007, and 5008 are closed

**MALFUNCTIONS/FAILURE TO INSERT:**

Prevent start of CTMT Purge Supply Fan by closing air valve to supply damper.

IMF CAV7B

**ACTION/CUES:**

1. Step 11, CUE: Freeze stats TSL-5612A & B for the supply fan are tripped
2. Step 12, ACTION: Remove the air valve malfunction. DMF CAV7B  
CUE: Freeze stats TSL-5612A & B have been reset

**EXAMINER COPY****INITIAL CONDITIONS:**

The plant is in Mode 5.

**INITIATING CUES:**

The Unit Supervisor directs you to start a purge of the Containment Vessel in accordance with section 3.1 of DB-OP-06503, Containment Purge System Procedure.

The Incore Instrument Tank will NOT be purged.

**(Provide the examinee a copy of DB-OP-06503, prerequisites completed)**

**CANDIDATE COPY****INITIAL CONDITIONS:**

The plant is in Mode 5.

**INITIATING CUES:**

The Unit Supervisor directs you to start a purge of the Containment Vessel in accordance with section 3.1 of DB-OP-06503, Containment Purge System Procedure.

The Incore Instrument Tank will NOT be purged.

**PERFORMANCE INFORMATION**

NOTE: Critical steps denoted with a "C". Failure to meet any one of these standards for this item constitutes failure. Sequence is NOT critical unless denoted in the "Comments".

START TIME: _____
-------------------

1. PERFORMANCE STEP: Implement the correct procedure section.

STANDARD: Locates Section 3.1 of DB-OP-06503, Containment Purge System Procedure

CUE: **None**

\_\_\_\_\_  
SAT UNSAT

2. PERFORMANCE STEP: Make a plant announcement.

STANDARD: Use the GAITRONICS to announce "Attention all station personnel, starting the containment vessel purge".

CUE: **None**

\_\_\_\_\_  
SAT UNSAT

3. PERFORMANCE STEP: Open the purge CTMT isolation valve CV5008.

.....**C**.....

STANDARD: Press the OPEN pushbutton on HIS 5008. RED light ON, GREEN light OFF

COMMENT: Sequence NOT required.

CUE: **None**

\_\_\_\_\_  
SAT UNSAT

4. PERFORMANCE STEP: Open the purge CTMT isolation valve, CV5006.

.....**C**.....

STANDARD: Press the OPEN pushbutton on HIS 5006. RED light ON, GREEN light OFF

COMMENT: Sequence NOT required.

CUE: **None**

\_\_\_\_\_  
SAT UNSAT

- 
5. PERFORMANCE STEP: Open the purge CTMT isolation valve, CV5005.  
.....**C**.....

STANDARD: Press the OPEN pushbutton on HIS 5005. RED light ON, GREEN light OFF

COMMENT: Sequence NOT required.

CUE: **None**

---

SAT UNSAT

- 
6. PERFORMANCE STEP: Open the purge CTMT isolation valve, CV5007.  
.....**C**.....

STANDARD: Press the OPEN pushbutton on HIS 5007. RED light ON, GREEN light OFF

COMMENT: Sequence NOT required.

CUE: **None**

---

SAT UNSAT

- 
7. PERFORMANCE STEP: Start CTMT purge exhaust fan.  
.....**C**.....

STANDARD: Turn handswitch HIS 5013, to START.

CUE: **None**

---

SAT UNSAT

- 
8. PERFORMANCE STEP: Verify CTMT Purge Exhaust fan starts.

STANDARD: Verifies HIS 5013 RED light ON, GREEN light OFF.

COMMENT: The fan will start in approximately 120 seconds.

CUE: **None.**

---

SAT UNSAT

- 
9. PERFORMANCE STEP: Start the CTMT purge supply fan.

STANDARD: Within 20 seconds after the exhaust fan starts, turn handswitch HIS 5003 to START.

COMMENT: Fan is failed.

CUE: **None**

---

SAT UNSAT

10. PERFORMANCE STEP: GO TO Section 4.3, inability to complete proper system startup

STANDARD: Routes to Section 4.3

CUE: **None**

SAT UNSAT

11. PERFORMANCE STEP: Verify the CTMT Purge Exhaust Fan and CTMT Purge Supply fan are OFF.

STANDARD: Verifies HIS5003 CTMT Purge Supply Sys Fan GREEN light ON, RED light OFF  
Verifies HIS5013 CTMT Purge Exhaust Sys Fan GREEN light ON, RED light OFF

COMMENT: The CTMT Purge Exhaust Fan will trip 20 seconds after starting without the Supply Fan running

CUE: **None**

SAT UNSAT

12. PERFORMANCE STEP: Refer to Attachment 5, Containment Purge System Troubleshooting Guide. Send an EO to investigate

STANDARD: Verbal communication with an Equipment Operator to investigate the problem using Attachment 5.

CUE: **If asked, the Unit Supervisor directs you to use an EO to check the problem Report as EO the Freeze stats are found tripped for the Purge Supply Fan**

SAT UNSAT

13. PERFORMANCE STEP: Direct the EO to reset Freeze stats TSL-5612A & B

STANDARD: Verbal communication with Equipment Operator to reset Freeze stats TSL-5612A & B

COMMENT: The Booth Operator will remove the fault as soon as the fan trips

CUE: **If asked, the Unit Supervisor directs you to have the Equipment Operator reset Freeze stats TSL-5612A & B.**

SAT UNSAT

14. PERFORMANCE STEP: Return to step 3.11. Start CTMT purge exhaust fan.  
.....**C**.....

STANDARD: Turn HIS 5013 to START.

COMMENT: The fan will start in approximately 120 seconds.

CUE: **None**

---

SAT UNSAT

14. PERFORMANCE STEP: Verify CTMT Purge Exhaust fan starts.

STANDARD: HIS 5013 RED light ON, GREEN light OFF.

CUE: **None**

---

SAT UNSAT

15. PERFORMANCE STEP: Start the CTMT purge supply fan.  
.....**C**.....

STANDARD: Within 20 seconds after the exhaust fan is running, turn hand switch  
HIS 5003 to START.

CUE: **None**

---

SAT UNSAT

17. PERFORMANCE STEP: Verify CTMT Purge Supply fan starts.

STANDARD: HIS 5003 RED light ON, GREEN light OFF.

CUE: **None**

---

SAT UNSAT

TERMINATING CUES: This JPM is complete (Terminated by the examiner)

---

END TIME

**Verification of Completion**

**Job Performance Measure No.** \_\_\_\_\_

**Examinee's Name:** \_\_\_\_\_

**Examiner's Name:** \_\_\_\_\_

**Date Performed:** \_\_\_\_\_

**Facility Evaluator:** \_\_\_\_\_

**Number of Attempts:** \_\_\_\_\_

**Time to Complete:** \_\_\_\_\_

**Question Documentation:**

**Question:** \_\_\_\_\_  
\_\_\_\_\_

**Response:** \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**Result:** Satisfactory/Unsatisfactory

**Examiner's signature and date:** \_\_\_\_\_



**In Plant JPM  
P1**

---

**Facility:** Davis-Besse **Task No.:** 001-011-05-0100

**Task Title:** Perform Attachment 5 of Control Room Evacuation per DB-OP-02508

**K/A Reference:** (004) AA1.06 4.1/4.2 **Job Performance Measure No.:** P1 (JPM 006)

**Examinee:** \_\_\_\_\_

**NRC Examiner:** \_\_\_\_\_ **Date:** \_\_\_\_\_

**Method of testing:**

Simulated Performance X Actual Performance \_\_\_\_

Classroom \_\_\_\_ Simulator \_\_\_\_ Plant X

***Read to the examinee:***

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

**Initial Conditions:**

The plant conditions are specified in the Initial Conditions and Initiating Cues.

**Task Standard:**

Isolate Letdown, start the Standby Makeup Pump and transfer both Makeup Pump suction to the BWST from outside the Control Room

**Required Materials:**

DB-OP-02508, Control Room Evacuation, Attachment 5

**General References:**

None

**Initiating Cue:**

The plant conditions are specified in the Initial Conditions and Initiating Cues.

**Time Critical Task:**

No

**Alternate Path:**

No

**Validation Time:**

15 Minutes

**EXAMINER COPY****INITIAL CONDITIONS:**

A hazardous condition has forced the evacuation of the Control Room

There is NO fire in the Control Room area

ONLY the Immediate Actions of Trip the Reactor and Initiate and Isolate SFRCS were performed prior to evacuation

Makeup Pump 1 is running

**INITIATING CUES:**

The Unit Supervisor directs you to perform Attachment 5 of DB-OP-02508, Control Room Evacuation

You have an emergency key ring

The Zone 3 Operator has been provided Attachment 6 and Attachment 7 for controlling the Atmospheric Vent Valves

**(Provide the examinee a copy of Attachment 5 of DB-OP-02508)**

**CANDIDATE COPY****INITIAL CONDITIONS:**

A hazardous condition has forced the evacuation of the Control Room

There is NO fire in the Control Room area

ONLY the Immediate Actions of Trip the Reactor and Initiate and Isolate SFRCS were performed prior to evacuation

Makeup Pump 1 is running

**INITIATING CUES:**

The Unit Supervisor directs you to perform Attachment 5 of DB-OP-02508, Control Room Evacuation

You have an emergency key ring

The Zone 3 Operator has been provided Attachment 6 and Attachment 7 for controlling the Atmospheric Vent Valves

**PERFORMANCE INFORMATION**

NOTE: Critical steps denoted with a "C". Failure to meet any one of these standards for this item constitutes failure. Sequence is NOT critical unless denoted in the "Comments".

START TIME: _____
-------------------

- 
1. PERFORMANCE STEP: Dispatch the Zone 3 operator to establish local manual control of the AVVs

STANDARD: Sign off step per initial conditions

CUE: **None**

\_\_\_\_\_  
SAT UNSAT

- 
2. PERFORMANCE STEP: Isolate Letdown  
.....**C**.....

STANDARD: Close MU 2B, REACTOR COOLANT LETDOWN COOLER INLET ISOLATION, using the local switch on Breaker BE 1172 on MCC E11B. Observe Green light ON Red light OFF

CUE: **Local switch (on BE 1172) has been placed in CLOSE. Green light goes ON Red light goes OFF**

\_\_\_\_\_  
SAT UNSAT

- 
3. PERFORMANCE STEP: Start the standby Makeup Pump  
.....**C**.....

STANDARD: Press local START Button on NP0372B for Makeup Pump 2 Main Oil Pump (AC). Observe Green light OFF Red light ON

CUE: **Local START button (on NP0372B) for Makeup Pump 2 Main Oil Pump has been pressed. Green light goes OFF, Red light goes ON**

\_\_\_\_\_  
SAT UNSAT

- 
4. PERFORMANCE STEP: Start the standby Makeup Pump

STANDARD: Check Main Oil Pump discharge pressure >15 psig on PI MU106A

CUE: **PI MU106A reads 23 psig**

SAT UNSAT

---

5. PERFORMANCE STEP: Start the standby Makeup Pump

STANDARD: Check MU Pump 2 Aux. Gear LO pump started at NP0372D. Observe Red light is LIT on NP0372D

CUE: **Red light is LIT on NP0372D**

SAT UNSAT

---

6. PERFORMANCE STEP: Start the standby Makeup Pump  
.....**C**.....

STANDARD: CLOSE/START pressed on NP0372A to START Makeup Pump 2. Observe Green light goes OFF, Red light goes ON

CUE: **CLOSE/START has been pressed on NP0372A.  
Green light goes OFF, Red light goes ON**

SAT UNSAT

---

7. PERFORMANCE STEP: Align makeup pumps suction to the BWST  
.....**C**.....

STANDARD: NV 3971 switch placed in BWST position. Observe Bottom Red light goes OFF, Top Red light goes ON

CUE: **Switch NV 3971 has been placed in BWST position  
Bottom Red light goes OFF, Top Red light goes ON**

SAT UNSAT

---

8. PERFORMANCE STEP: Align makeup pumps suction to the BWST  
.....**C**.....

STANDARD: NV 6405 switch placed in the BWST position. Observe Bottom Red light goes OFF, Top Red light goes ON

CUE: **Switch NV 6405 has been placed in the BWST position  
Bottom Red light goes OFF, Top Red light goes ON**

SAT UNSAT

---

9. PERFORMANCE STEP: Proceed to the Radwaste Panel and establish communications with the Unit Supervisor

STANDARD: Communications established with the Unit Supervisor from the Radwaste Panel

CUE: **Communications have been established**

---

SAT UNSAT

TERMINATING CUES: This JPM is complete (Terminated by the examiner)

---

END TIME

**Verification of Completion**

**Job Performance Measure No.** \_\_\_\_\_

**Examinee's Name:** \_\_\_\_\_

**Examiner's Name:** \_\_\_\_\_

**Date Performed:** \_\_\_\_\_

**Facility Evaluator:** \_\_\_\_\_

**Number of Attempts:** \_\_\_\_\_

**Time to Complete:** \_\_\_\_\_

**Question Documentation:**

**Question:** \_\_\_\_\_  
\_\_\_\_\_

**Response:** \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**Result:** Satisfactory/Unsatisfactory

**Examiner's signature and date:** \_\_\_\_\_



**In Plant JPM  
P2**

Facility: Davis-Besse Task No: 062-094-01-0401Task Title: Restore EDG to supply 4160 Essential Bus per DB-OP-02538K/A Reference: (064) AA1.03 3.1/3.3 Job Performance Measure No: P2 (JPM 079)

Examinee: \_\_\_\_\_

NRC Examiner: \_\_\_\_\_ Date: \_\_\_\_\_

**Method of testing:**Simulated Performance X Actual Performance \_\_\_\_Classroom \_\_\_\_ Simulator \_\_\_\_ Plant X***Read to the examinee:***

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

**Initial Conditions:**

The plant conditions are specified in the Initial Conditions and Initiating Cues.

**Task Standard:**

Restore power to D1 from EDG 2

**Required Materials:**

DB-OP-02538, Loss of D2P and DBP, Attachment 6

**General References:**

None

**Initiating Cue:**

The plant conditions are specified in the Initial Conditions and Initiating Cues.

**Time Critical Task:**

No

**Alternate Path:**

No

**Validation Time:**

22 Minutes

**EXAMINER COPY****INITIAL CONDITIONS:**

The plant has experienced a loss of essential DC Panel D2P

Bus D1 is de-energized

Emergency Diesel Generator 2 is not running

**INITIATING CUES:**

The Unit Supervisor directs you to restore Emergency Diesel Generator 2 to supply Bus D1 in accordance with Attachment 6: RESTORE POWER TO D1 BUS FROM EDG 2 of DB-OP-02538, Loss of D2P and DBP

**(Provide a copy of DB-OP-02538 Attachment 6)**

**CANDIDATE COPY****INITIAL CONDITIONS:**

The plant has experienced a loss of essential DC Panel D2P

Bus D1 is de-energized

Emergency Diesel Generator 2 is not running

**INITIATING CUES:**

The Unit Supervisor directs you to restore Emergency Diesel Generator 2 to supply Bus D1 in accordance with Attachment 6: RESTORE POWER TO D1 BUS FROM EDG 2 of DB-OP-02538, Loss of D2P and DBP

**PERFORMANCE INFORMATION**

NOTE: Critical steps denoted with a "C". Failure to meet any one of these standards for this item constitutes failure. Sequence is NOT critical unless denoted in the "Comments".

START TIME: \_\_\_\_\_

1. PERFORMANCE STEP: Open D2P07  
.....**C**.....

STANDARD: Place breaker D2P07 in the OFF position. Turn the key to extend the plunger and remove the key

CUE: **D2P07 is in OFF.**  
**Key has been turned and removed, the plunger is extended**

SAT UNSAT

2. PERFORMANCE STEP: Open D2P05  
.....**C**.....

STANDARD: Place breaker D2P05 in the OFF position. Turn the key to extend the plunger and remove the key

CUE: **D2P05 is in OFF.**  
**Key has been turned and removed, the plunger is extended**

SAT UNSAT

3. PERFORMANCE STEP: Open D2P09  
.....**C**.....

STANDARD: Place breaker D2P09 in the OFF position. Turn the key to extend the plunger and remove the key

CUE: **D2P09 is in OFF.**  
**Key has been turned and removed, the plunger is extended**

SAT UNSAT

4. PERFORMANCE STEP: Close D2N07  
.....**C**.....

STANDARD: Insert the key and turn to retract the plunger.  
Place breaker D2N07 in the ON position.

CUE: **Key is inserted and turned, plunger is retracted  
D2N07 has been placed in ON**

---

SAT UNSAT

5. PERFORMANCE STEP: Close D2N05  
.....**C**.....

STANDARD: Insert the key and turn to retract the plunger.  
Place breaker D2N07 in the ON position.

CUE: **Key is inserted and turned, plunger is retracted  
D2N07 has been placed in ON**

---

SAT UNSAT

6. PERFORMANCE STEP: Close D2N09  
.....**C**.....

STANDARD: Insert the key and turn to retract the plunger.  
Place breaker D2N09 in the ON position.

CUE: **Key is inserted and turned, plunger is retracted  
D2N09 has been placed in ON**

---

SAT UNSAT

7. PERFORMANCE STEP: Verify the DC control power source disconnect switches on  
buses DBP and DBN are closed

STANDARD: Verify the DC breakers are in the ON position

CUE: **DBN02 is in the ON position  
DBN04 is in the ON position  
DBP02 is in the ON position  
DBP04 is in the ON position  
DBP07 is in the ON position  
DBP11 is in the ON position**

---

SAT UNSAT

8. PERFORMANCE STEP: Transfer D1 control power to alternate  
.....**C**.....

STANDARD: Place knife switch in Cubicle 13 of D1 bus to ALTERNATE position

CUE: **Knife switch is placed in ALTERNATE**

SAT UNSAT

9. PERFORMANCE STEP: Verify D1 load breakers are tripped

STANDARD: Check the following breakers OPEN using indicating lights, mechanical indicators or communicate with the control room (GREEN light is LIT/position indicator at OPEN):

AD 110, Bus D1 Normal Feed (HIS 6233)  
AACD1, XFRMR XBD to BUS D1 (HIS 6230)  
AD 107, SW Pump 2 (HIS 1371) **OR** AD 109, SW Pump 3 as 2 (HIS 1372B)  
AD 111, HPI Pump 2 (HIS 1523)  
AD 112, LPI/DH Pump 2 (HIS DH 6A)  
AD 105, Makeup Pump 2 (HIS MU24B)

CUE: **AD110, GREEN light is LIT/position indicator at OPEN  
OR HIS 6233 GREEN light is LIT  
AACD1, GREEN light is LIT/position indicator at OPEN  
OR HIS 6230 GREEN light is LIT.  
AD107 (AD109) GREEN light is LIT/position indicator at OPEN  
OR HIS 1371(1372B) GREEN light is LIT.  
AD109, NO lights lit/breaker racked OUT  
OR HIS NO lights lit  
AD111, GREEN light is LIT/position indicator at OPEN  
OR HIS 1523 GREEN light is LIT.  
AD112, GREEN light is LIT/position indicator at OPEN  
OR HIS DH6A GREEN light is LIT.  
AD105, GREEN light is LIT/position indicator at OPEN  
OR HIS MU24B GREEN light is LIT.**

SAT UNSAT

10. PERFORMANCE STEP: Open CB1  
.....**C**.....

STANDARD: Breaker CB1 is placed in OFF in Panel C3616

CUE: **Breaker CB1 is in OFF**

SAT UNSAT

11. PERFORMANCE STEP: Close CB2  
.....**C**.....

STANDARD: Breaker CB2 is placed in ON in Panel C3616. Expects EDG 2 start.

CUE: **CB2 is in ON. Emergency Diesel Generator 2 has started**

SAT UNSAT

12. PERFORMANCE STEP: Verify Emergency Diesel Generator 2 starts and loads D1 Bus

STANDARD: Check indications of Emergency Diesel Generator 2 start.  
Breaker AD101 Red light ON  
Speed at SI 6232A is 900 RPM  
Voltage at DG 2 VOLTS (P1-1076) is 4160 VAC  
KW load indicated on KW meter

CUE: **EDG 2 has started and loading is in progress**

SAT UNSAT

TERMINATING CUES: This JPM is complete (Terminated by the examiner)

END TIME



**Verification of Completion**

**Job Performance Measure No.** \_\_\_\_\_

**Examinee's Name:** \_\_\_\_\_

**Examiner's Name:** \_\_\_\_\_

**Date Performed:** \_\_\_\_\_

**Facility Evaluator:** \_\_\_\_\_

**Number of Attempts:** \_\_\_\_\_

**Time to Complete:** \_\_\_\_\_

**Question Documentation:**

**Question:** \_\_\_\_\_  
\_\_\_\_\_

**Response:** \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**Result:** Satisfactory/Unsatisfactory

**Examiner's signature and date:** \_\_\_\_\_

**In Plant JPM  
P3**

---

Facility: Davis-Besse Task No: 078-010-04-0400

Task Title: Bypass and Isolate the In Service Air Dryers per DB-OP-02528, IA Malfunctions

K/A Reference: (078) AA2.03 2.6/2.9 Job Performance Measure No: P3 (078)

Examinee: \_\_\_\_\_

NRC Examiner: \_\_\_\_\_ Date: \_\_\_\_\_

**Method of testing:**

Simulated Performance X Actual Performance \_\_\_\_

Classroom \_\_\_\_ Simulator \_\_\_\_ Plant X

***Read to the examinee:***

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

**Initial Conditions:**

The plant conditions are specified in the Initial Conditions and Initiating Cues.

**Task Standard:**

Bypass and Isolate the In Service Instrument Air Dryers

**Required Materials:**

DB-OP-02528, Instrument Air System Malfunctions, Step 4.2.2 and Attachment 20

**General References:**

None

**Initiating Cue:**

The plant conditions are specified in the Initial Conditions and Initiating Cues.

**Time Critical Task:**

No

**Alternate Path:**

No

**Validation Time:**

10 Minutes

**EXAMINER COPY****INITIAL CONDITIONS:**

The plant is operating at 100% power

Both sets of Instrument Air Dryers are in service due to high air usage

**INITIATING CUES:**

The Control Room announces Instrument Air pressure is lowering

The Unit Supervisor directs you to perform Attachment 20 of DB-OP-02528 to bypass and isolate the in service air dryers

**(Provide examinee a copy of Attachment 20 from DB-OP-02528, Instrument Air System Malfunctions)**

**CANDIDATE COPY****INITIAL CONDITIONS:**

The plant is operating at 100% power

Both sets of Instrument Air Dryers are in service due to high air usage

**INITIATING CUES:**

The Control Room announces Instrument Air pressure is lowering

The Unit Supervisor directs you to perform Attachment 20 per step 4.2.2 of DB-OP-02528 to bypass and isolate the in service air dryers

**PERFORMANCE INFORMATION**

NOTE: Critical steps denoted with a "C". Failure to meet any one of these standards for this item constitutes failure. Sequence is NOT critical unless denoted in the "Comments".

START TIME: _____
-------------------

1. PERFORMANCE STEP: Bypass Instrument Air Dryers 3 & 4  
.....**C**.....

STANDARD: Open IA 411, IA Dryers 3 & 4 Bypass to Receiver, by rotating handle parallel to pipe

**CUE: Handle for IA 411 has been placed parallel to pipe**

\_\_\_\_\_  
SAT UNSAT

2. PERFORMANCE STEP: Isolate Instrument Air Dryers 3 & 4  
.....**C**.....

STANDARD: Close IA 419, IA Dryers 3 & 4 Inlet Isolation by rotating handle perpendicular to pipe

**CUE: Handle for IA 419 has been placed perpendicular to pipe**

\_\_\_\_\_  
SAT UNSAT

3. PERFORMANCE STEP: Isolate Instrument Air Dryers 3 & 4  
.....**C**.....

STANDARD: Close IA 413, IA Dryers 3 & 4 Outlet Isolation by rotating handle perpendicular to pipe

**CUE: Handle for IA 413 has been placed perpendicular to pipe**

\_\_\_\_\_  
SAT UNSAT

4. PERFORMANCE STEP: De-energize Instrument Air Dryers 3 & 4

STANDARD: Place HIS 5941, Dryers 3 & 4 On/Off Switch in OFF. Observe GREEN light ON and RED light OFF

**CUE: HIS 5941 is in OFF. GREEN light is ON and RED light is OFF**

\_\_\_\_\_  
SAT UNSAT

5. PERFORMANCE STEP: Bypass Instrument Air Dryers 1 & 2  
.....**C**.....

STANDARD: Open IA 289, IA Dryers 1 & 2 Bypass to Receiver, by rotating handle parallel to pipe

CUE: **Handle for IA 289 has been placed parallel to pipe**

SAT UNSAT

6. PERFORMANCE STEP: Isolate Instrument Air Dryers 1 & 2  
.....**C**.....

STANDARD: Close IA 24, IA Dryers 1 & 2 Inlet Isolation, by rotating handle perpendicular to pipe

CUE: **Handle for IA 24 has been placed perpendicular to pipe**

SAT UNSAT

7. PERFORMANCE STEP: Isolate Instrument Air Dryers 1 & 2  
.....**C**.....

STANDARD: Close IA 31, IA Dryers 1 & 2 Outlet Isolation, by rotating handle perpendicular to pipe

CUE: **Handle for IA 31 has been placed perpendicular to pipe**

SAT UNSAT

8. PERFORMANCE STEP: De-energize Instrument Air Dryers 1 & 2

STANDARD: Place HIS 5940, Dryers 1 & 2 On/Off Switch in OFF. Observe GREEN light ON and RED light OFF

CUE: **HIS 5940 is in OFF. GREEN light is ON and RED light is OFF**

SAT UNSAT

TERMINATING CUES: This JPM is complete (Terminated by the examiner)

END TIME

**Verification of Completion**

**Job Performance Measure No.** \_\_\_\_\_

**Examinee's Name:** \_\_\_\_\_

**Examiner's Name:** \_\_\_\_\_

**Date Performed:** \_\_\_\_\_

**Facility Evaluator:** \_\_\_\_\_

**Number of Attempts:** \_\_\_\_\_

**Time to Complete:** \_\_\_\_\_

**Question Documentation:**

**Question:** \_\_\_\_\_  
\_\_\_\_\_

**Response:** \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**Result:** Satisfactory/Unsatisfactory

**Examiner's signature and date:** \_\_\_\_\_