

KHNPDCRAIsPEm Resource

From: Ciocco, Jeff
Sent: Tuesday, September 01, 2015 5:28 AM
To: apr1400rai@khnp.co.kr; KHNPDCRAIsPEm Resource; Harry (Hyun Seung) Chang; Andy Jiyong Oh; Christopher Tyree
Cc: Curran, Gordon; Dias, Antonio; Wunder, George; Lee, Samuel
Subject: APR1400 Design Certification Application RAI 186-8009 (09.05.07 - Emergency Diesel Engine Lubrication System)
Attachments: APR1400 DC RAI 186 SPSB 8009.pdf; image001.jpg

KHNP,

The attachment contains the subject request for additional information (RAI). This RAI was sent to you in draft form. Your licensing review schedule assumes technically correct and complete responses within 30 days of receipt of RAIs. However, KHNP requests, and we grant, 60 days to respond to RAI question 09.05.07-1 and 30 days to respond to RAI question 09.05.07-2. We may adjust the schedule accordingly.

Please submit your RAI response to the NRC Document Control Desk.

Thank you,

Jeff Ciocco
New Nuclear Reactor Licensing
301.415.6391
jeff.ciocco@nrc.gov



Hearing Identifier: KHNP_APR1400_DCD_RAI_Public
Email Number: 235

Mail Envelope Properties (d8254cbdddf040cf86c15f398c2b51df)

Subject: APR1400 Design Certification Application RAI 186-8009 (09.05.07 - Emergency Diesel Engine Lubrication System)
Sent Date: 9/1/2015 5:27:56 AM
Received Date: 9/1/2015 5:27:59 AM
From: Ciocco, Jeff

Created By: Jeff.Ciocco@nrc.gov

Recipients:

"Curran, Gordon" <Gordon.Curran@nrc.gov>
Tracking Status: None
"Dias, Antonio" <Antonio.Dias@nrc.gov>
Tracking Status: None
"Wunder, George" <George.Wunder@nrc.gov>
Tracking Status: None
"Lee, Samuel" <Samuel.Lee@nrc.gov>
Tracking Status: None
"apr1400rai@khnp.co.kr" <apr1400rai@khnp.co.kr>
Tracking Status: None
"KHNPDCDRAIsPEM Resource" <KHNPDCDRAIsPEM.Resource@nrc.gov>
Tracking Status: None
"Harry (Hyun Seung) Chang" <hyunseung.chang@gmail.com>
Tracking Status: None
"Andy Jiyong Oh" <jiyong.oh5@gmail.com>
Tracking Status: None
"Christopher Tyree" <Christopher.tyree@aecom.com>
Tracking Status: None

Post Office: HQPWMSMRS08.nrc.gov

Files	Size	Date & Time
MESSAGE	695	9/1/2015 5:27:59 AM
APR1400 DC RAI 186 SPSB 8009.pdf		87993
image001.jpg	5040	

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

REQUEST FOR ADDITIONAL INFORMATION 186-8009

Issue Date: 09/01/2015
Application Title: APR1400 Design Certification Review – 52-046
Operating Company: Korea Hydro & Nuclear Power Co. Ltd.
Docket No. 52-046
Review Section: 09.05.07 - Emergency Diesel Engine Lubrication System
Application Section: 9.5.7

QUESTIONS

09.05.07-1

APR-1400 DCD Tier 2 Section 9.5.7.2.1 states that, while in standby, the motor-driven prelube oil pump draws oil from the engine sump tank and delivers it through the lube oil/preheating water heat exchanger and the full-flow filter to the engine. DCD Tier 2 Section 9.5.7.2.1 states that, while in standby, the motor-driven prelube oil pump draws oil from the engine sump tank and delivers it through the lube oil/preheating water heat exchanger and the full-flow filter to the engine.

NUREG/CR-0660, "Enhancement of Onsite Emergency Diesel Generator Reliability," cautions against pre-lube periods exceeding 5 minutes unless approved by the diesel manufacturer. NUREG-0800, SRP 9.5.7, Section III.3.F and G, which is based on NUREG/CR-0660, state similar caution.

The applicant is requested to justify the emergency diesel engine lubrication system (EDELS) compliance with the guidelines presented in NUREG/CR-0660, and revise the DCD accordingly to clarify compliance with the above guidelines.

09.05.07-2

In accordance with NUREG-0800, SRP 9.5.7, onsite lubricating oil storage capacity for each diesel engine sufficient for seven days operation after any design basis event and a continuous loss of off-site power as specified in ANSI/ANS-59.52.. NUREG-0800, SRP 14.2 provides additional guidance on review of the acceptability of the pre-operational and startup tests.

Emergency Diesel Generator Auxiliaries Test #106 in DCD Tier 2, Section 14.2 confirms the 7-day requirement for fuel oil storage, but does not confirm the 7-day requirement for lubricating oil storage.

The applicant is requested to provide assurance that the lubricating oil storage design will contain and confirm the 7-day storage requirement. The DCD should be revised accordingly.

