



L-2015-228  
10 CFR 52.3

September 8, 2015

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D.C. 20555-001

Re: Florida Power & Light Company  
Proposed Turkey Point Units 6 and 7  
Docket Nos. 52-040 and 52-041  
Voluntary Revised Response to NRC Request for Additional Information Letter No. 061  
(eRAI 6432) Related to SRP Section 03.07.01 - Seismic Design Parameters

Reference:

FPL Letter L-2015-085 to NRC dated April 2, 2015, Voluntary Revised Response to NRC Request for Additional Information Letter No. 061 (eRAI 6432) Related to SRP Section 03.07.01 - Seismic Design Parameters

In the Reference, Florida Power & Light Company (FPL) provided a revised response to the Nuclear Regulatory Commission's (NRC) request for additional information (RAI) 03.07.01-15. The revised response to RAI 03.07.01-15 included AP1000 Turkey Point Site Specific Seismic Evaluation Report, TPG-1000-S2R-802, Revision 6 dated March 2015, (Westinghouse Proprietary Class 2) and AP1000 Turkey Point Site Specific Seismic Evaluation Report TPG-1000-S2R-807 Revision 3 dated March 2015 (Westinghouse Non-Proprietary Class 3).

Subsequent to the submittal of the Reference, it was determined that a typographical error existed with respect to the elevation for the development GMRS at -16 ft instead of -35 ft. in Attachment 2, Enclosure 2, Page 19 of 231 and Attachment 2, Enclosure 3, Page 19 of 231 of the Reference. Westinghouse has issued AP1000 Turkey Point Site Specific Seismic Evaluation Report, TPG-1000-S2R-802, Revision 7 dated August 2015, (Westinghouse Proprietary Class 2) and AP1000 Turkey Point Site Specific Seismic Evaluation Report TPG-1000-S2R-807 Revision 4 dated August 2015 (Westinghouse Non-Proprietary Class 3) to correct the error. These documents will be provided in the next revision of the COL Application.

Florida Power & Light Company

700 Universe Boulevard, Juno Beach, FL 33408

D097  
NRO

Proposed Turkey Point Units 6 and 7  
Docket Nos. 52-040 and 52-041  
L-2015-228 Page 2

If you have any questions, or need additional information, please contact me at 561-691-7490.

I declare under penalty of perjury that the foregoing is true and correct.

Executed on September 8, 2015.

Sincerely,



William Maher  
Senior Licensing Director – New Nuclear Projects

WDM/RFB

cc:

PTN 6 & 7 Project Manager, AP1000 Projects Branch 1, USNRC DNRL/INRO  
Regional Administrator, Region II, USNRC  
Senior Resident Inspector, USNRC, Turkey Point Plant 3 & 4