

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9204140186 DOC. DATE: 92/04/06 NOTARIZED: NO DOCKET #
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287

AUTH. NAME AUTHOR AFFILIATION
 GROGAN, J.E. Duke Power Co.
 RECIP. NAME RECIPIENT AFFILIATION
 MOUBERRY, A. North Carolina, State of
 KEPLER, R. North Carolina, State of

SUBJECT: Submits amend to 911202 application for amend to NPDES
 Permit NC0026255, allowing use of copper sulfate & Cutrine
 Plus algicides & revising two flows. Form 101 & MSDS sheets
 for listed chemicals encl.

DISTRIBUTION CODE: C001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 30
 TITLE: Licensing Submittal: Environmental Rept Amdt & Related Correspondence

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	
	PD2-3 LA	3 3	PD2-3 PD	1 1	
	WIENS, L	1 1			
INTERNAL:	ACRS	6 6	NRR/DET/ESGB 8D	1 1	
	OC/LEMB	1 0	OGC/HDS2	1 0	
	<u>REG FILE</u> 01	1 1	RGN2 DRSS/RPB	1 1	
EXTERNAL:	EG&G SIMPSON, F	2 2	NRC PDR	1 1	
	NSIC	1 1			

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 20 ENCL 18

R
I
D
S
/
A
D
S

R
I
D
S
/
A
D
D
S

Duke Power Company
Wachovia Center
P.O. Box 1007
Charlotte, N.C. 28201-1007



DUKE POWER

April 6, 1992

Mr. Arthur Mouberry
Permits and Engineering Unit
Division of Environmental Management
P. O. Box 29535
Raleigh, NC 27626-0535

Attn: Mr. Randy Kepler
NPDES Permits Group

RE: Training and Technology Center
NPDES Permit NC 0026255
Amendment Request to Permit Application
File: MC 702.13

Dear Mr. Kepler:

With reference to the December 2, 1991, letter to you requesting NPDES permit renewal for the Duke Power Training and Technology Center, we request an amendment to our application. This amendment is needed to allow the use of copper sulfate and Cutrine Plus algicides, and to revise two flows on the December 2, 1991, application. Please find enclosed a Form 101 and an MSDS sheet for each of these chemical products. Calculations are included that are based on the revised flow rates.

Due to recent algal problems at our facility, we have already submitted to the NCDNRCD toxicity data for the use of Cutrine Plus. We have received verbal approval to begin use of this product and anticipate written approval in the near future.

Duke Power Company requests an amendment to certain flow numbers on the "Application for Permit to Discharge - Short Form D" originally submitted to you December 2, 1991. Attachment 8 is the amended form with the following changes: (1) Item 6.c., "Other Discharges," should be amended to 50,000 or more gallons per day; and (2) Item 6.d., "Maximum Per Operating Day," should be amended to 50,000 or more gallons per day.

The original numbers listed in the December 2, 1991, application reflected the reduced flow rates due to a reduction in in-house laboratory testing. The Training and Technology Center laboratory projects that its flow may increase in the future due to increased testing. The system


9204140186 920406
PDR ADOCK 05000269
P PDR

COOL
11

was originally designed and permitted for these higher flow rates.

We appreciate your consideration of this request. Should you have any questions or desire additional information, please contact Norma Atherton at (704) 382-2116 or Robert Wylie at (704) 373-2028.

Sincerely,



James E. Grogan, Vice President
Generation Services

Attachments

- c. Mr. Rex Gleason (w/attachment)
NRC Document Control Desk

BIOCIDE/CHEMICAL TREATMENT
WORKSHEET-FORM 101

The following calculations are to be performed on any biocidal products ultimately discharged to the surface waters of North Carolina. This worksheet must be completed separately for each biocidal product in use. This worksheet is to be returned with all appropriate data entered into the designated areas with calculations performed as indicated.

I. Facility Name Duke Power Company / Training and Technology Center
NPDES # NC 0026255
County Mecklenburg
Receiving Stream Lake Norman / Catawba River Basin 7Q10 80 (cfs)

(All above information supplied by the Division of Environmental Management)

What is the Average Daily Discharge (A.D.D.) volume of the water handling systems to the receiving water body?

A.D.D. = 0.013 (In M.G.D.)

Please calculate the Instream Waste Concentration (IWC in percent) of this discharge using the data entered above.

$$IWC = \frac{(A.D.D.) \times 100}{(7Q10)(0.646)} = \frac{(0.013) \times 100}{(80)(0.646) + (A.D.D.)} = 0.025 \%$$

This value (IWC) represents the waste concentration to the receiving stream during low flow conditions.

II. What is the name of the whole product chemical treatment proposed for use in the discharge identified in Part I?

Cutrine Plus

Please list the active ingredients and percent composition:

<u>Copper Alkanolamine Complex</u>	_____	%
_____	_____	%
_____	_____	%
_____	_____	%
_____	_____	%

What feed or dosage rate (D.R.) is used in this application? The units must be converted to grams of whole product used per day.

D.R. = 2300 grams/day

ATTACHMENT

Estimate total volume of the water handling system between entry of biocidal product and NPDES discharge point. On an attached sheet please provide justification for this estimate (system volume, average cycles per blowdown, holding lagoon size, etc.)

Volume = .552 million gallons *See ATTACHMENT 4*

What is the pH of the handling system prior to biocide addition? If unknown, enter N/A. 7

What is the decay rate (D.K.) of the product? If unknown, assume no decay (D.K.=0) and proceed to asterisk. The degradation must be stated at pH level within 1/2 pH standard unit within handling system. Enter the half life (Half Life is the time required for the initial product to degrade to half of its original concentration). Please provide copies of the sources of this data.

H.L. = 0 Days

The decay rate is equal to $\frac{1}{H.L.} \times 0.69 = \underline{0}$ = Decay Rate (D.K.)

Calculate degradation factor (D.F.). This is the first order loss coefficient.

$$D.F. = \frac{(A.D.D.)}{(Volume)} + (D.K.) = \frac{(0.013)}{(0.552)} + (0) = \underline{0.0236}$$

Calculate Steady State Discharge Concentration:

$$Dischg\ Conc. = \frac{(D.R.)}{(D.F.)(Volume)(3785)} = \frac{(2300)}{(0.0236)(0.552)(3785)} = \underline{46.6} \text{ mg/l}$$

Calculate concentration of biocide instream during low flow conditions.

(Receiving Stream Concentration)

$$\frac{(Dischg. Conc.) \times (IWC\%)}{100} = \frac{(46.6) \times (0.025)}{100} = \underline{0.0117} \text{ mg/l}$$

Receiving Stream Concentration

III. Calculate regulated limitation.

List all LC50 data available for the whole product according to the following columns. (Note that units should be in mg/l). Please provide copies of the sources of this data.

Organism	Test Duration	LC50 (mg/l)
<u>See Attachment 3</u>	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____

Choose the lowest LC50 listed above:

Enter the LC50: 1.2 mg/L

If the half life (H.L.) is less than 4 days, perform the following calculation.

Regulated Limitation = $0.05 \times \text{LC50} =$ _____ mg/l

If the half life (H.L.) is greater than 4 days or unknown, perform the following calculation.

Regulated Limitation = $0.01 \times \text{LC50} =$ 0.012 mg/l

Choose the appropriate regulated limitation from the calculations immediately above and place in this blank:

0.012 mg/liter

From Part II enter the receiving stream concentration:

0.0117 mg/liter

IV. Analysis.

If the receiving stream concentration is greater than the calculated regulated limitation, then this biocide is unacceptable for use.

J. R. Garrison
Name (Print)

J. R. Garrison / RR21
Signature
Person in Responsible Charge

3/12/92
Date

BIOCIDE/CHEMICAL TREATMENT
WORKSHEET-FORM 101

The following calculations are to be performed on any biocidal products ultimately discharged to the surface waters of North Carolina. This worksheet must be completed separately for each biocidal product in use. This worksheet is to be returned with all appropriate data entered into the designated areas with calculations performed as indicated.

I. Facility Name Duke Power Company / Training and Technology Center
NPDES # NC 0026255
County Mecklenburg
Receiving Stream Lake Norman / Catawba River Basin 7Q10 80 (cfs)

(All above information supplied by the Division of Environmental Management)

What is the Average Daily Discharge (A.D.D.) volume of the water handling systems to the receiving water body?

A.D.D. = 0.013 (in M.G.D.)

Please calculate the Instream Waste Concentration (IWC in percent) of this discharge using the data entered above.

$$IWC = \frac{(A.D.D.) \times 100}{(7Q10)(0.646)} = \frac{(0.013) \times 100}{(80)(0.646) + (A.D.D.)} = 0.025 \%$$

This value (IWC) represents the waste concentration to the receiving stream during low flow conditions.

II. What is the name of the whole product chemical treatment proposed for use in the discharge identified in Part I?

Citrine Plus

Please list the active ingredients and percent composition:

Copper Alkanolamine Complex _____ %

What feed or dosage rate (D.R.) is used in this application? The units must be converted to grams of whole product used per day.

D.R. = 2,288 grams/day

ATTACHMENT 2

Estimate total volume of the water handling system between entry of biocidal product and NPDES discharge point. On an attached sheet please provide justification for this estimate (system volume, average cycles per blowdown, holding lagoon size, etc.)

Volume = .259 million gallons SEE ATTACHMENT 4

What is the pH of the handling system prior to biocide addition? If unknown, enter N/A. 7

What is the decay rate (D.K.) of the product? If unknown, assume no decay (D.K.=0) and proceed to asterisk. The degradation must be stated at pH level within 1/2 pH standard unit within handling system. Enter the half life (Half Life is the time required for the initial product to degrade to half of its original concentration). Please provide copies of the sources of this data.

H.L. = 0 Days

The decay rate is equal to $\frac{1}{H.L.} \times 0.69 = \underline{0}$ = Decay Rate (D.K.)

Calculate degradation factor (D.F.). This is the first order loss coefficient.

$$D.F. = \frac{(A.D.D.)}{(Volume)} + (D.K.) = \frac{(0.013)}{(.259)} + (0) = \underline{.0502}$$

Calculate Steady State Discharge Concentration:

$$Dischg\ Conc. = \frac{(D.R.)}{(D.F.)(Volume)(3785)} = \frac{(2,288)}{(.0502)(.259)(3785)} = \underline{46.5} \text{ mg/l}$$

Calculate concentration of biocide instream during low flow conditions.

(Receiving Stream Concentration)

$$\frac{(Dischg. Conc.) \times (IWC\%)}{100} = \frac{(46.5) \times (0.025)}{100} = \underline{0.0117} \text{ mg/l}$$

Receiving Stream Concentration

III.

Calculate regulated limitation.

List all LC50 data available for the whole product according to the following columns. (Note that units should be in mg/l). Please provide copies of the sources of this data.

Organism	Test Duration	LC50 (mg/l)
<u>See Attachment 3</u>	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____

Choose the lowest LC50 listed above:

Enter the LC50: 1.2 mg/L

If the half life (H.L.) is less than 4 days, perform the following calculation.

Regulated Limitation = $0.05 \times \text{LC50} =$ _____ mg/l

If the half life (H.L.) is greater than 4 days or unknown, perform the following calculation.

Regulated Limitation = $0.01 \times \text{LC50} =$ 0.0120 mg/l

Choose the appropriate regulated limitation from the calculations immediately above and place in this blank:

0.0120 mg/liter

From Part II enter the receiving stream concentration:

0.0117 mg/liter

IV. Analysis.

If the receiving stream concentration is greater than the calculated regulated limitation, then this biocide is unacceptable for use.

J. R. Garrison

Name (Print)

J. R. Garrison / RRW

Signature

3/12/92

Date

Person in Responsible Charge

TOXICOLOGY DATA

ORGANISM	FORMULATED PRODUCT	TOXICITY BIOASSAY	ACTIVE INGREDIENT (copper)
Rat	Between 650 and 2,420 mg/kg ¹	ACUTE ORAL LD ₅₀ [*]	Between 58 and 215 ¹ mg/kg ¹
Leghorn Chicken	Greater than 2,500 ppm ¹	SUBACUTE DIETARY LC ₅₀ ^{**}	Greater than 225 ppm ¹
Ring-necked Pheasant	Greater than 1,000 ppm ²		Greater than 70 ppm ²
Mallard Duck	Greater than 1,000 ppm ²		Greater than 70 ppm ²
Rainbow Trout (44 ppm Total Hardness)	Less than 3.0 mg/l ²	96 HOUR LC ₅₀ ^{***} 96 HOUR LC ₅₀ ^{***}	Less than 0.2 mg/l ²
Rainbow Trout (290 ppm Total Hardness)	56 mg/l ¹		4.0 mg/l
Bluegill (48 ppm Total Hardness)	13.3 mg/l ¹		1.2 mg/l
Bluegill (200 ppm Total Hardness)	83 mg/l		7.5 mg/l
Channel Catfish	67 mg/l ²		6.0 mg/l
Blue Shrimp (Juvenile)	211 mg/l ¹		19.0 mg/l
Grass Shrimp	68 mg/l ²		4.8 mg/l
Fiddler Crab	2,200 mg/l ²		156 mg/l

¹ = Data from 9% copper mixed ethanalamine complex (Cutrine®-Plus).

² = Data from 7.1% copper-triethanolamine complex (Cutrine®).

* Acute oral LD₅₀ is the "lethal dosage determined to kill 50% of a test population of animals under laboratory conditions. Chemical is fed directly to the animal."

** Subacute Dietary LC₅₀ is the "lethal concentration of a chemical determined to kill 50% of a test population of animals when introduced in the food rations of the animals. Test is run for 8 days."

*** 96 Hour LC₅₀ is the "lethal concentration of a chemical in water determined to kill 50% of a test population of animals exposed for a 96 hour period."

ATTACHMENT 4

VOLUME SIZE OF TREATMENT SYSTEM

1. Pond Elevation = 10 ft

$$45' \times 164' \times 10' = 73,800 \text{ ft}^3 = .552 \times 10^6 \text{ gals.}$$

2. Pond Elevation = 6 ft

$$37' \times 156' \times 6' = 34,632 \text{ ft}^3 = .259 \times 10^6 \text{ gals.}$$



HMS CODE

H= 2
F= 0
R= 1
PP= B

(X)

MATERIAL SAFETY DATA SHEET

Revision: 10/1/91

DE NAME: **CUTRINE PLUS**

SECTION I

MANUFACTURER'S NAME: APPLIED BIOCHEMISTS, INC.
6120 West Douglas Ave.
Milwaukee, WI 53218

EMERGENCY PHONE NUMBERS:

(414) 242-5870

LEAKS OR SPILLS - Contact Chemtrac at 1-(800) 424-9300

PRODUCT NAME: Cutrine Plus
CHEMICAL NAME & SYNONYMS: Copper Alkanolamine Complex

CHEMICAL FAMILY: Copper and Nitrogen Compounds
FORMULA: Formulation

SECTION II - Hazardous Ingredients

Copper Carbonate	CAS# 12069-89-1	
Monoethanolamine	41-43-5	Not a known carcinogen
Triethanolamine	107-71-6	

SECTION III - Physical Data

MELTING POINT (Deg. F): 212 °F
SPECIFIC GRAVITY (H₂O = 1): 1.2 @ 27°C

VAPOR PRESSURE (mm Hg.):
VOLATILE BY VOLUME(%): Nil

VAPOR DENSITY (AIR=1):
EVAPORATION RATE (_____ =1):

SOLUBILITY IN WATER: Complete
REACTIVITY IN WATER: Soluble

APPEARANCE AND ODOR: Blue viscous liquid. Slight odor.

SECTION IV - Fire & Explosion Hazard Data

FLASH POINT (Method Used): N/A
AUTO-IGNITION TEMPERATURE: > 205°F

FLAMMABLE LIMITS: Not Flammable
Lel: Uel:

EXTINGUISHING MEDIA: CO₂, H₂O or dry chemical. Polymer foam for large fires.

SPECIAL FIRE FIGHTING PROCEDURES: None

SECTION V - HEALTH HAZARD DATA

THRESHOLD LIMIT VALUE:

Copper mists: 1.0 mg/M³
Ethanolamines: 3 p/m 8 mg/M³

EFFECTS OF OVEREXPOSURE:

Contact with skin and eyes may be irritating. Vapors or mist may cause irritation with pain, coughing and discomfort to eyes, nose, throat and chest.

EMERGENCY FIRST AID PROCEDURES:

Inhalation: Remove to fresh air
Eyes: Flush with plenty of water for at least 15 minutes. Get medical attention.
Skin: Flush with plenty of water for at least 15 minutes.
Ingestion: Get immediate medical attention.

SECTION VI - REACTIVITY DATA

STABILITY

() UNSTABLE (XXX) STABLE

CONDITIONS TO AVOID:

Thermal decomposition may cause oxides of carbon/nitrogen.

COMPATIBILITY (Materials to Avoid):

Strong acids and nitrites

HAZARDOUS POLYMERIZATION:

() MAY OCCUR (XXX) WILL NOT OCCUR

CONDITIONS TO AVOID:

Contact with strong acids and nitrites

SECTION VII - SPILL OR LEAK PROCEDURES

STEPS TO BE TAKEN IN CASE MATERIAL IS RELEASED OR SPILLED:

Flush heavily with water after picking up all possible spillage.

WASTE DISPOSAL METHOD:

Incinerate in a furnace or flush small amount into sewer system.
More than 5 gallons, contact local authorities for directions.

SECTION VIII - SPECIAL PROTECTION INFORMATION

RESPIRATORY PROTECTION (Specify Type):

VENTILATION

LOCAL EXHAUST:

MECHANICAL (General):
Acceptable

SPECIAL:

PROTECTIVE GLOVES:

Preferable

EYE PROTECTION:

Goggles

OTHER PROTECTIVE EQUIPMENT:

Safety Shower and eye wash

SECTION IX - SPECIAL PRECAUTIONS

PRECAUTIONS TO BE TAKEN IN HANDLING AND STORING:

May cause skin damage. Do not get on skin, eyes or clothing.
KEEP OUT OF REACH OF CHILDREN

OTHER PRECAUTIONS:

Trade Name Formulation And Active Ingredient	Description (Type, mode of action, target pests, precautions, application rates)	Manufacturer
Aquathol K Liquid Dipotassium Salt of Endothall (40.3%) active	Broad range contact herbicide for controlling underwater weeds. Especially effective against Pondweeds (Potamogeton Spp.) Application rates range from 0.3 to 3.2 gallons per acre foot depending upon species and nature of area to be treated.	Penwalt Corporation AgChem Division, Fresno, California
Aquathol Granular Dipotassium Salt of Endothall (10.1%) active	Broad range contact herbicide. Soluble active ingredient released from clay granules to give herbicidal effect. Application rates range from 13 to 135 pounds per acre-foot depending upon species and nature of area to be treated.	Penwalt Corporation AgChem Division, Fresno, California
Cutrine-Plus Liquid Copper from Alkanolamine Complex (9%) active	Chelated copper algaecide effective against most species of planktonic, filamentous, and bottom algae types. Non-corrosive to equipment. Does not precipitate out of solution in hard water. Compatible in tank mixes with Aquathol K and Diquat. Application rates range from 0.6 to 1.2 gallons per acre-foot.	Applied Biochemists 5300 W. County Line Rd. Mequon, WI 53092 1-800-558-5106 6120 W. Douglas Ave Milwaukee, WI 53221
Cutrine-Plus Granular Copper Alkanolamine Complex (3.7%)	Soluble active ingredient released from clay granules effective against most bottom growing forms of algae. Especially effective for spot treatments or in moving water. Application rate 60 pounds per surface acre.	Applied Biochemists 5300 W. County Line Rd Mequon, WI 53092 1-800-558-5106
Diquat Diquat cation (19%)	Broad range herbicide rapidly absorbed by plants. Effective against most submerged, floating, and emergent weeds. Do not use in muddy waters. May be corrosive to applying equipment. Application rates range from 0.5 to 2 gallons per surface acre.	Valent Ortho-Chemical Company Mendota Heights, Illinois sets W.A. Nuttall & Co.
Vegatrol LV 4-D 2,4-D LV Ester (69.9%)	Selective systemic-type herbicide especially effective against water milfoil, coontail, and water lilies. Do not use in ponds used for irrigation purposes. Application rates range from 0.75 to 1.4 gallons per acre-foot.	Velsicol Chemical Corporation Chicago, Illinois
Weedtrine II Granular Iso-Octyl Ester of 2,4-D (30.22%)	Soluble active ingredient released from clay granules. Effective against selected species of submerged and emergent aquatic plants. Application rates range from 100-150 pounds per surface acre.	Applied Biochemists 5300 W. County Line Rd. Mequon, WI 53092 1-800-558-5106

BIOCIDE/CHEMICAL TREATMENT
WORKSHEET-FORM 101

The following calculations are to be performed on any biocidal products ultimately discharged to the surface waters of North Carolina. This worksheet must be completed separately for each biocidal product in use. This worksheet is to be returned with all appropriate data entered into the designated areas with calculations performed as indicated.

I. Facility Name DUKE POWER COMPANY / TRAINING AND Technology Center
NPDES # NC 0026255
County Mecklenburg

Receiving Stream LAKE NORMAN / CATAWBA RIVER BASIN 7Q10 80 (cfs)

(All above information supplied by the Division of Environmental Management)

What is the Average Daily Discharge (A.D.D.) volume of the water handling systems to the receiving water body?

A.D.D. = 0.013 (in M.G.D.)

Please calculate the instream Waste Concentration (IWC in percent) of this discharge using the data entered above.

$$IWC = \frac{(A.D.D.) \times 100}{(7Q10)(0.646)} = \frac{(0.013) \times 100}{(80)(0.646) + (A.D.D.)} = \underline{0.025\%}$$

This value (IWC) represents the waste concentration to the receiving stream during low flow conditions.

II. What is the name of the whole product chemical treatment proposed for use in the discharge identified in Part I?

Copper Sulfate

Please list the active ingredients and percent composition:

<u>Copper (II) Sulfate Pentahydrate</u>	<u>100</u> %
_____	_____ %
_____	_____ %
_____	_____ %
_____	_____ %

What feed or dosage rate (D.R.) is used in this application? The units must be converted to grams of whole product used per day.

D.R. = 4536 grams/day

Estimate total volume of the water handling system between entry of biocidal product and NPDES discharge point. On an attached sheet please provide justification for this estimate (system volume, average cycles per blowdown, holding lagoon size, etc.)

Volume = 0.552 million gallons See ATTACHMENT 4

What is the pH of the handling system prior to biocide addition? If unknown, enter N/A. 7

What is the decay rate (D.K.) of the product? If unknown, assume no decay (D.K.=0) and proceed to asterisk. The degradation must be stated at pH level within 1/2 pH standard unit within handling system. Enter the half life (Half Life is the time required for the initial product to degrade to half of its original concentration). Please provide copies of the sources of this data.

H.L. = 0 Days

The decay rate is equal to $\frac{1}{H.L.} \times 0.69 = \underline{0}$ = Decay Rate (D.K.)

Calculate degradation factor (D.F.). This is the first order loss coefficient.

$$D.F. = \frac{(A.D.D.)}{(Volume)} + (D.K.) = \frac{(0.013)}{(0.552)} + (0) = \underline{0.0236}$$

Calculate Steady State Discharge Concentration:

$$Dischg\ Conc. = \frac{(D.R.)}{(D.F.)(Volume)(3785)} = \frac{(4536)}{(0.0236)(0.552)(3785)} = \underline{95.882\ mg/l}$$

Calculate concentration of biocide instream during low flow conditions.

(Receiving Stream Concentration)

$$\frac{(Dischg.\ Conc.) \times (IWC\%)}{100} = \frac{(95.882) \times (0.025)}{100} = \underline{0.0240\ mg/(CuSO_4)}$$

$$(.0240\ mg/L) \times \frac{(63.54\ M.Wt.\ Cu)}{(249.68\ M.Wt.\ CuSO_4)} = 0.0061\ mg/L\ Cu$$

Receiving Stream Concentration

III.

Calculate regulated limitation.

$$= 6.1\ \mu g/L\ Cu$$

List all LC50 data available for the whole product according to the following columns. (Note that units should be in mg/l). Please provide copies of the sources of this data.

Organism	Test Duration	LC50 (mg/l)
<u>See page 3</u>		

Choose the lowest LC50 listed above:

Enter the LC50: Action Level = 7ug/L of Copper used for calculation

If the half life (H.L.) is less than 4 days, perform the following calculation.

Regulated Limitation = $0.05 \times \text{LC50} = \underline{\hspace{2cm}}$ mg/l

If the half life (H.L.) is greater than 4 days or unknown, perform the following calculation.

Regulated Limitation = $0.01 \times \text{LC50} = \underline{\hspace{2cm}}$ mg/l

Choose the appropriate regulated limitation from the calculations immediately above and place in this blank:

7ug/L Cu. mg/liter

From Part II enter the receiving stream concentration:

0.0240 mg/liter of Copper Sulfate
 OR 6.1 ug/L of Copper

IV. Analysis.

If the receiving stream concentration is greater than the calculated regulated limitation, then this biocide is unacceptable for use.

J.R. GARRISON

Name (Print)

J.R. Garrison / nga

Signature

4/6/92

Date

Person in Responsible Charge

BIOCIDE/CHEMICAL TREATMENT
WORKSHEET-FORM 101

The following calculations are to be performed on any biocidal products ultimately discharged to the surface waters of North Carolina. This worksheet must be completed separately for each biocidal product in use. This worksheet is to be returned with all appropriate data entered into the designated areas with calculations performed as indicated.

- I. Facility Name DUKE POWER COMPANY / TRAINING AND Technology Center
 NPDES # NC 0026255
 County Mecklenburg
 Receiving Stream LAKE NORMAN / CATAWBA RIVER BASIN 7Q10 80 (cfs)
 (All above information supplied by the Division of Environmental Management)
 What is the Average Daily Discharge (A.D.D.) volume of the water handling systems to the receiving water body?

A.D.D. = 0.013 (In M.G.D.)

Please calculate the Instream Waste Concentration (IWC in percent) of this discharge using the data entered above.

$$IWC = \frac{(A.D.D.) \times 100}{(7Q10)(0.646)} = \frac{(0.013) \times 100}{(80)(0.646) + (A.D.D.)} = \underline{0.025\%}$$

This value (IWC) represents the waste concentration to the receiving stream during low flow conditions.

- II. What is the name of the whole product chemical treatment proposed for use in the discharge identified in Part I?
Copper Sulfate

Please list the active ingredients and percent composition:

<u>Copper (II) Sulfate Pentahydrate</u>	<u>100</u> %
_____	_____ %
_____	_____ %
_____	_____ %
_____	_____ %

What feed or dosage rate (D.R.) is used in this application? The units must be converted to grams of whole product used per day.

D.R. = 2268 grams/day

Estimate total volume of the water handling system between entry of biocidal product and NPDES discharge point. On an attached sheet please provide justification for this estimate (system volume, average cycles per blowdown, holding lagoon size, etc.)

Volume = 0.259 million gallons See ATTACHMENT 4

What is the pH of the handling system prior to biocide addition? If unknown, enter N/A. 7

What is the decay rate (D.K.) of the product? If unknown, assume no decay (D.K.=0) and proceed to asterisk. The degradation must be stated at pH level within 1/2 pH standard unit within handling system. Enter the half life (Half Life is the time required for the initial product to degrade to half of its original concentration). Please provide copies of the sources of this data.

H.L. = 0 Days

The decay rate is equal to $\frac{1}{H.L.} \times 0.69 = \underline{0}$ = Decay Rate (D.K.)

Calculate degradation factor (D.F.). This is the first order loss coefficient.

$$D.F. = \frac{(A.D.D.)}{(Volume)} + (D.K.) = \frac{(0.013)}{(0.259)} + (0) = \underline{.0502}$$

Calculate Steady State Discharge Concentration:

$$Dischg\ Conc. = \frac{(D.R.)}{(D.F.)(Volume)(3785)} = \frac{(2268)}{(.0502)(.259)(3785)} = \underline{46.09\ mg/l}$$

Calculate concentration of biocide instream during low flow conditions.

(Receiving Stream Concentration)

$$\frac{(Dischg.\ Conc.) \times (IWC\%)}{100} = \frac{(46.09) \times (0.025)}{100} = \underline{.012\ mg\ (CuSO_4)}$$

$$(.012\ mg/L) \times \frac{(63.54\ M.Wt.\ Cu)}{(249.68\ M.Wt.\ CuSO_4)} = 0.0030\ mg/L\ Cu\ Receiving\ Stream\ Concentration$$

iii.

Calculate regulated limitation.

OR 3.0 mg/L Cu

List all LC50 data available for the whole product according to the following columns. (Note that units should be in mg/l). Please provide copies of the sources of this data.

Organism	Test Duration	LC50 (mg/l)
<u>See page 3</u>		

Choose the lowest LC50 listed above:

Enter the LC50: ACTION Level = 7ug/L of Copper (used for calculation)

If the half life (H.L.) is less than 4 days, perform the following calculation.

Regulated Limitation = $0.05 \times \text{LC50} = \underline{\hspace{2cm}}$ mg/l

If the half life (H.L.) is greater than 4 days or unknown, perform the following calculation.

Regulated Limitation = $0.01 \times \text{LC50} = \underline{\hspace{2cm}}$ mg/l

Choose the appropriate regulated limitation from the calculations immediately above and place in this blank:

7ug/L Cu mg/liter

From Part II enter the receiving stream concentration:

0.012 mg/liter (of CuSO_4)
= 3.0ug/L Cu

IV. Analysis.

If the receiving stream concentration is greater than the calculated regulated limitation, then this biocide is unacceptable for use.

J. R. GARRISON

Name (Print)

J. R. Garrison / nqa

Signature

Person in Responsible Charge

4/6/92

Date

Mallinckrodt

Material Safety Data

Emergency Phone Number: 314-539-1600

Mallinckrodt provides the information contained herein in good faith but makes no representation as to its comprehensiveness or accuracy. Individuals receiving this information must exercise their independent judgment in determining its appropriateness for a particular purpose.

Mallinckrodt makes no representations, or warranties, either express or implied, of merchantability, fitness for a particular purpose with respect to the information set forth herein or to the product to which the information refers. Accordingly, Mallinckrodt will not be responsible for damages resulting from use of or reliance upon this information.

Inv. Rev. 221

Performance and Laboratory Chemical Div., P.O. Box 800, Paris, KY 40362.

CUPRIC SULFATE

PRODUCT IDENTIFICATION:

Synonyms: Copper (II) Sulfate Pentahydrate (1:1:5); blue vitriol; Sulfuric acid copper (2+) salt (1:1), Pentahydrate

Formula CAS No.: 7758-99-8 (Hydrated)

TSCA CAS No.: 7758-98-7 (Anhydrous)

Molecular Weight: 249.68

Chemical Formula: $\text{CuSO}_4 \cdot 5\text{H}_2\text{O}$

Hazardous Ingredients: Cupric sulfate

PRECAUTIONARY MEASURES

WARNING! HARMFUL IF SWALLOWED. CAUSES IRRITATION.

Avoid contact with eyes, skin and clothing. Wash thoroughly after handling.

EMERGENCY/FIRST AID

If swallowed, induce vomiting immediately by giving two glasses of water and sticking finger down throat. Never give anything by mouth to an unconscious person. In case of contact, immediately flush skin or eyes with plenty of water for at least 15 minutes.

In all cases call a physician.

SEE SECTION 5.

DOT Hazard Class: ORM-E

SECTION 1 Physical Data

Appearance: Transparent blue triclinic crystals or crystalline granules or power.

Odor: Odorless.

Solubility: 24.3g/100g H_2O @ 30°C (86°F)

Boiling Point: > 400°C (752°F) decomposes

Melting Point: Loses water @ 110°C (230°F)

Specific Gravity: 2.28

Vapor Density (Air = 1): No information found.

Vapor Pressure (mm Hg): No information found.

Evaporation Rate: (water = 1): slowly efforescent.

SECTION 2 Fire and Explosion Information

Fire:

Not considered to be a fire hazard.

Explosion:

Not considered to be an explosion hazard. Sealed container may rupture during fire conditions from pressure water vapor release.

Fire Extinguishing Media:

Use any means suitable for extinguishing surrounding fire. Water spray may be used to keep fire exposed containers cool.

Special Information:

In the event of a fire, wear full protective clothing and NIOSH-approved self-contained breathing apparatus with full facepiece operated in the pressure demand or other positive pressure mode. When heated above 110°C (230°F) material will melt. Avoid using a direct water stream on molten material as it may causes splattering.

SECTION 3 Reactivity Data

Stability:

Stable under ordinary conditions of use and storage.

Hazardous Decomposition Products:

When heated to decomposition cupric oxide and sulfur oxide may form.

Hazardous Polymerization:

Will not occur.

Incompatibilities:

At temperatures greater than 250°C (482°F) the anhydrous salt will ignite hydroxylamine. Solutions are acidic and can react with magnesium to evolve flammable hydrogen gas.

SECTION 4 Leak/Spill Disposal Information

Ventilate area of leak or spill. Clean-up personnel require protective clothing and respiratory protection from dust.

Spills: Pick up and place in a suitable container for reclamation or disposal in a method that does not generate dust.

Disposal: Whatever cannot be saved for reclamation may be disposed in a RCRA approved hazardous waste facility. Reportable Quantity (RQ) (CWA/CERCLA): 10 lbs. Anhydrous

Ensure compliance with local, state and federal regulations.

ATTACHMENT 7

Mallinckrodt

Material Safety Data

Mallinckrodt provides the information contained herein in good faith but makes no representation as to its comprehensiveness or accuracy. Individuals receiving this information must exercise their independent judgment in determining its appropriateness for a particular purpose.

Mallinckrodt makes no representations, or warranties, either express or implied, of merchantability, fitness for a particular purpose with respect to the information set forth herein or to the product to which the information refers. Accordingly, Mallinckrodt will not be responsible for damages resulting from use of or reliance upon this information.

Emergency Phone Number: 314-539-1600

Performance and Laboratory Chemical Div., P.O. Box 800, Paris, KY 40362.

SECTION 5 Health Hazard Information

A. EXPOSURE / HEALTH EFFECTS

Inhalation:

May cause irritation to the upper respiratory tract; symptoms may include coughing, sore throat, and shortness of breath. May also cause symptoms similar to the common cold; including chills and stuffiness of the head.

Ingestion:

Toxic! May cause burning pain in the mouth, esophagus, and stomach. Hemorrhagic gastritis, nausea, vomiting, abdominal pain, metallic taste, and diarrhea may occur. If vomiting does not occur immediately systemic copper poisoning may occur. Symptoms may include capillary damage, headache, cold sweat, weak pulse, kidney and liver damage, central nervous excitation followed by depression, jaundice, convulsions, paralysis and coma. Death may occur from shock or renal failure.

Skin Contact:

May cause irritation and itching.

Eye Contact:

Dust may cause irritation. Contact may cause conjunctivitis, ulceration, or clouding of the cornea.

Chronic Exposure:

Prolonged or repeated skin exposure may cause dermatitis. Prolonged or repeated exposure to dusts of copper salts may cause discoloration of the skin or hair, ulceration and perforation of the nasal septum, runny nose, metallic taste, and atrophic changes and irritation of the mucous membranes.

Aggravation of Pre-existing Conditions:

Persons with pre-existing skin disorders or impaired liver, kidney, or pulmonary function or pre-existing Wilson's disease may be more susceptible to the effects of this material.

B. FIRST AID

Inhalation:

Remove to fresh air. If not breathing, give artificial respiration. If breathing is difficult, give oxygen. Call a physician.

Ingestion:

If swallowed, induce vomiting immediately by giving two glasses of water, or milk if available and sticking finger down throat. Call a physician immediately. Never give anything by mouth to an unconscious person.

Skin Exposure:

Remove any contaminated clothing. Wash skin with plenty of water for at least 15 minutes. If irritation develops, get medical attention.

Eye Exposure:

Wash eyes with plenty of water for at least 15 minutes, lifting lower and upper eyelids occasionally. Get medical attention immediately.

C. TOXICITY DATA (RTECS, 1986)

Oral rat LD50: 300 mg/kg. Mutation references cited.

SECTION 6 Occupational Control Measures

Airborne Exposure Limits:

-OSHA Permissible Exposure Limit (PEL):
1 mg/m³ (TWA) for copper dusts & mists as Cu
-ACGIH Threshold Limit Value (TLV):
1 mg/m³ (TWA) for copper dusts & mists as Cu

Ventilation System:

A system of local and/or general exhaust is recommended to keep employee exposures below the Airborne Exposure Limits. Local exhaust ventilation is generally preferred because it can control the emissions of the contaminant at its source, preventing dispersion of it into the general work area. Please refer to the ACGIH document, "Industrial Ventilation, A Manual of Recommended Practices", most recent edition, for details.

Personal Respirators: (NIOSH Approved)

If the TLV is exceeded, a dust/mist respirator with chemical goggles may be worn, in general, up to ten times the TLV. Consult respirator supplier for limitations. Alternatively, a supplied air full facepiece respirator or airlined hood may be worn.

Skin Protection:

Wear protective gloves and clean body-covering clothing.

Eye Protection:

Use chemical safety goggles. Contact lenses should not be worn when working with this material. Maintain eye wash fountain and quick-drench facilities in work area.

SECTION 7 Storage and Special Information

Keep in a tightly closed container, stored in a cool, dry, ventilated area. Protect against physical damage. Isolate from incompatible substances. Solutions are corrosive to mild steel.

CUPSU

ATTACHMENT 7

Mallinckrodt

Material Safety Data

Mallinckrodt provides the information contained herein in good faith but makes no representation as to its comprehensiveness or accuracy. Individuals receiving this information must exercise their independent judgment in determining its appropriateness for a particular purpose.

Mallinckrodt makes no representations, or warranties, either express or implied, of merchantability, fitness for a particular purpose with respect to the information set forth herein or to the product to which the information refers. Accordingly, Mallinckrodt will not be responsible for damages resulting from use of or reliance upon this information.

Emergency Phone Number: 314-539-1600

Performance and Laboratory Chemical Div., P.O. Box 800, Paris, KY 40362.

Addendum to Material Safety Data Sheet

REGULATORY STATUS

This Addendum Must Not Be Detached from the MSDS

Identifies SARA 313 substance(s)

Any copying or redistribution of the MSDS must include a copy of this addendum

(Chem.Key: CUPSU)

Hazard Categories for SARA
Section 311/312 Reporting

Acute	Chronic	Fire	Pressure	Reactive
X	X			

Product or Components
of Product:

CUPRIC SULFATE (7758-98-7)

SARA EHS Sect. 302 RQ (lbs.)	TPQ (lbs.)	SARA Section 313 Chemicals Name List	Chemical Category	CERCLA Sec.103 RQ (lbs.)	RCRA Sec. 261.33
No	No	No	Copper compound	10	No

SARA Section 302 EHS RQ: Reportable Quantity of Extremely Hazardous Substance, listed at 40 CFR 355.

SARA Section 302 EHS TPQ: Threshold Planning Quantity of Extremely Hazardous Substance. An asterisk (*) following a Threshold Planning Quantity signifies that if the material is a solid and has a particle size equal to or larger than 100 micrometers, the Threshold Planning Quantity = 10,000 LBS.

SARA Section 313 Chemicals: Toxic Substances subject to annual release reporting requirements listed at 40 CFR 372.65.

CERCLA Sec. 103: Comprehensive Environmental Response, Compensation and Liability Act (Superfund). Releases to air, land or water of these hazardous substances which exceed the Reportable Quantity (RQ) must be reported to the National Response Center, (800-424-8802); Listed at 40 CFR 302.4

RCRA: Resource Conservation and Reclamation Act. Commercial chemical product wastes designated as acute hazards and toxic under 40 CFR 261.33

Effective Date: 04-06-89 Supersedes 08-05-85

CUPRIC SULFATE

ATTACHMENT 7

7. If any of the types of waste identified in item 6, either treated or untreated, are discharged to places other than surface waters, check below as applicable.

Waste water is discharged to:	0.1-999	1000-4999	5000-9999	10,000-49,999	50,000 or more
	(1)	(2)	(3)	(4)	(5)
A. Municipal sewer system	NA				
B. Unchaperoned well	NA				
C. Septic tank	NA				
D. Evaporation lagoon or pond	NA				
E. Other, specify:	NA				

8. Number of separate discharge points:

- A. 01 B. 02-3 C. 4-5 D. 6 or more

9. Name of receiving water or waters Lake Norman, Catawba River Basin

10. Does your discharge contain or is it possible for your discharge to contain one or more of the following substances added as a result of your operations, activities, or processes: ammonia, cyanide, aluminum, beryllium, cadmium, chromium, copper, lead, mercury, nickel, selenium, zinc, phenols, oil and grease, and chlorine (residual).

- A. yes B. no

I certify that I am familiar with the information contained in the application and that to the best of my knowledge and belief such information is true, complete, and accurate.

James E. Grogan
Printed Name of Person Signing

Vice President, Generation Services
Title

4/7/92
Date Application Signed

x James E. Grogan
Signature of Applicant

North Carolina General Statute 143-215.6(b)(2) provides that: Any person who knowingly makes any false statement representation, or certification in any application, record, report, plan or other document files or required to be maintained under Article 21 or regulations of the Environmental Management Commission implementing that Article, or who falsifies, tampers with or knowingly renders inaccurate any recording or monitoring device or method required to be operated or maintained under Article 21 or regulations of the Environmental Management Commission implementing that Article, shall be guilty of a misdemeanor punishable by a fine not to exceed \$10,000, or by imprisonment not to exceed six months, or by both. (18 U.S.C. Section 1001 provides a punishment by a fine of not more than \$10,000 or imprisonment not more than 5 years, or both for a similar offense.)

BIOCIDE/CHEMICAL TREATMENT
WORKSHEET-FORM 101

The following calculations are to be performed on any biocidal products ultimately discharged to the surface waters of North Carolina. This worksheet must be completed separately for each biocidal product in use. This worksheet is to be returned with all appropriate data entered into the designated areas with calculations performed as indicated.

I. Facility Name DUKE Power Company / TRAINING and Technology Center
NPDES # NC 0026255
County Mecklenburg
Receiving Stream LAKE NORMAN / CATAWBA RIVER BASIN 7Q10 80 (cfs)

(All above information supplied by the Division of Environmental Management)

What is the Average Daily Discharge (A.D.D.) volume of the water handling systems to the receiving water body?

A.D.D. = 0.0525 (in M.G.D.)

Please calculate the Instream Waste Concentration (IWC in percent) of this discharge using the data entered above.

$$IWC = \frac{(A.D.D.) \times 100}{(7Q10)(0.646)} = \frac{(0.0525) \times 100}{(80)(0.646) + (A.D.D.)} = \frac{.101}{(.0525)} \%$$

This value (IWC) represents the waste concentration to the receiving stream during low flow conditions.

II. What is the name of the whole product chemical treatment proposed for use in the discharge identified in Part I?

Cutrine Plus

Please list the active ingredients and percent composition:

<u>Cutrine Plus - Copper Aikanolamine</u>	<u>100</u>	<u>%</u>
<u>Complex</u>		<u>%</u>
		<u>%</u>
		<u>%</u>
		<u>%</u>

What feed or dosage rate (D.R.) is used in this application? The units must be converted to grams of whole product used per day.

D.R. = 2300 grams/day

Estimate total volume of the water handling system between entry of biocidal product and NPDES discharge point. On an attached sheet please provide justification for this estimate (system volume, average cycles per blowdown, holding lagoon size, etc.)

Volume= 0.552 million gallons see Attachment 4

What is the pH of the handling system prior to biocide addition? If unknown, enter N/A. 7

What is the decay rate (D.K.) of the product? If unknown, assume no decay (D.K.=0) and proceed to asterisk. The degradation must be stated at pH level within 1/2 pH standard unit within handling system. Enter the half life (Half Life is the time required for the initial product to degrade to half of its original concentration). Please provide copies of the sources of this data.

H.L. = 0 Days

The decay rate is equal to $\frac{1}{H.L.} \times 0.69 = \underline{0}$ = Decay Rate (D.K.)

Calculate degradation factor (D.F.). This is the first order loss coefficient.

$$D.F. = \frac{(A.D.D.)}{(Volume)} + (D.K.) = \frac{(.0525)}{(.552)} + (0) = \underline{0.0951}$$

Calculate Steady State Discharge Concentration:

$$Dischg\ Conc. = \frac{(D.R.)}{(D.F.)(Volume)(3785)} = \frac{(2300)}{(0.0951)(0.552)(3785)} = \underline{11.58} \text{ mg/l}$$

Calculate concentration of biocide instream during low flow conditions.

(Receiving Stream Concentration)

$$\frac{(Dischg. Conc.) \times (IWC\%)}{100} = \frac{(11.58) \times (.101)}{100} = \underline{0.0117} \text{ mg/l}$$

Receiving Stream Concentration

III. Calculate regulated limitation.

List all LC50 data available for the whole product according to the following columns. (Note that units should be in mg/l). Please provide copies of the sources of this data.

Organism	Test Duration	LC50 (mg/l)
<u>see Attachment 3</u>		

Choose the lowest LC50 listed above:

Enter the LC50: 1.2 mg/L

If the half life (H.L.) is less than 4 days, perform the following calculation.

Regulated Limitation = $0.05 \times \text{LC50} =$ _____ mg/l

If the half life (H.L.) is greater than 4 days or unknown, perform the following calculation.

Regulated Limitation = $0.01 \times \text{LC50} =$ 0.012 mg/l

Choose the appropriate regulated limitation from the calculations immediately above and place in this blank:

0.012 mg/liter

From Part II enter the receiving stream concentration:

0.0117 mg/liter

IV. Analysis.

If the receiving stream concentration is greater than the calculated regulated limitation, then this biocide is unacceptable for use.

J. R. GARRISON
Name (Print)

J. R. Garrison / nge
Signature

4/6/92
Date

Person in Responsible Charge

BIOCIDE/CHEMICAL TREATMENT WORKSHEET-FORM 101

The following calculations are to be performed on any biocidal products ultimately discharged to the surface waters of North Carolina. This worksheet must be completed separately for each biocidal product in use. This worksheet is to be returned with all appropriate data entered into the designated areas with calculations performed as indicated.

i. Facility Name DUKE POWER Company / Training And Technology Center
NPDES # NC 0026255
County Mecklenburg
Receiving Stream LAKE NORMAN / CATAWBA RIVER BASIN 7Q10 80 (cfs)
(All above information supplied by the Division of Environmental Management)

What is the Average Daily Discharge (A.D.D.) volume of the water handling systems to the receiving water body?

A.D.D. = 0.0525 (in M.G.D.)

Please calculate the Instream Waste Concentration (IWC in percent) of this discharge using the data entered above.

IWC = (A.D.D.) X 100 / (7Q10)(0.646) = (.0525) X 100 / (80)(0.646) + (A.D.D.) / (.0525) = 0.101 %

This value (IWC) represents the waste concentration to the receiving stream during low flow conditions.

ii. What is the name of the whole product chemical treatment proposed for use in the discharge identified in Part I?

Outrine Plus

Please list the active ingredients and percent composition:

Table with 2 columns: Active ingredient name and Percent composition. Row 1: Copper Alkanolamine Complex, 100%. Other rows are blank.

What feed or dosage rate (D.R.) is used in this application? The units must be converted to grams of whole product used per day.

D.R. = 2288 grams/day

Estimate total volume of the water handling system between entry of biocidal product and NPDES discharge point. On an attached sheet please provide justification for this estimate (system volume, average cycles per blowdown, holding lagoon size, etc.)

Volume = .259 million gallons See Attachment 4

What is the pH of the handling system prior to biocide addition? If unknown, enter N/A. 7

What is the decay rate (D.K.) of the product? If unknown, assume no decay (D.K.=0) and proceed to asterisk. The degradation must be stated at pH level within 1/2 pH standard unit within handling system. Enter the half life (Half Life is the time required for the initial product to degrade to half of its original concentration). Please provide copies of the sources of this data.

H.L. = 0 Days

The decay rate is equal to $\frac{1}{H.L.} \times 0.69 = \underline{0}$ = Decay Rate (D.K.)

Calculate degradation factor (D.F.). This is the first order loss coefficient.

$$D.F. = \frac{(A.D.D.)}{(Volume)} + (D.K.) = \frac{(0.0525)}{(.259)} + (0) = \underline{0.203}$$

Calculate Steady State Discharge Concentration:

$$Dischg\ Conc. = \frac{(D.R.)}{(D.F.)(Volume)(3785)} = \frac{(2288)}{(.203)(.259)(3785)} = \underline{11.50} \text{ mg/l}$$

Calculate concentration of biocide in stream during low flow conditions.

(Receiving Stream Concentration)

$$\frac{(Dischg. Conc.) \times (IWC\%)}{100} = \frac{(11.50) \times (.101)}{100} = \underline{0.0117} \text{ mg/l}$$

Receiving Stream Concentration

iii. Calculate regulated limitation.

List all LC50 data available for the whole product according to the following columns. (Note that units should be in mg/l). Please provide copies of the sources of this data.

Organism	Test Duration	LC50 (mg/l)
See Attachment 3		

Choose the lowest LC50 listed above:

Enter the LC50: 1.2 mg/L

If the half life (H.L.) is less than 4 days, perform the following calculation.

Regulated Limitation = 0.05 x LC50 = _____ mg/l

If the half life (H.L.) is greater than 4 days or unknown, perform the following calculation.

Regulated Limitation = 0.01 x LC50 = 0.0120 mg/l

Choose the appropriate regulated limitation from the calculations immediately above and place in this blank:

0.0120 mg/liter

From Part II enter the receiving stream concentration:

0.0117 mg/liter

IV. Analysis.

If the receiving stream concentration is greater than the calculated regulated limitation, then this biocide is unacceptable for use.

J. R. GARRISON

Name (Print)

J. R. Garrison / nqa

Signature

4/5/92

Date

Person in Responsible Charge

BIOCIDE/CHEMICAL TREATMENT
WORKSHEET-FORM 101

The following calculations are to be performed on any biocidal products ultimately discharged to the surface waters of North Carolina. This worksheet must be completed separately for each biocidal product in use. This worksheet is to be returned with all appropriate data entered into the designated areas with calculations performed as indicated.

I. Facility Name Duke Power Company / Training And Technology Center
NPDES # NC 0D26255
County Mecklenburg
Receiving Stream LAKE NORMAN / CATAWBA RIVER BASIN 7Q10 80 (cfs)

(All above information supplied by the Division of Environmental Management)

What is the Average Daily Discharge (A.D.D.) volume of the water handling systems to the receiving water body?

A.D.D. = 0.0525 (in M.G.D.)

Please calculate the Instream Waste Concentration (IWC in percent) of this discharge using the data entered above.

$$IWC = \frac{(A.D.D.) \times 100}{(7Q10)(0.646)} = \frac{(0.0525) \times 100}{(80)(0.646) + (A.D.D.)} = \frac{5.25}{67.68 + 0.0525} = .101\%$$

This value (IWC) represents the waste concentration to the receiving stream during low flow conditions.

II. What is the name of the whole product chemical treatment proposed for use in the discharge identified in Part I?

Copper Sulfate

Please list the active ingredients and percent composition:

<u>Copper (II) Sulfate Pentahydrate</u>	<u>100</u> %
_____	_____ %
_____	_____ %
_____	_____ %
_____	_____ %

What feed or dosage rate (D.R.) is used in this application? The units must be converted to grams of whole product used per day.

D.R. = 4536 grams/day

Estimate total volume of the water handling system between entry of biocidal product and NPDES discharge point. On an attached sheet please provide justification for this estimate (system volume, average cycles per blowdown, holding lagoon size, etc.)

Volume = 0.552 million gallons *see Attachment 4*

What is the pH of the handling system prior to biocide addition? If unknown, enter N/A. 7

What is the decay rate (D.K.) of the product? If unknown, assume no decay (D.K.=0) and proceed to asterisk. The degradation must be stated at pH level within 1/2 pH standard unit within handling system. Enter the half life (Half Life is the time required for the initial product to degrade to half of its original concentration). Please provide copies of the sources of this data.

H.L. = 0 Days

The decay rate is equal to $\frac{1}{H.L.} \times 0.69 = \underline{0}$ = Decay Rate (D.K.)

Calculate degradation factor (D.F.). This is the first order loss coefficient.

$$D.F. = \frac{(A.D.D.)}{(Volume)} + (D.K.) = \frac{(0.0525)}{(0.552)} + (0) = \underline{0.0951}$$

Calculate Steady State Discharge Concentration:

$$Dischg\ Conc. = \frac{(D.R.)}{(D.F.)(Volume)(3785)} = \frac{(4536)}{(0.0951)(0.552)(3785)} = \underline{22.83\ mg/l}$$

Calculate concentration of biocide instream during low flow conditions.

(Receiving Stream Concentration)

$$\frac{(Dischg.\ Conc.) \times (IWC\%)}{100} = \frac{(22.83) \times (.101)}{100} = \underline{0.0231\ mg/l}$$

$$(0.0231\ mg/l) \times \frac{(63.54\ M.\ wt.\ Cu)}{(294.68\ M.\ wt.\ CuSO_4)} = 0.0059\ mg/L\ Cu$$

iii. Calculate regulated limitation. = 5.9 ug/L Cu Receiving Stream Concentration

List all LC50 data available for the whole product according to the following columns. (Note that units should be in mg/l). Please provide copies of the sources of this data.

Organism	Test Duration	LC50 (mg/l)
<u>See Page 3</u>		

Pond Elevation of 6 feet
(Higher Flows)

BIOCIDE/CHEMICAL TREATMENT
WORKSHEET-FORM 101

The following calculations are to be performed on any biocidal products ultimately discharged to the surface waters of North Carolina. This worksheet must be completed separately for each biocidal product in use. This worksheet is to be returned with all appropriate data entered into the designated areas with calculations performed as indicated.

i. Facility Name Duke Power Company / Training and Technology Center
 NPDES # NC 0026255
 County Mecklenburg

Receiving Stream Lake Norman / Catawba River BASIN 7Q10 80 (cfs)
 (All above information supplied by the Division of Environmental Management)

What is the Average Daily Discharge (A.D.D.) volume of the water handling systems to the receiving water body?

A.D.D. = 10525 (In M.G.D.)

Please calculate the Instream Waste Concentration (IWC in percent) of this discharge using the data entered above.

$$IWC = \frac{(A.D.D.) \times 100}{(7Q10)(0.646)} = \frac{(.0525) \times 100}{(80)(0.646) + (A.D.D.)} = .101\%$$

This value (IWC) represents the waste concentration to the receiving stream during low flow conditions.

ii. What is the name of the whole product chemical treatment proposed for use in the discharge identified in Part i?

Copper Sulfate

Please list the active ingredients and percent composition:

<u>Copper (II) Sulfate Pentahydrate</u>	<u>100</u> %
_____	_____ %
_____	_____ %
_____	_____ %
_____	_____ %

What feed or dosage rate (D.R.) is used in this application? The units must be converted to grams of whole product used per day.

D.R. = 2268 grams/day

Estimate total volume of the water handling system between entry of biocidal product and NPDES discharge point. On an attached sheet please provide justification for this estimate (system volume, average cycles per blowdown, holding lagoon size, etc.)

Volume = 0.259 million gallons *see Attachment 1*

What is the pH of the handling system prior to biocide addition? If unknown, enter N/A. 7

What is the decay rate (D.K.) of the product? If unknown, assume no decay (D.K.=0) and proceed to asterisk. The degradation must be stated at pH level within 1/2 pH standard unit within handling system. Enter the half life (Half Life is the time required for the initial product to degrade to half of its original concentration). Please provide copies of the sources of this data.

H.L. = 0 Days

The decay rate is equal to $\frac{1}{H.L.} \times 0.69 = \underline{0}$ = Decay Rate (D.K.)

Calculate degradation factor (D.F.). This is the first order loss coefficient.

$$D.F. = \frac{(A.D.D.)}{(Volume)} + (D.K.) = \left(\frac{0.0525}{0.259} \right) + (0) = \underline{0.203}$$

Calculate Steady State Discharge Concentration:

$$Dischg\ Conc. = \frac{(D.R.)}{(D.F.)(Volume)(3785)} = \frac{(2268)}{(0.203)(0.259)(3785)} = \underline{11.39\ mg/l}$$

Calculate concentration of biocide instream during low flow conditions.

(Receiving Stream Concentration)

$$\frac{(Dischg.\ Conc.) \times (IWC\%)}{100} = \frac{(11.39) \times (0.101)}{100} = \underline{0.0115\ mg/l}$$

$$(0.0115\ mg/L) \times \frac{(63.54\ M.Wt.\ Cu)}{(249.68\ M.Wt.\ CuSO_4)} = 0.0029\ mg/L\ Cu$$

Calculate regulated limitation. or 2.9 ug/L Cu

List all LC50 data available for the whole product according to the following columns. (Note that units should be in mg/l). Please provide copies of the sources of this data.

Organism	Test Duration	LC50 (mg/l)
<u>See Page 3</u>		

Choose the lowest LC50 listed above:

Enter the LC50: Action Level = 7 ug/L of Cu (used for calculation)

If the half-life (H.L.) is less than 4 days, perform the following calculation.

Regulated Limitation = $0.05 \times \text{LC50} = \underline{\hspace{2cm}}$ mg/l

If the half-life (H.L.) is greater than 4 days or unknown, perform the following calculation.

Regulated Limitation = $0.01 \times \text{LC50} = \underline{\hspace{2cm}}$ mg/l

Choose the appropriate regulated limitation from the calculations immediately above and place in this blank:

7 ug/L mg/liter Cu

From Part II enter the receiving stream concentration:

.0115 mg/liter CuSO₄

OR 2.9 ug/L Cu

IV. Analysis.

If the receiving stream concentration is greater than the calculated regulated limitation, then this biocide is unacceptable for use.

J. R. GARRISON

Name (Print)

J. R. Garrison /mga

Signature

4/6/92

Date

Person in Responsible Charge