

OCONEE NUCLEAR STATION
MONTHLY OPERATING STATUS REPORT

August 1989

1. Personnel Exposure

For the month of August, no individual(s) exceeded 10 percent of their allowable annual radiation dose limit.

2. The total station liquid release for August has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for August has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

8910190174 891013
PDR ADCK 05000269
R PDC