

OCONEE NUCLEAR STATION
MONTHLY OPERATING STATUS REPORT

October 1991

1. Personnel Exposure -

For the month of October, no individual(s) exceeded 10 percent of their allowable annual radiation dose limit.

2. The total station liquid release for October has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for October has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this list.

Revised mth rept

9112200234 911213
PDR ADOCK 05000269
R PDR