

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9207070341 DOC. DATE: 92/06/24 NOTARIZED: NO DOCKET #
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287

AUTH. NAME AUTHOR AFFILIATION
 HAMPTON, J.W. Duke Power Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards supplement to 891229 response to NRC Bulletin
 88-008 re thermal stresses in piping connected to RCS, per
 920623 telcon w/NRC.

DISTRIBUTION CODE: IE16D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 19
 TITLE: Bulletin Response 88-08 - Thermal Stress in Piping to RCS.

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		L	T		ID CODE/NAME		L	T
	PD2-3 LA		1	0		PD2-3 PD		1	1
	WIENS, L		1	1					
INTERNAL:	AEOD/DOA		1	1		NRR HARTZMAN, M		1	1
	NRR HUM, M		1	1		NRR MOZAFARI, B		1	1
	NRR/DET/EMEB 7E		1	1		NRR/DOEA/OEAB11		1	1
	NRR/DOEA/OGCB11		1	1		NRR/DREP/PEPB9D		1	1
	NRR/DST/ 8E2		1	1		NRR/PMAS/ILRB12		1	1
	REG FILE 02		1	1		RES/DSIR/EIB		1	1
	RGN2 FILE 01		1	1					
EXTERNAL:	NRC PDR		1	1		NSIC		1	1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 18 ENCL 17

Duke Power Company
Oconee Nuclear Generation Department
P.O. Box 1439
Seneca, SC 29679

J.W. HAMPTON
Vice President
(803)885-3499 Office
(704)373-5222 FAX



DUKE POWER

June 24, 1992


U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Subject: Oconee Nuclear Station, Units 1, 2, and 3
Docket Nos. 50-269, -270, -287
NRC Bulletin 88-08

By letter dated December 29, 1989 information was provided to the NRC concerning the results of our analysis in response to Action Item 3 of the NRC Bulletin concerning thermal stresses in piping systems connected to the Reactor Cooling System.

A phone conversation conducted on Jun. 23, 1992 between the NRC Oconee Project Manager and Steve Sills of Oconee Civil Engineering indicated that additional information concerning this response was desired.

This letter provides a more detailed description of the HPI analysis performed on the piping referenced in the previous submittal.


J. W. Hampton
Vice President

OCK/ock

Attachments

xc: (W/Attachments)

Mr. S. D. Ebnetter, Regional Administrator
US Nuclear Regulatory Commission, Region II

Mr. L. A. Wiens, Project Manager
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission

Mr. P. E. Harmon
NRC Senior Resident Inspector
Oconee Nuclear Station

9207070341 920624
PDR ADDCK 05000269
Q PDR

Document Control Desk
February 28, 1992
Page 2

bx: (W/O Attachments)

R. L. Gill, Jr.
M. E. Patrick
G. K. McAninch
File: OS-801.01

6.0 DESCRIPTION OF HPI ANALYSIS

The HPI line was instrumented as shown in Figure 2 to quantify the level of stratification, if any, in the piping. The temperature data was reviewed and reduced into the piping thermal load shown in Figure 3. Figure 4 consists of ten pages of the actual temperature data collected. As noted in Figure 3 and described in detail in this Section, the thermal loading was constructed to envelope variations from the observed temperature data; so, final stress results are not sensitive to reasonable variations from the observed Unit 1 data in terms of flow rate, flow direction or cyclic frequency.

The analysis method used in the HPI analysis corresponds to the method presented in NB-3653 of ASME Section III, '87 Addenda, adapted for stratified conditions. To complete a NB-3653 fatigue evaluation requires that three stress intensities be defined:

S_n = Maximum Secondary Stress Intensity
 S_p = Peak Stress Intensity
 S_{alt} = Alternating Stress Intensity

However, these code defined stress intensities must be augmented by additional stress quantities due to stratification. A stratified non-linear top of pipe to bottom of pipe temperature distribution can be described by a uniform portion, a linear portion and a non-linear portion. The uniform portion of the profile corresponds to the expansion temperature typically used in thermal expansion analysis. The linear portion, T-linear, produces a bending moment in the pipe. The moment equivalent of T-linear, M_{eq} , can be calculated as follows:

$$M_{eq} = E \alpha Z \text{ T-linear}$$

The resultant moment loads on the piping due to M_{eq} are then multiplied by C_2/Z for inclusion in the maximum secondary stress intensity, S_n ; and, multiplied by $K_2 C_2/Z$ for inclusion in the maximum peak stress intensity, S_p . The stress due to the non-linear portion, ΔT_3 , is calculated as:

$$\frac{E \alpha |\Delta T_3|}{(1-\nu)}$$

and, included in the code equation for peak stress intensity.

Without a clearly defined fluid flow time history the stress due to ΔT_1 and ΔT_2 was approximated. Numerous one-dimensional heat transfer analyses were performed. The analyses were performed on cross-sections varying in thickness from 1/4" to 3/4" in .01" increments. A step change in temperature from 70°F to 500°F was applied to the inside surface. The hold time for the hot temperature was varied as was the heat transfer coefficient. Outside surface temperatures were then observed. This heat transfer analysis work was performed in November and December of 1988 as a part of the bounding analysis calculation for NRCB 88-08 (Reference 8).

The outside temperatures for the 3/4" thick section were tracked until the rate of change in temperature and the total change in temperature matched the values reported for Farley in NRCB 88-08. The hold time and heat transfer coefficient that matched the Farley temperatures were then taken as the representative thermal load to be used in the analysis. When applied to a .35" thick section the analysis showed a rate of temperature change of 156°F in one minute.

The through wall thermal stresses due to ΔT_1 and ΔT_2 were then time phased with the stress due to the stratified bending stress. The stress due to ΔT_1 and ΔT_2 equalled 7.0 Ksi when the combined stress was a maximum.

A Reynolds number was calculated for the heat transfer coefficient corresponding to the representative thermal load. The number indicated turbulent flow. The maximum rate of temperature change actually observed at the outside surface was 110°F/min (See Figure 3). As noted in Figure 3, this maximum value was observed only once during the unexpected Oconee 1 reactor shutdown on 3/1/89 (See Figure 4 sheet 3 of 10). The 110°F/min temperature change was accompanied by a total elimination of the thermal stratification, also indicating turbulent flow inside the pipe. Conclude that the 7.0 Ksi corresponding to an outside temperature change of 156°F/min will be a conservative value to use in the evaluation of the cyclic thermal stratification event.


The actual observed temperatures also indicated an essentially linear temperature profile from top to bottom of the pipe. Thus, the stress due to the non-linear portion, ΔT_3 , was assumed to be zero. Since the observed temperature distribution was approximately linear with no abrupt well defined boundary layer, any striping effects which could be associated with the stratified conditions were assumed negligible. Due to the relative low rate of heat transfer; and, since there are no significant material discontinuities in the affected HPI piping, the stresses due to the Ta-Tb effect were also considered negligible.

The Oconee RCS Functional Specification (Reference 14) defines 360 cycles of start-up and cooldown. So, 360 cycles of stress were evaluated when going from RCS full power conditions plus stratified conditions to the zero stress state. As shown in Figure 3 2.1×10^6 cycles of stress were evaluated when going from RCS full power conditions, plus stratified conditions, back to RCS full power conditions alone (i.e. 2.1×10^6 cycles of stress due to the stratified conditions).

The minimum cycle time actually observed was 20 minutes (See Figure 1). The maximum number of cycles observed in any two hour period was five, corresponding to 24 minute cycles; and, the maximum number of cycles observed during any eight hour period was nine, corresponding to 53 minute cycles. To account for the fact that the cycle time could potentially worsen the minimum observed cycle time (20 min) was cut in half, to 10 minutes (See Figure 3). In light of the actual observed data, assuming one cycle every 10 minutes over the life of the plant is considered conservative. One cycle every 10 minutes corresponds to 2.1×10^6 cycles over the forty year life of the plant.

The 120°F maximum top-to-bottom temperature difference was observed at only one location on the piping, immediately down stream of valve LHPI-152. The temperature decays as the distance away from the RCS increases. At a point approximately ten feet upstream of valve LHPI-152 (measured along the pipe and away from the RCS) the temperature decays to a point that stratification should not be significant. But for analysis purposes the maximum temperature difference of 120°F is rounded up to 150°F. This full 150°F stratification gradient is applied to the horizontal piping over the length of piping from points twenty-feet upstream of valves HP-152, 153 to the pipe-to-RCS nozzle weld points.

The maximum cumulative usage factor calculated for all of the Oconee unit HPI piping components was 0.81. The value at first appears to be high, close to the allowable value of 1.0. However, considering the conservative assumptions used in the analysis described above, the results adequately confirm the structural integrity of the line for the 40 year life of the plant.



- Notes:
- 1) HPI Pumps A & B supply normal make-up (i.e. normal high pressure injection). HPI Pump C is used only for emergency safety injection.
 - 2) AB = Auxiliary Building, RB = Reactor Building
 - 3) The portions of HPI piping between HP-153 and Reactor Inlet Line; and, between HP-152 and Reactor Inlet Line, were identified as potentially susceptible to the type of event described in NRC Bulletin 88-08.

FIGURE 1





Figure 2



GENERAL NOTES


- 1) PIPE SPEC:
 Δ 2 1/2" SCH. 160 S.S. TYPE 316H, ASTM A-376.
 Δ 2 1/2" & 4" SCH. 160 SS, TYPE 304H, ASTM A-376
- 2) DESIGN DATA:
 Δ 2500 PSIG @ 450°F.
 Δ 3050 PSIG @ 200°F.
- 3) MOMENTS OF PRIMARY COOLANT SYSTEM
 SEE B&W DWGS 128625E & 128626E.
- 4) DIMENSIONS AS SHOWN ARE FOR PIPE
 IN THE COLD ERECTED POSITION.
- 5) TYPICAL SHIELDING PENETRATION NO. (5)

CALC. NO. 02-3681

REV.	PERFD.	DATE	CHG.D.	DAI
0	CM	7/18/81	JLR	7/22

PAGE 27 OF

PEN. NO. 52
 & EL. 812'-0"
 (REF)



Thermocouple Names & Locations
(Thermocouple Names are circled, etc)

Parametric Comparison Of
 Cyclic Thermal Stratification Data
 'Analyzed' vs 'Observed'


Quantity	Preliminary Bounding Analysis	Actual Observed	As Used in Final Fatigue Evaluation
Maximum rate of temperature change at outside surface	200 ^o F/min (note 1)	110 ^o F/min	156 ^o F/min
Maximum temp. difference from of pipe to bottom of pipe; and, shape of gradient	200 F stepped at the three o'clock position	120 F linear from top-to-bottom	150 F linear from-top-to-bottom (note 2)
Amount of horizontal piping considered stratified per HPI leg (see Fig. 1)	3ft	10ft	20ft (note 3)
Number of applied cycles	1 <u>cycle</u> 2 minutes	1 <u>cycle</u> 20 minutes	1 <u>cycle</u> 10 minutes
	=143,000 <u>cycles</u> yr	=14,300 <u>cycles</u> yr	=28,600 <u>cycles</u> yr

- Notes: 1) This maximum was observed only once, during the unexpected reactor shutdown on 3/1/89. The high rate of temp. change was accompanied by a total elimination of the thermal stratification (See discussion on page 7). A more representative value to associate with the 20 minute period cycles would be on the border of 10^oF/min. Thus the 110^oF/min used in the Fatigue Evaluation is conservative.
- 2) See discussion on page 8
- 3) See discussion on page 8

FIGURE 3

HPI LINE 152 TEMPERATURES


LOTUS WKS:SL122221; on MONTH:2; DAY:22



(FIGURE 4)

HPI LINE 153 TEMPERATURES


LOTUS WKS.SL122221, on MONTH:2, DAY:22



(FIGURE 4)
(Sheet 2 of 10)

HPI LINE 152 TEMPERATURES


LOTUS WKS:SL123012; on MONTH:3; DAY:01



(FIGURE 4)
(Sheet 3 of 10)

HPI LINE 153 TEMPERATURES


LOTUS WKS:SLI23012; on MONTH:3; DAY:01



(FIGURE 4)
(Sheet 4 of 10)

HPI LINE 152&153 NOZZEL TEMPERATURES


LOTUS WKS:SL125301; on MONTH:5; DAY:30



(FIGURE 4)
(Sheet 5 of 10)

HPI LINE 152 PIPE TEMPERATURES


LOTUS WKS:SL125301; on MONTH:5; DAY:30



(FIGURE 4)
(Sheet 6 of 10)

HPI LINE 153 PIPE TEMPERATURES


LOTUS WKS:SL125301; on MONTH:5; DAY:30



(FIGURE 4)

HPI LINE 152&153 NOZZEL TEMPERATURES


LOTUS WKS:SL126031; on MONTH:6; DAY:03



(FIGURE 4)
(Sheet 8 of 10)

HPI LINE 152 PIPE TEMPERATURES


LOTUS WKS:SL126031; on MONTH:6; DAY:03



(FIGURE 4)
(Sheet 9 of 10)

HPI LINE 153 PIPE TEMPERATURES

LOTUS WKS:SL126031; on MONTH:6; DAY:03



(FIGURE 4)