

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8408200059      DOC. DATE: 84/08/08      NOTARIZED: YES      DOCKET #  
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co.      05000269  
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co.      05000270  
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co.      05000287

AUTH. NAME      AUTHOR AFFILIATION  
 TUCKER, H.B.      Duke Power Co.  
 RECIP. NAME      RECIPIENT AFFILIATION  
 DENTON, H.R.      Office of Nuclear Reactor Regulation, Director

SUBJECT: Application for amend to Licenses DPR-38, DPR-47 & DPR-55,  
 revising air lock testing frequency from quarterly to  
 semiannually, fee encl.

DISTRIBUTION CODE: A017S      COPIES RECEIVED: LTR 1 ENCL 1      SIZE: 3+6  
 TITLE: OR Submittal: Append J Containment Leak Rate Testing

NOTES: AEOD/Ornstein:1cy.      05000269  
 OL:02/06/73  
 AEOD/Ornstein:1cy.      *-NO Check Rec'd*      05000270  
 OL:10/06/73  
 AEOD/Ornstein:1cy.      05000287  
 OL:07/19/74

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	NRR OR84 BC 01	7 7		
INTERNAL:	ADM-LFMB	1 0	ELD/HDS4 08	1 1
	NRR/DSI/ASB	1 1	NRR/DSI/CSB 06	1 1
	<u>REG FILE</u> 04	1 1	RGN2	1 1
EXTERNAL:	ACRS 07	10 10	LPDR 03	1 1
	NRC PDR 02	1 1	NSIC 05	1 1
	NTIS	1 1		
NOTES:		1 1		

DUKE POWER COMPANY

P.O. BOX 33189  
CHARLOTTE, N.C. 28242

HAL B. TUCKER  
VICE PRESIDENT  
NUCLEAR PRODUCTION

TELEPHONE  
(704) 373-4531

August 8, 1984

Mr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Attention: Mr. John F. Stolz, Chief  
Operating Reactors Branch No. 4

Subject: Oconee Nuclear Station  
Docket Nos. 50-269, 50-270, 50-287


Dear Sir:

Pursuant to 10 CFR §50.90, please find attached (Attachment 1) a proposed amendment to the Oconee Facility Operating License and revisions to the Oconee Nuclear Station Technical Specifications. The proposed amendment would revise Technical Specification 4.4.1.5.2(a) and (involves a change of the air lock testing frequency from quarterly to semiannually). The supporting technical justification is provided in Attachment 3.

Please note that the proposed amendment would change the Technical Specification 4.4.1.5.2(a) to conform to the requirements of 10 CFR 50, Appendix J and results in very minor changes to facility operation clearly in keeping with the regulations. Duke has determined that the proposed amendment warrants a No Significant Hazards Consideration (Attachment 2). A copy of this application is also forwarded to the South Carolina Department of Health and Environmental Control for review and appropriate, subsequent consultation with the staff.

Pursuant to 10 CFR 170.21, please find enclosed a check in the amount of \$150.00 for the application fee.


Very truly yours,



Hal B. Tucker

MAH:slb

Attachment



No check Rec'd

A017  
[Redacted]  
11

Mr. Harold R. Denton, Director  
August 8, 1984  
Page 2

cc: Mr. James P. O'Reilly, Regional Administrator  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30323

Ms. Helen Nicolaras  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Mr. J. C. Bryant  
NRC Resident Inspector  
Oconee Nuclear Station


Mr. Hayward Shealey, Chief  
Bureau of Radiological Health  
South Carolina Department of Health and Environmental Control  
2600 Bull Street  
Columbia, South Carolina 29201

Mr. Harold R. Denton, Director

August 8, 1984

Page 3

HAL B. TUCKER, being duly sworn, states that he is Vice President of Duke Power Company; that he is authorized on the part of said Company to sign and file with the Nuclear Regulatory Commission this request for amendment of the Oconee Nuclear Station Technical Specifications, Appendix A to Facility Operating Licenses DPR-38, DPR-47, and DPR-55; and that all statements and matters set forth therein are true and correct to the best of his knowledge.



\_\_\_\_\_  
Hal B. Tucker, Vice President

Subscribed and sworn to before me the 8th day of August, 1984.

  
\_\_\_\_\_  
Notary Public

My Commission Expires:

September 20, 1984