

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8604040172 DOC. DATE: 86/03/25 NOTARIZED: NO DOCKET #
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287

AUTH. NAME AUTHOR AFFILIATION
 TUCKER, H. B. Duke Power Co.
 RECIP. NAME RECIPIENT AFFILIATION
 DENTON, H. R. Office of Nuclear Reactor Regulation, Director (post 851125
 STOLZ, J. F. PWR Project Directorate 6

SUBJECT: Revised application to amend Licenses DPR-38, DPR-47, &
 DPR-55, changing Tech Specs to reflect independent testing of
 shunt & undervoltage trip per 850523 Generic Ltr 85-10. Revs
 consist of editorial corrections to Table 4.1.

DISTRIBUTION CODE: A055D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2+10
 TITLE: DR/Licensing Submittal: Salem ATWS Events GL-83-28

NOTES: AEOD/Ornstein: 1cy. 05000269
 AEOD/Ornstein: 1cy. 05000270
 AEOD/Ornstein: 1cy. 05000287

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PWR-B ADTS	1 1	PWR-B EB	1 1
PWR-B PEICSB	2 2	PWR-B FOB	1 1
PWR-B PD6 PD 01	3 3	NICOLARAS, H	1 1
PWR-B PEICSB	1 1	PWR-B RSB	1 1

INTERNAL:	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	ADM/LFMB	1 0	ELD/HDS4	1 0
	IE/DI	1 1	IE/DGAVT	1 1
	NRR BWR ADTS	1 1	NRR LASHER, D	1 1
	NRR PWR-A ADTS	1 1	NRR PWR-B ADTS	1 1
	NRR/DSRO/RSIB	1 1	NRR/TAMB	1 1
	<u>REG FILE</u> 04	1 1	RGN2	1 1

EXTERNAL:	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	24X	1 1	LPDR	03 1 1
	NRC PDR 02	1 1	NSIC	05 1 1

NOTES: 1 1

DUKE POWER COMPANY

P.O. BOX 33189

CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

TELEPHONE
(704) 373-4531

March 25, 1986

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Mr. John F. Stolz, Project Director
PWR Project Directorate No. 6

Subject: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287

Dear Sir:

Pursuant to 10 CFR 50, Part 50.90, please find attached a proposed amendment to the Oconee Facility Operating License and revision to the Oconee Nuclear Station Technical Specifications. This proposal (Attachment 1) consists of changes to Technical Specification 3.5, Instrumentation Systems and Tables 3.5.1-1 and 4.1-1.

The proposed amendment is in response to Generic Letter 85-10, dated May 23, 1985 and the NRC letter to B&W Owner's Group dated December 6, 1985. Generic Letter 85-10 requires that the appropriate surveillance and test sections of the technical specifications be revised to include independent testing of the shunt and undervoltage trip attachments and silicon controlled rectifiers.

By a letter dated September 17, 1985 Duke Power Company submitted an amendment request in response to Generic Letter 85-10 and the NRC letter dated February 11, 1985. That submittal included a proposed revision to Table 4.1-1 of the Oconee Technical Specifications to specifically note that the shunt and undervoltage trip attachments are independently tested. Duke Power Company also indicated that additional Technical Specification changes in response to Generic Letter 85-10 will be submitted as they become available.

The attached proposed Technical Specifications are intended to supplement our previous submittal dated September 17, 1985. The proposed changes in Table 4.1-1 are slightly different from our September 17, 1985 submittal. The difference is due to editorial corrections and does not alter the intent of the proposed change in Table 4.1-1.

Duke Power Company has performed an evaluation in accordance with the standards in 50.92 and determined that the proposed amendment request involves no significant hazards considerations. Technical justification and basis in support of this evaluation are presented in Attachment 2.

8604040172 860325
PDR ADDCK 05000269
P PDR

A055
11

Mr. Harold R. Denton, Director
March 25, 1986
Page Two

Duke is forwarding a copy of this application to the South Carolina Department of Health and Environmental Control for review and, as appropriate, subsequent consultation with the NRC staff.

Inasmuch as these proposed changes are supplemental to Duke's September 17, 1985 amendment request, Duke considers that no additional application fee is necessary.

Very truly yours,



Hal B. Tucker

MAH:slb

Attachments

cc: Dr. J. Nelson Grace, Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Ms. Helen Nicolaras
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Mr. Heyward Shealy, Chief
Bureau of Radiological Health
South Carolina Department of Health &
Environmental Control
2600 Bull Street
Columbia, South Carolina 29201

Mr. J. C. Bryant
ONS Resident Inspector
Oconee Nuclear Station