

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8608250012 DOC. DATE: 86/08/13 NOTARIZED: YES DOCKET #
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287

AUTH. NAME AUTHOR AFFILIATION
 TUCKER, H. B. Duke Power Co.
 RECIP. NAME RECIPIENT AFFILIATION
 DENTON, H. R. Office of Nuclear Reactor Regulation, Director (post 851125
 STOLZ, J. F. PWR Project Directorate 6

SUBJECT: Application for amend to Licenses DPR-38, DPR-47 & DPR-55
 providing limiting conditions for valve operability of RCS
 vents to meet requirements of Generic Ltr 83-37. Fee paid.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3+4
 TITLE: OR Submittal: General Distribution

NOTES: AEOD/Ornstein: 1cy. S. West, NRR: 1cy. 05000269
 AEOD/Ornstein: 1cy. S. West, NRR: 1cy. 05000270
 AEOD/Ornstein: 1cy. S. West, NRR: 1cy. 05000287

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	PWR-B EB		1	1		PWR-B PEICSB		2	2
	PWR-B FOB		1	1		PWR-B PD6 LA		1	0
	PWR-B PD6 PD 01		5	5		NICOLARAS, H		1	1
	PWR-B PEICSB		1	1		PWR-B RSB		1	1
INTERNAL:	ADM/LFMB		1	0		ELD/HDS4		1	0
	NRR/ORAS		1	0		<u>REG FTL</u>	04	1	1
	RCN2		1	1					
EXTERNAL:	EG&G BRUSKE, S		1	1		LPDR	03	1	1
	NRC PDR 02		1	1		NSIC	05	1	1
NOTES:			2	2					

Rec'd w/check \$150.00

DUKE POWER COMPANY

P.O. BOX 33189
CHARLOTTE, N.C. 28242

TELEPHONE
(704) 373-4531

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

August 13, 1986

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

ATTENTION: Mr. J.F. Stolz, Director
PWR Project Directorate No. 6

Subject: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287


Dear Sir:

By letter dated November 25, 1985, the NRC requested additional information to complete its review of Duke's October 8, 1984 submittal in response to Generic Letter 83-37. Per Duke's response to Item II.B.1 dated January 30, 1986 and pursuant to 10CFR50, Part 50.90, please find attached (Attachment 1) a proposed amendment to the Oconee Nuclear Station (ONS) Facility Operating Licenses and revisions to the ONS Technical Specifications. The proposed amendment addresses the operability of the reactor coolant system vents to meet the intent of Generic Letter 83-37. The proposed new T.S. 3.1.13 provides limiting conditions for valve operability; an action statement for the event wherein the LCO is not satisfied, as well as the safety basis per GL 83-37.

Duke has determined the attached proposed amendment as having No Significant Hazards Consideration. Please find attached the No Significant Hazards Consideration Evaluation (Attachment 2). Duke is forwarding a copy of this application to the South Carolina Department of Health and Environmental Control for review and, as appropriate, subsequent consultations with the staff.

Pursuant to 10CFR170.21, enclosed is a check in the amount of \$150.00 for the application fee.

Very truly yours,



Hal B. Tucker

PJN/37/jgm

Attachments

8608250012 860813
PDR ADOCK 05000269
P PDR

*Rec'd w/ check
\$150.00*

*Acc 1
11*

Mr. Harold R. Denton
August 13, 1986
Page 2

xc: Dr. J. Nelson Grace, Regional Administrator
U.S. Nuclear Regulatory Commission - Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323


Ms. Helen Pastis
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Mr. Heyward Shealy, Chief
Bureau of Radiological Health
S.C. Dept. of Health & Environmental Control
2600 Bull Street
Columbia, S.C. 29201

J.C. Bryant
NRC Resident Inspector
Oconee Nuclear Station


Mr. Harold R. Denton
August 13, 1986
Page 3

HAL B. TUCKER, being duly sworn, states that he is Vice President of Duke Power Company; that he is authorized on the part of said Company to sign and file with the Nuclear Regulatory Commission this request for amendment of the Oconee Nuclear Station Technical Specifications, Appendix A to Facility Operating Licenses DPR-38, DPR-47, and DPR-55; and that all statements and matters set forth therein are true and correct to the best of his knowledge.



Hal B. Tucker, Vice President

Subscribed and sworn to before me this 13th day of August, 1986.



Linda L. Kessler
Notary Public

My Commission Expires:

May 1, 1989

