Section		Page
1.5.4	Instrument Channel Calibration	1-3
1.5.5	Heat Balance Check	1-4
1.5.6	Heat Balance Calibration	1-4
1.6	POWER DISTRIBUTION	1-4
1.6.1	Quandrant Power Tilt	1-4
1.6.2	Reactor Power Imbalance	1-4
1.7	CONTAINMENT INTEGRITY	1-4
1.8	RADIOLOGICAL EFFLUENT CONTROL	1-5
1.8.1	Source Check	1-5
1.8.2	Offsite Dose Calculation Manual (ODCM)	1-5
1.8.3	Process Control Program (PCP)	1-5
1.8.4	Solidification	1-5
1.8.5	Gaseous Radwaste Treatment System	1-5
1.8.6	Ventilation Exhaust Treatment System	1-5
1.8.7	Purge-Purging	1-5
1.8.8	Venting	1-6
1.8.9	Member(s) of the Public	1-6
1.8.10	Unrestricted Area	1-6
1.9	Core Operating Limits Report	1-6
2	SAFETY LIMITS AND LIMITING SAFETY SYSTEM SETTINGS	2.1-1
2.1	SAFETY LIMITS, REACTOR CORE	2.1-1
2.2	SAFETY LIMITS - REACTOR COOLANT SYSTEM PRESSURE	2.2-1
2.3	LIMITING SAFETY SYSTEM SETTINGS, PROTECTIVE INSTRUMENTATION	2.3-1
3	LIMITING CONDITIONS FOR OPERATION	3.0-1
3.0	LIMITING CONDITION FOR OPERATION	3.0-1
3.1	REACTOR COOLANT SYSTEM	3.1-1

### 1.8.8 VENTING

Venting is the controlled process of discharging air of gas from a confinement to maintain temperature, pressure, humidity, concentration or other operating condition, in such a manner that replacement air or gas is not provided or required during Venting. Vent, used in system names, does not imply a venting process.

## 1.8.9 MEMBER(S) OF THE PUBLIC

Member(s) Of The Public shall include all persons who are not occupationally associated with the plant. This category does not include employees of the utility, its contractors or its vendors. Also excluded from this category are persons who enter the site to serve equipment or to make deliveries. This category does include persons who use portions of the site for recreational, occupational or other purposes not associated with the plant.

#### 1.8.10 UNRESTRICTED AREA

An Unrestricted Area shall be any area at or beyond the site boundary to which access is not controlled by the licensee for purposes of protection of individuals from exposure to radiation and radioactive materials or any area within the site boundary used for residential quarters or industrial, commercial institutional and/or recreational purposes.

# 1.9 CORE OPERATING LIMITS REPORT

The Core Operating Limits Report (COLR), its supplements and revisions, are unit-specific and reload/cycle-specific document(s) containing the cycle specific limits for the current operating reload/cycle. The limits in the COLR, including supplements and revisions, are only applicable during the reload/cycle number(s) given in the title. NRC approved methodologies are used as the basis for the results reported in the COLR.

# 6.9 CORE OPERATING LIMITS REPORT

## Specification

- 6.9.1 The core operating limits shall be established for each reload core and shall be maintained available in the Control Room. The limits shall be established and implemented on a time scale consistent with normal procedural changes.
- 6.9.2 The analytical methods used to generate the core operating limits shall be those previously reviewed and approved by the NRC\*.
- 6.9.3 A report containing the core operating limits shall be provided to the NRC Document Control Desk with copies to the Regional Administrator and the Resident Inspector within 30 days after their implementation.

<sup>\*</sup>DPC-NE-1002A, Reload Design Methodology II, October 1985. NFS-1001A, Reload Design Methodology, April 1984.