## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR	:8907200220 DOC.DATE: 89/07/14 NOTARIZED: YES DOCKET #
	Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
	Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270
50-287	Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287
AUTH.NAME	AUTHOR AFFILIATION Duke Power Co
TUCKER, H.B.	Duke Power Co.
RECIP.NAME	
•	Document Control Branch (Document Control Desk)
CIID TECE Ann	ligation for amends to Timeseas DDD 20 DDD 47 C DDD EE

SUBJECT: Application for amends to Licenses DPR-38, DPR-47 & DPR-55, deleting requirements for leak testing of MSSV.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR SIZE: SIZE: TITLE: OR Submittal: General Distribution

## NOTES:

	RECIPIENT ID CODE/NAME PD2-3 LA WIENS,L	COPI LTTR 1 5	ES ENCL 1 5	RECIPIENT ID CODE/NA PD2-3 PD	<b>ME</b> .	COP: LTTR 1	IES ENCL 1
INTERNAL:	ACRS NRR/DEST/CEB 8H NRR/DEST/ICSB NRR/DEST/RSB 8E NUDOCS-ABSTRACT OGC/HDS2 RES/DSIR/EIB	1 1 1 1 1	6 1 1 1 0 1	NRR/DEST/ADS NRR/DEST/ESB NRR/DEST/MTB NRR/DOEA/TSB OC/LEMB REG_FILE	8D 9H	1 1 1 1 1	1 1 1 0 1
EXTERNAL:	LPDR NSIC	1	1	NRC PDR		1	1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 28 ENCL 26

AAZ

## DUKE POWER COMPANY P.O. BOX 33189 CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

TELEPHONE (704) 373-4531

July 14, 1989

US Nuclear Regulatory Commission Document Control Desk Washington, DC 20555

Subject: Oconee Nuclear Station

Docket Nos. 50-269, -270, -287
Main Steam Stop Valve Leak Testing
Proposed Technical Specifications

## Gentlemen:

Pursuant to 10CFR50, Part 50.90, please find attached (attachment 1) a proposed amendment to the Oconee Nuclear Station (ONS) facility operating licenses and revisions to the ONS Technical Specifications. As discussed in my request for temporary waiver of compliance dated June 28, 1989, changes to Specification 4.8 are necessary in order to delete requirements for leak testing of main steam stop valves. The ASME Section XI IWV-2200 valve category for the main steam stop valves is currently under evaluation. Upon completion of this evaluation and if necessary, leak testing requirements per IWV-3420 will be incorporated into the inservice test program.

I have determined the attached proposed amendment as having no significant hazards considerations. Attachment 3 provides the No Significant Hazards Consideration Evaluation. Attachment 2 provides the supporting Technical

8907200220 890714 PDR ADOCK 05000269 P PDC 9001

Justification. I am forwarding a copy of this application to the South Carolina Department of Health and Environmental Control for review and, as appropriate, subsequent consultation with the staff.

Very truly yours,

Hal B. Tucker

PJN

xc: S. Ebneter, Regional Administrator U.S. Nuclear Regulatory Commission 101 Marietta Street, NW., Suite 2900 Atlanta, Georgia 30323

> L. A. Wiens Office of Nuclear Regulation U.S. Nuclear Regulatory Commission Washington, DC 20555

P. H. Skinner NRC Resident Inspector Oconee Nuclear Station

Heyward Shealy Bureau of Radiological Health South Carolina Department of Health and Environmental Control 2600 Bull Street Columbia, South Carolina 29201 Document Control Des July 14, 1989 Page 3

Hal B. Tucker, being duly sworn, states that he is Vice President of Duke Power Company, that he is authorized on the part of said Company to sign and file with the Nuclear Regulatory Commission this revision to the Oconee Nuclear Station License Nos. DPR-38, DPR-47, and DPR-55; and that all statements and matters set forth therein are true and correct to the best of his knowledge.

Hal B. Tucker, Vice President

Subscribed and sworn to before me this 14th day of July, 1989

My Commission Expires:

Than 7, 1994

NOTAR, PUBLIC