

Official Transcript of Proceedings

NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Wednesday, September 9, 2015

Work Order No.: NRC-1870

Pages 1-160

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

+ + + + +

627TH MEETING

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

WEDNESDAY

SEPTEMBER 9, 2015

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Advisory Committee met at the Nuclear
Regulatory Commission, Two White Flint North, Room
T2B3, 11545 Rockville Pike, at 1:00 p.m., John W.
Stetkar, Chairman, presiding.

COMMITTEE MEMBERS:

JOHN W. STETKAR, Chairman

DENNIS C. BLEY, Vice Chairman

RONALD G. BALLINGER, Member

SANJOY BANERJEE, Member

CHARLES H. BROWN, JR., Member

MICHAEL L. CORRADINI, Member-at-Large

DANA A. POWERS, Member

JOY REMPE, Member

PETER RICCARDELLA, Member

HAROLD B. RAY, Vice Chairman

STEPHEN P. SCHULTZ, Member

GORDON R. SKILLMAN, Member

DESIGNATED FEDERAL OFFICIAL:

Weidong Wang

ALSO PRESENT:

EDWIN M. HACKETT, ACRS

PHIL AMWAY, Exelon Corporation

JON BARR, RES/DSA/AAB

ROBERT BEALL, NRR/DPR/PRMB/PFLT

PAULA GOTSCH, Grandmothers, Mothers and More
for Energy Safety *

JOHN GRUBB, Xcel Energy

PAUL GUNTER, Beyond Nuclear

STEVE KRAFT, NEI

MARY LAMPERT, Pilgrim Watch *

DAVID LOCHBAUM, Union of Concerned Scientists

ABY MOHSENI, NRR/DPR

ERIC OESTERLE, NRR/DPR/PRMB/PFLT

MARTY STUTZKE, RES/DRA

RICH WACHOWIAK, EPRI

* Present via telephone

C O N T E N T S

	<u>Page</u>
Opening Remarks by the ACRS Chairman	4
Review of Containment Protection and Release Reduction	5
Remarks by Subcommittee Chairman, Stephen P. Schultz	5
Briefing and Discussion by NRC Staff	8
Briefing and Discussion by Industry	58
Briefing and Discussion with Public	118

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

P R O C E E D I N G S

1:02 p.m.

CHAIRMAN STETKAR: The meeting will now come to order. This is the first day of the 627th meeting of the Advisory Committee on Reactor Safeguards.

During today's meeting, the Committee will consider the following: Review of Containment and Release Reduction, Discussion of Commission Meeting Topics, and Preparation of ACRS Reports.

This meeting is being conducted in accordance with the provisions of the Federal Advisory Committee Act. Mr. Weidong Wang is the Designated Federal Official for the initial portion of this meeting.

We have received -- that's not correct. We have received several written comments and requests to make oral statements from members of the public regarding today's sessions. And we have time allocated for that process.

There will be a phone bridge line. To preclude interruption of the meeting the phone will be placed in a listen in mode during the presentations and Committee discussion.

A transcript of the meeting -- portions f

1 the meeting is being kept. And it is requested that
2 speakers use one of the microphones. Identify
3 themselves and speak with sufficient clarity and
4 volume so that they can be readily heard.

5 I also ask everybody to check your little
6 phones and other communications devices. And please
7 turn them off so we're not interrupted.

8 We will open the phone bridge line at the
9 conclusion of this session on Containment Protection
10 and Release Reduction, to be sure that we have
11 comments from anyone who is listening in out there.

12 As an item of interested, I'd also like to
13 note the passing of former ACRS Member Dr. Don Miller,
14 who served on the Committee between 1995 and 1999.
15 And we certainly recognized Don's tremendous
16 contributions to nuclear safety throughout his career.
17 We're sorry to hear about his passing.

18 With that, unless any of the members have
19 any other items for discussion, we'll turn to the
20 first item on our agenda. Which is Review of the
21 Containment Production and Release Reduction.

22 And Steve Schultz will lead us through
23 that portion of the meeting. Steve?

24 MEMBER SCHULTZ: Thank you, John, for
25 introducing the topic. Our ACRS Subcommittees on

1 Fukushima and on Reliability and PRA have met jointly
2 to review this matter during two meetings in 2014, and
3 on July 7 and August 18, this year.

4 During each of these meetings, we had the
5 benefit of discussions with the NRC Staff,
6 representatives of the Industry and the public.

7 Separately, this Committee has also been
8 reviewing the related staff guidance and industry
9 implementation of the response to the NRC Order EA-
10 13109, which will ensure a severe accident capable
11 venting systems in these facilities.

12 In our meetings in 2014, the Subcommittees
13 reviewed the general concepts of the analysis and
14 evaluation approach the staff intended to use in
15 structuring the regulatory basis in its documentation.

16 In July and August this year, the
17 Subcommittees have reviewed the detailed technical
18 analysis work and evaluations performed by the staff
19 which support this document. That is the document on
20 Containment Protection and Release Reduction for BWR
21 Mark I and Mark II containments. As well as the
22 result in findings and recommendations.

23 We also heard presentations from industry
24 representatives regarding their development and
25 analysis of severe accident management approaches for

1 these facilities. And discussed these findings.

2 We discussed filtering strategies in
3 severe accident management issues. And received
4 comments from members of the public.

5 At our Subcommittee -- at our previous
6 Subcommittee meeting on this subject, on August 18, we
7 heard from staff and industry regarding their views.
8 And are pleased to have them back today at this full
9 Committee session to summarize their positions.

10 In addition, at this meeting, as John
11 indicated, we will hear presentations from David
12 Lochbaum of the Union of Concerned Scientists, Paul
13 Gunter of Beyond Nuclear, and Mary Lampert of Pilgrim
14 Watch on their views. And we'll also hear from any
15 other interested members of the public who wish to
16 make comments.

17 Following our August Subcommittee meeting,
18 the Commission completed their deliberations on the
19 matter. And decided not to proceed with Rulemaking
20 Alternative 1 as described in the staff SECY paper.
21 They provided clear direction to the staff to proceed
22 accordingly.

23 Since the Commission has rendered their
24 decision on this -- the alternatives that were
25 presented by the staff, the Committee intends today to

1 focus on deliberations on the technical aspects of
2 containment protection and release reduction for these
3 facilities. With emphasis on the performance of
4 severe accident capable venting systems and engineered
5 filter systems.

6 We'll now proceed with the presentations.
7 And I would like to invite Aby Mohseni of the staff to
8 begin. Aby?

9 MR. MOHSENI: Thank you very much. Good
10 afternoon Mr. Chairman and distinguished members. I
11 am Aby Mohseni, Deputy Director for the Division of
12 Policy and Rulemaking in NRR.

13 And we appreciate the opportunity to
14 address the Committee today. The NRC staff is here
15 today to provide a high level overview of the draft
16 reg basis for the containment protection and release
17 reduction rulemaking's CPRR.

18 The staff previously made detailed
19 presentations on the CPRR rulemaking to the ACRS PRA
20 and Fukushima Subcommittees on July 7 and August 18,
21 2015. And has benefitted from their feedback.

22 The NRC staff developed a Commission
23 paper, SECY 15-0085 and a supporting draft regulatory
24 basis that provides details on the high level
25 conservative estimate and the benefits of external

1 water addition.

2 Since the last time we met with you, the
3 Commission has provided direction to the staff in SRM
4 SECY 15-0085 to discontinue the CPRR rulemaking
5 activities, proceed with the implementation of Order
6 EA-13-109. And use as applicable, the draft CPRR
7 regulatory basis to support other near term task force
8 Tier III items related to containment protection.

9 To start today's presentation, Bob Beall
10 will provide an overview of the CPRR regulatory
11 evaluation. Bob is the lead PM for the CPRR
12 rulemaking in the Office of Reactor Regulations.

13 Next, Marty Stutzke from the Office of
14 Nuclear Regulatory Research will briefly talk about
15 the risk and PRA results in the draft CPRR regulatory
16 basis. We also have John Barr from the Office of
17 Research to answer questions as needed.

18 So now, let me turn it over to Bob.

19 MR. BEALL: Thank you, Aby. Good
20 afternoon, gentlemen. I'd like to start on page two,
21 slide two, by going over a background information on
22 the overall Fukushima lessons learned.

23 CPRR rulemaking is just one part of a much
24 larger NRC activity related to the lessons learned
25 from the Fukushima accident. In this slide, we see a

1 number of the Fukushima activities that the NRC is
2 looking at right now.

3 And if you look at towards the center or
4 the upper center right portion of the slide, you can
5 see where CPRR is. This says containment protection
6 and release reduction rulemaking.

7 And it's also right next to the hardened
8 vent order. Which is EA-13-10. But in addition to
9 that, you also see there's a number of activities
10 related to seismic and flooding activities with walk
11 downs and reevaluations.

12 There's also onsite and offsite activities
13 related to the FLEX equipment. And you also see
14 there's emergency procedures and other activities like
15 offsite blackout vents that's also part of the lessons
16 learned.

17 So, CPRR is just on a facet of a much
18 larger NRC activity related to the Fukushima lessons
19 learned.

20 On the next slide, in the draft CPRR
21 regulatory basis, the staff came up with four
22 alternatives for the Commission to consider. They can
23 be broken down into high level actions with related to
24 containment protection and release reduction.

25 Alternatives 1, 2 and 3 are related to

1 containment protection. And Alternative 4 is release
2 reduction.

3 Alternative 1 had to do with no rulemaking
4 or maintain the status quo was going with, staying
5 with the Order EA-13-109, which talks about over
6 pressure protection. It also has a kind of a benefit
7 of severe accident water addition to help cool core
8 debris.

9 Alternative 2 had to do with codifying or
10 making genetically applicable the Order. So basically
11 we would take the Order EA-13-109 and add it to the
12 regulations.

13 Alternative 3 was a combination of
14 Alternatives 1 and 2, which is codifying the Order.
15 But also require that the use of severe accident water
16 addition or SAWA as part of the regulations.

17 MEMBER CORRADINI: So, can I ask? So, at
18 this point, you're going to get to 4, which I know is
19 different.

20 I'm still personally struggling about the
21 difference between 1, 2, and 3. And I think that
22 having the -- I asked this at the Subcommittee and I
23 want to make sure that I've got it right in my head.

24 So is the difference between 1, 2, and 3
25 from a technical standpoint, no difference? And it's

1 more a process?

2 Or is there a technical difference between
3 1, 2, and 3? That's what I'm still struggling with.

4 MR. BEALL: There is really no technical
5 difference between 1, 2 and 3. Because all three of
6 them have the severe accident water addition as part
7 of the regulatory evaluation.

8 MEMBER CORRADINI: Okay. And just to help
9 me then, under Alternative 3, you note, and I think
10 you guys noted this before in the Subcommittee about
11 protection against major containment failure modes.

12 I don't appreciate what your pointing out
13 there that makes it different. What does that mean?

14 MR. BEALL: The Order EA-13-109 was
15 specifically written to address over-pressurization.
16 But, when you add the addition of water, severe
17 accident water addition, that also can apply to other
18 containment failure modes like liner melt-through.

19 MEMBER CORRADINI: Sure.

20 MR. BEALL: Or, leakage through the
21 drywall head.

22 MEMBER CORRADINI: Sure. But wouldn't
23 that apply to 1 and 2?

24 MR. BEALL: It can. But it's not
25 specifically called out like it would be in

1 Alternative 3.

2 When we would codify the Order plus
3 requiring severe accident water addition, we could of
4 -- we could actually -- we could also talk about
5 protecting against alternative containment failure
6 modes instead of just over-pressurization. Which is
7 what the Order calls out for you to protect against.

8 CHAIRMAN STETKAR: Bob, let me --

9 MR. BEALL: It's a very subtle difference.

10 CHAIRMAN STETKAR: Let me see if I can
11 understand it though. In principle, Alternative 2 and
12 the Order, Alternative 2 simply codifying through
13 rulemaking the Order, --

14 MR. BEALL: That's correct.

15 CHAIRMAN STETKAR: Could in principle, I'm
16 not saying in practice. Could in principle be
17 satisfied by someone designing a drywell vent with no
18 water addition that would survive the condition in the
19 drywell with no water addition?

20 Is that correct?

21 MR. BEALL: In principle that's correct.

22 CHAIRMAN STETKAR: Okay.

23 MR. BEALL: Because in Phase II of the
24 Order allows you having a drywell vent operational.

25 CHAIRMAN STETKAR: And that's all that it

1 requires? Is a drywell vent that satisfies that
2 function?

3 MR. BEALL: Right. Or you can have --

4 CHAIRMAN STETKAR: It has to be
5 operational.

6 MR. BEALL: Right, it has to be
7 operational.

8 CHAIRMAN STETKAR: And so I said, in
9 principle, if I could design it with the right
10 materials and environmental qualifications and
11 reliability, that drywell vent with no water addition
12 could satisfy either Alternative 1 or the codified
13 version in Alternative 2.

14 MR. BEALL: Yes, sir, that is correct.

15 CHAIRMAN STETKAR: Okay. In Alternative
16 3, it actually adds the requirement for water
17 addition.

18 VICE CHAIR BLEY: The reason why they say
19 there's no technical difference, as I understand it,
20 is because now you expect all the licensees to come in
21 under any of the three with SAWA.

22 MR. BEALL: That's correct. Yes, sir.

23 VICE CHAIR BLEY: But --

24 MEMBER CORRADINI: Okay. But if I might
25 just interject. So, technically, all three of them

1 except for the process by which the licensees would
2 follow, technically would have the same effect under
3 1, 2, and 3. Unless I'm -- in practice.

4 Forget about principle for the moment.

5 MR. BEALL: Right.

6 MEMBER CORRADINI: From a practice
7 standpoint, they would be practically the same. They
8 are the same.

9 MR. BEALL: Right. So for like -- as John
10 said, is that Alternative 1 and 2, you could come in
11 --

12 MEMBER CORRADINI: Right, right, right.
13 Okay. I'm with you there. I'm with you there.

14 CHAIRMAN STETKAR: That's why I tried to
15 -- you're trying to see what is the distinction.

16 MEMBER CORRADINI: Yes.

17 CHAIRMAN STETKAR: And in my mind, that's
18 -- it's a -- if you accept the fact that all of the
19 licensees are going to satisfy the Order with water
20 addition, then there is no distinction.

21 MEMBER CORRADINI: Okay.

22 CHAIRMAN STETKAR: But in principle, there
23 could be.

24 MEMBER CORRADINI: Okay.

25 MR. BEALL: In Alternative 4, it's

1 classified under release reduction. And Alternative
2 4 it talks about using engineered filters and other
3 filtering strategies to reduce your offsite release to
4 through the vent.

5 In slide four, as Steve and Aby talked
6 about, we have an SRM, all from the draft -- from the
7 Commission on the draft regulatory basis.

8 The SRM instructed the staff to
9 discontinue the CPRO rulemaking. And to not issue the
10 draft regulatory basis for public comment.

11 They asked us to continue on with the
12 Order EA-13-109 as written. And to implement it
13 without additional -- any additional regulatory
14 actions.

15 It also --

16 MEMBER CORRADINI: So if I might now, now
17 we've got that technically they're all the same in
18 prac -- potentially in practice.

19 MR. BEALL: Um-hum.

20 MEMBER CORRADINI: So from a process
21 standpoint, what is the commitment under Alternative
22 1 by those licensees to follow the Order --

23 MR. BEALL: Right.

24 MEMBER CORRADINI: And SAWA or SAWM,
25 whatever it is, would be part of that implementation

1 of the Order that would be --

2 MR. BEALL: That's correct. That's --

3 MEMBER CORRADINI: Expected and --

4 MR. BEALL: Yes, that's correct. That's
5 Phase II of the Order.

6 MEMBER CORRADINI: Okay.

7 MR. BEALL: Right. Phase I of the Order
8 talks about having an operable wetwell vent. And
9 Phase II gives you the drywell vent. Or having a --
10 maintaining the wetwell vent in this direction.

11 MEMBER CORRADINI: Excellent. Thank you.

12 MR. BEALL: Yes, sir?

13 MEMBER BROWN: With the SAWA and stuff,
14 when you originally did that Order, didn't -- I mean,
15 we had a lot of extensive discussions on the water
16 management and the water addition and all that stuff
17 in the last meeting or two.

18 And but I don't remember that being talked
19 about to that extent in the early Order. But so --
20 but it's still okay?

21 I mean it -- isn't this more of an
22 industry initiative under the water addition stuff?
23 As opposed to being a regulation?

24 Or, is the Order encompassing enough to
25 get what we've heard in the last couple of meetings,

1 covered under the severe accident water addition and
2 water management protocols that you all discussed with
3 us?

4 MR. BEALL: The water is encompassing
5 enough that they would -- it gives the licensees a
6 choice. Okay? Under Phase II to the drywell vent, or
7 have an alternative method to satisfy -- to maintain
8 the wetwell vent.

9 MEMBER BROWN: So that's the wetwell vent
10 issue then.

11 MR. BEALL: Right. That's right. That's
12 correct.

13 MEMBER BROWN: So then the Order was
14 explicit enough of that.

15 MR. BEALL: Yes, sir.

16 MEMBER BROWN: I guess I didn't understand
17 that. Okay. Thank you.

18 MR. BEALL: Okay.

19 MEMBER CORRADINI: Sorry.

20 MR. BEALL: Go ahead.

21 MEMBER CORRADINI: I'm still not all the
22 way there yet. So, under what the Commission is
23 moving forward with, which is Alternative 1, Plant X
24 says that here's how I'm going to satisfy Phase 1.
25 Here I'm going to satisfy Phase II.

1 And in practice, part of Phase II is water
2 addition and the associated management for days,
3 weeks, of managing the water supply such that one has
4 what they have -- so that they can vent. And then
5 appropriately manage the water for coolability.

6 MR. BEALL: Correct.

7 MEMBER CORRADINI: Is that water addition
8 strategy checkable by the staff? And if so, how is it
9 going to be checkable?

10 MR. BEALL: I can't address that. That's
11 prob --

12 MEMBER CORRADINI: I use the word
13 checkable because anything else I use is probably
14 illegally binding. I just want to know how are you
15 going to check?

16 MR. BEALL: That's a question that would
17 have to be answered by the folks in the JLD, who's
18 managing the Order. You know, because I'm -- so I
19 don't know how they're going to be checking that.

20 Because we didn't move it in that phase of
21 the rulemaking to codify and come up with rule
22 language and things like that.

23 MEMBER CORRADINI: Oh. But you're saying
24 at this point, you hadn't anticipated that direction.
25 So it's to be determined.

1 MR. BEALL: To be determined.

2 MEMBER CORRADINI: But it has to be
3 checkable, right?

4 MR. BEALL: I assume it would be.

5 MEMBER CORRADINI: Okay.

6 MR. BEALL: But, that's a question for the
7 --

8 CHAIRMAN STETKAR: But on -- I mean, the
9 ability for the NRC staff to confirm that a licensee
10 is satisfying their compliance with an Order, doesn't
11 seem to be an issue specific item. Is it?

12 I think what we're asking is, if a
13 licensee says I will comply with Order whatever, Order
14 X. And by complying with Order X, I will do A, B and
15 C. I don't care what those are.

16 Does the staff have a mechanism and a
17 requirement to confirm that indeed that licensee is
18 maintaining A and B and C?

19 MR. BEALL: The --

20 CHAIRMAN STETKAR: That's a process issue.
21 It has nothing to do with severe accident water
22 addition or anything.

23 MR. BEALL: Right. Right.

24 CHAIRMAN STETKAR: And a couple of us, I
25 being one, don't know the answer to that question. I

1 think that's why we've raised it.

2 MEMBER CORRADINI: We're anticipating the
3 answer is it's checkable. But, I just want to make
4 sure that I understand. If 1 through 3 are
5 approximately the same except for process, I'm trying
6 to understand the process subtleties. That's all.

7 CHAIRMAN STETKAR: It's clear that if it's
8 a rule, it's codified in the regulations.

9 MEMBER CORRADINI: Right.

10 CHAIRMAN STETKAR: And we know how those
11 are treated. But what we're asking is, how is a
12 licensee commitment to comply with an Order treated in
13 a regulatory checkability -- thanks for the word,
14 space.

15 MR. MOHSENI: It is the same. It has the
16 same legal authority as the rules do. What you have
17 in regulation, you have additional parts of the
18 regulation that would kick in.

19 For example, there might be references to
20 other parts of the regulation that generally adds more
21 to the context of this rule. Whereas, in an Order,
22 you only have what the Order says.

23 And the Order generally is more focused on
24 what exactly it is that the Order is about. It does
25 not reinvent all the other additional components that

1 are in a regulation that goes generally with a
2 regulation.

3 And you don't have those benefits,
4 flexibilities that the regulation offers sometimes.
5 Exemptions for example.

6 CHAIRMAN STETKAR: Okay.

7 MR. MOHSENI: Where as an Order in fact is
8 enforceable. And just as much as regulatory
9 requirements are.

10 And because the number of plants affected
11 by this thing, by this particular rule, are not
12 expected to increase in future, hence an order seems
13 to be an efficient way of actually capturing the
14 essence that was intended to be captured in codifying
15 the rule -- the Order.

16 MEMBER SCHULTZ: Aby, going back to the
17 example that John gave, the simple one where the
18 licensee had determined and committed -- committed as
19 a result of the order to the staff that they are going
20 to do A, B and C.

21 The staff then has the right and the
22 responsibility to validate that A, B and C are in fact
23 being accomplished going forward.

24 MR. MOHSENI: That's correct. There will
25 be verification that in fact it satisfies the Order.

1 The Order isn't -- the Phase II of the
2 Order says if you chose not to have a hardwell vent,
3 you have to demonstrate why that is adequate for the
4 protection of the containment.

5 In fact, this requires a subsequent
6 analysis by NRC to approve the methodology that the
7 licensees offer as meeting the Order.

8 So yes, there will be a schedule. There
9 will be a time line for when NRC actually indicates
10 that the Order is satisfied by each licensee.

11 CHAIRMAN STETKAR: Marty, that's for
12 initial satisfaction of the Order itself. I today say
13 that I will do A and B and C to satisfy this Order.
14 The NRC reviews that and says yes indeed, we believe
15 that if you do A and B and C, you will satisfy the
16 Order.

17 What I think we're asking about in terms
18 of checkability, is seven years from now, does the NRC
19 have the ability to go to that licensee and check
20 whether you still have the capability. Whether that's
21 hardware or training or procedures or whatever, to
22 indeed accomplish A and B and C.

23 That's the sense of checkability. Not the
24 initial ability to meet the order. But continued
25 ability throughout the life of the facility.

1 MR. BEALL: Like Aby said that, you know,
2 it's almost like doing the rulemaking, codifying it.
3 Except that, you know, it's an Order.

4 So, it should be able -- it should be
5 falling under the ROP process for the site resident
6 inspectors to look at the commitment. Making sure
7 they're complying to commitment.

8 And having any site inspections as needed.

9 MEMBER POWERS: they can site against the
10 commitment?

11 MR. BEALL: That's correct.

12 MEMBER CORRADINI: That's all we need.

13 MEMBER POWERS: They can site against
14 commitment, then it's the same as a regulation.

15 MEMBER BROWN: Do you have the ability
16 when they say they're going to do -- to use John's
17 example, C. We will comply with C. They have to
18 execute.

19 There's got to be a method to what they
20 do. Here's how we're going to do it.

21 MR. BEALL: UM-hum.

22 MEMBER BROWN: Do you have the ability
23 because it's an Order to be able to say, we don't
24 agree with the way you're doing it. And you need to
25 do it in a slightly different manner?

1 Or do you have to accept what they say
2 because they say they're complying with the Order?

3 MR. BEALL: NO. We don't have to agree
4 with that. We can --

5 MEMBER BROWN: You can get a change --

6 MR. BEALL: We can get a change.

7 MEMBER BROWN: To satisfy some -- so
8 you're satisfied that they are in fact complying with
9 the intent of the Order.

10 MR. BEALL: Yes, sir.

11 MEMBER BROWN: Okay.

12 MR. OESTERLE: Thank you. Eric Oesterle
13 from the staff. I'm the team lead for the Fukushima
14 Lessons Learned Rulemaking Team.

15 I just wanted to point out that once the
16 licensees have provided their plans for compliance
17 with the Order, that becomes part of the licensing
18 basis. And compliance with the licensee's licensing
19 basis is part of the normal inspection process that we
20 go through.

21 And as Bob said, resident inspectors will
22 routinely inspect those types of activities. In
23 addition, the staff has already been working with
24 industry on guidance for implementing the Orders.

25 And one thing that we've seen is that this

1 guidance has developed a template for implementing
2 actions under Phase II. And they all include severe
3 accident water additions.

4 So, that's one indicator that we have from
5 industry, including our discussions with them here
6 that all licensees are either going with severe
7 accident water addition. Or any alternative has to be
8 reviewed and approved by the NRC.

9 Later this years, I think by December, we
10 expect all of the implementation plans from licensees
11 for compliance with the Order. And that's when we'll
12 get the, you know, the 100 percent verification that
13 they're following, you know, the template that has
14 been developed for implementing the Order in
15 accordance with the ISG guidance document that's been
16 developed.

17 So I just want to make the difference that
18 it's not really a commitment that they're making here.
19 They're complying with an Order that becomes part of
20 their licensing basis.

21 MEMBER RICCARDELLA: Are there plant
22 specific submittals? Or a general topical report
23 submittal? Or some combination of the --

24 MR. BEALL: It would be plant specific.

25 MEMBER RICCARDELLA: Okay.

1 MR. BEALL: Okay. On slide five. And
2 part of the draft regulatory basis that was submitted
3 to the Commission, the technical analysis that's
4 provided by the staff, supported all four
5 alternatives.

6 That allowed the Commission to look over
7 all the alternatives and all the data. And then come
8 up with a -- their recommendation and direction they
9 gave to the staff last month.

10 So, the -- but the technical analysis did
11 demonstrate that the risk reduction from this --
12 that's shown in the risk reduction in the draft
13 regulatory basis was not a substantial safety
14 improvement.

15 Also, that the safety goal of the QHO, the
16 Quantitative Health Objective limit of 2 times 10 to
17 the minus 6, versus the CPRR high level conservative
18 estimate that we calculated, was over an order of
19 magnitude difference.

20 So, we were way below the NRC safety goal
21 for that. And also the valuation and Marty will be
22 talking about some of this stuff in a little bit,
23 showed that, you know, we took advantage of the flex
24 equipment, operator actions, probabilities and things
25 like that and all that was all factored into the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 analysis that the staff did.

2 And on slide six, I'd like to turn it over
3 to Marty.

4 MR. STUTZKE: Good afternoon. Slide six
5 shows an example risk calculation to try to remind all
6 of us how these numbers are estimated like this.

7 Starting up at the top, when we began the
8 analysis. We defined a variety of what are called
9 sub-alternatives. And a sub-alternative is nothing
10 more than a specific set of CPRR strategies.

11 For example, we'll consider a strategy
12 that says gee, we're going to have severe accident
13 water addition. And that water is going to go into
14 the reactor vessel. And we will open the wetwell vent
15 first. And an operator will do that as opposed to
16 some rupture disk.

17 All of these different combinations.
18 There's 20 sub-alternatives for -- defined, evolved as
19 we continued to work on the process.

20 What's important to realize is that the
21 strategies are -- or a sub-alternative specifies a
22 capability or what is possible within the strategies.
23 Probabilistically then, we treat it inside risk
24 assessment and estimate the probability whether the
25 strategy succeeds or fails.

1 So, looking a little bit down on there,
2 you see a box called CDET. That is the Core Damage
3 Event Tree. The notion is that we come in with an
4 extended loss of A/C power as the initiating event to
5 that tree.

6 That CDET then models the FLEX
7 implementation probability through a variety of
8 accident sequences. In reality, that CDET has 340
9 sequences of which 280 go to core damage.

10 So, it's rather lengthy that way. And
11 this is where the approximate 40 percent reduction
12 comes from, like this.

13 All of that is just to get started with
14 the real purpose of our analysis, which is CPRR.
15 Because we needed to establish the boundary and the
16 initial conditions for the thermal hydraulics work.

17 And that's what the CDET provides us. So
18 we group those sequences into what are called plant
19 damage states. They are then fed into an APET or an
20 Accident Progression Event Tree.

21 And out of the APET, what we get are
22 release category frequencies that come out. And a
23 release category defines a specific type of release.
24 One that will happen, how much material is released.
25 How much energy is associated with the release.

1 Things like this that we get out of MELCOR
2 calculations that are then input to our max
3 calculations for consequence. So the actual risk
4 calculation per se, is this table.

5 So we have a variety of release categories
6 for each sub-alternative. Their associated
7 frequencies. We go through the thermohydraulics and
8 the consequence calculations.

9 And John provides the conditional
10 consequence. We simply multiply those two numbers
11 together and add them up like this.

12 MEMBER BANERJEE: Does this take into
13 account also the weather at its max?

14 MR. STUTZKE: Yes.

15 MEMBER BANERJEE: So that there's the --
16 but you take into account what weather class it is,
17 the frequency of that. And that's all fed into this?

18 MR. BARR: All of -- this is Jon Barr.
19 So, all of the conditional consequences are mean
20 values over about 1,000 different weather trials.

21 And those are based on site specific
22 weather for the reference point.

23 MEMBER BANERJEE: That was my question.
24 Thank you.

25 MR. STUTZKE: Within the release category,

1 there's something subtle, because they are encoded.
2 But it tells us how the material is escaping into the
3 environment.

4 The middle column there, where you see the
5 labels like WW or DW. That stands for venting through
6 the wetwell or venting through the drywell.

7 If you scroll down the list a little bit,
8 you see one called OP, over-pressurization failure of
9 the containment. Meaning that none of the vents got
10 opened in time. Okay, so that's an example of the
11 containment failure mode.

12 The last column, IRV stands for in-vessel
13 retention. LMT is liner melt-through. So, those are
14 other additional containment failure mechanisms that
15 come up.

16 What's important to realize is that within
17 each sub-alternative or each risk calculation is there
18 are different pathways for material to escape into the
19 environment. And not all of those pathways are
20 filterable.

21 In other words, if there's an over-
22 pressurization failure, it doesn't go through the
23 vent. And so putting a filter on the vent is not a
24 benefit. The same way if there's a liner melt-
25 through, that doesn't matter whether there's a filter

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 on the vent either.

2 So, we spent a great deal of time trying
3 to track and understand the different ways that the
4 containment was failing. So that when we apply a CPRR
5 strategy to it, we're not over-crediting it or under-
6 crediting it in the computation.

7 MEMBER RICCARDELLA: Excuse me. Why do
8 some of the subcategories include drywell venting when
9 I thought we weren't, you know, most of the SAWA
10 strategies don't include a drywell vent.

11 MR. STUTZKE: Okay. When -- these
12 strategies evolved over time. And one of the first
13 strategies that came from our discussions was a so
14 called passive drywell vent.

15 So we were going to put a rupture disk in
16 there, not a valve. And it's like, okay, everybody's
17 dead or they're incapacitated. And it will blow at
18 the right time and therefore relieve the pressure.

19 So, that is one of the sub-alternatives.
20 I can show it to you. The same way later on as the
21 importance of water addition during severe accidents
22 became obvious to us.

23 We defined flavors of that to SAWA, severe
24 accident water addition, which is the pump just start
25 it and let it run. And the whole containment would

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 fill up. As compared to a severe accident water
2 management strategy that says throttle it and don't
3 submerge the wetwell vent.

4 So, it truly -- I mean, on a personal
5 note, we used to go to these meetings among ourselves
6 and with industry. And I'd come back with three more
7 sub-alternatives I would have to analyze. Of course
8 by tomorrow. This sort of thing.

9 But, that's the nature of --

10 MEMBER POWERS: Maybe that should have
11 been done before it was suggested.

12 CHAIRMAN STETKAR: Knowing Marty, he did.
13 He just -- Marty, be careful with your paper there so
14 you don't hit the mic.

15 Go back to the earlier slide. Because I
16 want to make sure I don't -- I want to make sure I
17 remember something from the full. Nope, not quite
18 that early.

19 MR. STUTZKE: Not that early, right. I
20 agree with that one.

21 CHAIRMAN STETKAR: There we go. This
22 slide says that you indeed did model the operation of
23 FLEX equipment to potentially prevent core damage.
24 Right? And if it's correct.

25 If it prevented core damage, you didn't

1 have core damage. So that's what -- if it failed,
2 then it remained -- did it remain failed for the post-
3 core damage response?

4 MR. STUTZKE: It depends on how it failed.

5 CHAIRMAN STETKAR: Okay.

6 MR. STUTZKE: If the hardware itself
7 failed, that was the end of it.

8 CHAIRMAN STETKAR: Okay.

9 MR. STUTZKE: Okay. If the operator
10 failed to implement it in time, we did ask again,
11 given more time, could they be successful?

12 CHAIRMAN STETKAR: Okay. So the
13 operator's got a second chance if the hardware was
14 available. But if the hardware failed -- you know, I
15 recall there was also some timing issue related to
16 core damage.

17 That if for example, RCIC failed early,
18 you did not include credit for FLEX to prevent core
19 damage.

20 MR. STUTZKE: Right.

21 CHAIRMAN STETKAR: Am I remembering that
22 correctly?

23 MR. STUTZKE: That's correct. To add a
24 little more confusion to the jargon, FLEX has Phase I
25 and Phase II now.

1 CHAIRMAN STETKAR: Right. Yes.

2 MR. STUTZKE: As well as Phase III. Phase
3 I is reliance on your in plant equipment. So, the
4 logic structure says RCIC pump needs to work during
5 Phase I.

6 CHAIRMAN STETKAR: Right.

7 MR. STUTZKE: Meanwhile, everybody's
8 running around trying to install FLEX and drag the
9 portable equipment out and this sort of thing like
10 that. In this event tree, we assume that took a
11 minimum of four hours.

12 CHAIRMAN STETKAR: So that if you lost
13 RCIC early, you said you basically didn't have -- the
14 operators essentially didn't have the early chance to
15 save the core. They would still have the later
16 chance.

17 MR. STUTZKE: Yes.

18 CHAIRMAN STETKAR: And because the
19 hardware wasn't questioned. You questioned the
20 hardware in the back part of the model?

21 MR. STUTZKE: That's correct.

22 CHAIRMAN STETKAR: Okay.

23 MEMBER BANERJEE: Could I also ask a
24 question? MELCOR and -- yes, let's talk about MELCOR.

25 The calculations there, there's no

1 uncertainty in the results put on that in addition to
2 anything?

3 MR. STUTZKE: Not that the MELCOR team
4 did. I'll show you a slide and a couple back, where
5 I tried to inform my understanding of the
6 uncertainties by relying on the SOARCA uncertainty
7 analysis work.

8 It's very --

9 MEMBER BANERJEE: Okay. I think that's --

10 MR. STUTZKE: Yes, it's a very current
11 approach. But, yes.

12 MEMBER BANERJEE: At least it gives you a
13 rough idea.

14 MR. STUTZKE: Okay. If nothing else, it
15 demonstrates I pay attention to other research.

16 MEMBER BANERJEE: Right.

17 MR. STUTZKE: Okay. So slide number
18 seven. Sorry John, I got to turn this page. I just
19 need this, right.

20 Is trying to show the contributions to
21 risk at a very high level. So I picked four sub-
22 alternatives which are in the table below the graph.

23 And I apologize, the sub-alternatives have
24 rather we'll say strong nomenclatures to how they're
25 labeled. One --

1 CHAIRMAN STETKAR: Unintelligible is a
2 different terminology.

3 MR. STUTZKE: And they would routinely
4 change as the project evolved. Which I was going to
5 say pulled my hair out, but I guess it's too late for
6 that.

7 Like that, but I have tried to for this
8 example, to summarize it. If you look in the lower
9 right-hand corner, this is an example of a
10 specification of part of a sub-alternative.

11 So we can talk about the water injection
12 pathway. And here it says reactor pressure vessel.
13 Another choice would be to the drywell directly.

14 The water strategy, whether it's SAWA
15 versus SAWM. The venting priority, we're going to use
16 the wetwell vent first, or we're going to try the
17 drywell vent first. Vent control manual as opposed to
18 a passive rupture disk.

19 And a venting strategy. An open and leave
20 open strategy versus a vent cycling strategy. Where
21 the vent would then be reclosed after the containment
22 depressurizes by about ten pounds. Something like
23 that.

24 So, for each of the cases you see here,
25 all of these are the same so that we can do a fair

1 apples to apples comparison. In the first sub-
2 alternative, there is no water addition capability and
3 no filter.

4 All right. And you can see the risk.
5 Total risk is about 3 times 10 to the minus 9 per
6 reactor year like that.

7 MEMBER CORRADINI: What is the horizontal
8 access? Time?

9 MR. STUTZKE: No. The horizontal access
10 is just showing you the different cases.

11 MEMBER CORRADINI: Between 3 and 4, okay.

12 MR. STUTZKE: Right. So, moving over to
13 the column of 3(a), we now allow water addition
14 capability with its associated success or failure
15 probabilities in there.

16 And I'll call your attention to the green
17 line, which is the third down from the top. And it
18 has increased. That's actually the desired or the
19 preferred response.

20 Now, corresponding to a case where the
21 containment is in fact vented. And core debris is
22 being retained because water addition has been
23 successful.

24 If you'll look at the black line, which is
25 the total risk. So you can see that the inclusion of

1 a water addition capability does lower the risk
2 somewhat.

3 Moving over to the third column. Now we
4 add in the possibility of a filter on the containment
5 vent line. In this case the decontamination factor
6 was assumed to be 10.

7 This is a parametric study. It's not as
8 if we say they can actually achieve a DF of 10. It's
9 just want if it was 10.

10 And you can see the risk is lowered
11 somewhat. But it's not totally eliminated. And
12 that's because as I'd said before, not all the release
13 pathways are in fact filterable to that vent line.

14 Then when one increases the DF up to
15 1,000, assuming that's possible, you don't see much
16 change in the total risk at all.

17 MEMBER CORRADINI: So, it's all the
18 leakage around it?

19 MR. STUTZKE: It's the cases where things
20 like the SAWA capacity doesn't work. So they get a
21 liner melt-through.

22 MEMBER CORRADINI: Ah.

23 MR. STUTZKE: Okay.

24 MEMBER CORRADINI: So it's not that it's
25 working. But it's bypassing. It's a combination of

1 a whole bunch of failures.

2 MR. STUTZKE: That's correct.

3 MEMBER BANERJEE: Are these changes
4 significant within the uncertainties?

5 MR. STUTZKE: You must have read my
6 slides.

7 (Laughter)

8 MEMBER BANERJEE: I guessed again.

9 MR. STUTZKE: Yes. Next slides -- next
10 slide.

11 VICE CHAIR BLEY: Do look at that left-
12 hand scale. There's not a lot of change.

13 MEMBER BANERJEE: That's what it means.

14 CHAIRMAN STETKAR: This is a linear scale
15 in 5E to the minus 10 increments. This is --

16 MEMBER BANERJEE: Yes. And that's why I
17 asked it.

18 CHAIRMAN STETKAR: Now, something that
19 looks like a factor of 2 on a really small number.

20 MEMBER BANERJEE: And with very large
21 uncertainties.

22 MR. STUTZKE: Correct. If you flip to
23 slide number eight.

24 MEMBER SCHULTZ: Before we go Marty.

25 MR. STUTZKE: Yes?

1 MEMBER SCHULTZ: So, what you're saying is
2 for the cases on the right-hand side where filtration
3 comes into play, for some period of time the pathway
4 to the filter is functional?

5 MR. STUTZKE: No. Remember this is a
6 compilation of many sequences. So --

7 MEMBER SCHULTZ: Many sequences. Okay.

8 MR. STUTZKE: In some cases the sequence
9 is such that there's no venting at all. So you get an
10 over-pressurization failure, which is not filtered.

11 Okay. So this is results of all of the
12 sequences summed together.

13 MEMBER SCHULTZ: So it's a combination of
14 possibilities --

15 MR. STUTZKE: Correct.

16 MEMBER SCHULTZ: That are represented by
17 the point result.

18 MR. STUTZKE: Correct. Yes, it's not a
19 specific sequence.

20 MEMBER SCHULTZ: But that could be an
21 outcome. In other words that could be an outcome
22 where the pathway, the venting pathway to the filter
23 is functional. But then the containment fails or the
24 liner melts through and at that point, it releases
25 through that pathway.

1 MR. STUTZKE: That's correct.

2 MEMBER SCHULTZ: Okay. Thank you.

3 MR. STUTZKE: Okay. This slide shows the
4 comparison of the risk results to the NRC's safety
5 goal. And I think the -- let's try to review this
6 from the bottom up because it answers Dr. Banerjee's
7 question.

8 And that is, the 20 regulatory sub-
9 alternatives are shown displayed across there with
10 their uncertainty bounds on there. Those uncertainty
11 bounds include the uncertainty in the seismic hazard
12 curves, the seismic fragility, the equipment
13 reliability, the operator reliability, and
14 simplistically in the consequence that we got out of
15 MACCS.

16 And the consequence uncertainty was then
17 formed by SOARCA. But it's very simple. It's just a
18 log normal variable on top of it.

19 But it provides some idea of as you say,
20 if you look at the change in the red dots, which are
21 the mean values on this. On the previous side, you
22 see a reduction of 50 percent.

23 But the uncertainty band was well over an
24 order of magnitude. Most of that being driven by the
25 uncertainty in the seismic hazard curve itself, like

1 that.

2 Working up at the --

3 CHAIRMAN STETKAR: But that uncertainty
4 though is a constant for all of these?

5 MR. STUTZKE: That is correct.

6 CHAIRMAN STETKAR: Yes. So it's -- I'm
7 just thinking, we've not seen --

8 MR. STUTZKE: The other thing to remember
9 that makes it a little bit more confusing is what
10 you're looking at is a fleet average risk here.
11 Averaged over all the BWR Mark I and Mark II plants.

12 And they all have their own uncertainties
13 in the seismic hazard curves because those were site
14 specific. Okay. So you really begin to -- and those
15 were propagated through the trees for the -- but it
16 gets difficult then to begin to interpret the result.

17 MEMBER BANERJEE: How much of that is the
18 seismic part?

19 MR. STUTZKE: Most of it.

20 MEMBER BANERJEE: Most of it. So, if you
21 took the seismic out, it would just be a much smaller
22 incident.

23 MR. STUTZKE: That's correct.

24 CHAIRMAN STETKAR: You did say that there
25 is -- you characterized this simplistic. There's just

1 a log number distribution. But, you mentioned it and
2 I think we did discuss it a little bit at the
3 Subcommittee.

4 There is some characterization in the
5 MACCS part of the process in here. I mean, it's small
6 compared to the seismic hazard I think you explained.
7 But there is something in there.

8 MR. STUTZKE: It's there. On Table -- on
9 the Table on slide six. What we're talking about is
10 the conditional consequence. I treated that as a mean
11 value.

12 CHAIRMAN STETKAR: Um-hum.

13 MR. STUTZKE: And I put a parametric
14 uncertainty around it, log normal.

15 CHAIRMAN STETKAR: Okay.

16 MR. STUTZKE: And I mean, I can tell you,
17 the air factor was set to 10 because that's what we
18 were seeing out of the SOARCA uncertainty.

19 CHAIRMAN STETKAR: But it was set to ten?
20 Which is a reasonableness. Okay.

21 MR. STUTZKE: Yes.

22 CHAIRMAN STETKAR: Okay.

23 MR. STUTZKE: Moving up the side, I've
24 tried to put some arrows in here that group the sub-
25 alternatives by the SECY paper alternatives. Stating

1 on the left-hand side, you'll see there's two sub-
2 alternatives where we consider only the severe
3 accident capable event.

4 No first accident water addition
5 capability or no external filtration. Then we have a
6 block there labeled alternatives one, two and three,
7 that do include the water addition. And alternative
8 four is water addition plus filtration.

9 This goes back to the kind of evolving
10 nature of how the calculation is done. Dr. Corradini
11 will probably realize, this has been relabeled, then
12 what we showed at the subcommittee meeting in response
13 to your question.

14 Okay. When we started the analysis, the
15 assumption was as laid out in the SRM to SECY 12-0157
16 that said, assume you have a severe accident capable
17 vent and go from there.

18 So, we did just that. It didn't occur
19 until later that it wasn't physically possible to
20 design that vent without water addition capability.

21 So the first two bars are like -- the
22 first two sub-alternatives are as if you have I think
23 of it like a super vent. It doesn't need water
24 addition in order to be used.

25 So, the materials are right. And it can

1 just vent when it needs to vent.

2 The next block of alternatives, adding the
3 water addition capability, is done. The presumption
4 was, it was being done to prevent liner melt-through.
5 Another important containment failure mode.

6 Retroactively, it turns out well, you need
7 in order to practically design the vent, you need the
8 water addition.

9 MEMBER CORRADINI: So, my question was,
10 now there's various ways to look at this figure since
11 it's got so much information on it.

12 But, the previous one, if you can go back
13 just one click. So, the black line under 3(a), now go
14 forward, 3(a) and 4(b), is where? That black line is
15 the red or the blue?

16 MR. STUTZKE: That black line is the red
17 dots.

18 MEMBER CORRADINI: The red dots. Okay.
19 Are the red dots. And the uncertainty from site --
20 I'm just trying to try to remember all this. The
21 uncertainty and seismic dominates the range.

22 But if I'm going to have a very bad day,
23 I'm going to have a very bad day within a factor of 2
24 regardless.

25 MR. STUTZKE: That's correct.

1 MEMBER CORRADINI: Even --

2 MR. STUTZKE: If I under --

3 CHAIRMAN STETKAR: On a mean value, it
4 depends on what you call a very bad day.

5 MEMBER CORRADINI: And my point is, if
6 you're --

7 CHAIRMAN STETKAR: If you're at the 95th
8 percentile confidence in terms of what you
9 characterize as a very bad day, in terms of what is
10 the 95th percentile of the frequency of a damaging
11 earthquake, I mean, you could interpret that as
12 looking at the patter of the black Xs at the top.

13 MEMBER CORRADINI: Right. But you're
14 looking at how --

15 CHAIRMAN STETKAR: And so how you
16 characterize a very bad day, it depends on --

17 MEMBER CORRADINI: But there's still a
18 factor of 2.

19 CHAIRMAN STETKAR: It's a factor of 2
20 delta on the black Xs. That's right. Okay.

21 MEMBER CORRADINI: That's what I'm trying
22 to get at. Okay.

23 CHAIRMAN STETKAR: Right.

24 MR. STUTZKE: The other thing you need to
25 remember is when you're making a comparison to the

1 safety goal that's supposed to be done on the mean
2 value. Not the other percentiles.

3 MEMBER CORRADINI: But I'm sure we're
4 going to have other speakers that are going to argue
5 about that. So I don't want to argue about that right
6 now.

7 I just want to say that if I had the Y
8 axis with no numbers, but the relative spacing of them
9 had meaning, there's really not a lot of movement
10 between them however I try to start managing the acts
11 -- the consequences. That's what I'm --

12 MR. STUTZKE: I think that's a fair
13 characterization.

14 CHAIRMAN STETKAR: If the first two -- I
15 think Marty, what you were saying though, is if that
16 first two were quantified without a vent, which is
17 what you're saying, you couldn't really design it.
18 You assumed it was a --

19 MR. STUTZKE: Right.

20 CHAIRMAN STETKAR: A magic vent.

21 MR. STUTZKE: Exactly.

22 CHAIRMAN STETKAR: The mean values there,
23 the red dots on those first two bars, would certainly
24 be higher then where they are. Would they be as high
25 as your high level conservative estimate?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. STUTZKE: I don't think so.

2 CHAIRMAN STETKAR: Okay.

3 MR. STUTZKE: I mean, we obviously, we
4 didn't quantify it since the Commission instructed us
5 to assume that you have the vent.

6 CHAIRMAN STETKAR: Yes.

7 MR. STUTZKE: It might help to review how
8 that -- what that high level conservative estimate
9 means. Or how it was derived.

10 CHAIRMAN STETKAR: Could you do that?

11 MR. STUTZKE: Yes. Let me do that now.

12 MEMBER SCHULTZ: Before you do that though
13 Marty, I just -- I mean, we're focusing as I think we
14 did on the Subcommittee on the first two points.
15 First two cases on the left.

16 But, we know what we're going to hear from
17 industry. And that is in order for them to implement
18 the Order, they're going to talk about severe accident
19 capable vents with post accident water addition.

20 CHAIRMAN STETKAR: I was just trying to
21 get a -- since we're arguing about the --

22 MEMBER SCHULTZ: No, I got it. I actually
23 --

24 CHAIRMAN STETKAR: Fact that there are two
25 alternatives.

1 MEMBER SCHULTZ: No, I understand.

2 CHAIRMAN STETKAR: As we go, two
3 alternatives, one, two, three and four.

4 MEMBER SCHULTZ: Right.

5 CHAIRMAN STETKAR: I'm just trying to get
6 a sense of how big the delta in the opposite direction
7 would be if we did not have venting capability.

8 MEMBER SCHULTZ: Correct. Okay. Yes, I'm
9 fine with that.

10 CHAIRMAN STETKAR: Do you follow me? How
11 big is that delta?

12 MEMBER SCHULTZ: I just want to provide
13 the perspective to the Committee on the discussion
14 content.

15 CHAIRMAN STETKAR: And that gets us to how
16 they've defined that high level conservative.

17 MEMBER RICCARDELLA: A question on your
18 95th percentile. Does that include the variability
19 from plant to plant? Or is that 95th percentile
20 uncertainty on the mean?

21 MR. STUTZKE: On the means.

22 MEMBER RICCARDELLA: So, you could
23 conceivably get a plant that's --

24 MR. STUTZKE: That could be an outlier
25 plant.

1 MEMBER RICCARDELLA: Ultimately, are we
2 going to get plant specific information of this type?
3 I mean, this brings to mind that, you know, the
4 statistician who drowned in a river with an average
5 depth of six inches.

6 MR. STUTZKE: Yes. Now, I don't believe
7 that we will have this on a plant specific basis from
8 licensees.

9 MEMBER RICCARDELLA: But don't we need to
10 have some understanding of how bad a worse case plant
11 could be relative to the mean?

12 MR. STUTZKE: Well, the whole strategy of
13 the argument here, and looking at the fleet-wide mean,
14 is to convince yourself on the average, everything is
15 okay.

16 Remember, we're not after to estimate the
17 risk of any specific plant. What we're trying to show
18 you is, we think the risk is reasonably below some
19 regulatory limit.

20 And that lets you do -- simplify the
21 computations somewhat.

22 MEMBER RICCARDELLA: I understand.

23 MR. STUTZKE: So, the real question is,
24 even though, you know, if I picked my black Xs, the
25 95th percentile of the mean, and you ask, well, how

1 bad could it really be?

2 MEMBER RICCARDELLA: At the worst plant.

3 MR. STUTZKE: At the worst plant. That's
4 what the high level conservative estimate attempts to
5 address.

6 MEMBER RICCARDELLA: Okay.

7 MR. STUTZKE: And that high level
8 conservative estimate was, we went through the
9 results. Well, let me remind the Committee, and
10 perhaps the full Committee hasn't heard this story.

11 Was, when we had presented to the
12 Subcommittee a while back, there were valid concerns
13 about the human reliability. The ability of the
14 operators to function.

15 It's a very complicated problem to
16 estimate those probabilities. Especially post-core
17 damage.

18 So, I started thinking about it and said
19 look. If I just take the highest ELAP frequency
20 across the fleet, not the average, but the worst one
21 that I got. And I multiply it times the worst
22 condition or consequence that John calculated for me.

23 That number is well below the safety goal.
24 More than an order of magnitude below the safety goal.

25 MEMBER CORRADINI: Well even if you took

1 the worst of those?

2 MR. STUTZKE: Correct.

3 MEMBER CORRADINI: Regardless of location?

4 MR. STUTZKE: Correct. But, remember his
5 calculations are for a generic site I believe.

6 MR. BARR: The MACCS calculations were for
7 a referenced Mark I site, which was Peach Bottom. In
8 the sensitivities that we looked at that went into the
9 high level conservative estimate, there were some
10 other sites used for population, distribution and
11 economic values there. Thank you.

12 MR. STUTZKE: Yes. And the frequency site
13 is, of course, site specific. Like that. But the
14 flavor of it is, give no credit whatsoever for any
15 CPRR strategy at this point.

16 Everything goes to the worst possible
17 release category. Which is a combination of over-
18 pressurization and liner melt-through at this point in
19 time.

20 Like that. And you can see, we generated
21 into the high level conservative estimate about 7
22 times 10 to the minus 8. As compared to the safety
23 goal of 2 times 10 to the minus 6.

24 And you say --

25 MEMBER BANERJEE: That's at the worst

1 site?

2 MR. STUTZKE: That's at the worst. Of
3 what site with the highest ELAP frequency. The site
4 with the highest frequency of release.

5 MEMBER RICCARDELLA: Which is related to
6 the seismic.

7 MR. STUTZKE: Which is related to -- well,
8 a combination of seismic and the seismic response of
9 the plant.

10 MEMBER BANERJEE: But the worst site must
11 also take into account things like weather and the
12 population distribution and all these other things.
13 Right?

14 MR. STUTZKE: Yes. I don't disagree with
15 you. I mean, ideally we would have a site specific
16 set of MACCS runs.

17 MEMBER BANERJEE: Right.

18 MR. STUTZKE: For all the plants. But
19 that's not feasible to this.

20 MEMBER BANERJEE: Right. But would you --
21 how would your estimate do in your judgement
22 encompassing that sort of thing?

23 MR. STUTZKE: I mean, it's to my mind,
24 it's an overlap of the meteorological patterns and the
25 population, the demographic data.

1 MEMBER BANERJEE: Direction the wind blows
2 and all that sort of stuff.

3 MR. STUTZKE: Like that.

4 MEMBER BANERJEE: Right.

5 MR. BARR: Right, exactly. And you almost
6 have to look at the actual weather data that would
7 correspond to the different sites to know.

8 So, Peach Bottom is not the most populous
9 site, Mark I site within 10 miles. It's very high
10 within 50 miles. But not within 10.

11 However, we could look at a higher
12 population site in 10 miles and find that the wind
13 typically blows away from population centers. So,
14 just because it has a higher population doesn't
15 necessarily mean a higher response.

16 MEMBER BANERJEE: Generally, your worst
17 case is a Pascal-F weather? Or what sort of weather
18 gives you your worst case?

19 MR. BARR: Generally, either the highest
20 consequences would be when there is rain over a
21 population center.

22 MEMBER BANERJEE: Oh, rain.

23 MR. BARR: Or when there is extremely slow
24 winds.

25 MEMBER BANERJEE: Which would be F

1 probably. Right, the unknown weather conditions.

2 MR. BARR: Yes.

3 MEMBER SKILLMAN: Are the data for
4 selecting the worst meteorological site and the data
5 for selecting the worst ELAP site readily available to
6 the public?

7 MR. STUTZKE: I don't believe -- I don't
8 recall in the draft regulatory basis that we provide
9 results on a plant by plant basis. I need to check.

10 MEMBER SKILLMAN: It would seem that for
11 this argument to be convincing, a reasonable member of
12 the public should be able to find that information.
13 And include in his or her own mind that you've really
14 identified what is that worst product.

15 The greatest ELAP frequency and the site
16 that has the meteorological information that would
17 suggest that is the most vulnerable site.

18 MR. STUTZKE: Yes. So I guess the -- to
19 wrap this up, of course we'll go to Robert, is that,
20 you know, again, you can see reductions or changes in
21 risk as various -- as a function of the various CPRR
22 strategies in there.

23 The changes are small as compared to the
24 overall uncertainty in the calculation. We -- looking
25 at the available uncertainty information that we have,

1 we are well below quantitative health objectives.

2 MR. BEALL: Okay. The last slide to wrap
3 up our presentation. Currently the CPRR rulemaking
4 activities have been discontinued.

5 The staff is planning to capture the
6 excellent job that the folks in research have done to
7 support the CPRR rulemaking as a NUREG. So, we'll
8 hope to have that documented and out sometime next
9 year.

10 And the Agency will continue to proceed
11 with implementing the Order EA-13-109. That concludes
12 our presentation.

13 MEMBER SCHULTZ: Are there questions by
14 Members of the Committee before we move to the
15 industry presentation?

16 (No response)

17 MEMBER SCHULTZ: Hearing none, thank you
18 very much. Appreciate the presentation today. And
19 we'll move right to the industry presentation.

20 If you would like to stand up, now would
21 be the time to do so while we make the change.

22 CHAIRMAN STETKAR: Just Steve on your
23 microphone. Just don't hit the microphone with your
24 papers.

25 MR. KRAFT: My apologies.

1 CHAIRMAN STETKAR: And keep it turned off
2 when you're not speaking. That's the other thing.
3 For those of you who haven't been here, we've
4 instituted a new policy that when you speak, turn it
5 on. Otherwise -- it helps not only our transcript,
6 but also people on the bridge line.

7 MEMBER SCHULTZ: We're then ready for the
8 next presentation from members of the industry. And
9 I'll call upon Steven Kraft to orchestrate the next
10 presentation. Thank you, Steve.

11 MR. KRAFT: Well, thank you. Thank you,
12 Mr. Chairman. I'll make another observation since
13 you've changed the procedures for handling the
14 microphones.

15 And I think my team, if you slide them a
16 little closer to you, it might be better. I've also
17 observed, you've increased the wattage of the lights
18 overhead. I sit in this seat often enough I can tell
19 the difference.

20 And I'm not so sure if it's that heat or
21 that heat at the other end of the table. But we'll
22 determine it going forward.

23 MEMBER BROWN: You and I have a stronger
24 difficulty with that sort of temperature down there.

25 MR. KRAFT: Yes, I have to remember to

1 turn on the -- yes, okay. Thank you, Charlie. I
2 appreciate that.

3 MEMBER BROWN: To the point. It was
4 important, the levity.

5 MR. KRAFT: So, thank you again, for
6 inviting us too such a --

7 MEMBER POWERS: I've noticed also fast and
8 more cooling capability too.

9 MEMBER BROWN: That's also true.

10 MR. KRAFT: You know, if we tell jokes
11 long enough, we can get through the time and just sort
12 of call it a day, right?

13 MEMBER POWERS: I guess so.

14 MR. KRAFT: Again, thank you for the
15 opportunity to meet with you. Let me introduce my
16 colleagues. Rick Wachowiak from the Electric Power
17 Research Institute. He's the Project Manager for the
18 CPRR rulemaking analysis that EPRI did.

19 Jon Grubb, who you may not have met
20 before, is the General Vice Chairman of the BWR
21 Owners' Group. He's with us today specifically to
22 talk about operator preparedness for beyond design
23 basis events.

24 This is a question that's come up several
25 times in our discussions. So we thought we'd ask Jon

1 to come along and talk about that.

2 And to his right is Phil Amway. Who is --
3 you are familiar with, Exelon Corporation.

4 So, I only have one slide here. And that
5 is to indicate our reasons for why we think the
6 Commission decision to end the CPRR rulemaking,
7 deciding there's no additional regulatory actions
8 necessary.

9 And that is first and foremost, and
10 perhaps the main reason is it was the right decision
11 for safety. In doing so, the Commission focuses both
12 industry and NRC resources on what is truly important
13 in safety.

14 And that ought to be something that should
15 apply regardless of what topic we're talking about.
16 Along with that is that the 29 affected plants are
17 already taking actions to protect BWR Mark I and Mark
18 II containments using the industry endorsed guidance
19 and pursuant to the Order.

20 So, as was reported as stated by the Staff
21 in a previous panel, no one's planning on building a
22 Mark I or Mark II. No licenses are expected. This
23 was addressed in the Commission both records. And I
24 though talked about that quite extensively.

25 The critical regulatory principle is

1 upheld. That decision should be based on quantitative
2 evaluations. And then quoting from the SRM for SECY
3 14-0087 on back fit rule and qualitative factors.

4 Qualitative factors should only inform
5 decision making in limited cases when quantitative
6 analyses are not possible or practical. I think this
7 applied in both the decision on this rulemaking as
8 well as the decision on the mitigating strategy we're
9 making to not include CMGs in requirements.

10 In both cases, the settings were very much
11 the same. Industry is already doing these things, et
12 cetera.

13 And that last item in the staff --
14 consistent with the staff's recommendation, CPRR
15 rulemaking, quantitative recommendation analysis fully
16 supported, taking no action requiring external
17 containment on filters where the staff recommended.
18 So that I thought was another reason why this made
19 some sense.

20 Before I turn to Rick to carry the
21 technical discussion, let's just go back for a moment
22 to the questions you were asking the staff about what
23 happens when the Order is issued. And what you can
24 do.

25 So, I think as I followed the

1 conversation, I think you finally got to the point of
2 agreeing or that upon issuing the Order, it becomes
3 part of the license. And this has to be done in
4 accordance with whatever guidance is approved, et
5 cetera.

6 But the question that came up that I
7 thought was asked one other time as well, was go out
8 seven years. And for some reason that I have a hard
9 time understanding why it would be true, but let's
10 accept it as such, a licensee decides they don't like
11 the system anymore. Or the cut the pipe flange it off
12 and come up with something else to do.

13 And how does that get noticed by the
14 Commission? It is true the Order itself has no
15 inspection requirements in it. That would be
16 something a rule would do.

17 Because the Order is part of the license,
18 it is inspectible by definition. Then what happens is
19 that as noted in Chairman Burns' vote record, the only
20 guidance approved available is the NEI 13-02 requires
21 everything that we, you know, have in that, in that
22 Order in a guidance to apply to the Order.

23 And if a licensee chooses or a licensee
24 chooses option two under the Order, which is the --
25 somehow a drywell vent that would somehow work. I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 don't know how without water addition, but it does.
2 They have come to back to the staff and explain how
3 the Order is met.

4 And that is the key right there. You
5 don't get out of that. You have to come back to the
6 staff. And I will tell you that we've had workshops
7 and meetings with the industry where we have talked
8 about this.

9 That if you are going to get so clever as
10 to say I can design that drywell vent. I can find
11 that valve disc material that will work.

12 Well, first of all, there's no guidance
13 that we are providing that allow that to happen.
14 That is made very clear in our guidance. You are
15 forced back to the Commission staff. And they will
16 ask you the same questions.

17 So, there's no way really out of it. And
18 I'm pleased to say as we reported to the Subcommittee
19 back in mid-August, that the BWORG did a survey of its
20 membership. All 29 affected units are going to be
21 water additioned. They also are going to do water
22 management and avoiding the severe action drywell
23 vent.

24 And as I -- we also reported, we are
25 conducting what we are calling a Consistency Assist

1 Program. We've been through several meetings. Phil
2 was one of the leaders of that effort to assure that
3 the 29 licensees are complying with the guidance as it
4 is written.

5 Granted, it was not done the same way at
6 every site. But that is -- we've never done that
7 before. I think that is an important step we are
8 taking here to assure that we actually close off any
9 possibility of, you know, not quite meeting it.

10 VICE CHAIR BLEY: Steve, can you tell us
11 a little more about that? How that works?

12 MR. KRAFT: Yes. Sure, Dennis. We of
13 course divided the country into regions and fleets
14 with BWRs. Each fleet, Phil representing Exelon was
15 the first one, were given a set of questions as to how
16 are you from a design philosophy point of view going
17 to meet the order? It was all done in spreadsheets.

18 And then we had a group of people of
19 people from the BWORG Fukushima Committee. I was the
20 loan NEI representative of course. And then we went
21 through how did you do that? How are you meeting
22 that?

23 And it was interesting to, you know,
24 someone says hey, we're doing it this way. And
25 another says oh, that's a great idea. So, we're

1 actually seeing some knowledge transfer going on.

2 And we're having another meeting, is it
3 the end of the month in Minneapolis, right? To finish
4 that out. Phil, do you want to talk about that?

5 MR. AMWAY: Yes. There's one at the end
6 of this month. And we're going this in two phases.
7 Every site now, with the exception of maybe a few that
8 are later on, have gone through and at least done a
9 preliminary look at their plant with the guidance.

10 And said, this is how we would do
11 SAWA/SAWM. So, that's kind of a high level, even
12 preconceptual design phase where we scope out what it
13 would take to implement SAWA/SAWM.

14 We'll do another phase later on in
15 November before we submit the Phase II OIP. Where
16 we'll go back and say okay, on such and such a date,
17 you presented your scoping evaluation as this.

18 How does that translate to the OIP that
19 will be submitted at the end of December? So can look
20 and make sure that was consistently done throughout
21 the initial scoping evaluation to the OIP, which
22 actually gets submitted.

23 MR. KRAFT: And just one additional step.
24 You have to -- we actually have a workshop next week,
25 a combined NEI and Owners' Group workshop where we are

1 going to walk through the template for the OIP.

2 So, there will be specific training as to
3 how you fill out this part. And what analysis is
4 required. What designs are required.

5 So, we're doing a lot to ensure that this
6 is -- we know this is complicated. And we're doing a
7 lot to ensure that it's done correctly.

8 VICE CHAIR BLEY: Does INPO have a role in
9 this process?

10 MR. KRAFT: Not yet. But they are -- you
11 probably know more about it than I do. And that IER
12 that they --

13 MR. AMWAY: Yes. I'm not sure that the
14 IER goes to that extent. But, what we did was, as
15 part of this process, we did the two pilot plants.

16 We had a Mark I pilot that went through
17 and took their initial scoping. Filled out the OIP
18 template with what their plan is for implementing
19 Phase II.

20 We did the same thing with a Mark II. And
21 then now that can go out as to the other sites as an
22 example of okay, we have the template. Here's an
23 example of one filled out for a Mark I. Here's an
24 example of one filled out for a Mark II.

25 That's how we did with the Phase I. It

1 worked very well in terms of making sure we had a
2 level of consistency. And now even with these
3 additional design consistency reviews that we're doing
4 for Phase II, will even bring that more into focus and
5 make sure that we're consistent in Phase II.

6 MR. KRAFT: Right. So specific to INPO
7 though. I think where INPO might get involved in
8 operator training and things like that after this will
9 implement.

10 I know that they have their own set of --
11 they don't call them orders obviously, but IERs, that,
12 you know, talk to requirements that they would look
13 for. That of course go beyond NRC regulatory
14 requirements into an area, you know, of excellence.

15 So, I think there's going to be some
16 actions taken there. But I don't think that's been
17 figured out quite yet for this.

18 VICE CHAIR BLEY: Now, is somebody going
19 to talk about how this rolls into training and -- so
20 I'll wait for that.

21 MR. KRAFT: Yes. Okay, Rick. You're up.

22 MR. WACHOWIAK: Okay. Good afternoon.
23 Rick Wachowiak from EPRI.

24 And we performed an independent analysis
25 of different strategies that could be used to reduce

1 the probability of containment failure. And to reduce
2 the release of radioactive materials into the
3 environment for an ELAP condition.

4 What we are trying to do here, is
5 establish the basis for any type of changes that could
6 be done to a plant in order to achieve the goals for
7 the CPRR rulemaking. And the way that we did this was
8 very similar to what Marty talked about.

9 We performed a focused Level III PRA for
10 a representative plant. And with an ELAP condition
11 initiated by various things. Losses of offsite power,
12 loss of the grid, seismic events that sort of thing.

13 And in our ideas for doing this to begin
14 with, we decided that it would be good to look at how
15 each end state progressed through to the release.

16 Because what we found in our original
17 report that we did back in 2012, that the results in
18 terms of the release were dependent on -- highly
19 dependent on the boundary conditions caused by the
20 scenario that you are in. The timing, the failure
21 mode, the condition of the components in the
22 containment.

23 So, we took the route of going through a
24 focused PRA so that we could assess all of the
25 scenarios. And we could identify the dominant

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 scenarios. And we could look at how the accident
2 progressed through each of those.

3 It's been the industry's contention all
4 along that severe accident management guidelines
5 played a great -- will play a great role in the
6 reduction of releases. And in the management of the
7 accident.

8 And that the operator actions that need to
9 take place are really a shaping factor in all of this.
10 So, our analysis included the -- included operator
11 actions.

12 Now, before we get into how we quantified
13 those or anything like that, we focused on the
14 dependence between actions. Things that would happen
15 early in the scenario and how that would affect the
16 outcome later in the scenario.

17 So, we focused more on the dependence
18 between actions and used the methodologies, SPAR-H
19 methodology that's been used in other PRAs to
20 calculate the numbers.

21 We did sensitivities and found that the
22 individual values that we assigned to the operator
23 actions were really insensitive for the result. But
24 the dependencies between the actions were where the
25 important pieces were.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 If the operators failed to do something
2 early, that affected their ability to be able to do
3 something later. If they didn't have certain pieces
4 of equipment, it affected their ability to respond to
5 events that come later.

6 So we found -- that's the one part that --
7 one of the parts that we focused on was getting the
8 dependence right.

9 MEMBER CORRADINI: So, just to ask --

10 MR. WACHOWIAK: Go ahead.

11 MEMBER CORRADINI: John's question of you
12 guys in a similar fashion, so you not only looked at
13 equipment failures, but if they didn't get an
14 operation done in a time window that was considered a
15 failure. But they could recover from that because
16 they had more time to maybe implement it later in
17 time? Does that make sense?

18 MR. WACHOWIAK: Yes. If we were
19 addressing a different phenomena. So, if they were
20 unable to get a portable pump installed in time to
21 prevent core damage, we gave them credit for being
22 able to get that water on the floor. Some credit for
23 being able to get that water on the floor to cool the
24 debris later on.

25 And we essentially took the same approach

1 that Marty did. That if the RCIC failure was early
2 that we didn't give them any credit.

3 However, we went through and looked and
4 took some of these plant surveys that Steve talked
5 about. But they were done for identifying plant
6 differences.

7 And saw that there was some margin there.
8 Most of the plants could actually install their
9 portable equipment faster then the required time.

10 And so we think if we were to go and do a
11 further study on this, you'd see that there's some
12 more margin. You could get some credit for getting
13 things installed a little sooner if the installed
14 equipment wasn't there in some scenarios.

15 CHAIRMAN STETKAR: You said you took
16 surveys of plants. And you said most could install
17 the equipment faster then their omitted time.

18 MR. WACHOWIAK: Said that they could.

19 CHAIRMAN STETKAR: Said that under the
20 worst earthquake that anybody's ever seen?

21 MR. WACHOWIAK: No. We didn't go into
22 that.

23 CHAIRMAN STETKAR: Because that's the
24 presumption on these analysis.

25 MR. WACHOWIAK: Yes, we didn't go into

1 that sort of detail. However, you have to remember
2 that this is supposed to be a mean analysis. And in
3 some cases they probably could. And in other cases
4 they probably couldn't.

5 So, for example, if we got into a -- it's
6 almost irrelevant with this because we didn't use it
7 in the analysis. We used it as a sensitivity to see
8 how close we were.

9 Because everybody with their licensee
10 committed times right on the bubble of where the
11 accident would go. It's now there is some margin to
12 that. If we use the committed times, then missing it
13 by a few minutes doesn't help the ability analysis.

14 CHAIRMAN STETKAR: Can those committed
15 times theoretically account for beyond design basis
16 seismic events?

17 MR. WACHOWIAK: I believe it does. It's
18 in the FLEX arena.

19 CHAIRMAN STETKAR: Right.

20 MR. WACHOWIAK: So --

21 CHAIRMAN STETKAR: Well, but we're talking
22 about the same people and equipment.

23 MR. WACHOWIAK: Same people, same
24 equipment. I --

25 MR. KRAFT: The way I understand, INPO did

1 some checking how industry was implementing FLEX. And
2 the results of that were that for example, under the
3 guidance 12-06, or for FLEX, you have to be able to
4 deploy within six hours.

5 And so go give you the most margin, you
6 then say you look at your -- you analyze your
7 deployment time. You say well, okay, it's two hours.
8 So you back up and say four hours after certain, we'll
9 start to deploy. When in fact we know they'll start
10 to deploy as soon as they can.

11 So, there's that margin that's inherently
12 built into these surveys. Although as Rick points
13 out, it's not the same at every plant. Not everyone
14 has the same particular margin.

15 MR. WACHOWIAK: Okay. And as I was going
16 into this, the accident management really involves
17 several things. Cooling the debris, managing the
18 decay heat, making sure that the consignment isn't
19 challenged.

20 And then if you are going to have a
21 release, to do the actions that you can to shape the
22 release. So that it's as small as you can make it.

23 So, our objectives in the evaluation.
24 First, we wanted to do a -- to look at a comprehensive
25 set of the scenarios in a probabilistic framework.

1 Thus, getting to the focus Level III PRA.

2 As an offshoot of this, we're -- also,
3 we're looking into what role FLEX plays in ELAP
4 mitigation in the risk arena. And we started that off
5 with this analysis.

6 And now there are other groups that are
7 analyzing using the benefits of FLEX possibly in other
8 risk informed initiatives. Most of it's voluntary
9 internal plant stuff right now. That's the stage that
10 we're at with this.

11 We also have a group at EPRI that's
12 looking into how do you really quantify the operator
13 actions. Or they're not really operator actions at
14 that point. It's more institutional actions that are
15 going on at the plant.

16 And we have another project that's looking
17 at how you would go about calculating those.

18 MEMBER SCHULTZ: Rick, it sounds
19 interesting. Could you have an example of some of
20 these strategies that are being discussed?

21 MR. WACHOWIAK: Other strategies that are
22 being --

23 MEMBER SCHULTZ: Well, what you've
24 described here is that there's other work going on, on
25 other projects. And we're looking for other

1 opportunities to use the FLEX equipment. Can you give
2 an example that would help us understand what's being
3 discussed?

4 MR. WACHOWIAK: Well, some of it is
5 dealing with how do you -- how would you in a
6 defensible way, put FLEX into your plant PRA?

7 So let's say a -- some sort of a
8 significance determination comes up. How would you
9 factor that in? What types of information would you
10 need? What is the role of the equipment? Role of the
11 operators in being able to defend that SDP?

12 That would be one case. Another is that
13 maybe there's some things associated with a risk
14 informed application. Is it right to put the FLEX
15 equipment in there?

16 Or is it better to not have it in that
17 particular application because of the other things
18 that creep in around it. Like maintenance rule and
19 other things like that.

20 So, really, we're looking at scoping. How
21 does the industry want to use and how should they use
22 the FLEX equipment in their probabilistic framework?

23 MR. KRAFT: There was a -- this is a
24 nascent, where the work is being run out of the risk
25 department for EPRI. And NEI has a part in it.

1 But I believe you actually saw part of it
2 at Palo Verde when we were behind Unit II. One of the
3 FLEX pumps was positioned and strapped down. It
4 wasn't hooked up.

5 And they were using that during I believe
6 an outage, if I remember the story correctly. And it
7 put them in a lower risk category during that outage
8 at the time.

9 It's a way of getting more use out of the
10 same equipment. That's the most obvious part of it
11 that would be helpful. There are others that are
12 being explored.

13 But again, you have to be careful. For
14 example, one plant's spent fuel pool implementation,
15 which isn't part of the FLEX order, but the same
16 concept, has decided to make that new wide range
17 instrumentation their normal instrumentation.

18 Well, the moment we heard that, we told
19 them, you better start looking at cyber security,
20 designation of critical digital assets, maintenance
21 role. You have to look at that stuff and either
22 analyze yourself into it or out of it, however it is.

23 But once you go beyond the use as
24 intended, credited use under the intention of the
25 order, which is the ELAP conditions, you then find

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 yourself in this other space you have to pay attention
2 to. So it becomes a corporate decision at the end.

3 MR. WACHOWIAK: So, another thing that we
4 wanted to do in the analysis was understand the
5 dominant severe accident scenarios. What are the
6 things that are getting us to the point of having some
7 sort of a release? And focus our strategies on the
8 scenarios that are really driving the risk.

9 That was one of the things that was in the
10 original SRM that started this whole thing off. To
11 focus on the dominant scenarios. And we took a look
12 at that.

13 We also found that some of the scenarios
14 that we evaluated in the previous paper from 2012,
15 didn't really turn out to be the dominant scenarios.
16 That other things were dominating the risk. And it
17 was an interesting insight from this.

18 We want to look at ways to look at -- I'm
19 sorry. We want to make sure that the way that we
20 present our filtering strategies that that is clear,
21 understandable, and people can, when they look at the
22 analysis, they can tell how the thing's proceeded from
23 the beginning to the end.

24 We are publishing this in two steps. The
25 first step is our report that's out right now. It

1 describes what the purpose of the report -- or purpose
2 of the analysis is. What the results are.

3 But the details in how we actually did all
4 the different analysis and what the nitty gritty on
5 all the event trees and all that, they're in a
6 subsequent report that's going to be published later
7 this year.

8 And John's probably the only one who is
9 going to be interested in looking at that. It's going
10 to be several thousand pages of event trees and things
11 like that.

12 CHAIRMAN STETKAR: Bring it on.

13 (Laughter)

14 MEMBER POWERS: Rick? Quit trying to suck
15 up to the Chairman.

16 (Laughter)

17 VICE CHAIR BLEY: When you started digging
18 into the dominant scenarios, did you have fully --
19 full scope PRAs with fire -- good fire PRA and seismic
20 and other externals?

21 MR. WACHOWIAK: Yes. We included seismic
22 explicitly in this. We did not do the details of a
23 fire PRA in this.

24 Now, there was some reasons for that.
25 One, with a hypothetical plant, it's really impossible

1 to get all of the different dependencies that might
2 show up with spurious actions. Things like that.

3 So it wasn't really feasible to do that
4 piece. And in looking at the contributors to ELAP,
5 we're not sure that fire is going to be a -- is going
6 to be a large contributor to ELAP itself.

7 Now, there might be some things with
8 diesel generators and stuff like that. But, once
9 again, we -- we're just not sure that that gets us to
10 the ELAP.

11 The loss of offsite power, yes. But I'm
12 not sure that it's going to be dominant for ELAP.

13 The other interesting thing that we found
14 with the seismic portion though, is that everything,
15 if we alter the seismic contribution to the ELAP, it
16 kind of just shifts all our numbers all together.

17 It doesn't change any of the deltas that
18 we look at. It's just if you have a greater seismic
19 cap -- or seismic hazard, then everything shifts up.
20 And the deltas between the strategies shift up.

21 If it's lower, everything shifts out.
22 Because the seismic tends to cause the things that
23 just can't be dealt with by any of the strategies
24 anyway. Too much of the infrastructure gets damaged.
25 And most of the things go down the damage branch.

1 It was an interesting study.

2 VICE CHAIR BLEY: All right. Well, one
3 wonders if that's because of the way your -- this
4 plant, imagined plant is set up. Or if it's, you
5 know, is it part of the analysis process or is it
6 real?

7 MR. WACHOWIAK: That's a good question.

8 VICE CHAIR BLEY: And if somebody were
9 looking at their own full scope plant specific PRAs,
10 we might get a better feel for that.

11 MR. WACHOWIAK: Yes, you'd find some
12 different things. Especially from the fragility.
13 Because we picked a particular fragility for the DC
14 system based on one of the configuration that's out
15 there that's not really amenable to staying together
16 in a seismic event.

17 So, yes, that's part of a bounding piece
18 of this. But, once again, you'd have to go through
19 all the differences.

20 Marty took a shot at that. And I think he
21 came to about the same conclusion. That the delta
22 results all follow along in the seismic area.

23 We wanted to inform the implementation of
24 13-109 to the extent possible. And we used some of
25 the results from this to identify how water addition

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 is beneficial to the plant. Should be included in 13-
2 109.

3 And how it affects the temperature and
4 other boundary conditions inside the containment.
5 Making the equipment being installed for 13-109 in the
6 reasonable range rather than the super range that was
7 talked about earlier here.

8 Providing insights to the Owners' Group on
9 the EPG/SAGs, we'll hear a little bit more about that
10 later. But there's a couple of things that have been
11 approved by the Committee that have come out of this
12 work on how to implement SAWA and SAWM in the EPG/SAGs
13 that follow along with what we did.

14 We set this analysis up so that a cost
15 benefit could be done later as a follow on. That
16 never actually got to a point where it was needed. So
17 the industry did not do any cost benefit analysis.

18 So, here's our chart that looks somewhat
19 similar to what Marty had presented. I have only mean
20 values on here.

21 We didn't do a comprehensive uncertainty
22 analysis. But we did do sensitivity studies or
23 sensitivity analyses to see which types of things
24 could affect the outcome of the means.

25 Our pink bars are basically a vent is

1 available, but there's no SAWA. The green bars are
2 things where SAWA is there, but it's injected via the
3 RPV. So it goes into the RPV, through the hole where
4 the core debris came out and into containment.

5 Blue is directly injecting into the
6 consignment. And the hatched areas are the ones where
7 we looked at what we might be able to get further with
8 some sort of hypothetical engineered filter.

9 Our results are a little less scattered
10 then what Marty's were. It may be because ours is on
11 a log scale and his was on a linear scale. But, it in
12 general were the same sort of results.

13 And we superimposed a -- what looks like
14 it was a preliminary version of his 5th and 95th on
15 there. I noticed that from his higher scenarios, the
16 upper black X was about 70 minus 9. And so we didn't
17 try to match one to one.

18 I think his lower 95th was somewhere in
19 the 1 to 2 times 10 to the minus 10. So, it must have
20 been 3 times 10 to the minus 10 a few months ago when
21 we published our report.

22 So, in here, we can see that we're well
23 away from the QHO on this particular risk metric. Our
24 results are right in the middle of where the NRC got
25 their results.

1 They used a similar type of analysis. And
2 we expected this to be the same. We've done
3 sensitivities where we show how much these move around
4 based on different operator actions. Or different
5 frequencies for ELAP. And different seismic
6 fragilities. Different things like that.

7 And things move around a little bit. But
8 they don't really change all that much. I mean, we're
9 still talking about 2 times 10 to the minus 9 here.
10 So, it's not changing very much in an absolute scale.

11 MEMBER SCHULTZ: Rick, could you describe
12 why your results in the cases for engineered filters
13 don't show a differential between the different
14 approaches that are used with regard to the
15 engineering filter design?

16 MR. WACHOWIAK: Because this particular
17 risk metric is driven by the scenarios where the
18 filter isn't effective. So, if I were to split one of
19 these bars, let's say the green -- one of the green
20 ones was there.

21 How much of this risk is associated with
22 an unfiltered release because it bypasses the filter.
23 Versus how much of it is in -- risk is in the filtered
24 release.

25 What you'd see is a very small sliver in

1 the filtered release part. And the risk itself is
2 driven by the scenarios that have un -- that are
3 unfiltered. Even though the filter is present.

4 MEMBER SCHULTZ: So again, it's a
5 combination of scenarios similar to what the staff
6 presented.

7 MR. WACHOWIAK: Yes.

8 MEMBER SCHULTZ: Thank you.

9 CHAIRMAN STETKAR: But despite that, the
10 staff did ostensibly the same thing. And they were
11 showing roughly a factor of 2ish.

12 MR. WACHOWIAK: Yes. There's a reason --

13 CHAIRMAN STETKAR: It's thought to be
14 discernable.

15 MR. WACHOWIAK: There's a little bit of a
16 reason for that I think in that the difference between
17 the ability to do a MAAP case for a scenario versus a
18 MELCOR case for a scenario. I think they had
19 approximately 20, 30 some odd MELCOR cases that they
20 bend into their different results.

21 We did an explicit MAAP calculation for
22 every single one of our results. And so, some of the
23 way that the venting was, you could get more credit
24 for a filter or less credit for a filter depending on
25 which scenario you pick.

1 And so I think some of those variabilities
2 probably had a little bit more to do with venting
3 them. The other thing is that MELCOR in these
4 calculations does tend to in some of the scenarios
5 that turn out to be a little more important, not the
6 dominant ones.

7 But the ones that are a little bit more
8 important get to a point where the filter works for a
9 while. But then the vessel fails. And the liner
10 melts later. And so they're getting a little bit more
11 performance out of a filter than our MAAP cases did
12 because of the timing of the containment failure.

13 So, a little bit of differences on the
14 consequence analysis. But as you saw with the ranges
15 on there, I, you know, the differences are within the
16 uncertainty of doing any of these calculations.

17 But I think that's -- those are the chief
18 reasons why you saw a little bit of movement on the
19 NRC cases. And not as much movement on ours.

20 MEMBER POWERS: Excuse me, Rick. I
21 presume these are again averages of all the plants?
22 And do you have any comments on that?

23 MR. WACHOWIAK: Yes. We didn't do a fleet
24 average like Marty did. We picked a representative
25 plant.

1 MEMBER POWERS: Okay.

2 MR. WACHOWIAK: So this is for a
3 representative plant. Now we looked at some features
4 that other plants had that we thought might affect
5 what the analysis would do.

6 And we compared the representative plant
7 to the -- for the -- to information that was received
8 from other plants. You know, how do you do these
9 things?

10 MEMBER POWERS: Um-hum.

11 MR. WACHOWIAK: What are the -- you know,
12 what are your seismic characteristics? Things like
13 that. And then we did sensitivity studies in our
14 report to identify whether or not those idiosyncrasies
15 from the different plants would make a difference to
16 the conclusions that we're reaching.

17 And we decided that it's all -- it
18 wouldn't make any difference in the conclusion that
19 you draw. That there is very little difference
20 between anything except adding water.

21 Adding water is really the only thing that
22 we see where it makes a marked change to the outcome
23 of the risk.

24 MEMBER POWERS: Thank you.

25 MR. WACHOWIAK: And so yes, we did it for

1 sensitivity and not through an uncertainty sort of
2 analysis.

3 Okay. What did we see in this study? The
4 role of the operator is essential for this. As you
5 can see on the fourth bullet down there, explored
6 adding something that was maybe totally passive. That
7 didn't involve the operators.

8 What we found is that water addition was
9 always going to require operators. There really isn't
10 a passive way to retrofit that onto an existing plant
11 right now.

12 And when we tried to put in a passive
13 vent, the designs that we came up with for a totally
14 passive vent, had the unfortunate response that it
15 increased the core damage frequency. And so even
16 though it did some things to reduce the releases, we
17 had an increase in core damage frequency.

18 The reason why it increased the core
19 damage frequency is it took away the -- one of the
20 FLEX options for extending RCIC operation by venting
21 the containment.

22 So, yes, you can do it. It change -- I
23 think we'd rather keep the core from melting rather
24 than having the incremental capability on the release.

25 And then that was even in one of these

1 other bars here though. I don't remember which
2 exactly one it is, passive filter down here.

3 When we get to the consequence analysis,
4 the core damage frequency increase is offset by a
5 little bit more filtration. And the risk comes out to
6 be the same anyway.

7 So, still, we thought it was better if we
8 preserved that.

9 MEMBER SKILLMAN: Rick, perhaps it's
10 simply assumed in bullet one. But it seems to me that
11 an additional insight would be if the essential -- if
12 the role of the operators is as essential as you
13 indicate, that training has a yet more important role
14 then it might have had before.

15 MR. WACHOWIAK: I think John's going to
16 address the training on the severe accident
17 guidelines.

18 MEMBER SKILLMAN: Okay. Thank you.

19 MR. WACHOWIAK: Oh, let's see. The
20 importance of water addition was identified here. I
21 think we've said that at every meeting.

22 It is something that can show a difference
23 between, in the risk from what we have without the
24 water addition. But remember, water addition has
25 always been part of the severe accident strategies at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the BWR.

2 It's always been there. What we did hear
3 though, is say, let's look at the scenarios you might
4 be in when you need the water addition. And let's
5 make sure that the water addition is available in the
6 dominant scenarios.

7 In the scenarios that you might get a
8 chance to use it. So, it wasn't really identifying,
9 oh, yes, you need water. We always knew you needed
10 water.

11 This helps us identify what are the
12 conditions going to be when you need the water. And
13 if it will inform the plants on how they're going to
14 implement the water.

15 As I said, we did try to confirm that our
16 analysis was robust by doing various sensitivity
17 studies not only on phenomena that might happen in the
18 -- during the course of the scenario. But also, at
19 some different configurations that some plants might
20 have.

21 And tried to convince ourselves -- we did
22 convince ourselves that there wasn't really something
23 lurking around the corner that was going to change the
24 results by -- an awful lot from what we have here.

25 MEMBER SCHULTZ: Rick, I understand your

1 comments about we always knew that water was
2 important. And that the operators in any response
3 would be trained to add water, add water, add water.
4 That happened after TMI for sure.

5 But my question is, it did seem that when
6 we first started looking at severe accident capable
7 venting through the drywell that it was a revelation.
8 That in fact the drywell vents were not going to be
9 able to perform their function given the temperatures
10 that were being calculated for the severe accident.

11 MR. WACHOWIAK: Yes. That's what I mean
12 by identifying what are the scenarios? What are the
13 actual conditions going to be.

14 Like I said, I mean, who we had with that
15 water --

16 MEMBER SCHULTZ: Okay. Okay. I was just
17 wondering if it would be specifically related to what
18 we found with the drywell vent. Because that was
19 significant.

20 MR. KRAFT: Yes. There was a -- more of
21 a moment in our consideration of all this where, as I
22 said before, the ability to add water is the essence
23 of all our safety systems.

24 So that's nothing new. And under this
25 Order, it's to add water -- well, it's to be able to

1 vent containment with the power out, let's just say
2 that.

3 Reliably, you know, the word reliable
4 drives a lot of the Order. But, when we finally
5 finished up the wetwell vent and the industry was
6 launched on doing those plans, we began turning our
7 attention to the drywell vent.

8 And by that time Rick had enough analysis
9 done that we were starting to see the temperature
10 profiles in containment, it occurred to us that the
11 original thought when we started writing, you know,
12 industry started writing the Order, was we knew water
13 addition was going to come along.

14 The question was, where in the sequence of
15 the development of the requirements was it going to
16 come along? And it occurred to us that water addition
17 as part of the Order actually made much more sense
18 then waiting.

19 And then of course the water addition
20 then, you know, also has the filtering effect that
21 research was showing. So, we came to NRC senior
22 levels saying, you know, we need to modify our
23 guidance.

24 And there was a brush up on that. I wrote
25 a letter that got, you know, a good response.

1 So, the point being, is that you're right.
2 There came a time where we said, you know, we learned
3 from this. Let's do this the right way.

4 And then everything is beginning to fall
5 out the way they have.

6 MR. WACHOWIAK: And one of the interesting
7 things at least to me, about this was, when we started
8 looking at ways to get the information from our
9 analysis off of our super computer, is we used our
10 super computer to analyze all of the scenarios
11 individually with the MAAP and MACCS run.

12 It generates a lot of data. And we have
13 to find ways to get it off the computer and be able to
14 look at it.

15 And this temperature thing with SAWA
16 didn't come out really until we'd developed one of
17 those ways. We took a slice of things and oh heck,
18 when water works, the temperatures are always down.

19 When water doesn't work, the temperatures
20 are always up. So, if you add SAWA to the vent, the
21 temperatures for the design come out very nice.

22 And so, I've covered all these things. But
23 I just want to say, the water addition provides the
24 best -- overall best safety benefit. But once again,
25 everything is in the very, very low range of risk.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And so, it does provide benefit. It's the
2 right thing to do. And what we're -- we were already
3 doing it. What we want to make sure we understand is,
4 is it going to be there when we need it.

5 And this helps inform us what types of
6 design considerations, access considerations, do we
7 need to do to make sure that we implement these things
8 that were in the SAMGs.

9 Our other conclusion is that we couldn't
10 come up with any way to do this without operators.
11 So, just like the questions that keep coming up, where
12 does this fall? And a lot of it falls into the SAMG
13 development.

14 And other alternatives that we looked at,
15 we found things that in some scenarios would reduce
16 the releases. But when we put them in the overall
17 context of the whole probabilistic framework, when we
18 looked at all the scenarios, it just didn't affect
19 enough of the dominant scenarios to make much
20 difference.

21 That's it for me. I'll let you figure out
22 how to get the next slide.

23 MR. GRUBB: All right. Good afternoon.
24 I'm John Grubb from Xcel Energy.

25 In my day job, I'm the General Manager of

1 Fleet Operations for our Fukushima Response at both
2 our Monticello and Prairie Island plants. So that's
3 implementation of all of the Fukushima related Orders
4 for our two sites.

5 I'm also, as Steve mentioned, I'm the Vice
6 Chair of the BWR Owners' Group general committee. And
7 I'm going to talk about what we've done to try to
8 prepare our operating crews for beyond design basis
9 events.

10 First off, information on the BWR Owners'
11 Group. It's a forum for our member utilities to
12 improve plant safety primarily.

13 We also look at improving reliability of
14 the plants, minimizing and sharing costs, and also
15 very important, to facilitate regulatory interaction
16 with both INPO, the NRC, NEI, EPRI, all the key
17 stakeholders.

18 All U.S. Boiling Water Reactors, all of
19 those utilities are members. This BWR Owners' Group
20 is open to all international BWRs. Currently we have
21 12 international BWRs that are participating in the
22 Owners' Group.

23 MEMBER SCHULTZ: Is that by utility? Or

24 --

25 MR. GRUBB: By utility.

1 MEMBER SCHULTZ: Okay. Thank you.

2 MR. GRUBB: And I have the list if you
3 want to see it later.

4 Within the BWR Owners' Group, we did form
5 -- our initial committee was an ad hoc committee
6 formed in late 2011 that became a general committee
7 that all members participate in.

8 And ad hoc is just a quicker way to get
9 moving on the process. So we did that initially.

10 That was first formed in late 2011. That
11 Fukushima Response Committee then worked with the
12 existing Emergency Procedures Committee, which I'll
13 talk about on the next slide, and with EPRI to develop
14 the criteria for the FLEX support guidelines.

15 It's important to note that the
16 procedures, these FSGs that we have developed at each
17 site, do work in conjunction with the EOPs and SAMGs
18 that were already in place.

19 So this was not something sitting off on
20 a shelf that the operator's got to think of at the
21 time of this unusual event. They're integrated into
22 the existing EOPs and SAMGs.

23 Also, that each plant used this generic
24 set of criteria that we developed as an Owners' Group.
25 And developed plant specific FLEX support procedures

1 for beyond design basis events.

2 We will use -- we are using the exact same
3 process for the 13-109 Order. The vent Order
4 requirements for both Phase I and Phase II. So, the
5 industry -- you know, the Fukushima Committee and the
6 Emergency Procedures Committee are putting together
7 the criteria that the individual sites will then use
8 to meet the requirements of the Order.

9 All right. Emergency Procedures
10 Committee. We've had this in place for a number of
11 years. This is ac -- that Committee has experts from
12 each one of the U.S. utilities as well as several
13 international BWRs.

14 The focus of this Committee is improving
15 plant operations and safety. And then we are taking
16 into consideration the events at Fukushima.

17 And out of that we have been able to
18 already make changes to the emergency procedures, the
19 severe accident management guidelines. And we are
20 implementing those into the FLEX support guidelines as
21 well.

22 So, that Committee is very active. I
23 think we have -- at this point, we have five
24 subcommittees of the Emergency Procedures Committee,
25 looking at the different aspects of the Fukushima

1 lessons learned.

2 It's important to talk about the BWR
3 Owners' Group does work quite a bit internationally to
4 make sure not only are we sharing with our
5 international partners the lessons we've learned
6 through our implementation of the FLEX and the Orders
7 here.

8 But, also they're sharing with us what
9 they're leaning. Because a lot of the internationals
10 are taking a slightly different approach then we've
11 taken in the United States to the Fukushima response.

12 So, we have tech support guideline skill
13 set workshops where we go to -- we do them both
14 domestically and internationally. Where we get
15 together with the BWR partners and talk about the
16 lessons learned.

17 We also do the severe accident workshops.
18 And both of these have case studies where we will walk
19 through the events and the sequence of damage
20 accidents.

21 And talk about why we made choices within
22 the United States on the FLEX criteria that we put in
23 place. And listen to the internationals tell us why
24 they might have gone a different route.

25

1 This Committee also advised the Owners'
2 Group and individual member utilities on issues
3 related to the emergency procedures. It's not at all
4 unusual for an individual plant who is in the process
5 of making a change to their emergency procedures, to
6 contact a chair of this committee and say hey, let us
7 run something by you. Could you talk to the committee
8 about this? Does this make sense, the road we're
9 heading down?

10 This committee also, it's really -- keeps
11 the history of the emergency procedures. So, it
12 maintains the guidelines. All the appendices. All of
13 the issue files, conference reports.

14 So we can see from when we first put this
15 committee together, the series of decisions that were
16 made to the existing emergency procedures that we have
17 in place at this point.

18 This is kind of a pictorial pre-Fukushima.
19 On the left there is the procedure hierarchy we had at
20 the BWRs, starting with design basis external events.
21 Station lack of coping capabilities. And the super
22 accident management guidelines working in conjunction
23 with the emergency plans.

24 When you think about the procedures that
25 we put in place for FLEX and will be similar for the

1 severe accident -- or the vent Order, it's really just
2 an increase in defense-in-depth procedurally and
3 training wise. Because we're preparing the operators
4 for something that wasn't really part of their
5 training prior to this.

6 We're giving them a set of tools that they
7 can use to diagnose and manage the plant for this
8 different set of events that we're looking at for both
9 FLEX and for the vent Order.

10 All right. Again, I mentioned that each
11 plant used the generic criteria to develop a set of
12 specific FLEX procedures for response to beyond design
13 basis events. We're going through the same process
14 for the vent Order right now.

15 The procedure guidelines and the criteria
16 are being established by the Fukushima Response
17 Committee working with our Emergency Procedures
18 Committee.

19 At each one of the plants, and once
20 they've developed their -- their onsite Fukushima team
21 develops their specific criteria strategies and
22 procedures for responding to the beyond design basis
23 events that gets put right into the operator training
24 program.

25 So they've got a -- there's a validation

1 process they go through. All the crews have to go
2 through and perform these procedures in their
3 training.

4 And all of this was required for FLEX
5 prior to the plant declaring that they had met the
6 requirements of the FLEX Order.

7 The FLEX and beyond design basis screening
8 has been added to the operator training program. So
9 it will be revisited at a frequency and depth as far
10 as how much they cover it based on their existing
11 training program.

12 It becomes a little bit of a balancing act
13 because you don't want to take too much training time
14 away from the normal training you do to run a complex
15 nuclear power plant. But you also don't want to
16 ignore it.

17 So the individual sites are making that
18 determination based -- depending on where they are on
19 their training program.

20 MEMBER CORRADINI: What is the purpose of
21 that? You said, what is the frequency?

22 MR. GRUBB: The frequencies are defined by
23 the individual stations. So the Owners' Group --

24 MEMBER CORRADINI: So it's a wide range?
25 It could range depending on the plant staff?

1 MR. GRUBB: Correct. Another thing I
2 wanted to make sure and mention on this slide, is the
3 training wasn't just for operations. So, the FLEX and
4 beyond design basis, there was extensive training and
5 procedural changes done for the rest of the emergency
6 response organization.

7 I think one of the staff slides talked
8 about some of the other things that were done as part
9 of the beyond design basis events. So, there's
10 training for engineering, radiation protection,
11 chemistry, even security depending on the plant and if
12 you take credit for the security officers in your
13 response.

14 This is a -- that was really the end of
15 it. You know, this is just a sample of the approach
16 that was taken at one of our plants on the amount of
17 training that was provided to operations.

18 So, I didn't intend to go through this.
19 I'd be happy to answer any questions.

20 MR. KRAFT: So that completes our prepared
21 presentation to this.

22 CHAIRMAN STETKAR: Let me ask, John, one
23 thing that I've asked a couple of times in the
24 Subcommittee, and since you're involved with
25 integrating the EOPs and SAMGs and FLEX procedures.

1 If I read the NEI guidance, NEI 13-02
2 that's specifically focused on compliance with Order
3 EA-13-109, I'm left with the impression that I don't
4 need to worry about getting water into what I'll call
5 the reactor vessel or what you might call the plant
6 from an external water supply for at least eight
7 hours.

8 Which means that I have up to eight hours
9 to try to get the pumps aligned. And power hooked up
10 to valves that might need to be opened.

11 How are the procedures in the plants
12 actually implementing that? Because there are many
13 cases were if I could get the water in earlier, I
14 wouldn't need it for a severe accident response.

15 So for ex -- my point is that if I decide
16 to put all of my equipment in a robust shelter that's
17 ten miles away from the plant because I've done an
18 analysis that says within eight hours I can get it
19 there.

20 And I don't have to worry about flooding.
21 I don't have to worry about, you know, very, very site
22 specific issues. Am I then precluding the fact that
23 I can use it for other things, like preventing core
24 damage?

25 MR. GRUBB: Well, what's interesting is,

1 at that the vent Order and the FLEX Order, they're not
2 contrary to each other. But, for the vent Order,
3 we've assumed FLEX doesn't work.

4 So, we got core damage and now we're
5 dealing with core damage. The plants, we will always
6 implement and put our FLEX equipment, our ability to
7 put water back into either the vessel or containment
8 in place as quick as reasonably can.

9 That will always be done. You can jump in
10 here Phil if I'm --

11 CHAIRMAN STETKAR: But the NEI guidance
12 specifically says I can have up to eight hours to do
13 that.

14 MR. GRUBB: Yes.

15 CHAIRMAN STETKAR: So if I'm implementing
16 -- if I'm following the NEI guidance, all I have to do
17 is be able to demonstrate that indeed I can get a
18 truck to drive the stuff down there and get the power
19 and the water connected within eight hours.

20 And I can check off the box that I comply
21 with the NEI guidance. That doesn't say -- that
22 doesn't say well, of course I know if I get it hooked
23 up faster that's a good thing.

24 It says that all I need to do is
25 demonstrate that I can do it within eight hours. It

1 might be seven and a half hours.

2 So how now is the Owners' Group and the
3 plants thinking about that from a realistic point of
4 view in terms of maintaining the broadest number of
5 options available to the operators? Not only to
6 mitigate core damage, which we hope we never get to,
7 but to prevent that core damage?

8 MR. GRUBB: Right.

9 CHAIRMAN STETKAR: If for example, RCIC
10 fails at T0?

11 MR. GRUBB: Okay. And I --

12 CHAIRMAN STETKAR: Which is your -- which
13 is by definition for BWRs with Mark I and Mark II, the
14 FLEX Phase I equipment. Which is assumed not to fail.

15 MR. GRUBB: Yes.

16 CHAIRMAN STETKAR: So that's why -- I
17 still haven't gotten a nice coherent story from
18 people. So I thought I'd ask you since you're
19 involved in getting people to actually do the things.

20 MR. AMWAY: And I'll start off, and feel
21 free if you need to add or modify. But the eight
22 hours, the way we - the way that's viewed from a 1302
23 perspective is that's what our analysis says how much
24 time we actually have to prevent containment failure.

25 The actual implementation through the

1 procedures is, you know, we're using the same type of
2 connection points and portable FLEX equipment to
3 implement SAWA/SAWM as we did for FLEX. So I mean,
4 we're all designing our FLEX strategies to get water
5 into the vessel as soon as possible.

6 And our strategy procedures will start in
7 the EOPs. Let's take your example. RCIC fails at T0.

8 CHAIR STETKAR: Right.

9 MR. AMWAY: Those EOPs are going to drive
10 us to start lining up alternate water injection
11 systems immediately. So the way this is really going
12 to work, you know, if RCIC fails at time zero, the
13 reactor water level's going down.

14 CHAIR STETKAR: Yes.

15 MR. AMWAY: And it's going to drive us
16 through the EOP lags. We're going to initiate actions
17 to start lining up the equipment, and one of two
18 things are going to happen. If we're really good and
19 we have a short deployment time, and we can, you know,
20 let's say in theory we could hook up that FLEX
21 equipment and start pumping in water before we get
22 core damage. That's where we're at.

23 CHAIR STETKAR: I understand that if, if,
24 if. What I'm asking about is if plants, say, and the
25 staff does their reviews, compliance following EA, any

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 I13-02 is adequate to meet this order. And a plant
2 decides that, "Yeah, I'm vulnerable to flooding or I'm
3 vulnerable to some other damage, high wind damage or
4 whatever."

5 And to protect the equipment that I'm
6 going to take credit for in phase two of FLEX, or for
7 severe accident conditions, I make the active decision
8 that I'm going to park that equipment 15 miles away
9 from the containment because I can demonstrate that I
10 can get it there and hooked up within eight hours.

11 It might take me six hours, but I can do
12 it within eight hours. I can't do it in an hour and
13 a quarter. I just physically can't do it in an hour
14 and a quarter. That decision would comply with all of
15 the guidance, and yet they couldn't do it in your
16 scenario with if, if, if, right?

17 MR. AMWAY: And I agree.

18 CHAIR STETKAR: So I'm asking on a plant
19 specific basis, are people thinking about that?

20 MR. AMWAY: And the answer is yes.

21 CHAIR STETKAR: Okay.

22 MR. AMWAY: I mean, we are definitely
23 looking at it. And like when we do the workshops and
24 we're doing these design consistency reviews, if
25 there's options that we can do that we can reasonably

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 shorten that deployment time and use of that SAWA
2 connection point, we'll do that and we'll consider it.
3 You know, and it's -

4 MR. GRUBB: The way we're viewing the
5 eight hours is I have to have a strategy that I can
6 deploy at my plant for any set of conditions, and this
7 is beyond an assigned basis set of conditions, and
8 assure, have absolute confidence I can have water
9 going into the vessel inside that eight hours. It's
10 - you'd almost like it going over and dropped in. If
11 I can't do that, I can't use this strategy.

12 CHAIR STETKAR: You can't use it. You're
13 right, but that's for containment protection. You're
14 giving up the core. See, that's part of the way that
15 the orders and the NEI guidance have been partitioned
16 between FLEX, FLEX, FLEX, if I use the term FLEX, is
17 to prevent core damage.

18 But there are built-in assumptions there
19 like RCIC is my phase one FLEX equipment, and by
20 definition it does not fail. So therefore, I don't
21 need phase two FLEX equipment to prevent core damage
22 because RCIC works.

23 Now the other flip side is now I've got
24 NEI guidance for this other order that presumes I give
25 up on the core. And it says well, to - the guidance

1 says all I've got to do is get the stuff there within
2 eight hours because I've done the most limiting
3 analysis for the most limiting plant. It says as long
4 as I get the stuff hooked up, water - depressurized
5 and water addition within eight hours or within some
6 margin, I'm okay.

7 VICE CHAIR BLEY: Let me John's thing
8 around a little bit. We understand that to get
9 everybody together and move ahead, people had to pick
10 starting points, and this was a starting point.

11 And kind of what we're asking now is we've
12 gotten everybody together. We're going to meet that
13 starting point, but are the plants thinking about real
14 flexibility beyond just responding to ELAP or whatever
15 it is?

16 MR. GRUBB: Yeah.

17 VICE CHAIR BLEY: That's what we're after.

18 MR. GRUBB: I do understand your question
19 better than you all think. I'll take this back to our
20 focus unit committee and make sure that they talk
21 about that, and that it's covered in our workshops.
22 But I can tell you as a plant operator, we're going to
23 deploy the equipment. Anything to protect the core,
24 they're going to deploy as quickly as possible.

25 And because of the way the order had to

1 assume some, you know, FLEX fail, they feel almost
2 contrary to one another. But we will be able to
3 implement the actions for both orders simultaneously.
4 So we'll be taking all of the actions for FLEX as soon
5 as we recognize and declare the event.

6 CHAIR STETKAR: And I think, you know, you
7 said, "As a plant operator." I think that's a little
8 bit from the perspective that we're coming through.
9 Now that everything is starting to come together,
10 people have developed strategies for FLEX. People
11 have developed strategy for severe accident
12 mitigation.

13 People have developed strategies for
14 hardening and protecting the equipment that will be
15 used. People are now developing guidance and
16 procedures, and whether you want to call them
17 guidelines or procedures, and training. All of it
18 eventually comes back to those operators.

19 MR. GRUBB: Right.

20 CHAIR STETKAR: And I'd hate to be the
21 operator sitting in the plant that says, "Yeah, I'd
22 really like to use all of this stuff, but somebody
23 made the smart decision that they wanted to park it 15
24 miles away because they were allowed to do that, and
25 I can't get to it."

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. AMWAY: And the thing I want to be
2 careful of is for the vast majority of plants that
3 have implemented FLEX with the hardened storage
4 requirements, the location of where that equipment is
5 being stored is already set. And the requirements of
6 13-02 is we protect it to the same level as we did for
7 FLEX.

8 What we can do, and I think, and that's
9 what I'm, you know, driving within my sights within
10 Exelon, is where we can structure those procedures
11 such that when the decision is made to deploy the
12 equipment, that they're going to do it the same way
13 whether it's an ELAP FLEX no core damage case, or an
14 ELAP FLEX fails core damage case.

15 It's the same series of actions that
16 they're doing so they don't get part way down one
17 strategy and realize, "This doesn't work. I am now,
18 you know, I've lost RCIC. I'm now on the SAWA case
19 and I've got to jump over to this other procedure and
20 get that out, and undo actions I did to get to where
21 I'm at to implement SAWA."

22 And that's where I see the biggest benefit
23 to shortening that deployment time, is to make sure
24 that the procedures are structured such that, you
25 know, it's a continuous set of actions from the time

1 they enter the EOPs, until they realize RCIC fails, to
2 the time they start hooking up the FLEX equipment
3 that's also serving the SAWA purpose.

4 CHAIR STETKAR: Right.

5 MR. AMWAY: So that there's no delay in
6 the decision making and the actions that are being
7 taken to get that water delivered as soon as
8 practical.

9 VICE CHAIR BLEY: John, could you put up
10 slide seven again? I know it wasn't - it's just a
11 sample case. Oops.

12 MR. GRUBB: Maybe I can. Maybe I can't.

13 VICE CHAIR BLEY: This is - can you
14 explain the general structure of this? And then I
15 have a question or two.

16 MR. GRUBB: This was from my Monticello
17 Plant. Monticello implemented the requirements of the
18 spent fuel and FLEX orders earlier this year with one
19 caveat. We do have a relaxation on the missile
20 protection of the vent. Monticello's strategy credits
21 our existing hard pipe vent for containment, venting
22 containment, and it does not meet the missile
23 protection requirements called up by the -

24 VICE CHAIR BLEY: I didn't want to
25 challenge details.

1 MR. GRUBB: I know.

2 VICE CHAIR BLEY: I wanted to know the
3 general structure.

4 MR. GRUBB: So if you look, this spring
5 would be T0, so back it off of the spring elements we
6 had. At about T9 is the first time we really
7 introduced FLEX to the operators, about an hour and a
8 half, all in the classroom, both licensed and
9 non-licensed.

10 By that point, the site had developed our
11 initial strategies. Our OIP had been submitted
12 actually about a year and a half earlier. So this was
13 kind of the first taste of what FLEX looks like for
14 the operators.

15 A month later, we got into the basic.
16 There was two industry CVTs that were put together, so
17 we gave those to - the first one to both licensed and
18 non-licensed, and then the second one just to the
19 licensed operators.

20 At T6, we went into the classroom and
21 walked through how the FLEX strategies work in
22 conjunction with our existing station black out
23 procedures, and the changes that were made to the
24 procedures to help them detect the event, the extended
25 loss of - the ELAP event earlier.

1 We talked about the mods that were being
2 done to assist the, you know. At Monticello, they did
3 two buildings that were separated. So we went through
4 all of the mods, the procedures, the new equipment.

5 We did plant walk downs for the people
6 that were going to be deploying the equipment out in
7 the field, so they got to hook up the truck and tow
8 the equipment out to the spot. They got to park it to
9 tie into the, either the injection line, or for
10 Monticello, it's repowering the batteries. Let's see.

11 VICE CHAIR BLEY: I can see the rest of
12 it. You don't have any T+ a month or a year.

13 MR. GRUBB: I had that in my slides. I
14 don't what happened to them on this. So we were
15 getting FLEX training all the way up to just before
16 the outage. So the last training cycle before the
17 outage was the last of the FLEX changes.

18 Some of the things we covered there, as we
19 were going through and developed our FSGs and things
20 were going on within the owner's group, and plants
21 were learning lessons as they went through
22 implementation, we made changes to things that we may
23 have presented earlier.

24 So we did do training all the way up right
25 until, you know, the last training cycle before our

1 spring outage.

2 VICE CHAIR BLEY: Are you planning - and
3 I know you have the usual training we have to get done
4 for the highest risk issues. But are you planning to
5 have exercises routinely in the future, and does
6 everybody get some of that?

7 MR. GRUBB: Yeah, somebody asked a
8 question about INPO earlier. I apologize, I don't
9 remember who that was. But one of the things that
10 INPO is doing is they're putting drill requirements in
11 place through the SERs where we now will touch
12 elements of the beyond design basis accidents through,
13 at some certain frequency. I don't know off the top
14 of my head what that is.

15 So I can tell you the last two drills that
16 Monticello did, both of those used elements of the
17 FLEX strategies although it wasn't really a FLEX
18 drill. Because of what - the scenario, it led them
19 into a place where they had the ability to deploy the
20 FLEX equipment, and in both cases, they did that.

21 VICE CHAIR BLEY: And in the past, when we
22 got the new operating procedures and emergency
23 procedures and ran through those on the simulator, we
24 found lots of places it didn't work and a lot of
25 cleanup. Have you found places where the strategies

1 have needed some cleanup or rethinking as you go
2 through?

3 MR. GRUBB: We've found a number of items.
4 So what we did at Monticello is, you know, we
5 completed our strategies sometime late last year. We
6 didn't finalize them until we went through the - every
7 operator had gone through the training.

8 So we captured comments throughout the
9 entire training process, you know, the seven weeks,
10 for all six crews, and then we did a final set of reps
11 too. So we found a lot of implementation type of
12 issues that we were able to fix before we had to
13 finally implement.

14 VICE CHAIR BLEY: Okay, thanks.

15 MR. AMWAY: The other opportunity to catch
16 that too is when we do our phase two staffing studies
17 where you actually go through and do the, you know,
18 the walk through of the procedures and the
19 validations, that type of thing. It's also another
20 opportunity where you can identify and catch those
21 things and have time to correct them before
22 implementation.

23 MEMBER SCHULTZ: All right, that's the end
24 of the industry's presentation. Any comments or
25 questions from the rest of the committee?

1 MEMBER RICCARDELLA: I just have one
2 question. Could someone comment on any differences
3 there might be between the actions being taken by the
4 U.S. versus international via Mark I, Mark II BWRs?

5 MR. GRUBB: I attended an IAEA meeting in
6 Vienna earlier this year that was all focused on
7 lessons learned from Fukushima, a lot of it on the
8 research side. But in general, I would say almost all
9 of the European and non-U.S. plants, frankly, are
10 implementing some type of a filter approach, not for
11 a technical reason, for a political reason. That was
12 talked about by a number of the presenters at that
13 meeting.

14 MEMBER RICCARDELLA: And haven't they seen
15 the data that shows that the filter doesn't do much?

16 MR. GRUBB: Well, both the BWR owners
17 group and EPRI, as well as the NRC was at that
18 meeting, and presented the data saying there's no
19 technical benefit from the filters, which is why we
20 went a different direction in the United States.

21 But the individuals that spoke at the
22 meeting, these are the individuals - and then once I
23 talked to between sessions, it was driven more
24 politically than technically.

25 MEMBER RICCARDELLA: Thank you.

1 MR. WACHOWIAK: There was - we looked at
2 some of the European Mark IIIs, and once again in
3 Spain, there was a political decision to have the
4 filter. And what they did was use an analysis similar
5 to ours to help define what the design requirements
6 for the filter were given that they had to have one.

7 MEMBER SCHULTZ: All right, at this point
8 then the industry presenters will leave the podium as
9 it were, and we'll go to the public comment
10 presentations where the members of the public have
11 requested time with the committee. John, could we
12 have a break at this point?

13 CHAIR STETKAR: You know, Steve, you're
14 running this portion of the meeting -

15 MEMBER SCHULTZ: Oh, thank you, so I would
16 like to call a break -

17 CHAIR STETKAR: - so, yes, we can.

18 MEMBER SCHULTZ: - so that all presenters
19 will be comfortable with their presentations and ready
20 to go in about - at 3:30.

21 CHAIR STETKAR: So we're recessed until
22 3:30.

23 (Whereupon, the above-entitled matter went
24 off the record at 3:19 p.m. and resumed at 3:31 p.m.)

25 AGENDA ITEM 2.2

1 MEMBER SCHULTZ: At this point by the
2 clock it's 3:30, so we'll come back on the record.
3 Thank you, John.

4 CHAIR STETKAR: The only reason I do that
5 is they use it as a time stamp on the -

6 MEMBER SCHULTZ: We now have it.

7 CHAIR STETKAR: - transcript.

8 MEMBER SCHULTZ: And in this session we
9 have presentations by members of the public who have
10 asked the committee for an opportunity to present to
11 the committee. And the first presentation is going to
12 be by David Lochbaum from the Union of Concerned
13 Scientists. Welcome to the forum, David, thank you.

14 MR. LOCHBAUM: Thank you, and good
15 afternoon, and thank you for looking into this topic
16 and also for allowing us this opportunity to share our
17 perspectives with you.

18 We reviewed the staff's draft regulatory
19 basis seeking to understand what the staff
20 recommended, and also why they recommended it. After
21 that review, we conclude that - we feel that the staff
22 miscalculated the QHO benefits of Alternative 4, and
23 calculated and then dismissed the non-QHO benefits of
24 Alternative 4.

25 Step back a minute. If you look at Order

1 EA-13-109, it did not change the situation from being
2 above the QHO goal to now being below it. In other
3 words, the very low probability of this bad accident
4 happening itself meant that nothing needed to be done
5 to meet the QHO goal.

6 Therefore, EA-13-109 also met the goal and
7 was ordered. Yet Alternative 4 is not being approved
8 and was thrown aside because it too, along with
9 everything else, does not - already meets the QHO
10 goal.

11 We would agree with the staff and the
12 commission now if the individual latent cancer
13 fatality had been determined realistically and if it
14 was the dominant factor. But we totally disagree with
15 the staff and the commission's conclusion and the
16 bizarre path to it.

17 There was discussion earlier whether rule
18 making or ordering effects checkability by the NRC
19 staff. Let me relate a big difference that affects
20 the public. In rule making, the public has a right to
21 contest the nonsense. In ordering, the public only
22 gets to observe nonsense. We were deprived our due
23 process by the decision to forego rule making for a
24 wink, wink, nudge, nudge, say no more ordering with
25 the staff.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 When the orders were issued, there was
2 opportunities by the public to contest the orders or
3 intervene in the orders, but at that time, it was a
4 bait and switch. We were told there would be a rule
5 making to follow it up and we held our powder until
6 that moment which has now been taken away from us, and
7 we're not real happy about that.

8 This is Figure 4-24 from the draft
9 regulatory basis, and it provided the consequence
10 reduction factors for Alternatives 3 and 4 under four
11 different emergency evacuation scenarios. The staff
12 decided that CRFs of 3.1 to 6.0 were not enough to
13 justify the cost of Alternative 4. I urge you to keep
14 this point in mind because I'll return to it pretty
15 soon.

16 While the staff looked at an unsuccessful
17 evacuation scenario, their conclusion rested on
18 confidence that evacuations will be 100 percent
19 successful. The staff assumes that the trend -

20 MEMBER POWERS: Is that conclusion that
21 they rest on 100 percent successful - I mean, there's
22 a base line refusal to evacuate in most of the models.
23 It's 100 percent successful save for that default
24 value of the refusal to evacuate?

25 MR. LOCHBAUM: And the dead people too.

1 They don't leave either.

2 MEMBER POWERS: Well -

3 MR. LOCHBAUM: If you look at the first
4 alternatives and what they considered in the base
5 model for the conclusion, it was no value - there was
6 essentially no radiation exposure avoided to the
7 population within 10 miles, which basically translates
8 into all of those people getting out of the way before
9 the plume went by.

10 MEMBER POWERS: So they overload the
11 default. There's a default level of people that
12 refuse to evacuate.

13 MR. LOCHBAUM: That's the little band of
14 people who didn't get out before the plume went by.
15 If everybody had gotten out - but it's 100 percent
16 successful based on the definition of what a
17 successful evacuation is.

18 MEMBER POWERS: On what 100 percent
19 successful is, yeah, okay, so they kept those -

20 MR. LOCHBAUM: The same -

21 MEMBER POWERS: - whatever the default
22 value is for - by some sociologists on how many people
23 would just adamantly refuse, there being contestations
24 of that in the literature saying that that value
25 varies in response to technological accidents. The

1 default value comes from all kinds of evacuations.

2 And some people would contest that it's a
3 little too high because people in technological
4 events, and by that they mean like, oh, in the south
5 every once in a while they dump railroad cars of
6 chlorine, that people over respond to those and
7 under-respond to other kinds of things.

8 MR. LOCHBAUM: It's very magical because
9 the people who are downwind evacuate. The people who
10 are upwind, it's assumed that they don't evacuate and
11 get in the way of those that are downwind, so it's a
12 very magical process.

13 MEMBER POWERS: Well, I think they always
14 assumed some sort of default value for shadow
15 evacuations and - I mean -

16 MR. LOCHBAUM: It's assumed -

17 MEMBER POWERS: It's built into model that
18 you've always had some fraction of those people who
19 were not directed to evacuate did anyway, and
20 therefore clog up arteries to some extent. I mean, I
21 thought that always was built into the models unless
22 you deliberately go in and override that.

23 MR. LOCHBAUM: Right.

24 MEMBER POWERS: Which is not easy to do.

25 MR. LOCHBAUM: That's my understanding

1 too.

2 MEMBER POWERS: Okay.

3 MR. LOCHBAUM: In the draft regulatory
4 basis, the staff assumed that trained and qualified
5 nuclear officials would only be 53 to 60 percent
6 successful in preventing core damage using FLEX at
7 all, but the untrained amateurs were nearly 100
8 percent successful running away from it.

9 MEMBER POWERS: I really did not
10 understand that in your paper. It's in your - the
11 people - I'm not sure who the amateurs are. The
12 people that order evacuations and whatnot are the
13 state officials. You can't call them amateurs. I
14 mean, they're professional emergency preparedness
15 trained. Sometimes it's the sheriff's department, but
16 -

17 MR. LOCHBAUM: Right, but the people that,
18 when they push that button and hit the evacuation
19 siren, the people that are supposed to get out of the
20 way have children in school. They have children -

21 MEMBER POWERS: Well, nearly all the
22 school districts have emergency preparations and
23 things like that. If the amateurs you're talking
24 about are the citizens, then fair enough, but the
25 people running the evacuation are not amateurs.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. LOCHBAUM: It's the people you're
2 trying to protect. They have received essentially no
3 training on this. It's assumed they'll do whatever
4 those trained responders tell them to do. There's no
5 training. There's no awareness. It's as assumption
6 that's never been tested that these people -

7 MEMBER POWERS: Well, that's not quite
8 true. We've done evacuations, certainly have done
9 them in connection with Rocky Flats, and then there
10 have been a few others like Crystal River and all of
11 the - there have been a dozen or so. And it's hardly
12 my area of expertise, but I've always been impressed
13 that - at the level of compliance, shall we say.

14 MR. LOCHBAUM: Yeah, if you look at the
15 data and throw out stuff like Hurricane Rita where
16 people didn't get out in time, it all looks good. It
17 doesn't - it's the various cherry picking. Those who
18 are advocates of emergency planning and evacuations
19 will pick the ones that people did get out, and they
20 have excuses of why Hurricane Rita is a bad data point
21 and gets to be thrown out. The science is not there
22 to support that it's just 100 percent.

23 MEMBER POWERS: Hurricane Rita is a data
24 point that I use in my class because it - I used to
25 have a slide in my class about how the death rate, the

1 deaths due to evacuation itself as opposed to whatever
2 prompting, were very low, and Hurricane Rita promptly
3 forced me to throw that slide out because it really
4 screws things up.

5 But I mean, I'm not sure what you mean by
6 cherry picking. Even I average Hurricane Rita death
7 rates in, okay, it doubled my death rates, tripled it
8 maybe, that's still a pretty small number. And the
9 evacuation rates, I mean, the problem is they're slow.

10 MR. LOCHBAUM: They're slow and you
11 mentioned earlier the evacuation of the untrained
12 amateurs. We citizens aren't consistent. We don't
13 respond.

14 So the statistics on people who don't
15 evacuate, employing the releases or whatever, those
16 are not selected by proponents that are arguing that
17 the evacuations are successful. There are reasons why
18 all of these things don't apply because it wasn't a
19 nuclear plant, or it wasn't whatever.

20 MEMBER POWERS: Well, I mean, the
21 statistics on failure to evacuate chlorine are lower
22 than they are for hurricanes. So when they average
23 the two together, or in whatever magical way they
24 decide to average, they actually get a number that
25 some people contend are too high.

1 MR. LOCHBAUM: It's nearly 100 percent. -

2 MEMBER POWERS: Yeah, yeah -

3 MR. LOCHBAUM: - through the industry
4 study.

5 MEMBER POWERS: Yeah, it's only about half
6 a percent.

7 MR. LOCHBAUM: You can't take all of the
8 data and throw out all of the bad points and still get
9 100 percent.

10 MEMBER POWERS: Well, I don't think - I
11 mean, I'm not sure what bad point they're throwing out
12 when you say that.

13 MR. LOCHBAUM: They're assuming nearly 100
14 percent evacuation except for those who refuse to
15 evacuate.

16 MEMBER POWERS: Yeah.

17 MR. LOCHBAUM: That's the best they could
18 possibly be. They're not accounting for anything less
19 than the best that it could possibly be, and that's -
20 I hope that's the case, but that's not good public
21 policy. That's a convenient answer. It's not good
22 public policy. If they choose to do it by a majority
23 of votes and adopt bad public policy, so be it.

24 But when it doesn't represent reality and
25 it assumes the optimum best assuming only those who

1 refuse to go get out in time, there's no way in the
2 world as a scientific organization we can say, "Oh,
3 yeah, there's sound reasoning behind that gimmick."

4 MEMBER POWERS: But you have statistics on
5 what, 50 some evacuations? We have statistics on some
6 evacuations.

7 MR. LOCHBAUM: I bet you look at the
8 highest ones pulling that close to what the NRC is
9 assuming for this case, but I won't know that answer
10 yet anyway, so in the interest of time, I'm going to
11 move onto my next slide.

12 MEMBER POWERS: Okay.

13 MR. LOCHBAUM: I mentioned earlier that
14 the staff regulatory basis looked at the consequence
15 reduction factors. Then I noticed that they only
16 looked at that for the alternatives between - or for
17 the differences between Alternatives 3 and 4. Table
18 4-24 from the draft technical basis provided the data
19 for Option 1 or 2 as well, so I calculated the
20 consequence reduction factor between 2 and 3.

21 For individual latent cancer fatality
22 risks, that difference was - CRF was 2.27. For the
23 difference between 3 and 4, it was 2.73. If you go
24 across that table, in every single case the
25 consequence reduction factor between the status quo

1 and the SAWA option is less, much less than the
2 consequence reduction factor between 3 and 4.

3 The small, the allegedly small consequence
4 reduction factor between 3 and 4 was utilized by the
5 staff to say that Alternative 4 was not justified, yet
6 they recommended Alternative 3 which had even smaller
7 consequence reduction factors.

8 We also did an exercise based on the
9 highest range cost for the external filter, \$64
10 million, taking an assumed value of life of \$5 million
11 per dead person, then you roughly have to save - the
12 external filter would have to save about 12 lives to
13 be justified.

14 On this table, the staff provided the
15 average individual latent cancer fatality risk for the
16 SAWA case, Alternative 3, and the SAWA case plus the
17 external filter which was Alternative 4. That delta
18 is 9.5 times 10 to the minus fifth.

19 So if you multiply the delta ILCF factor
20 of 9.5 times 10 to the minus fifth, times an effective
21 population, divided by the cost, you have to figure
22 out how many people could be exposed to that radiation
23 level and be experiencing that individual latent
24 cancer fatality in order for that \$64 million to be
25 justified. At \$5 million per life, that number turns

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 out to be 134,737 persons.

2 Going back to your earlier question about
3 what is the population around the plants, had the
4 staff looked at the population within 10 miles and
5 shown that there's only 20,000 people, so it's no way
6 that they could not get out in time but that it would
7 save 12 lives, but they've not done that. We'll do
8 that once I get access to that data.

9 If you assume the value of a life is as
10 high as \$8 million, then it's 84,211 people who have
11 to be exposed for that \$64 million filter to be
12 justified.

13 MEMBER POWERS: What did they use in their
14 cost benefit? I don't remember.

15 MR. LOCHBAUM: The Office of Management
16 Budget had been saying they've been using \$3 million
17 roughly.

18 MEMBER POWERS: That sounds about what I
19 thought.

20 MR. LOCHBAUM: At that number, the
21 affected population is 224,561 people who - what we're
22 going to do is look at what percentage of the
23 population within 10 miles do these numbers represent
24 to try to come up with some conclusion. Is it
25 reasonable that most of those people will be out?

1 Basically, what percent success rate does
2 the evacuation have to be in order to keep the numbers
3 below the value of life cost justified? So we'll -
4 even though the commission has ruled, so it's a moot
5 point, but we have a calculator and some time, so
6 we'll do that.

7 But it disappoints us that we don't
8 understand how the staff came to a conclusion that
9 Alternative 3 was justified when its consequence
10 reduction factors are less than that of Alternative 4.

11 The other thing we don't understand, and
12 this goes back - on this slide. The lefthand column,
13 as we understand, is doing nothing. I mentioned this
14 earlier. And in the beginning and the middle in the
15 next couple of columns is Alternative 3, which is what
16 the staff recommended.

17 All of those are below the high level
18 conservative estimate which the NRC panel said was the
19 worst case, worst ELAP, and all of that stuff, so
20 that's the worst of the worst. The NOC order which
21 led to Alternative 3 being basically what's being
22 happening was already below. How did the staff
23 justify issuing the order for improvements that were
24 below the QHO to begin with and ended up below the QHO
25 at the end?

1 Given the fact that EPRI's data and the
2 NOC's data shows very little variability amongst the
3 individual latent cancer fatality for the various
4 options, why is Alternative 3 the right one out of
5 those options?

6 Why not go for Alternative 4 and also gain
7 the huge economic benefits that it provides by not
8 contaminating large parts of the American countryside?
9 Why was that not factored into the evaluation?

10 None of these options, even the one that
11 was ordered and the one that the NRC recommended,
12 reduces the QHO below the QHO goal. They are already
13 below that. So what game is being played on the
14 American public by this bait and switch with doing an
15 order and denying the public its opportunity for rule
16 making? How in the world did that happen? What
17 justified the order and how does that justification
18 not mean we need to pursue rule making for Alternative
19 4?

20 It doesn't mean pursuing rule making means
21 that you automatically have to adopt Alternative 4,
22 but gives us, the public, a chance to recommend that,
23 and it also gives us a chance to fight the NRC in
24 court if they choose not to do that, but they took
25 away that right.

1 I also had some comments about some things
2 that perhaps should have been considered in
3 Alternative 5, but in the interest of time, that's in
4 the record in the material I provided. I think it's
5 pretty straightforward. I'll omit covering that
6 unless there's any questions over the reliability of
7 the SRVs or any of the other issues. Hearing none.

8 MEMBER SCHULTZ: The next presenter for
9 us, excuse me, the next presenter for us this
10 afternoon is Paul Gunter from Beyond Nuclear. Paul?

11 MR. GUNTER: Thank you very much. Yes, my
12 name Paul Gunter. I'm a Director of the Reactor
13 Oversight Project at Beyond Nuclear. I'm going to
14 make no pretense that I'm a technical expert on this,
15 but we have - I've basically come before you
16 representing the informed public, and we have also
17 been active in interventions before the U.S. Nuclear
18 Regulatory Commission.

19 And I think that that brings us to, well,
20 perhaps the most egregious point in this rule making,
21 is that I, you know, looking at the transcript from
22 August 18, it's apparent to us that you, as the NRC's
23 independent expert panel, were as blind-sided by the
24 taking an informational paper from staff and turning
25 it into a vote, that that was as much as - I would

1 suspect that would be as much a surprise to you as it
2 was to the public in terms of the course that we were
3 moving along, that it seems to have been an extreme
4 waste of your time.

5 But it's - and I think that that is part
6 of this very egregious decision which fails to uphold
7 the concept of defense in depth, as well as Dave has
8 pointed out, removes the public due process to present
9 our own expert testimony. And, you know, let's make
10 no bones about this.

11 By pulling this rule making, the
12 commission basically voted to, in majority, to kick
13 the public out of standing in any kind of legal
14 challenge to a controversial issue that has now gone
15 on more than four decades with regard to the
16 unreliability of the Mark I and the Mark II
17 containment, and it's consistent with this process of
18 keep away.

19 And I've been around long enough to
20 understand that it took a Freedom of Information Act
21 through the Union of Concerned Scientists to reveal in
22 1978 the Hanauer memo recommending - where the AEC
23 recommended we should suspend operations of these
24 reactors and make no more.

25 You know, it took five years for that memo

1 to get out. And by that time, the AEC and the NRC had
2 already proceeded down a path to license 16 more Mark
3 Is. And it, you know, it just goes on that, you know,
4 we, as the public, and public safety as monkey in the
5 middle, has seen this ball go over our head time and
6 time again.

7 Generic Letter 89-16 was done, as I've
8 pointed out to you earlier, under 10 CFR 5059. It was
9 treated like changing out the wastepaper basket liners
10 in the control room. You know, it was basically
11 presented to us as no significant safety issue. And
12 by removing that, by turning it into a voluntary
13 initiative for this industry, the public again was
14 denied participation and a formal standing.

15 So now we arrive at, you know, our
16 realization post-Fukushima that an affirmation of what
17 we'd known already, where these containments are
18 highly prone to failure. As was presented in 1986, it
19 was a 90 percent chance of failure by Harold Denton.
20 And, you know, if you are informed and following this
21 along, you understand that if these containments are
22 challenged, they will probably fail, and yet we have
23 been denied standing all the way through the process.

24 Now, we arrived at a point with SECY
25 2012-0157 where to my surprise, there was - including

1 myself after study, there was broad approval of the
2 staff decision to move to the filtered vent system.
3 And there was an opportunity for the NRC to gain a
4 consensus of public confidence that public safety was
5 the primary concern, and that opportunity was lost
6 here.

7 But in fact, it was picked up in Japan.
8 And, you know, I just picked a couple of days here,
9 several days where we were sort of flabbergasted by
10 this about face that we saw where, you know, we had
11 been awaiting the opportunity on the August 18 ACRS
12 subcommittee meeting to meet and talk about some of
13 these ideas.

14 That subcommittee meeting was predated by
15 AREVA announcing that it was installing the 14th
16 installation at Japanese nuclear power stations, and
17 that was BWRs and PWRs with these filtered containment
18 venting systems.

19 And so, the day after, you know, the ACRS
20 subcommittee meets, we realize that the commission has
21 in fact again taken an informational order, we believe
22 out of context, and turned it into a vote. Now,
23 granted, Commissioner Svinicki wasn't alone in that
24 vote, and - but we were deeply surprised by the fact
25 that the process that was moving forward was abandoned

1 so abruptly.

2 And again, it closed out your
3 participation, you know, despite the fact that we, you
4 know, were not in full agreement with your direction
5 in this as well, but it removed our expert opinion on
6 how these aging Mark I and Mark II containment systems
7 will be managed in the next accident.

8 That said though, you know, we had known
9 for a couple of years that the Japanese were
10 proceeding with the filtration containment venting
11 system. This is the schematic for the Shimane BWR.
12 This is the schematic for Kashiwazaki-Kariwa.

13 Now, there was an NRC senior management
14 team that went to Japan and reviewed this. I had the
15 opportunity to talk to David Skeen who was, you know,
16 quite impressed by the small footprint that these
17 double-filtered containments was providing.

18 And you know, as the staff had recognized
19 in the SECY 2012-0157, you have to take more than just
20 the limited scope that we have by hypothetical
21 analysis, and this is one of our big concerns is that
22 - and this was also expressed in the notation vote of
23 Chairwoman Allison Macfarlane in the vote on
24 2012-0157, where she explained that, you know, when
25 you look at the hypothetical, when you look at the

1 probability assessments, it does not match up with
2 what we are seeing in reality, and that the -

3 You know, the reality is that these
4 containments if challenged will fail, and the failure
5 trees are hypothetical and will be surprised. But,
6 you know, we've made a choice now to limit the defense
7 in depth, and the die is cast on this.

8 But again, it's particularly egregious
9 that we are not getting an opportunity to address a
10 lot of the uncertainties that have even been presented
11 by the National Academy of Sciences where, if you look
12 at their June 2014 paper through the Fukushima
13 committee and their analysis, their Appendix L which
14 looks at the factoring the costs of severe nuclear
15 accidents and the backfit decisions, when they ran
16 their assessment of the costs of Fukushima Daiichi,
17 their figures were exceeding \$2 billion.

18 And they raised the question in Appendix
19 L, "It is instructive to compare these costs to the
20 estimates developed by the NRC staff for a
21 hypothetical accident at the Peach Bottom nuclear
22 plant in Pennsylvania. These costs were used in the
23 staff's backfit analysis for filtered vents."

24 And it goes on to say that, "The total
25 estimate costs for the hypothetical accident at the

1 Peach Bottom plant are therefore \$6 billion." So the
2 NAS pointed out that that's about 33 - their estimate,
3 their tally of this ongoing estimate was 33 times
4 higher than the NRC estimate in its - in going by its
5 quantitative analysis. And therefore, I think that
6 that was part of the justification for also
7 incorporating the qualitative analysis which put the
8 filtered venting system into play.

9 But you know, and again, it is our concern
10 that we're being denied an opportunity to bring in a
11 whole host of independent expert analysis to challenge
12 this on the record through due process. And I
13 speculate that that is in good part why this rule
14 making process was ended so abruptly in that it
15 basically closes the record.

16 I just wanted to close with a couple of
17 inclusion into the record here, the comments of
18 Commission Jeff Baran in that he pointed out in his
19 notation vote, "In my view, it is premature for the
20 commission to consider the draft regulatory basis at
21 this time without the benefit of public comment or the
22 ACRS review.

23 I approve the staff's established plan
24 based on clear commission direction to seek public
25 comment and ACRS review of the draft regulatory basis

1 prior to its submission to the commission for a
2 notation vote.

3 Furthermore, there is no reason for the
4 commission to vote on the draft regulatory basis
5 before the ACRS has reviewed and provided
6 recommendations on the document. Under the staff's
7 original schedule, the ACRS plan to hold a
8 subcommittee meeting and provide a letter to the
9 commission after the staff reviewed and addressed
10 public comments for the draft regulatory basis.

11 The staff should resume this course though
12 the staff previously presented the draft results of
13 the regulatory analysis to the ACRS, this will be the
14 first time the ACRS will examine the draft regulatory
15 basis as a whole and share its thoughts with the
16 commission. We should wait for the ACRS letter before
17 making substantive decisions about the draft
18 regulatory basis."

19 Emphasis here, "This is an important
20 post-Fukushima rule making. A wide range of stake
21 holders will have a variety of perspectives on the
22 four alternatives presented in the draft regulatory
23 basis. We should hear their views and critiques of
24 these alternatives and the staff's regulatory analysis
25 before taking any alternatives off of the table.

1 Therefore, consistent with the existing
2 commission directive, the staff should carry out its
3 plan to seek public comment and the ACRS review of the
4 draft regulatory basis prior to submission to the
5 commission for the next few months - in the next few
6 months for a notation vote."

7 So just in closing, basically we feel that
8 we - that this order, this notation vote was
9 essentially effectively a gag order on the American
10 public's ability and opportunity to formally provide
11 input into severe accident mitigation efforts for the
12 continued operation of the GE Mark I and Mark II
13 reactors.

14 Ironically, the international nuclear
15 industry is simultaneously cashing in on the effort to
16 restart Japan's nuclear power plants where their
17 nuclear regulatory authority has ordered state of the
18 art engineered external filters on severe accident
19 capable hardened containment vents as a prerequisite
20 to resume operation.

21 And then that - you know, I provided this
22 - the subcommittee with the AREVA press release, and
23 that's part of your records. And, you know, I think
24 the die is cast.

25 MEMBER SCHULTZ: Paul, we do have all of

1 that information available, and it's been available,
2 made available to the committee already. Any comments
3 or questions from the members? With that, I'd like -
4 we're not done with the public comment period. We
5 have one more to move forward. I wanted to thank
6 David and Paul for your comments to the committee
7 today.

8 At this point, for the members of the
9 public that are on the phone line, Mary Lampert of
10 Pilgrim Watch has requested time before this meeting,
11 had made a formal request for time to make a
12 presentation to the committee. She is on the public
13 line, so we're going to open that line and allow Mary
14 to make that presentation to us at this time.

15 There will be an opportunity for others on
16 the telephone line to make comment following her
17 presentation. But I'd like you all to reserve the
18 time for Mary to make her presentation first. And so,
19 if you could, please put your phones on mute except
20 for Mary. Mary, are you there?

21 MS. LAMPERT: Yes, I am. Are the slides
22 up?

23 MEMBER SCHULTZ: We do have the slides up,
24 and David is at the computer. He could show the
25 slides for you if you indicate when you're going to

1 move from slide to slide.

2 MS. LAMPERT: Certainly. Slide two,
3 please. Good afternoon. I'm speaking from my home in
4 Duxbury, Mass, which is located across open water
5 about six miles from the Pilgrim Nuclear Power
6 Station, a Mark I reactor. So I've a vested interest
7 in this, and a vested interest in having a filter.

8 Slide three, please. The staff does not
9 recommend filters, although we know other egress
10 routes that you can have releases from are filtered.
11 The staff reversed its course and they changed the way
12 it performed as a cost benefit analysis, relied on
13 flawed and unsupported assumptions, and used outdated
14 consequence codes, the MACCS and SOARCA.

15 Slide four. As for the analysis of
16 offsite economic consequences, the staff
17 recommendation sent economic consequences of a release
18 from a vent to the back of the bus. The staff did
19 this because economic consequences indisputably show
20 that adding a filter to SAWA would provide the most
21 bang for the buck.

22 Table 4-23 before you on the slide shows
23 that an \$11 to \$64 million filter saves \$3.51 billion
24 in economic consequences. And of course, the solution
25 to this inconvenient truth was to give it considerably

1 less weight than it deserves. However, tell that to
2 the agricultural industry that I can see now in
3 Duxbury Bay that has a very large oyster farm.

4 Tell that to the cranberry growers. Tell
5 that to the people whose investment is in their homes.
6 Tell that to my three sons who are looking forward to
7 a very sizable amount of money from the sale of this
8 house when I kick the bucket, which will be sooner if
9 I have to listen to what has gone before us.

10 Slide five. Instead of giving the offsite
11 economic consequences their due, the staff prioritized
12 health consequences and pretended that they would be
13 essentially zero, although in fact, if an honest
14 analysis had been done, they too would justify a
15 filter.

16 How did they pull this magic trick turning
17 offsite health costs to zero? First, they made the
18 ludicrous assumption that evacuations will take less
19 than six hours. Second, they assume that SAWA and
20 SAWM, however you pronounce it, will delay releases to
21 allow timely evacuation.

22 And thirdly, with no basis given, assuming
23 it would be effective 60 percent of the time, and then
24 conveniently, the staff ignored its admission that
25 SAWA does not work 20 percent of the time. Third,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 health costs become zero by limiting health impacts to
2 cancer fatalities and limiting to a too small
3 geographic area.

4 Slide six, please. First, let's look at
5 evacuation. I can speak on this because I have been
6 appointed by the town of Duxbury within Pilgrim's EPZ
7 to review the radiological emergency plan and
8 procedures each year. I have done this since the year
9 2000, so I know this subject.

10 Evacuations indeed will take far longer
11 than six hours if the foolish assumptions the NRC uses
12 are corrected. We first have to remember that when
13 reactors were built, many of them like Pilgrim,
14 etcetera, were built in less populated areas. They
15 are now in more densely populated areas with an
16 insufficient infrastructure, meaning that people are
17 not going to get out of Dodge in time.

18 Also, many reactors are on large bodies of
19 water such as the one I'm looking at. Therefore, you
20 only have 180 degrees available for evacuation, not
21 like a few reactors in the Midwest where it's not
22 densely populated and there are evac routes around the
23 entire circle.

24 So what NRC does is create fiction. Our
25 emergency management director during Winter Storm Juno

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 here is on record saying it would take four days to
2 evacuate the population. That is not less than six
3 hours.

4 Slide seven. Some of the ridiculous
5 assumptions in NUREG/CR 7002, which forms the basis
6 for evacuation time estimates, and I presume, is what
7 the staff relied upon to come up with this foolishness
8 that evacuations will occur in less than six hours.

9 First, how do they judge public response?
10 They don't tell them in telephone surveys that the
11 questions are about a nuclear disaster, and hence they
12 get false responses. That is what Sandia has done.
13 That is what ALD that does the evacuation time
14 estimates for reactors do in their telephone surveys,
15 general question, "What would you do in any old
16 evacuation disaster?"

17 However, what we have seen is by a
18 telephone survey that was done here in southeastern
19 Massachusetts that actually told people and asked the
20 question, "What would you do in the event that there
21 was a disaster at the Pilgrim Nuclear Power Station?"

22 Seventy percent said they would evacuate,
23 and those respondents were from 10 to 25 miles distant
24 from the reactor, so not the 20 percent from 10 to 15
25 miles that is assumed by the NUREG NRC, no, far

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 greater.

2 Then they asked specifically to those
3 respondents, and all at the 95 percent confidence
4 level, "What would you do if you were told that you
5 were not in the EPZ, in other words, not to evacuate?"
6 Fifty percent said they would evacuate. What does
7 this tell us?

8 The assumptions of the shadow evacuation
9 are wrong, so therefore expect a cork put in the
10 bottle clogging the evac route. Then also, the
11 segmented evacuation assumed inside the EPZ which is
12 that everyone will obey, and only those directed to
13 evacuate will evacuate having an orderly evacuation,
14 letting those closer out first.

15 We know with today's communication
16 capability that as soon - I tell you, as soon as I
17 hear that there is a release or that the two mile
18 around Pilgrim is told to evacuate, I won't hear that
19 instantaneously either on email, on the phone, what
20 have you, and I'm out of Dodge. That is clear.

21 And it is also clear another telephone
22 survey that happened here in Duxbury was whether
23 people could hear the sirens and the siren message.
24 Seventy percent of those in Duxbury said, "No, we
25 can't hear the siren message." So if you can't hear

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the siren message or the siren, then how is a
2 segmented evacuation going to occur?

3 And so assumption after assumption that
4 brings about the fiction that you can have a timely
5 evacuation, it has been shown to be bologna, and as a
6 result of that, you will find that if you did an
7 honest analysis, that the health costs indeed would
8 increase.

9 Slide eight, please. This is a review on
10 this slide. I don't have to repeat it for you. What
11 it - of the Cape Cod telephone survey, which was paid
12 for by Entergy by the way, that shows the 250 percent
13 to 300 percent increase in the number of evacuees,
14 which will bring about a huge increase in traffic
15 density, a decrease in speed, and a dramatic increase
16 in the evacuation time. This is proof in the pudding,
17 an actual survey that shows the foolishness of the
18 assumption that leads to the statement that ETEs will
19 take less than six hours.

20 Slide nine, please. Last, the draft's own
21 Figure 24, dash 24, shows the health benefits of
22 adding a filter. The short columns to the right are
23 SAWA and filter, plus the filter. They lead to a
24 dramatic drop in latent cancer fatality risk,
25 especially as evacuation time increases which are the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 columns on the far right, or no evacuation at all.

2 Slide ten, please. The staff assumption
3 of health costs equaling zero rests on another
4 ludicrous assumption, and that is the assumption that
5 SAWA will work 60 percent of the time. Also, the
6 staff ignored that accidents that cannot be assumed to
7 be slow breaking, that 40 percent of the time that the
8 staff assumed SAWA would not work. And may I add any
9 solution that purports to ensure public health and
10 safety, even 60 percent of the time, is morally
11 corrupt.

12 Next slide, please, slide 11. An example
13 - I provide an example that SAWA is unlikely. There
14 is no basis to assume it will work six out of ten
15 times by pointing to Pilgrim's plan for supplemental
16 water.

17 Entergy's proposed system here requires
18 workers to bring a portable pump and flexible hose to
19 a barge landing area to connect by a block pulley
20 system to an installed mooring system in the barge
21 landing area, and then the suction pipe supposedly
22 will be connected to the pump on the tractor that will
23 feed into a buried pipe providing coolant to the
24 reactor.

25 What could go wrong? The real question

1 is, "What possibly could go right with this Rube
2 Goldberg plan?" First, the truck tractor pump is
3 housed in storage sheds in another - and obviously not
4 located right by Cape Cod Bay. So the question would
5 be, such as during Juno, a storm in January here, or
6 the following one in February, or during another
7 natural event where there would be a lot of debris,
8 can the road be cleared to get the little truck, and
9 the hose, etcetera, and the people down to the Bay?

10 Supposedly, this has to be - debris
11 removal accomplished in six to nine hours. What does
12 that do a timely evacuation? Then to get down to the
13 barge landing area, there is a very narrow sandy road
14 on the edge of the Bay, that supposedly this whole
15 operation is going to be carried forth.

16 Take a 17-foot storm tide plus a 10-foot
17 wave, and as the cartoon shows, you're going to have
18 to work with the truck in the water. If that doesn't
19 occur and they manage to get down there and stay on
20 the road, what is the likelihood that this snatch
21 block pulley system, you know, which you use to get
22 your dinghy close to show, is not going to get clogged
23 either with seaweed or with ice? The whole plan is
24 ridiculous.

25 Slide 12, please. Last, the health

1 impacts were underestimated because the radiation
2 health impacts that they looked at with cancer
3 fatalities, they did not look at cancer incidents.
4 They didn't look at reproductive disorders, other
5 health impacts that they discussed in BEIR IV. They
6 also ignored the likely geographic impact of exposure,
7 and essentially by using a straight line and
8 restricting it to 10 miles.

9 Slide 13, please. The third reason the
10 staff analysis is not credible is that they relied
11 upon a faulty cost benefit analysis and they used the
12 outdated computer tools of MACCS and SOARCA. I think
13 the cartoon says it all, that all of the numbers we've
14 heard, and it's been mind numbing. You could say,
15 "Hey, they don't lie," but luckily assumptions do lie.

16 And I'll slip to the next slide 14. And
17 you can see there I've submitted papers previously to
18 your group on what is wrong with the MELCOR analysis,
19 quoting heavily from David Chanin who wrote the
20 FORTRAN 4 code. I also was mystified on why the staff
21 used MACCS and not a later so-called improved version
22 of that code.

23 On slide 14, I've listed some of the ways
24 in which the use of the MACCS served to underestimate
25 consequences. For example, they only considered in

1 the code iodine, and in a small fraction, caesium-137.
2 And Dave Lochbaum talked about the fact that NRC's
3 value of life is \$3 million where other agencies are
4 using \$5 million to \$9 million.

5 Slide 15 discusses more ways in which the
6 code - use of that code underestimates costs,
7 particularly economic costs, although the staff
8 analysis itself justified filters just based on
9 economics alone.

10 Slide 16. I'm trying to go as quickly as
11 I can to give other members of the public on the phone
12 an opportunity. The slide 16 has the NRC's OIG audit
13 report issued June 24, 2015. They found that the
14 staff has limited costs estimates making it vulnerable
15 to errors and flawed decision making. This analysis
16 that has been done is a prime example.

17 The staff's flawed cost benefit analysis
18 got the right answer for industry, but the wrong
19 answer for public health, public safety, and the
20 public's pocketbook. There is no way even this
21 analysis justifies not recommending a filter.

22 It seems that the commission didn't like
23 the answer the staff presented a couple of years ago
24 to have a filter, the majority of the staff, but
25 Chairwoman Macfarlane did. And so, the game was kick

1 it back for more study, which really said, "Get the
2 right answer this time for industry."

3 And then the ground work to getting the
4 right answer started to be put into play. "No, we're
5 not going to have qualitative analysis. We're just
6 going to focus on quantitative," even though there
7 were papers by the NRC Jamali indicating all of the
8 various uncertainties and unknowns that require
9 looking at qualitative.

10 Oh, and as far as health, just yesterday
11 there was a report. "Oh, we're going to cancel that
12 cancer study around reactors because God forbid we
13 might have the wrong answer." It goes on, and on, and
14 on which means that the public has lost almost 100
15 percent respect for the NRC as an institution.

16 The public expects an accident because -
17 here in the U.S. because that is the only thing that
18 is clear will make - will shake up the NRC to get back
19 to protecting the public and not the industry, and an
20 accident is likely to occur in a Mark I, like the
21 reactor I'm looking at right now.

22 So therefore, I say to the ACRS, do your
23 job to protect the public, to bring the turnaround, if
24 for no other reason than to start getting some respect
25 back in the public for the agency, and also so you can

1 look yourselves in the face when there is the next
2 accident. And I thank you very much for this
3 opportunity.

4 MEMBER SCHULTZ: Mary, thank you for your
5 comments. Any questions or comments from the
6 committee? With that, what I would like to do at this
7 point is to ask members of the public on the phone
8 line who would like to make a comment to please state
9 your name and make your comment to the committee. Is
10 there anyone on the line who would like to make a
11 comment? If so, please state your name and proceed.

12 MS. GOTSCH: Are the lines open?

13 MEMBER SCHULTZ: The line is open.

14 MS. GOTSCH: Okay, my name is Paula Gotsch.
15 I'm a member of Grandmothers, Mothers, and More for
16 Energy Safety. I would like to begin by saying the
17 most intelligent thing I heard today. I think it was
18 probably somebody from ACRS, maybe not, who mentioned
19 the story of the statistician who drowned in a river
20 with an average depth of six inches.

21 And that seemed to me to be the theme for
22 the day in terms of what I heard in terms of all of
23 this risk assessment and all of these things that are
24 supposed to save us.

25 I also thought that the person who spoke

1 about, "Here is the order. Here is what we know we
2 have to do. We have - we comply by doing A, B, or C."
3 This is each individual plan. Now, where does the
4 followup from that happen? How do we check to make
5 sure that the plants not only do this now, but
6 continue to do it? I thought that was, you know,
7 reasonable of all of these things I've heard.

8 And I just want to say - hello? Hello, am
9 I still on?

10 MEMBER SCHULTZ: We're still here or
11 you're still there. Thank you.

12 MS. GOTSCH: Okay, I heard a funny noise.
13 I didn't know what that was. Okay, I just want to say
14 I'm in the Oyster Creek area. We had a forest fire
15 over in the Pinelands yesterday, the day before
16 yesterday. And then - now that's west of the plant.
17 Now, we've been told most times, you know, that things
18 blow out to sea.

19 Okay, so I'm now choking in my house from
20 this smoke that you get from this forest fire. And I
21 say smoke is what you would smell if you could smell
22 radiation. You know, it's a good way to test your
23 nose, what way the wind is blowing.

24 The next day I'm talking to my
25 daughter-in-law who lives now in Monmouth County which

1 is northeast of here, and her house is suddenly full
2 of smoke. Then I hear on the report that Queens and
3 Brooklyn also got this smoke from the Pinelands, which
4 shows that the plumes and the air currents, they do
5 what they want.

6 It might also be a reason there's so much
7 breast cancer on Long Island. I don't know. But in
8 terms of this pat little idea of protecting the public
9 in the event of an emergency and they'd all come out
10 fine, that is totally beyond comprehension.

11 Okay, now Oyster also, the reassurance
12 that there would be all of these training programs for
13 these people that are supposed to run around with
14 their flashlights or whatever they're doing to do all
15 of these things that have to happen in an emergency,
16 the reassurance of the training continuing.

17 I will say that Exelon ended up being
18 cited three times by the annual inspections for their
19 members not - their workers, some of them, not
20 following procedures. They were, you know, those cute
21 little things. They have white, yellow, and green,
22 whatever, findings that don't seem to mean very much
23 in the long run.

24 They were guilty of, I think it might have
25 been a white performance malfunction there. And I'm

1 not going to start knocking the workers. I don't know
2 what kind of training they get. All I know is that
3 the turnover is very often.

4 I've been told by some of the plant people
5 that I know that the institutional memory is shot on
6 that plant which is the reason they kept putting the
7 wrong cables, the safety cables, they kept putting the
8 wrong ones in for three times, which was considered a
9 yellow, by the way.

10 So there was a problem of institutional
11 memory going on in these plants. The fact that -
12 another thing is now you've got high burnup fuel in
13 those plants. That raises the temperature on an
14 accident I would imagine tremendously.

15 And then I also was surprised to hear such
16 an unscientific statement from somebody saying that
17 the reason they have the filtered vents in Europe is
18 political because he heard it from some of these
19 speakers. I don't think Frank von Hippel is an idiot.
20 He is a very smart professor from Princeton who has
21 been around a long time, top of his field, who wrote
22 an article about the importance of filtered vents. I
23 don't think that man is political at all. He doesn't
24 have a political bone in his body.

25 So I think, you know, hearsay on something

1 and getting the false, you know, this false feeling
2 that all of these filtered vents are going in in
3 Europe because it's political since Fukushima,
4 actually some of those filtered vents were already in
5 there before Fukushima until some people figured out,
6 "Hey, they might save a few people."

7 So in terms of - and I will agree with
8 Paul totally. You cheated us out of our chance to
9 have something to say about what you're saying, to do
10 this FLEX program. It sounds like - it does sound
11 like a Rube Goldberg.

12 And the other thing is - oh, something
13 someone said - I wrote everything down that made me -
14 that there is no sense putting filters on because the
15 stuff leaks out other passageways and you can't filter
16 them. Another reason to show that this plant is not
17 fulfilling the responsibility nuclear was supposed to
18 have to protect the people from the radiation.

19 We were supposed to have a leak tight
20 containment. We weren't supposed to have all of this
21 stuff leaking out all over. We know that there's been
22 tremendous amounts of radiation in the past released
23 from Oyster, I mean, millions of whatever you call
24 them, curies or whatever you want to - I don't know
25 what the heck you call them now. All I know is it's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 bad.

2 And so therefore, number one, you
3 shouldn't even be operating these plants. And you
4 know what else occurred to me? You're all trying to
5 - you know, arguing over how to do this for now, how
6 many years since Fukushima? And saying, "Oh, we
7 should do this. We should do that." That meant that
8 all of those years before Fukushima we - no one would
9 have known what to do if there was an accident here.

10 We wouldn't have been any smarter than the
11 Japanese. And in terms of - I really believe that
12 you're sitting there thinking, "Oh, but what are the
13 chances this is going to happen?" Well, you know
14 what? How long can we keep our fingers crossed? This
15 could happen.

16 And I want to agree with Mary. When will
17 we get someone who when the buck gets to the - and I'm
18 talking to ACRS here. And I'm saying some of you are
19 smart because you have that smart thing you said about
20 A, B, C, and where do we find out the compliance, and
21 I loved the story about the guy who drowns in a river
22 with an average of six inches.

23 Some of you are smart enough to know b.s.
24 when you hear it. And so, someone's got to stand firm
25 and stop it, and say, "Give these people their

1 hearings. Give them their legal rights," and not let
2 this b.s. continue. And I really appreciate the time.

3 MEMBER SCHULTZ: Thank you, Paula. I
4 appreciate your comments. I would like to ask anyone
5 on the phone who would like to make a comment to
6 please identify yourself and make your comment. I'm
7 listening. If you are on the phone and would like to
8 make a comment, please state your name and do so.

9 Hearing none, at this point we will close
10 the phone line. But I'd like to ask if there are
11 members of the public in the audience here in the
12 meeting room to - if you'd like to make a comment, to
13 come to the microphone and do so. Seeing no one
14 taking advantage of that, I would like to close this
15 session and turn the meeting back over to you, John.

16 CHAIR STETKAR: Thanks very much, Steve.
17 I did, because we do have a number of members of the
18 public who are obviously very interested in these
19 issues, I wanted to make you aware that on August 27
20 the commission did issue a staff requirements
21 memorandum for SECY 15-0065 instructing the staff to
22 go ahead with issuing proposed rule making regarding
23 mitigation of beyond design basis events which does
24 explicitly address the core damage prevention aspects
25 of FLEX.

1 So the public will have the opportunity as
2 part of that rule making package to certainly provide
3 review and comments on that aspect of the FLEX
4 proposals.

5 Now, I didn't know whether members of the
6 public - I wanted to take the opportunity because it
7 is relatively recent within the last two weeks anyway.
8 So that will - I don't know when it will be issued for
9 public comments, but at least the commission has
10 approved its issuance.

11 And with that, unless there are any other
12 comments from members of the committee - I'd again -
13 I'd like to personally thank everyone that we've heard
14 from this afternoon. I think it was a very good
15 discussion. I think we do provide a forum for the
16 public to express their concerns and place their
17 concerns on the record.

18 We do consider very seriously the input
19 from the public, and we'll do that in our
20 deliberations. And with that, we are adjourned. I'm
21 sorry, we are - I always get that wrong. We are off
22 the record and we are recessed for this portion of our
23 meeting.

24 (Whereupon, the above-entitled matter went
25 off the record at 4:41 p.m.)




ACRS Full Committee Meeting: Containment Protection and Release Reduction Rulemaking

September 9, 2015

Background

NRC Activities to Address Fukushima Lessons Learned



Order EA-13-109 and CPRR Rulemaking

Containment Protection

- Alternative 1 (no rulemaking – status quo)
 - Order EA-13-109 for overpressure protection
 - SAWA/SAWM for Phase 2
 - Establishes design conditions & supports wetwell level control.
 - Collateral benefit of core debris cooling.
- Alternative 2 (codify order)
 - Core debris cooling remains collateral benefit.
- Alternative 3 (codify order plus require SAWA)
 - Rule for protection against major containment failure modes.

Release Reduction

- Alternative 4 (engineered filter/filtering strategy)

Commission Decision SRM for SECY-15-0085


- The Commission directed the staff to not issue the draft CPRR regulatory basis for public comment.
- The Commission approved Alternative 1, Order EA-13-109 implementation without additional regulatory actions.
- The staff should leverage the draft CPRR regulatory basis to the extent applicable to support resolution of the post-Fukushima Tier 3 item related to containments of other designs (Near-Term Task Force Recommendation 5.2).

CPRR Rulemaking


Evaluation of Alternatives

- Technical Analyses
 - The technical analyses demonstrated that the reduction in risk was not a substantial safety improvement per the backfit criteria.
 - Consideration of Severe Accidents.
 - Low Frequency-High Consequence Events with low estimated risks to public health and safety.
 - Quantitative Health Objective Limit $\approx 2 \times 10^{-6}$ vs. CPRR High-Level Conservative Estimate $\approx 7 \times 10^{-8}$
 - Evaluation of alternatives considers factors such as the performance of other response capabilities (i.e. FLEX equipment, Operator actions, etc.)

Example Risk Calculation



Contributions to Risk



Sub-Alternative	1	3A	4Bi(1)	4Ci(1)
water addition capability	no	yes	yes	yes
filter	no	no	DF=10	DF=1000
CCFP	100%	42%	42%	42%


CCFP = conditional containment failure probability (overpressurization and/or LMT)
LMT = liner melt-through

For each sub-alternative:

- Injection pathway: RPV
- Water strategy: severe accident water addition (SAWA)
- Vent priority: wetwell first
- Vent control: manual
- Vent strategy: open-and-leave-open

Comparison to NRC Safety Goal

- Frequency-weighted individual LCF risk is orders of magnitude below the NRC Safety Goal QHO
- High-level conservative estimate using highest ELAP frequency and highest conditional LCF risk about 30 times below QHO
- Risk reduction from regulatory alternatives are within uncertainty bounds



CPRR Conclusions

- CPRR rulemaking activities have been discontinued.
- The staff is planning to issue a NUREG technical report to document the completed CPRR analysis.
- Proceeding with licensee implementation and NRC oversight of Order EA-13-109.

Containment Protection and Release Reduction Rulemaking Regulatory Evaluation

Advisory Committee on Reactor Safeguards
September 9, 2015



Commission Decision Supports Safety

- Decision to implement Order EA-13-109 without additional regulatory actions focuses both the NRC and industry resources on what is truly important for safety
- The 29 affected plants are already taking actions to protect BWR Mark I and II containments using industry guidance endorsed by NRC pursuant to the Order.
- Supports the critical regulatory principle that decisions should be based on quantitative evaluations and “qualitative factors should only inform decision making in limited cases when quantitative analyses are not possible or practical.” [SRM-SECY-14-0087]
- The CPRR Rulemaking quantitative analysis fully supported not taking action to require external containment filters on BWR Mark I and II plants.

Technical Evaluations of CPRR Strategies



Rick Wachowiak (EPRI): EPRI Project Manager

Advisory Committee on Reactor Safeguards
September 9, 2015

CPRR Rulemaking


- Evaluation of the residual benefits of filtering strategies should be made in the context of an effective accident management capability and focused on the dominant accident scenarios
- Industry has always viewed the CPRR Rulemaking in the context of accident management
 - Response to postulated severe accidents like the accidents at Fukushima requires operator action
- Accident management involves:
 - Cooling core debris
 - Managing decay heat
 - Mitigating releases

Objectives of EPRI Evaluation

- Consider a comprehensive set of extended loss of ac power (ELAP) scenarios in a probabilistic framework
- Understand the role FLEX plays in ELAP mitigation
- Understand dominant severe accident scenarios
- Develop clear, manageable analysis of filtering strategy alternatives
- Support open dialog with NRC staff on assumptions, technical issues, dominant scenarios, and insights
- Inform the implementation of EA 13-109 (to the extent feasible)
- Providing insights to BWROG on EPG/SAGs
- Support industry decision-makers on the cost-benefit considerations

*Technical Basis for Severe Accident Mitigating Strategies:
Volume 1. EPRI, Palo Alto, CA: 2015. 3002003301.*

Example Results: Latent Cancer Fatality Risk



Insights

- Essential role of the operators
- Importance of water addition
- Incremental benefit of engineered filters
- Totally passive vent shown to increase core damage frequency (CDF)
- Sensitivity cases confirmed that the margins identified in the base results are not challenged by uncertainties

Conclusions

- Adoption of severe accident water addition strategies provides the greatest overall safety benefit, both in terms of protecting containment and reducing releases
- Manual actions would be required to manage the severe accident for all strategies
- Other alternatives investigated provide negligible additional benefit to public health and safety



Together...Shaping the Future of Electricity

Preparing BWR Operating Crews for Beyond Design Basis Events

Advisory Committee on Reactor Safeguards

September 9, 2015





BWROG

- Mission of BWROG

Provide a forum for member utilities to improve plant safety, improve reliability, minimize & share costs, and facilitate regulatory interaction.

- All US BWRs are members
- All international BWRs are eligible to be members, currently there are 12 international participants

Fukushima Subcommittee




- Fukushima Response *ad hoc* committee formed in late 2011
- This committee worked with the existing Emergency Procedures Committee (EPC) and EPRI to develop FLEX Support Guidelines (FSGs) criteria
- These procedures work in conjunction with the station EOPs and SAMG
- Each plant used the generic FSGs criteria to create plant specific FLEX procedures for response to BDB events

Emergency Procedures Committee



- Expert participation from all US and several international BWRs
- Improve plant operations and safety by taking into consideration the events at Fukushima
 - EPG/SAGs; FLEX Guidance (FSGs)
- Experience and information sharing and worldwide workshops
 - Revision 3 EPG/SAG workshops to facilitate a uniform understanding of revision and their technical bases among the members
 - Technical Support Guideline Skill Set workshops with case studies
 - Severe Accident Workshops with case studies
- Advises the BWROG and utilities on issues related to emergency response strategies
- Maintains guidelines and associated appendices, issue files, conference reports, analyses, etc.

FLEX Support Guidelines



Operator Training

- Each plant used the generic FSG criteria to create plant specific FLEX procedures for response to BDB events
- Operator training was developed and delivered for the new procedures and overall FLEX concept prior to plant being compliant with FLEX Order
- FLEX and BDB training added to the Operations training program



Back Up Info

- **Operator Training**
- **T-9 months:**
- FLEX Introduction (1.5 hours CR for all licensed and non-licensed Operators)
- *Provided the basics of Site response strategy as well as definitions, assumptions, etc.*
- **T-8 months:**
- Basic FLEX (1 hr Industry CBT for all licensed and non-licensed Operators)
- *Industry developed overview of the FLEX concept and the Lessons Learned from Fukushima*
- Advanced FLEX (1 hr Industry CBT for all SROs)
- *Industry developed generic discussion of SAFER response and timelines as well as leadership under stressful situations*
- **T-6 months:**
- FLEX Classroom SBO Overview (15 hours classroom for all Operators)
- *Site modifications, procedure changes, and new procedures for FLEX.*
- In-Plant Walkthroughs (4 hours for Non-Licensed Operators)
- *Focused on initial site assessment, deployment paths, staging concerns, equipment maneuvering and operation*
- SBO and FLEX Simulator Exercises (4 hours simulator for all Licensed Operators with Non-licensed Operator participation)
- *Simulator scenarios designed for SBO and ELAP implementation efforts*
- SBO and Flowcharts (Los)
- *AOP training on SBO and use of the C.5-4000 SBO Guideline; presented the integration of EOP activities into AOP/FLEX activities*



Public and Environment Protection by Release Reduction

David Lochbaum
Director, Nuclear Safety Project

September 9, 2015

Draft Regulatory Basis for Containment Protection and Release Reduction for Mark I and Mark II Boiling Water Reactors (10 CFR Part 50)

U.S. Nuclear Regulatory Commission

Office of Nuclear Reactor Regulation

Office of Nuclear Regulatory Research

May 2015


**Sources: Unless noted otherwise, all graphics and text quotes
in this presentation are from this document (ML15022A214)**

3.5 Regulatory Evaluation Conclusion

Based on the considerations discussed above, the staff is planning to pursue a rulemaking to make the requirements of Order EA-13-109 generically applicable, with an additional requirement for the use of SAWA/SAWM (i.e., alternative 3). This approach would provide the administrative benefits described for alternative 2, while also including the potential synergistic severe accident mitigation opportunities associated with SAWA/SAWM. Unlike alternative 4, a rulemaking to make Order EA-13-109 generically applicable with additional requirements for SAWA/SAWM seems unlikely to have significant additional costs for licensees because, as far as the staff is aware, licensees are currently planning to adopt SAWA/SAWM strategies as part of the implementation of Order EA-13-109. Alternative 4 would provide some additional safety enhancements, but as discussed above provides only minimal safety benefits with regard to the QHOs while having a significant cost of development and implementation.

The Regulatory Analysis of Alternative 4 miscalculated QHO benefits and essentially neglected all non-QHO benefits.

Figure 3-3: Uncertainty Bounds for Individual Latent Cancer Fatality Risk



- If core damage occurs, there would be a release due to containment venting and/or containment failure caused by over-pressurization or liner melt-through for all CPRR alternatives. However, the estimated mean individual latent cancer fatality risk (0-10 miles) is more than two orders of magnitude below the relevant NRC Safety Goal Quantitative Health Objective. The risk is low because the core-damage frequency is low and the conditional latent cancer fatality risk is low.

If the individual latent cancer fatality risk had been determined realistically and if it were the dominant factor, UCS would concur with the Regulatory Analysis that Alternative 3 was the way to go.


But it is not and we do not think Alternative 3 is the right thing to do.

ILCFs Not Determined Realistically

- Assuming protective actions are taken in the intermediate and long-term phases, the ILCF risk is maintained at a level well below the QHO, when multiplied by the accident frequency.

Regulatory Analysis unrealistically assumed that protective actions would be nearly 100% reliable in evacuating individuals before they were exposed to significant levels of radioactivity.

Figure 4-24: CRF for Conditional ILCF Risk (0-10 mi) for Evacuation Sensitivity Calculations for BWR Mark I MELCOR Case 49




ILCFs Not Determined Realistically

As Figure 4-24 in the Regulatory Analysis shows, the NRC's base model assumed protective actions (i.e., evacuations) would be ~100% successful.

Figure 4-24 also shows that less than 100% success results in larger individual latent cancer fatality risks during the emergency phase than for ALL phases examined by the base model.

The Regulatory Analysis's conclusion relies on a non-validated assumption of ~100% success.

Figure 3-1: Calculation of High-Level Conservative Estimate



- The evaluation assumed that 60 percent of the time the pre-core-damage water addition (FLEX) will be successful in preventing core damage. This assumption is informed by the results of the risk evaluation, which used scoping estimates of human error probabilities, and the NRC review of licensees' mitigating strategies, including plant walkdowns. Half of the failure probability is due to failure to implement needed operator actions and the remaining half is due to equipment failures.

4.2.4 Summary of Technical Approach

The core-damage frequency (CDF) due to ELAPs is calculated to be 8.9×10^{-6} /ry, which is 2 times lower than the value of 1.6×10^{-5} /ry that was estimated for SECY-12-0157. The CDF was calculated by averaging together the CDF for each BWR plant that has a Mark I containment and a RCIC system. As shown in Figure 4-2, "Contributions to ELAP Frequency and Core-Damage Frequency," the internal event ELAPs and seismic ELAPs caused by earthquakes with peak ground accelerations ranges from 0.3 to 0.7g are notable contributors to the CDF. Figure 4-2 also indicates that the conditional core-damage probability (CCDP) given the occurrence of an ELAP is about 47 percent (i.e., the SBO mitigation strategies reduce the CDF by about 53 percent).

Highly trained nuclear professionals are only assumed to be 53-60% successful in preventing core damage. Untrained amateurs are assumed to be ~100 successful in running from it.

The Regulatory Analysis seems to be evacuating the wrong individuals.

Why not evacuate the nuclear professionals and let the amateurs apply their talent, skill, or luck, to preventing reactor core damage?

Non-ILCFs Improperly Dismissed

Table 4-24: Average Mark II Conditional Offsite Consequences for the Different MELCOR Cases Associated with the CPRR Alternatives

	MELCOR Case	MACCS Bin	Individual Latent Cancer Fatality Risk (0-10 mi)	Population Dose (rem) (0-50 mi)	Offsite Cost (\$ 2013) (0-50 mi)	Land Contamination (sq. miles) (0-50 mi)	Population Subject to Long-Term Protective Actions (0-50 mi)
Status Quo (No Water)	1	8	4.70E-04	6,110,000	85,500,000,000	854	721,000
	5	6	2.29E-04	2,160,000	24,000,000,000	303	62,400
	6	7	3.08E-04	4,140,000	80,800,000,000	698	619,000
	Average:		3.40E-04	4,100,000	63,000,000,000	620	470,000
SAWA	10	5	1.35E-04	689,000	4,250,000,000	130	15,400
	11	4	7.90E-05	202,000	844,000,000	44	1,030
	24	6	2.29E-04	2,160,000	24,000,000,000	303	62,400
	Average:		1.50E-04	1,000,000	9,700,000,000	160	26,000
SAWA + External Filter	10DF10	4	7.90E-05	202,000	844,000,000	44	1,030
	11DF10	3	6.58E-06	20,700	393,000,000	2	0
	24DF10	4	7.90E-05	202,000	844,000,000	44	1,030
	Average:		5.50E-05	140,000	690,000,000	30	690

With an external filter, Alternative 4 achieves only a modest reduction in ILCF but huge reductions in all other concurrent consequences.

Table 4-23: Average Mark I Conditional Offsite Consequences for the Different MELCOR Cases Associated with the CPRR Alternatives

	MELCOR Case	MACCS Bin	Individual Latent Cancer Fatality Risk (0-10 mi)	Population Dose (rem) (0-50 mi)	Offsite Cost (\$ 2013) (0-50 mi)	Land Contamination (sq. miles) (0-50 mi)	Population Subject to Long-Term Protective Actions (0-50 mi)
Status Quo (No Water)	1	12	2.91E-04	1,720,000	13,000,000,000	549	64,500
	2	15	2.59E-04	1,740,000	15,700,000,000	573	111,000
	4	10	4.06E-04	1,360,000	9,900,000,000	479	51,400
	5	10	4.06E-04	1,360,000	9,900,000,000	479	51,400
	6	12	2.91E-04	1,720,000	13,000,000,000	549	64,500
	Average:		3.30E-04	1,600,000	12,000,000,000	530	69,000
SAWA/ SAWM	8	11	1.35E-04	1,110,000	5,960,000,000	286	40,500
	9	7	1.21E-04	524,000	2,740,000,000	190	15,000
	10	7	1.21E-04	524,000	2,740,000,000	190	15,000
	11	7	1.21E-04	524,000	2,740,000,000	190	15,000
	12	11	1.35E-04	1,110,000	5,960,000,000	286	40,500
	13	7	1.21E-04	524,000	2,740,000,000	190	15,000
	14	7	1.21E-04	524,000	2,740,000,000	190	15,000
	15	7	1.21E-04	524,000	2,740,000,000	190	15,000
	16	7	1.21E-04	524,000	2,740,000,000	190	15,000
	21	11	1.35E-04	1,110,000	5,960,000,000	286	40,500
	22	12	2.91E-04	1,720,000	13,000,000,000	549	64,500
	23	11	1.35E-04	1,110,000	5,960,000,000	286	40,500
	25	7	1.21E-04	524,000	2,740,000,000	190	15,000
	26	7	1.21E-04	524,000	2,740,000,000	190	15,000
	28	7	1.21E-04	524,000	2,740,000,000	190	15,000
	29	6	7.95E-05	253,000	1,150,000,000	116	3,440
	30	7	1.21E-04	524,000	2,740,000,000	190	15,000
	Average:		1.30E-04	720,000	4,000,000,000	230	23,000
SAWA/ SAWM + External Filter	8DF10	6	7.95E-05	253,000	1,150,000,000	116	3,440
	9DF10	5	2.03E-05	71,200	220,000,000	41	118
	10DF10	5	2.03E-05	71,200	220,000,000	41	118
	11DF10	5	2.03E-05	71,200	220,000,000	41	118
	12DF10	6	7.95E-05	253,000	1,150,000,000	116	3,440
	13DF10	5	2.03E-05	71,200	220,000,000	41	118
	14DF10	5	2.03E-05	71,200	220,000,000	41	118
	15DF10	5	2.03E-05	71,200	220,000,000	41	118
	16DF10	5	2.03E-05	71,200	220,000,000	41	118
	21DF10	6	7.95E-05	253,000	1,150,000,000	116	3,440
	22DF10	6	7.95E-05	253,000	1,150,000,000	116	3,440
	23DF10	6	7.95E-05	253,000	1,150,000,000	116	3,440
	25DF10	5	2.03E-05	71,200	220,000,000	41	118
	26DF10	5	2.03E-05	71,200	220,000,000	41	118
	28DF10	5	2.03E-05	71,200	220,000,000	41	118
	29DF10	4	1.72E-05	48,400	141,000,000	23	7
	30DF10	5	2.03E-05	71,200	220,000,000	41	118
	Average:		3.80E-05	120,000	490,000,000	62	1,100



With an external filter, Alternative 4 achieves only a modest reduction in ILCF but huge reductions in all other concurrent consequences.

damages (5 trillion yen). This compensation is mainly given to 86,000 individuals that have been displaced from areas of the government mandated evacuation and affected businesses.⁴³

In comparison to a cost of about \$76 billion for an accident affecting 86,000 individuals, Mark I source term bin 14, represented by case 22dw, subjects 93,700 individuals to long-term protective actions for the area within 50 miles. This case has a total offsite economic cost of about \$12.9 billion associated with the 50-mile area. Comparing the two costs for accidents that displace a roughly similar population size shows that the Government of Japan projects the cost to be roughly 6 times higher than the MACCS calculation in this analysis. The reason for this difference is not well understood yet, as the estimates are based on a number of factors such as the length of time before people return and the level of necessary cleanup efforts. As more

The Regulatory Analysis of post-Fukushima upgrades acknowledges that actual costs from Fukushima are only about 6 times higher than the post-accident costs it calculated for reasons that are “not well understood yet.”

When in doubt, throw it out?

Alternative 5: More Reliable MBDBE?

Why not severe-accident-capable reliable reactor pressure vessel relief capability?

Why not FLEX pumps that can inject into the reactor pressure vessel up to the SRV pressure?


Why not severe-accident-capable reliable instrumentation?

Reliable RPV Relief Valves

- The plant operators will reduce RPV pressure using the safety relief valves (SRVs) to a range of 200-400 psig in order to minimize SRV cycling and to minimize heatup of the suppression pool.
- The CDETs credit local manual operation of SRVs if dc power fails.

But the SRVs require more than dc power in order to be manually opened.

Figure 4-20: Mark I RPV Water Level for Case 9-IVR



Reliable RPV Relief Valves

The ADS uses selected SRVs for depressurization of the reactor, as described in Section 6.3. Each of the SRVs used for automatic depressurization is equipped with an air accumulator and check valve arrangement. These accumulators ensure that the valves can be held open following failure of the air supply to the accumulators. They are sized to be capable of opening the valves and holding them open against the maximum drywell pressure of 62 psig. The accumulator capacity is sufficient for each ADS valve to provide two actuations against 70 percent of the maximum drywell design pressure.

5.2-15

HCGS-UFSAR

Revision 0
April 11, 1988

Source: Hope Creek Generating Station Updated Final Safety Analysis Report

SRVs need dc power and pneumatic pressure to open. Why not require severe-accident-capable reliable RPV relief valves?

High Pressure FLEX RPV Injection

- If the RCIC pump fails, core cooling can be provided by aligning the portable FLEX pump for RPV injection and depressurizing the RPV below the portable FLEX pump's shutoff head.

FLEX seems inflexible by needing the RPV pressure to be low enough for it to inject water. Why not procure portable FLEX pumps flexible enough to inject water to the RPV all the way up to the SRV pressure?

Reliable Instrumentation

Operator actions to prevent or mitigate severe accidents are contingent on the availability and functionality of equipment and diagnostic instruments under severe accident conditions. The MELCOR analysis provides insights on the timeline for such actions. The SRM to SECY-12-0157 mentions consideration of equipment availability as one of several performance measures. The impacts of equipment availability can be quantitatively measured by the conditional uncontrolled release index (CURI) which is reviewed in Section 5, "Performance Criteria Information". The operator relies on instruments to know when to add water and/or to take other accident management actions. Therefore, instrument availability and reliability play an important role in this respect. In the PRA done as part of this evaluation, FLEX was assumed to be 60 percent successful. In the accident progression analysis using MELCOR, instruments measuring the RPV and containment water levels and pressures were assumed to be available. Note that 10 CFR 50.34(f)(2)(xix) requires licensees to provide instrumentation adequate for monitoring plant conditions following an accident that includes core damage.

- Information on some parameters may not be available to the operators or may be ambiguous for decisionmaking.


Successful mitigation depends on reliable diagnoses. Why not identify key parameters that must be monitored for the EOPs, EPGs, and SAMGs and require severe-accident-capable reliable instrumentation?

GE Mark I and Mark II Containment Protection & Release Reduction:

A Fukushima Lesson Unlearned In U.S.

**NRC ACRS Full Committee
September 9, 2015**

**Paul Gunter
Beyond Nuclear**



Some context to Commission “About-Face”

August 17, 2015

AREVA delivers Filtered Containment Venting System to Hamaoka for its 14th installation at Japanese nuclear power stations

August 18, 2015


As per NRC plan, ACRS subcommittee meets and agrees to draft letter to Commission on Containment Protection and Release Reduction (CPRR) proposed rulemaking

August 19, 2015

- Commission Notation Vote (3-1) adopts “Status Quo”**
- Abandons CPRR proposed rulemaking activity**
- Abruptly closes out independent expert analyses and public comments on severe accident management for controversial U.S. Mark I and Mark II containment systems including external filtration in vent lines**

フィルタ付VENT設備の概要

＜2号機イメージ図＞



【フィルタ付VENT設備の概要】 about Filtered vent system

1. フィルタ付VENT設備本体の概略寸法・設置数


Filtered vent system measurement
概略寸法: 直径約2m, 高さ約8m (円筒形) Diameter 2m, height: 8m (cylinder)
設置数: 4基 (2号機), 5基 (3号機) Unit number: 4 (unit 2), 5 (unit 3)

2. フィルタ付VENT設備格納槽の概略寸法


Filtered vent storage tank measurement
幅約13m × 長さ約25m × 高さ約12m (2号機) W 13m * L 25m * H 12m (Unit 2)
幅約13m × 長さ約28m × 高さ約14m (3号機) W 13m * L 28m * H 14m (Unit 3)

地上式及び地下式フィルタベント装置の概要について

- Ground FCVS lead vent line from pressure resistant vent line (underground FCVS leads directly from containment vessel), then decrease radioactive material then vent it from the roof of reactor building.
- The valves which need to operate can manipulate from outside of shielding wall during accident.
- Do not share the line with other equipment for sure to lead the gas to filter.



filter vent equipment structure フィルタ装置の構造



Metal filter

Metal filter gathers radioactive particle when gas pass through metal filter.

Water Scrubber

Water gathers radioactive particle when gas pass through metal filter.


To collect radioactive particle effectively, blow off the gas fast and furiously by scrubber nozzle, and break up bubbles by gas bubble fragmentation instrument



Extraction rate higher than 99.9%
Radioactive particle (Radioactive Cesium)

※地上式フィルタベントと地下式フィルタベントの性能は同等であり、地上式フィルタベント設備もしくは地下式フィルタベント設備のいずれかで原子力規制庁の「炉心損傷防止及び格納容器破損防止対策の有効性の評価に係る標準評価手法（審査ガイド）」の要求を満たす設計とする。

DISCONNECT OR DUAL STRATEGY IN BOILING WATER REACTOR OWNERS GROUP RISK-BENEFIT COMMUNICATIONS?



PUBLIC PROTECTION REQUIRES FILTERS

Mary Lampert, Pilgrim Watch


ACRS Presentation

September 9, 2015

Good Afternoon



Staff Analysis Does Not Recommend Filters What's Wrong?



An “Inconvenient Truth”

A \$11- \$64 million filter saves \$ 3.51 billion in Economic Consequences

Table 4-23: Average Mark I Conditional Offsite Consequences for the Different MELCOR Cases Associated with the CPRR Alternatives

	MELCOR Case	MACCS Bin	Individual Latent Cancer Fatality Risk (0-10 mi)	Population Dose (rem) (0-50 mi)	Offsite Cost (\$ 2013) (0-50 mi)	Land Contamination (sq. miles) (0-50 mi)	Population Subject to Long-Term Protective Actions (0-50 mi)
Status Quo (No Water)	1	12	2.91E-04	1,720,000	13,000,000,000	549	64,500
	2	15	2.59E-04	1,740,000	15,700,000,000	573	111,000
	4	10	4.06E-04	1,380,000	9,900,000,000	479	51,400
	5	10	4.06E-04	1,380,000	9,900,000,000	479	51,400
	6	12	2.91E-04	1,720,000	13,000,000,000	549	64,500
	Average:		3.30E-04	1,600,000	12,000,000,000	530	69,000
	8	11	1.35E-04	1,110,000	5,980,000,000	288	40,500
SAWA/SAWM	9	7	1.21E-04	524,000	2,740,000,000	190	15,000
	10	7	1.21E-04	524,000	2,740,000,000	190	15,000
	11	7	1.21E-04	524,000	2,740,000,000	190	15,000
	12	11	1.35E-04	1,110,000	5,980,000,000	288	40,500
	13	7	1.21E-04	524,000	2,740,000,000	190	15,000
	14	7	1.21E-04	524,000	2,740,000,000	190	15,000
	15	7	1.21E-04	524,000	2,740,000,000	190	15,000
	16	7	1.21E-04	524,000	2,740,000,000	190	15,000
	21	11	1.35E-04	1,110,000	5,980,000,000	288	40,500
	22	12	2.91E-04	1,720,000	13,000,000,000	549	64,500
	23	11	1.35E-04	1,110,000	5,980,000,000	288	40,500
	25	7	1.21E-04	524,000	2,740,000,000	190	15,000
	26	7	1.21E-04	524,000	2,740,000,000	190	15,000
	28	7	1.21E-04	524,000	2,740,000,000	190	15,000
	29	6	7.65E-05	253,000	1,150,000,000	118	3,440
	30	7	1.21E-04	524,000	2,740,000,000	190	15,000
	Average:		1.30E-04	720,000	4,000,000,000	230	23,000
SAWA/SAWM + External Filter	8DF10	6	7.65E-05	253,000	1,150,000,000	118	3,440
	9DF10	5	2.03E-05	71,200	220,000,000	41	118
	10DF10	5	2.03E-05	71,200	220,000,000	41	118
	11DF10	5	2.03E-05	71,200	220,000,000	41	118
	12DF10	6	7.65E-05	253,000	1,150,000,000	118	3,440
	13DF10	5	2.03E-05	71,200	220,000,000	41	118
	14DF10	5	2.03E-05	71,200	220,000,000	41	118
	15DF10	5	2.03E-05	71,200	220,000,000	41	118
	16DF10	5	2.03E-05	71,200	220,000,000	41	118
	21DF10	6	7.65E-05	253,000	1,150,000,000	118	3,440
	22DF10	6	7.65E-05	253,000	1,150,000,000	118	3,440
	23DF10	6	7.65E-05	253,000	1,150,000,000	118	3,440
	25DF10	5	2.03E-05	71,200	220,000,000	41	118
	26DF10	5	2.03E-05	71,200	220,000,000	41	118
	28DF10	5	2.03E-05	71,200	220,000,000	41	118
	29DF10	4	1.72E-05	48,400	141,000,000	23	7
	30DF10	5	2.03E-05	71,200	220,000,000	41	118
	Average:		3.80E-05	120,000	490,000,000	62	1,100

An Honest Analysis

Health Costs Justify a Filter

NRC's "Solution" to that "Inconvenient Truth"

- Assume evacuations take < 6 hours
- Assume SAWA/SAWM will delay releases to allow timely evacuations
 - Staff ignores its admission that SAWA does not work 40% of the time.
- Improperly limiting health impacts to cancer fatalities & to a too small geographic area

Evacuations take more than 6 hours Especially in nuclear disasters



NUREG/CR-7002 Guidance & ETE's Underestimate Evacuation Times

Incorrect Assumptions - How many will evacuate

Examples:

- NRC telephone surveys do not explain survey is for nuclear disaster and elicit false information – Cape Survey (70%) v. Sandia (20%)
- Staged evacuation not supported – Cape Survey
- Shadow evacuation > 20% and extends to at least 25 miles, not 5 miles – Cape Survey
- Siren messages not heard by 70% - Town of Duxbury Survey

Cape Cod Telephone Survey

Told Respondents to Assume a Nuclear Accident


- 70% (not 20%) would evacuate
- 50% would evacuate even if told they were not in the EPZ
- The Cape Cod respondents lived 10-25 miles from Pilgrim; their “shadow evacuation” was not limited to those within 15 miles as assumed by NRC

Bottom Line:

- The number within the EPZ that will evacuate is three (3) times the NRC assumption
- 50% “Shadow evacuation” outside the EPZ is 2 ½ times NRC assumption
- 250% to 300% increase in number of evacuees → huge increase in traffic density and decrease in speed → dramatic increase in ETE

NRC's Draft Figure 4-24

Clear Health Benefit From Adding Filters




Staff Assumption of Health Costs

Another Ludicrous Assumption

Staff assumed that accidents will be slow breaking allowing timely evacuations

- This depends on SAWA working. Staff assumed this would be the case only 60% of the time.
- Staff ignored accidents that cannot be assumed to be slow breaking - the 40% of the time that Staff said SAWA will not work.
- Any “solution” that purports to insure public health and safety even 60% of the time is wrong.

SAWA/SAWM - No Basis to Assume Works 6 out of 10 times – Pilgrim's Plan




Health Impact Underestimated

Staff limited Radiation Health Impacts to Cancer Fatalities

- Ignored cancer incidence, birth defects, reproductive disorders, other health impacts discussed in BEIR VII
- Ignored likely geographic impact

Staff Draft based Faulty Cost-benefit Analysis & Use Outdated Computer Tools - MELCOR/MACCS/SOARCA



© Scott Adams, Inc./Dist. by UFS, Inc.

What's Wrong with Staff PRA Analysis

1. PRA multiplies “probability” and “consequences.”
2. Staff Underestimated Probability
 - Assumed SAWA works
 - MACCS assumes (1) core damage event every 31,000 reactor years.
 - History shows (5) actual core damages in 36 years - 1 every 7 yrs.
3. Staff Underestimated Consequences
 - Considered only gamma (Iodine) and a small fraction of Cs-137
 - Realistic ETE's result in much greater consequences
 - NRC says a life is worth \$3 million; other agencies say \$5-9 million

What's Wrong with Staff PRA Analysis (cont'd)

4. Unrealistically limited radioactive release concentration and geographic area impacted by using simplistic straight-line Gaussian plume model

5. Underestimated economic costs although Staff analysis justified filters.

- Underestimated size of contaminated area and extent of contamination
- Underestimated volume of contaminated waste
- Ignored forests, wetlands, and bodies of water that cannot be decontaminated
- Ignored that technologies needed for cleanup have not been developed
- Ignored that there is no cleanup standard - Reichmuth & Luna
- Ignored that there are no locations to bring large volumes of waste

OIG Audit of NRC's Regulatory Analysis Process (OIG-15-A-15 June 24, 2015)

OIG found that NRC Staff has limited cost-estimating experience making it "vulnerable to errors and flawed decision-making."

- This analysis is a good example
- The Staff's flawed cost-benefit analysis got the right answer for industry; but the wrong answer for public health and safety