

Entergy Operations, Inc. River Bend Station 5485 U.S. Highway 61N St. Francisville, LA 70775 Tel 225-381-4177

Joseph A. Clark Manager, Regulatory Affairs

August 31, 2015

RBG-47610

U.S. Nuclear Regulatory Commission Attn: Document Control Desk Washington, DC 20555

Subject: River Bend Station - Unit 1 Docket No. 50-458 License No. NPF-47 Report of Changes and Errors to 10CFR50.46

References: 1. Letter RBG-47488, "Report of Changes and Errors to 10 CFR 50.46," dated July 29, 2014

Dear Sir or Madam:

There has been no notice of changes or errors associated with the RBS ECCS analysis since the last 10 CFR 50.46 report provided to the NRC [Reference 1]. The table below summarizes the effects on the current ECCS analysis performed by General Electric – Hitachi Nuclear Energy (GEH) using their NRC approved SAFER/GESTR – LOCA methodology.

Since the last 10 CFR 50.46 report provided to the NRC, RBS has performed Refueling Outage 18 where the remaining GE14 fuel type was removed from the core. The RBS core is now composed of the GNF2 and GNF3 fuel types.

Previously, the GNF2 was the limiting fuel type. GNF3 is now the limiting fuel type with a PCT of 1830°F incorporating 10 CFR 50.46 error notifications up to and including NL-2014-04. As can be seen the PCT for the GNF3 fuel remains well below the 2200°F acceptance criteria of 10 CFR 50.46.

AUDI

| Notification Letter | Nature Of Change / Error | Estimated PCT Effect (°F) | |
|---|--|------------------------------|------|
| | | GNF2 | GNF3 |
| Previous Periods | | | |
| NL-2014-04 | SAFER04A E4 – Bundle / Lower Plenum CCFL Head | 0 | 0 |
| NL-2014-03 | SAFER04A E4 – Minimum Core DP Model | -15 | -15 |
| NL-2014-02 | SAFER04A E4 – Mass Non-Conservatism | · 0 | 0 |
| NL-2014-01 | SAFER04A E4 – Maintenance Update Changes | • 0 | 0 |
| NL-2012-01 | PRIME Fuel Properties Implementation for Fuel Rod T/M Performance, replacing GESTR Fuel Properties | 45 | 45 |
| NL-2011-03 | Impact of updated formulation for gamma heat deposition to channel wall for 9x9 and 10x10 fuel bundles | -40 | -40 |
| NL-2011-02 | Impact of database error for heat deposition on the Peak Cladding Temperature (PCT) for 10x10 fuel bundles | 25 | 25 |
| Net of errors / changes | | 15 | 15 |
| Sum of absolute magnitude of changes / errors | | 125 | 125 |

This letter does not contain any commitments.

For further information, please contact me at (225) 381-4177.

Sincerely,

JAC/bmb

RBF1-15-0141

cc: U. S. Nuclear Regulatory Commission Region IV 1600 East Lamar Blvd. Arlington, TX 76011-4511

> NRC Senior Resident Inspector P. O. Box 1050 St. Francisville, LA 70775

RBG-47610 Page 3 of 3

> U. S. Nuclear Regulatory Commission Attn: Mr. Alan Wang MS O-8B1 One White Flint North 11555 Rockville Pike Rockville, MD 20852

Department of Environmental Quality Office of Environmental Compliance Radiological Emergency Planning and Response Section Ji Young Wiley P.O. Box 4312 Baton Rouge, LA 70821-4312

Public Utility Commission of Texas Attn: PUC Filing Clerk 1701 N. Congress Avenue P. O. Box 13326 Austin, TX 78711-3326

RBF1-15-0141