



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

EXELON GENERATION COMPANY, LLC

DOCKET NO. STN 50-455

BYRON STATION, UNIT NO. 2

RENEWED FACILITY OPERATING LICENSE

Renewed License No. NPF-66

1. The Nuclear Regulatory Commission (the Commission or the NRC) has found that:
 - A. The application for a renewed license filed by the applicant* complies with the standards and requirements of the Atomic Energy Act of 1954, as amend (the Act), and the Commission's regulations set forth in 10 CFR Chapter I, and all required notifications to other agencies or bodies have been duly made;
 - B. Construction of Byron Station, Unit 2 (the facility) has been substantially completed in conformity with Construction Permit No. CPPR-131 and the application, as amended, the provisions of the Act and the regulations of the Commission;
 - C. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the regulations of the Commission (except as exempted from compliance in Section 2.D. below);
 - D. There is reasonable assurance: (i) that the activities authorized by this renewed operating license can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I (except as exempted from compliance in Section 2.D. below);
 - E. Exelon Generation Company, LLC is technically qualified to engage in the activities authorized by this renewed license in accordance with the Commission's regulations set forth in 10 CFR Chapter I;
 - F. Exelon Generation Company, LLC has satisfied the applicable provisions of 10 CFR Part 140, "Financial Protection Requirements and Indemnity Agreements," of the Commission's regulations;

*The Nuclear Regulatory Commission approved the transfer of the license from Commonwealth Edison Company to Exelon Generation Company, LLC on August 3, 2000.

Renewed License No. NPF-66

- G. The issuance of this renewed license will not be inimical to the common defense and security or to the health and safety of the public;
 - H. After weighing the environmental, economic, technical, and other benefits of the facility against environmental and other costs and considering available alternatives, the issuance of Renewed Facility Operating License No. NPF-66, subject to the conditions for protection of the environment set forth in the Environmental Protection Plan attached as Appendix B to Renewed License No. NPF-37, issued November 19, 2015, is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied; and
 - I. The receipt, possession, and use of source, byproduct and special nuclear material as authorized by this renewed license will be in accordance with the Commission's regulations in 10 CFR Parts 30, 40 and 70.
 - J. Actions have been identified and have been or will be taken with respect to (1) managing the effects of aging during the period of extended operation on the functionality of structures and components that have been identified to require review under 10 CFR 54.21(a)(1), and (2) time-limited aging analyses that have been identified to require review under 10 CFR 54.21(c), such that there is reasonable assurance that the activities authorized by this renewed license will continue to be conducted in accordance with the current licensing basis, as defined in 10 CFR 54.3, for the facility, and that any changes made to the facility's current licensing basis in order to comply with 10 CFR 54.29(a) are in accordance with the Act and the Commission's regulations.
2. Facility Operating License No. NPF-66, dated January 30, 1987, as amended, is hereby superseded by Renewed Facility Operating License No. NPF-66, issued to Exelon Generation Company, LLC (the licensee) to read as follows:
- A. The renewed license applies to the Byron Station, Unit No. 2, a pressurized water reactor, and associated equipment (the facility), owned by Exelon Generation Company, LLC. The facility is located in north central Illinois within Rockvale Township, Ogle County, Illinois and is described in the licensee's Updated Final Safety Analysis Report, as supplemented and amended, and in the licensee's Environmental Report, as supplemented and amended.
 - B. Subject to the conditions and requirements incorporated herein, the Commission hereby licenses Exelon Generation Company, LLC:
 - (1) Pursuant to Section 103 of the Act and 10 CFR Part 50 to possess, use and operate the facility at the designated location in accordance with the procedures and limitations set forth in this renewed license;

- (2) Pursuant to the Act and 10 CFR Part 70, to receive; possess and use at any time special nuclear material as reactor fuel, in accordance with the limitations for storage and amounts required for reactor operation, as described in the Updated Final Safety Analysis Report, as supplemented and amended;
- (3) Pursuant to the Act and 10 CFR Parts 30, 40 and 70, to receive, possess, and use at any time any byproduct, source and special nuclear material as sealed neutron sources for reactor startup, sealed sources for reactor instrumentation and radiation monitoring equipment calibration, and as fission detectors in amounts as required;
- (4) Pursuant to the Act and 10 CFR Parts 30, 40 and 70, to receive, possess, and use in amounts as required any byproduct, source or special nuclear material without restriction to chemical or physical form, for sample analysis or instrument calibration or associated with radioactive apparatus or components; and
- (5) Pursuant to the Act and 10 CFR Parts 30, 40 and 70, to possess, but not separate, such byproduct and special nuclear materials as may be produced by the operation of the facility.

C. The renewed license shall be deemed to contain and is subject to the conditions specified in the Commission's regulations set forth in 10 CFR Chapter I and is subject to all applicable provisions of the Act and to the rules, regulations, and orders of the Commission now or hereafter in effect; and is subject to the additional conditions specified or incorporated below:

(1) Maximum Power Level

The licensee is authorized to operate the facility at reactor core power levels not in excess of 3645 megawatts thermal (100 percent rated power) in accordance with the conditions specified herein.

(2) Technical Specifications

The Technical Specifications contained in Appendix A (NUREG-1113), as revised through Amendment No. 192 and the Environmental Protection Plan contained in Appendix B, both of which were attached to Renewed License No. NPF-37, dated November 19, 2015, are hereby incorporated into this renewed license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

(3) Deleted.

(4) Deleted.

(5) Deleted.

(6) Additional Conditions

The Additional Conditions contained in Appendix C, as revised through Amendment No. 151, are hereby incorporated into this renewed license. The licensee shall operate the facility in accordance with the Additional Conditions.

(7) Exelon Generation Company, LLC shall provide the Director of the Office of Nuclear Reactor Regulation, a copy of any application, at the time it is filed, to transfer (excluding grants of security interests or liens) from Exelon Generation Company, LLC to its direct or indirect parent, or to any other affiliated company, facilities for the production, transmission, or distribution of electric energy having a depreciated book value exceeding ten percent (10%) of Exelon Generation Company, LLC's consolidated net utility plant, as recorded on Exelon Generation Company, LLC's books of account.

(8) Exelon Generation Company, LLC shall have decommissioning trust funds for Byron, Unit 2, in the following minimum amount, when Byron, Unit 2, is transferred to Exelon Generation Company, LLC:

Byron Unit 2	\$156,560,489
--------------	---------------

(9) The decommissioning trust agreement for Byron, Unit 2, at the time the transfer of the unit to Exelon Generation Company, LLC is effected and thereafter, is subject to the following:

(a) The decommissioning trust agreement must be in a form acceptable to the NRC.

(b) With respect to the decommissioning trust fund, investments in the securities or other obligations of Exelon Corporation or affiliates thereof, or their successors or assigns are prohibited. Except for investments tied to market indexes or other non-nuclear sector mutual funds, investments in any entity owning one or more nuclear power plants are prohibited.

- (c) The decommissioning trust agreement for Byron, Unit 2 must provide that no disbursements or payments from the trust shall be made by the trustee unless the trustee has first given the Director of the Office of Nuclear Reactor Regulation, 30 days prior written notice of payment. The decommissioning trust agreement shall further contain a provision that no disbursements or payments from the trust shall be made if the trustee receives prior written notice of objection from the NRC.
 - (d) The decommissioning trust agreement must provide that the agreement can not be amended in any material respect without 30 days prior written notification to the Director of the Office of Nuclear Reactor Regulation.
 - (e) The appropriate section of the decommissioning trust agreement shall state that the trustee, investment advisor, or anyone else directing the investments made in the trust shall adhere to a "prudent investor" standard, as specified in 18 CFR 35.32(a)(3) of the Federal Energy Regulatory Commission's regulations.
- (10) Exelon Generation Company, LLC shall take all necessary steps to ensure that the decommissioning trust is maintained in accordance with the application for approval of the transfer of the Byron, Unit 2, license and the requirements of the Order approving the transfer, and consistent with the safety evaluation supporting the Order.
- (11) Mitigation Strategy License Condition

Develop and maintain strategies for addressing large fires and explosions and that include the following key areas:

- (a) Fire fighting response strategy with the following elements:
 - 1. Pre-defined coordinated fire response strategy and guidance
 - 2. Assessment of mutual aid fire fighting assets
 - 3. Designated staging areas for equipment and materials
 - 4. Command and control
 - 5. Training of response personnel
- (b) Operations to mitigate fuel damage considering the following:
 - 1. Protection and use of personnel assets
 - 2. Communications
 - 3. Minimizing fire spread
 - 4. Procedures for implementing integrated fire response strategy

5. Identification of readily-available pre-staged equipment
6. Training on integrated fire response strategy
7. Spent fuel pool mitigation measures

(c) Actions to minimize release to include consideration of:

1. Water spray scrubbing
2. Dose to onsite responders

(12) License Renewal License Conditions

(a) The information in the UFSAR supplement, submitted pursuant to 10 CFR 54.21(d), as revised during the license renewal application review process, and as supplemented by the Commitments applicable to Byron Unit 2 in Appendix A of the "Safety Evaluation Report Related to the License Renewal of Byron Station, Units 1 and 2, and Braidwood Station, Units 1 and 2" (SER) dated July 2015, is collectively the "License Renewal UFSAR Supplement." This Supplement is henceforth part of the UFSAR which will be updated in accordance with 10 CFR 50.71(e). As such, the licensee may make changes to the programs and activities applicable to Byron Unit 2 described in this Supplement provided the licensee evaluates such changes pursuant to the criteria set forth in 10 CFR 50.59 and otherwise complies with the requirements in that section.

(b) This License Renewal UFSAR Supplement, as revised per License Condition 12(a) above, describes certain programs to be implemented and activities to be completed prior to the period of extended operation.

1. The licensee shall implement those new programs and enhancements to existing programs no later than May 6, 2026.
2. The licensee shall complete those activities as noted in the Commitments applicable to Byron Unit 2 in this Supplement no later than May 6, 2026, or the end of the last refueling outage prior to the period of extended operation, whichever occurs later.

3. The licensee shall notify the NRC in writing within 30 days after having accomplished item (b)1 above and include the status of those activities that have been or remain to be completed in item (b)2 above.

- D. The facility requires no exemptions from the requirements of 10 CFR Part 50.

An exemption was previously granted pursuant to 10 CFR 70.24. The exemption was granted with NRC materials license No. SNM-1916, issued March 4, 1985, and relieved the licensee from the requirement of having a criticality alarm system. Therefore, the licensee is exempted from the criticality alarm system provision of 10 CFR 70.24 so far as this section applies to the storage of fuel assemblies held under this license.

- E. The licensee shall implement and maintain in effect all provisions of the approved fire protection program as described in the licensee's Fire Protection Report and the licensee's letters dated September 23, 1986, October 23, 1986, November 3, 1986, December 12 and 15, 1986, and January 21, 1987, and as approved in the SER dated February 1982 through Supplement No. 8, subject to the following provision:

The licensee may make changes to the approved fire protection program without prior approval of the Commission only if those changes would not adversely affect the ability to achieve and maintain safe shutdown in the event of a fire.

- F. Exelon Generation Company shall fully implement and maintain in effect all provisions of the Commission-approved physical security, training and qualifications, and safeguards contingency plans including amendments made pursuant to provisions of the Miscellaneous Amendments and Search Requirements revisions to 10 CFR 73.55 (51 FR 27817 and 27822), and the authority of 10 CFR 50.90 and 10 CFR 50.54(p). The combined set of plans¹, which contain Safeguards Information protected under 10 CFR 73.21, is entitled: "Byron Nuclear Power Station Security Plan, Training and Qualification Plan, and Safeguards Contingency Plan, Revision 3," submitted by letter dated May 17, 2006.

Exelon Generation Company shall fully implement and maintain in effect all provisions of the Commission-approved cyber security plan (CSP), including changes made pursuant to the authority of 10 CFR 50.90 and 10 CFR 50.54(p). The Exelon Generation Company CSP was approved by License Amendment No.175 and modified by License Amendment No. 191.

- G. Deleted

¹The training and Qualification Plan and Safeguards Contingency Plan are Appendices to the Security Plan.

- H. The licensee shall have and maintain financial protection of such type and in such amounts as the Commission shall require in accordance with Section 170 of the Atomic Energy Act of 1954, as amended, to cover public liability claims.
- I. This renewed license is effective as of the date of issuance and shall expire at midnight on November 6, 2046.

FOR THE NUCLEAR REGULATORY COMMISSION

/RA/

William M. Dean, Director
Office of Nuclear Reactor Regulation

Attachments:

- 1. Appendix A – Technical Specifications (NUREG-1113)
- 2. Appendix B – Environmental Protection Plan
- 3. Appendix C – Additional Conditions

Date of Issuance: November 19, 2015

Appendix A: Technical Specifications

Byron 2 uses the same Appendix A as Byron 1. Please refer to Byron 1 for Appendix A (ML15286A276).

Appendix B: Environmental Protection Plan

Byron 2 uses the same Appendix B as Byron 1. Please refer to Byron 1 for Appendix B (ML15286A276).

APPENDIX C

ADDITIONAL CONDITIONS

RENEWED FACILITY OPERATING LICENSE NO. NPF-66

The licensee shall comply with the following conditions on the schedules noted below:

<u>Amendment Number</u>	<u>Additional Condition</u>	<u>Implementation Date</u>
127	The safety limit equation specified in TS 2.1.1.3 regarding fuel centerline melt temperature (i.e., less than 5080 °F, decreasing by 58 °F per 10,000 MWD/MTU burnup as described in WCAP-12610-P-A, "VANTAGE+ Fuel Assembly Reference Core Report," April 1995) is valid for uranium oxide fuel without the presence of poisons mixed homogeneously into the fuel pellets. If fuel pellets incorporating homogeneous poisons are used, the topical report documenting the fuel centerline melt temperature basis must be reviewed and approved by the NRC and referenced in this license condition. TS 2.1.1.3 must be modified to also include the fuel centerline melt temperature limit for the fuel with homogeneous poison.	With implementation of the amendment

ADDITIONAL CONDITIONS

FACILITY OPERATING LICENSE NO. NPF-66

The licensee shall comply with the following conditions on the schedules noted below:

<u>Amendment Number</u>	<u>Additional Condition</u>	<u>Implementation Date</u>
151	<p>Upon implementation of Amendment No. 151 adopting TSTF-448, Revision 3, the determination of control room envelope (CRE) unfiltered air leakage as required by SR 3.7.10.4, in accordance with TS 5.5.18.c.(i), the assessment of CRE habitability as required by Specification 5.5.18.c.(ii), and the measurement of CRE pressure as required by Specification 5.5.18.d, shall be considered met. Following implementation:</p> <p>(a) The first performance of SR 3.7.10.4, in accordance with Specification 5.5.18.c.(i), shall be within the specified Frequency of 6 years, plus the 18-month allowance of SR 3.0.2, as measured from November 1, 2004, the date of the most recent successful tracer gas test, as stated in the January 31, 2005 letter response to Generic Letter 2003-01, or within the next 18 months if the time period since the most recent successful tracer gas test is greater than 6 years.</p> <p>(b) The first performance of the periodic assessment of CRE habitability, Specification 5.5.18.c.(ii), shall be within 3 years, plus the 9-month allowance of SR 3.0.2, as measured from November 1, 2004, the date of the most recent successful tracer gas test, as stated in the January 31, 2005 letter response to Generic Letter 2003-01, or within the next 9 months if the time period since the most recent successful tracer gas test is greater than 3 years.</p> <p>(c) The first performance of the periodic measurement of CRE pressure, Specification 5.5.18.d, shall be within 18 months, plus the 138 days allowed by SR 3.0.2, as measured from the date of the most recent successful pressure measurement test, or within 138 days if not performed previously.</p>	With implementation of the amendment