

IPRenewal NPEmails

From: Louie, Richard [rlouie@entergy.com]
Sent: Tuesday, September 29, 2015 12:45 PM
To: Wentzel, Michael
Subject: [External_Sender] 2015 Service Water Leaks

Mike,

In our letter dated 8/18/2015, we provided information regarding the number of leaks on the SW system for the past 10-years. For year 2015, the number we provided was current as of 6/30/2015.

Since that time, there has been an increase in the number of reported through-wall leakage flaws in ASME ISI Class 3 SW piping. The new number is 6 as of 9/17/2015.

This condition is being tracked in our condition reporting system under CR-IP2-2015-04239.

Please call me at your convenience to discuss this.

Thanks,

Richard Louie
rlouie@entergy.com

Regulatory Assurance
Indian Point Energy Center
(914) 254-6618

Hearing Identifier: IndianPointUnits2and3NonPublic_EX
Email Number: 5311

Mail Envelope Properties (CB159DC717B797428E92782CE3B5F40B0F1B245E)

Subject: [External_Sender] 2015 Service Water Leaks
Sent Date: 9/29/2015 12:44:37 PM
Received Date: 9/29/2015 12:45:07 PM
From: Louie, Richard

Created By: rlouie@entergy.com

Recipients:
"Wentzel, Michael" <Michael.Wentzel@nrc.gov>
Tracking Status: None

Post Office: JDCXMETSP003.etrsouth.corp.entergy.com

Files	Size	Date & Time
MESSAGE	683	9/29/2015 12:45:07 PM

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: